

**AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT**

|                                                                                                                                                                                                                                      |               |                                                                                                                                                                                                                                                                                                     |  |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| 1. CONTRACT ID CODE<br>J                                                                                                                                                                                                             |               | PAGE 1 OF 2 PAGES                                                                                                                                                                                                                                                                                   |  |
| 2. AMENDMENT/MODIFICATION NUMBER<br>0004                                                                                                                                                                                             |               | 3. EFFECTIVE DATE<br>08 MAY 2025                                                                                                                                                                                                                                                                    |  |
| 4. REQUISITION/PURCHASE REQUISITION NUMBER                                                                                                                                                                                           |               | 5. PROJECT NUMBER (If applicable)<br>P2 513392                                                                                                                                                                                                                                                      |  |
| 6. ISSUED BY<br>CODE<br>W072 ENDIST LOUISVILLE<br>KO CONTRACTING DIVISION, 600 DR MARTIN LUTHER KING JR PL<br>LOUISVILLE, KY 40202-2230<br>UNITED STATES<br>SETH DUKES, EMAIL: SETH.J.DUKES@USACE.ARMY.MIL TELEPHONE: (502) 315-6834 |               | 7. ADMINISTERED BY (If other than Item 6)<br>CODE<br>SCD: PAS:                                                                                                                                                                                                                                      |  |
| 8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)                                                                                                                                                       |               | <input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION NUMBER<br>W912QR25BA009<br><input checked="" type="checkbox"/> 9B. DATED (SEE ITEM 11)<br>28 MAR 2025<br><input type="checkbox"/> 10A. MODIFICATION OF CONTRACT/ORDER NUMBER<br><input type="checkbox"/> 10B. DATED (SEE ITEM 13) |  |
| CODE                                                                                                                                                                                                                                 | FACILITY CODE |                                                                                                                                                                                                                                                                                                     |  |

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

**12. ACCOUNTING AND APPROPRIATION DATA (If required)**

SEE SECTION G - CONTRACT ADMINISTRATION DATA

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.**

|                          |                                                                                                                                                                                                                       |
|--------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| CHECK ONE                | A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.                                                                   |
| <input type="checkbox"/> |                                                                                                                                                                                                                       |
| <input type="checkbox"/> | B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b). |
| <input type="checkbox"/> | C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:                                                                                                                                              |
| <input type="checkbox"/> | D. OTHER (Specify type of modification and authority)                                                                                                                                                                 |

**E. IMPORTANT:** Contractor ☐ is not ☐ is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

**14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)**

SEE SCHEDULE

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

|                                               |  |                                                            |  |
|-----------------------------------------------|--|------------------------------------------------------------|--|
| 15A. NAME AND TITLE OF SIGNER (Type or print) |  | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) |  |
| 15B. CONTRACTOR/OFFEROR                       |  | 16B. UNITED STATES OF AMERICA                              |  |
| 15C. DATE SIGNED                              |  | 16C. DATE SIGNED                                           |  |
| (Signature of person authorized to sign)      |  | (Signature of Contracting Officer)                         |  |

Previous edition unusable

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

# SUMMARY OF CHANGES

**Block 14 (Description of Amendment/Modification):** Solicitation Number W912QR25BA009 for the Construction of the Fire Station located at Youngstown ARS, Ohio is hereby amended as follows:

AMDT 00004

a. The following SPECIFICATION SECTIONS have been revised.

09 90 00 Paints & Coatings

27 20 00 Firefighter Alert System

b. The following DRAWINGS/PLANS have been updated.

I- 105 Furniture Plans

I-106 Furniture Plans

c. Wage Determination OH20250001 (Heavy and Highway) dated 4/25/2025, Modification 6, is hereby replaced in its entirety with the current revision dated 5/2/2025, Modification 7 and must be adhered to.

d. Wage Determination OH20250101 (Building) dated 3/14/2025, Modification 3, is hereby replaced in its entirety with the current revision dated 5/2/2025, Modification 4 and must be adhered to.

e. All other terms and conditions remain unchanged.

"General Decision Number: OH20250001 05/02/2025

Superseded General Decision Number: OH20240001

State: Ohio

Construction Types: Heavy and Highway

Counties: Ohio Statewide.

Heavy and Highway Construction Projects

Note: Contracts subject to the Davis-Bacon Act are generally required to pay at least the applicable minimum wage rate required under Executive Order 14026 or Executive Order 13658. Please note that these Executive Orders apply to covered contracts entered into by the federal government that are subject to the Davis-Bacon Act itself, but do not apply to contracts subject only to the Davis-Bacon Related Acts, including those set forth at 29 CFR 5.1(a)(1).

|                                                                                                                                                                   |                                                                                                                                                                                                                                                                                                                                         |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| If the contract is entered into on or after January 30, 2022, or the contract is renewed or extended (e.g., an option is exercised) on or after January 30, 2022: | <ul style="list-style-type: none"> <li>. Executive Order 14026 generally applies to the contract.</li> <li>. The contractor must pay all covered workers at least \$17.75 per hour (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on the contract in 2025.</li> </ul>  |
| If the contract was awarded on or between January 1, 2015 and January 29, 2022, and the contract is not renewed or extended on or after January 30, 2022:         | <ul style="list-style-type: none"> <li>. Executive Order 13658 generally applies to the contract.</li> <li>. The contractor must pay all covered workers at least \$13.30 per hour (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on that contract in 2025.</li> </ul> |

The applicable Executive Order minimum wage rate will be adjusted annually. If this contract is covered by one of the Executive Orders and a classification considered necessary for performance of work on the contract does not appear on this wage determination, the contractor must still submit a conformance request.

Additional information on contractor requirements and worker protections under the Executive Orders is available at <http://www.dol.gov/whd/govcontracts>.

| Modification Number | Publication Date |
|---------------------|------------------|
| 0                   | 01/03/2025       |
| 1                   | 02/07/2025       |
| 2                   | 02/14/2025       |

|   |            |
|---|------------|
| 3 | 02/28/2025 |
| 4 | 03/07/2025 |
| 5 | 03/14/2025 |
| 6 | 04/25/2025 |
| 7 | 05/02/2025 |

BROH0001-001 06/01/2024

DEFIANCE, FULTON (Excluding Fulton, Amboy & Swan Creek Townships), HENRY (Excluding Monroe, Bartlow, Liberty, Washington, Richfield, Marion, Damascus & Townships & that part of Harrison Township outside corporate limits of city of Napoleon), PAULDING, PUTNAM and WILLIAMS COUNTIES

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| Bricklayer, Stonemason..... | \$ 33.39 | 20.06   |

-----

BROH0001-004 06/01/2023

|                                   | Rates    | Fringes |
|-----------------------------------|----------|---------|
| CEMENT MASON/CONCRETE FINISHER... | \$ 32.40 | 19.30   |

-----

BROH0003-002 06/01/2024

FULTON (Townships of Amboy, Swan Creek & Fulton), HENRY (Townships of Washington, Damascus, Richfield, Bartlow, Liberty, Harrison, Monroe, & Marion), LUCAS and WOOD (Townships of Perrysburg, Ross, Lake, Troy, Freedom, Montgomery, Webster, Center, Portage, Middleton, Plain, Liberty, Henry, Washington, Weston, Milton, Jackson & Grand Rapids) COUNTIES

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| Bricklayer, Stonemason..... | \$ 33.39 | 20.06   |

-----

BROH0005-003 06/01/2020

CUYAHOGA, LORAIN & MEDINA (Hinckley, Granger, Brunswick, Liverpool, Montville, York, Homer, Harrisville, Chatham, Litchfield & Spencer Townships and the city of Medina)

|                           | Rates    | Fringes |
|---------------------------|----------|---------|
| BRICKLAYER                |          |         |
| BRICKLAYERS; CAULKERS;    |          |         |
| CLEANERS; POINTERS; &     |          |         |
| STONEMASONS.....          | \$ 36.64 | 17.13   |
| SANDBLASTERS.....         | \$ 36.39 | 17.13   |
| SEWER BRICKLAYERS & STACK |          |         |
| BUILDERS.....             | \$ 36.64 | 17.13   |
| SWING SCAFFOLDS.....      | \$ 37.14 | 17.13   |

-----

BROH0006-005 06/01/2024

CARROLL, COLUMBIANA (Knox, Butler, West & Hanover Townships), STARK & TUSCARAWAS

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

Bricklayer, Stonemason.....\$ 33.39

20.06

-----  
BROH0007-002 06/01/2024

## LAWRENCE

Rates

Fringes

Bricklayer, Stonemason.....\$ 33.39

20.06

-----  
BROH0007-005 06/01/2023

## PORTAGE &amp; SUMMIT

Rates

Fringes

BRICKLAYER.....\$ 32.40

19.30

-----  
BROH0007-010 06/01/2024

## PORTAGE &amp; SUMMIT

Rates

Fringes

MASON - STONE.....\$ 33.39

20.06

-----  
BROH0008-001 06/01/2024COLUMBIANA (Salem, Perry, Fairfield, Center, Elk Run,  
Middleton, & Unity Townships and the city of New Waterford),  
MAHONING & TRUMBULL

Rates

Fringes

BRICKLAYER.....\$ 33.39

20.06

-----  
BROH0009-002 06/01/2024BELMONT & MONROE COUNTIES and the Townships of Warren & Mt.  
Pleasant and the Village of Dillonvale in JEFFERSON COUNTY

Rates

Fringes

Bricklayer, Stonemason.....\$ 33.39

20.06

Refractory.....\$ 31.45

19.01

-----  
BROH0010-002 06/01/2024COLUMBIANA (St. Clair, Madison, Wayne, Franklin, Washington,  
Yellow Creek & Liverpool Townships) & JEFFERSON (Brush Creek &  
Saline Townships)

Rates

Fringes

Bricklayer, Stonemason.....\$ 33.39

20.06

-----  
BROH0014-002 06/01/2024HARRISON & JEFFERSON (Except Mt. Pleasant, Warren, Brush Creek,  
Saline & Salineville Townships & the Village of Dillonvale)

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| Bricklayer, Stonemason..... | \$ 33.39 | 20.06   |
| -----                       |          |         |
| BROH0016-002 06/01/2023     |          |         |

ASHTABULA, GEAUGA, and LAKE COUNTIES

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| Bricklayer, Stonemason..... | \$ 32.40 | 19.30   |
| -----                       |          |         |
| BROH0018-002 06/01/2024     |          |         |

BROWN, BUTLER, CLERMONT, HAMILTON, PREBLE (Gasper, Dixon, Israel, Lanier, Somers & Gratis Townships) & WARREN COUNTIES:

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| Bricklayer, Stonemason..... | \$ 33.39 | 20.06   |
| -----                       |          |         |
| BROH0022-004 06/01/2024     |          |         |

CHAMPAIGN, CLARK, CLINTON, DARKE, GREENE, HIGHLAND, LOGAN, MIAMI, MONTGOMERY, PREBLE (Jackson, Monroe, Harrison, Twin, Jefferson & Washington Townships) and SHELBY COUNTIES

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| Bricklayer, Stonemason..... | \$ 33.39 | 20.06   |
| -----                       |          |         |
| BROH0032-001 06/01/2024     |          |         |

GALLIA & MEIGS

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| Bricklayer, Stonemason..... | \$ 33.39 | 20.06   |
| -----                       |          |         |
| BROH0035-002 06/01/2024     |          |         |

ALLEN, AUGLAIZE, MERCER and VAN WERT COUNTIES

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| Bricklayer, Stonemason..... | \$ 33.39 | 20.06   |
| -----                       |          |         |
| BROH0039-002 06/01/2024     |          |         |

ADAMS & SCIOTO

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| Bricklayer, Stonemason..... | \$ 33.39 | 20.06   |
| -----                       |          |         |
| BROH0040-003 06/01/2024     |          |         |

ASHLAND, CRAWFORD, HARDIN, HOLMES, MARION, MORROW, RICHLAND, WAYNE and WYANDOT (Except Crawford, Ridge, Richland & Tymochtee Townships) COUNTIES

| Rates | Fringes |
|-------|---------|
|-------|---------|

Bricklayer, Stonemason.....\$ 33.39 20.06

FOOTNOTE: Layout Man and Sawman rate: \$1.00 per hour above journeyman rate.

Free standing stack work ground level to top of stack;  
Sandblasting and laying of carbon masonry material in swing stage and/or scaffold; Ramming and spading of plastics and gunniting: \$1.50 per hour above journeyman rate.

""Hot"" work: \$2.50 above journeyman rate.

-----  
BROH0044-002 06/01/2024

Rates Fringes

Bricklayer, Stonemason  
COSHOCKTON, FAIRFIELD,  
GUERNSEY, HOCKING, KNOX,  
KICKING, MORGAN,  
MUSKINGUM, NOBLE (Beaver,  
Buffalo, Seneca & Wayne  
Townships) & PERRY  
COUNTIES:.....\$ 33.39 20.06

-----  
BROH0045-002 06/01/2023

FAYETTE, JACKSON, PIKE, ROSS and VINTON COUNTIES

Rates Fringes

Bricklayer, Stonemason.....\$ 35.39 17.47

-----  
BROH0046-002 06/01/2024

ERIE, HANCOCK, HURON, OTTAWA, SANDUSKY, SENECA, WOOD (Perry & Bloom Townships) and WYANDOT (Tymochtee, Crawford, Ridge & Richland Townships) COUNTIES & the Islands of Lake Erie north of Sandusky

Rates Fringes

Bricklayer, Stonemason.....\$ 33.39 20.06

FOOTNOTE: Layout Man and Sawman rate: \$1.00 per hour above journeyman rate.

Free standing stack work ground level to top of stack;  
Sandblasting and laying of carbon masonry material in swing stage and/or scaffold; Ramming and spading of plastics and gunniting: \$1.50 per hour above journeyman rate.

""Hot"" work: \$2.50 above journeyman rate.

-----  
BROH0052-001 06/01/2024

ATHENS COUNTY

Rates Fringes

Bricklayer, Stonemason.....\$ 33.39 20.06

-----  
BROH0052-003 06/01/2024

NOBLE (Brookfield, Noble, Center, Sharon, Olive, Enoch, Stock,

Jackson, Jefferson &amp; Elk Townships) and WASHINGTON COUNTIES

W912QR25BA009\_CertF\_Specs-0004

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| Bricklayer, Stonemason..... | \$ 33.39 | 20.06   |

-----  
BROH0055-003 06/01/2024

DELAWARE, FRANKLIN, MADISON, PICKAWAY and UNION COUNTIES

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| Bricklayer, Stonemason..... | \$ 33.39 | 20.06   |

-----  
CARP0003-004 05/01/2017

MAHONING &amp; TRUMBULL

|                | Rates    | Fringes |
|----------------|----------|---------|
| CARPENTER..... | \$ 26.20 | 17.42   |

-----  
CARP0069-003 05/01/2017

CARROLL, STARK, TUSCARAWAS &amp; WAYNE

|                | Rates    | Fringes |
|----------------|----------|---------|
| CARPENTER..... | \$ 25.98 | 15.98   |

-----  
CARP0069-006 05/01/2017

COSHOCOTON, HOLMES, KNOX &amp; MORROW

|                | Rates    | Fringes |
|----------------|----------|---------|
| CARPENTER..... | \$ 24.04 | 15.29   |

-----  
CARP0171-002 05/01/2024

BELMONT, COLUMBIANA, HARRISON, JEFFERSON &amp; MONROE

|                | Rates    | Fringes |
|----------------|----------|---------|
| CARPENTER..... | \$ 31.82 | 25.11   |

-----  
CARP0200-002 05/01/2024ADAMS, ATHENS, DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, GALLIA,  
GUERNSEY, HIGHLAND, HOCKING, JACKSON, LAWRENCE, LICKING,  
MADISON, MARION, MEIGS, MORGAN, MUSKINGUM, NOBLE, PERRY,  
PICKAWAY, PIKE, ROSS, SCIOTO, UNION, VINTON and WASHINGTON  
COUNTIES

|                    | Rates    | Fringes |
|--------------------|----------|---------|
| CARPENTER.....     | \$ 33.15 | 22.43   |
| Diver.....         | \$ 39.41 | 10.40   |
| PILEDRIVERMAN..... | \$ 33.15 | 22.43   |

-----  
CARP0248-005 07/01/2008

LUCAS &amp; WOOD

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| CARPENTER.....          | \$ 27.27 | 14.58   |
| -----                   |          |         |
| CARP0248-008 07/01/2008 |          |         |

|                                                                                        | Rates    | Fringes |
|----------------------------------------------------------------------------------------|----------|---------|
| CARPENTER<br>DEFIANCE, FULTON, HANCOCK,<br>HENRY, PAULDING & WILLIAMS<br>COUNTIES..... | \$ 23.71 | 13.28   |
| -----                                                                                  |          |         |
| CARP0254-002 05/01/2017                                                                |          |         |

ASHTABULA, CUYAHOGA, GEAUGA & LAKE

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| CARPENTER.....          | \$ 32.40 | 16.97   |
| -----                   |          |         |
| CARP0372-002 05/01/2024 |          |         |

ALLEN, AUGLAIZE, HARDIN, MERCER, PUTNAM & VAN WERT

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| CARPENTER.....          | \$ 30.73 | 25.09   |
| -----                   |          |         |
| CARP0639-003 05/01/2017 |          |         |

MEDINA, PORTAGE & SUMMIT

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| CARPENTER.....          | \$ 30.42 | 16.99   |
| -----                   |          |         |
| CARP0735-002 05/01/2024 |          |         |

ASHLAND, ERIE, HURON, LORAIN & RICHLAND

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| CARPENTER.....          | \$ 33.43 | 22.31   |
| -----                   |          |         |
| CARP1311-001 05/01/2017 |          |         |

BROWN, BUTLER, CHAMPAIGN, CLARK, CLERMONT, CLINTON, DARKE,  
GREENE, HAMILTON, LOGAN, MIAMI, MONTGOMERY, PREBLE, SHELBY &  
WARREN

|                                | Rates    | Fringes |
|--------------------------------|----------|---------|
| Carpenter & Piledrivermen..... | \$ 29.34 | 15.95   |
| Diver.....                     | \$ 40.58 | 9.69    |
| -----                          |          |         |
| CARP1393-002 05/01/2024        |          |         |

CRAWFORD, DEFIANCE, FULTON, HANCOCK, HENRY, LUCAS, OTTAWA,  
PAULDING, SANDUSKY, SENECA, WILLIAMS & WOOD

| Rates | Fringes |
|-------|---------|
|-------|---------|

Piledrivermen & Diver's Tender...\$ 36.84 27.72

DIVERS - \$250.00 per day

-----  
CARP1393-003 05/01/2024

ALLEN, AUGLAIZE, HARDIN, MERCER, PUTNAM, VAN WERT & WYANDOT

Rates Fringes

Piledrivermen & Diver's Tender...\$ 34.68 27.60

DIVERS - \$250.00 per day

-----  
CARP1871-006 05/01/2017

BELMONT, HARRISON, & MONROE

Rates Fringes

Diver, Wet.....\$ 48.11 17.33

Piledrivermen; Diver, Dry.....\$ 32.07 17.33

-----  
CARP1871-008 05/01/2017

ASHLAND, ASHTABULA, CUYAHOGA, ERIE, GEAUGA, HURON, LAKE,  
LORAIN, MEDINA, PORTAGE, RICHLAND & SUMMIT

Rates Fringes

Diver, Wet.....\$ 45.80 18.84

Piledrivermen; Diver, Dry.....\$ 30.53 18.84

-----  
CARP1871-014 05/01/2017

CARROLL, STARK, TUSCARAWAS & WAYNE

Rates Fringes

Diver, Wet.....\$ 38.34 16.95

Piledrivermen; Diver, Dry.....\$ 25.56 16.95

-----  
CARP1871-015 05/01/2017

COSHOCTON, HOLMES, KNOX & MORROW

Rates Fringes

Diver, Wet.....\$ 37.34 16.07

Piledrivermen; Diver, Dry.....\$ 24.89 16.07

-----  
CARP1871-017 05/01/2017

MAHONING & TRUMBULL

Rates Fringes

Diver, Wet.....\$ 40.65 17.62

Piledrivermen; Diver, Dry.....\$ 27.10 17.62

-----  
CARP2235-012 01/01/2014

COLUMBIANA & JEFFERSON

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| PILEDRIVERMAN.....      | \$ 31.74 | 16.41   |
| -----                   |          |         |
| CARP2239-001 07/01/2008 |          |         |

CRAWFORD, OTTAWA, SANDUSKY, SENECA & WYANDOT

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| CARPENTER.....          | \$ 23.71 | 13.28   |
| -----                   |          |         |
| ELEC0008-002 05/27/2024 |          |         |

DEFIANCE, FULTON, HANCOCK, HENRY, LUCAS, OTTAWA, PAULDING,  
PUTNAM, SANDUSKY, SENECA, WILLIAMS & WOOD

|                         | Rates    | Fringes    |
|-------------------------|----------|------------|
| CABLE SPLICER.....      | \$ 38.98 | 18.96      |
| ELECTRICIAN.....        | \$ 48.40 | 4.5%+23.06 |
| -----                   |          |            |
| ELEC0032-003 12/02/2024 |          |            |

ALLEN, AUGLAIZE, HARDIN, LOGAN, MERCER, SHELBY, VAN WERT &  
WYANDOT (Crawford, Jackson, Marseilles, Mifflin, Ridgeland,  
Ridge & Salem Townships)

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| ELECTRICIAN.....        | \$ 39.17 | 23.45   |
| -----                   |          |         |
| ELEC0038-002 04/29/2024 |          |         |

CUYAHOGA, GEAUGA (Bainbridge, Chester & Russell Townships) &  
LORAIN (Columbia Township)

|                                                              | Rates    | Fringes |
|--------------------------------------------------------------|----------|---------|
| ELECTRICIAN<br>Excluding Sound &<br>Communications Work..... | \$ 45.23 | 23.88   |

FOOTNOTES;

- a. 6 Paid Holidays: New Year's Day; Memorial Day; July 4th;  
Labor Day; Thanksgiving Day; & Christmas Day
- b. 1 week's paid vacation for 1 year's service; 2 weeks' paid  
vacation for 2 or more years' service

|                         |  |  |
|-------------------------|--|--|
| -----                   |  |  |
| ELEC0038-008 04/29/2024 |  |  |

CUYAHOGA, GEAUGA (Bainbridge, Chester & Russell Townships) &  
LORAIN (Columbia Township)

|                                                                     | Rates    | Fringes |
|---------------------------------------------------------------------|----------|---------|
| Sound & Communication<br>Technician<br>Communications Technician... | \$ 32.30 | 14.38   |

Installer Technician.....\$ 31.05

14.34

W912QR25BA009\_CertF\_Specs-0004

## FOOTNOTES;

- a. 6 Paid Holidays: New Year's Day; Memorial Day; July 4th; Labor Day; Thanksgiving Day; & Christmas Day
- b. 1 week's paid vacation for 1 year's service; 2 weeks' paid vacation for 2 or more years' service

-----  
ELEC0064-003 11/25/2024

COLUMBIANA (Butler, Fairfield, Perry, Salem & Unity Townships)  
 MAHONING (Austintown, Beaver, Berlin, Boardman, Canfield, Ellsworth, Coitsville, Goshen, Green, Jackson, Poland, Springfield & Youngstown Townships), & TRUMBULL (Hubbard & Liberty Townships)

|                  | Rates    | Fringes |
|------------------|----------|---------|
| ELECTRICIAN..... | \$ 39.80 | 21.03   |

-----  
ELEC0071-005 01/06/2025

ASHTABULA, CUYAHOGA, GEAUGA, LAKE &amp; LORAIN

|                                                   | Rates    | Fringes  |
|---------------------------------------------------|----------|----------|
| LINE CONSTRUCTION: Equipment Operator             |          |          |
| DOT/Traffic Signal & Highway Lighting Projects... | \$ 39.97 | 27%+8.00 |
| Municipal Power/Transit Projects.....             | \$ 49.46 | 27%+8.25 |
| LINE CONSTRUCTION: Groundman                      |          |          |
| DOT/Traffic Signal & Highway Lighting Projects... | \$ 31.10 | 27%+8.00 |
| Municipal Power/Transit Projects.....             | \$ 38.47 | 27%+8.25 |
| LINE CONSTRUCTION: Linemen/Cable Splicer          |          |          |
| DOT/Traffic Signal & Highway Lighting Projects... | \$ 43.89 | 27%+8.00 |
| Municipal Power/Transit Projects.....             | \$ 54.96 | 27%+8.25 |

-----  
\* ELEC0071-010 01/06/2025

Statewide

|                              | Rates    | Fringes  |
|------------------------------|----------|----------|
| Line Construction            |          |          |
| Equipment Operator.....      | \$ 40.44 | 4%+16.09 |
| Groundman.....               | \$ 29.07 | 4%+13.81 |
| Lineman & Cable Splicers.... | \$ 46.02 | 4%+17.20 |

-----  
ELEC0082-002 12/02/2024

CLINTON, DARKE, GREENE, MIAMI, MONTGOMERY, PREBLE & WARREN  
 (Wayne, Clear Creek & Franklin Townships)

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                  |          |       |
|------------------|----------|-------|
| ELECTRICIAN..... | \$ 38.00 | 22.49 |
|------------------|----------|-------|

-----  
 \* ELEC0082-006 11/25/2024

CLINTON, DARKE, GREENE, MIAMI, MONTGOMERY, PREBLE & WARREN  
 (Wayne, Clear Creek & Franklin Townships)

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

Sound & Communication  
 Technician

|                           |             |       |
|---------------------------|-------------|-------|
| Cable Puller.....         | \$ 13.85 ** | 5.30  |
| Installer/Technician..... | \$ 27.70    | 15.71 |

-----  
 ELEC0129-003 02/24/2025

LORAIN (Except Columbia Township) & MEDINA (Litchfield &  
 Liverpool Townships)

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

|                  |          |       |
|------------------|----------|-------|
| ELECTRICIAN..... | \$ 42.95 | 18.81 |
|------------------|----------|-------|

-----  
 ELEC0129-004 02/24/2025

ERIE & HURON (Lyme, Ridgefield, Norwalk, Townsend, Wakeman,  
 Sherman, Peru, Bronson, Hartland, Clarksfield, Norwich,  
 Greenfield, Fairfield, Fitchville & New London Townships)

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

|                  |          |       |
|------------------|----------|-------|
| ELECTRICIAN..... | \$ 42.95 | 18.81 |
|------------------|----------|-------|

-----  
 ELEC0141-003 06/02/2024

BELMONT COUNTY

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

|                    |          |       |
|--------------------|----------|-------|
| CABLE SPLICER..... | \$ 42.94 | 27.74 |
| ELECTRICIAN.....   | \$ 39.04 | 27.62 |

-----  
 ELEC0212-003 11/26/2018

BROWN, CLERMONT & HAMILTON

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

Sound & Communication  
 Technician.....

|          |       |
|----------|-------|
| \$ 24.35 | 10.99 |
|----------|-------|

-----  
 ELEC0212-005 06/03/2024

BROWN, CLERMONT, and HAMILTON COUNTIES

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

|                  |          |       |
|------------------|----------|-------|
| ELECTRICIAN..... | \$ 35.43 | 22.05 |
|------------------|----------|-------|

-----  
 ELEC0245-001 08/26/2024

ALLEN, HARDIN, VAN WERT & WYANDOT (Crawford, Jackson,

Marseilles, Mifflin, Richland, Ridge &amp; Salem Townships)

W912QR25BA009\_CertF\_Specs-0004

|                             | Rates    | Fringes  |
|-----------------------------|----------|----------|
| Line Construction           |          |          |
| Equipment Operator.....     | \$ 32.95 | 28%+7.85 |
| Groundman Truck Driver..... | \$ 20.59 | 28%+7.85 |
| Lineman.....                | \$ 47.07 | 28%+7.85 |

FOOTNOTE: a. Half day's Paid Holiday: The last 4 hours of the workday prior to Christmas or New Year's Day

-----  
ELEC0245-003 01/01/2025

DEFIANCE, FULTON, HANCOCK, HENRY, HURON, LUCAS, OTTAWA,  
PAULDING, PUTNAM, SANDUSKY, SENECA, WILLIAMS, and WOOD COUNTIES

|                                           | Rates    | Fringes  |
|-------------------------------------------|----------|----------|
| Line Construction                         |          |          |
| Cable Splicer.....                        | \$ 53.90 | 8.10+28% |
| Groundman/Truck Driver.....               | \$ 20.51 | 8.10+28% |
| Heli-arc Welding.....                     | \$ 47.17 | 8.10+28% |
| Lineman.....                              | \$ 46.87 | 8.10+28% |
| Operator - Class 1.....                   | \$ 37.50 | 8.10+28% |
| Operator - Class 2.....                   | \$ 32.81 | 8.10+28% |
| Traffic Signal & Lighting Technician..... | \$ 42.18 | 8.10+28% |

FOOTNOTE: a. 6 Observed Holidays: New Year's Day; Memorial Day; Independence Day; Labor Day; Thanksgiving Day; & Christmas Day. Employees who work on a holiday shall be paid at a rate of double their applicable classified straight-time rates for the work performed on such holiday.

-----  
ELEC0245-004 01/01/2025

ERIE COUNTY

|                             | Rates    | Fringes     |
|-----------------------------|----------|-------------|
| Line Construction           |          |             |
| Cable Splicer.....          | \$ 49.14 | 26.75%+6.75 |
| Cablesplicer.....           | \$ 53.90 | 28%+8.10    |
| Groundman/Truck Driver..... | \$ 20.51 | 28%+8.10    |
| Lineman.....                | \$ 46.87 | 28%+8.10    |
| Operator - Class 1.....     | \$ 37.50 | 28%+8.10    |
| Operator - Class 2.....     | \$ 32.81 | 28%+8.10    |

FOOTNOTE: a. 6 Observed Holidays: New Year's Day; Memorial Day; Independence Day; Labor Day; Thanksgiving Day; & Christmas Day. Employees who work on a holiday shall be paid at a rate of double their applicable classified straight-time rates for the work performed on such holiday.

-----  
ELEC0246-001 10/28/2024

|                  | Rates    | Fringes      |
|------------------|----------|--------------|
| ELECTRICIAN..... | \$ 44.00 | 30.38%+24.31 |

FOOTNOTE: a. 1 1/2 Paid Holidays: The last scheduled workday prior to Christmas & 4 hours on Good Friday.

-----  
ELEC0306-005 05/27/2024

MEDINA (Brunswick, Chatham, Granger, Guilford, Harrisville, Hinckley, Homer, Lafayette, Medina, Montville, Sharon, Spencer, Wadsworth, Westfield & York Townships), PORTAGE (Atwater, Aurora, Brimfield, Deerfield, Franklin, Mantua, Randolph, Ravenna, Rootstown, Shalersville, Streetsboro & Suffield Townships), SUMMIT & WAYNE (Baughman, Canaan, Chester, Chippewa, Congress, Green, Milton, & Wayne Townships)

|                    | Rates    | Fringes |
|--------------------|----------|---------|
| CABLE SPLICER..... | \$ 46.81 | 20.95   |
| ELECTRICIAN.....   | \$ 42.55 | 20.95   |

-----

ELEC0317-002 05/29/2023

GALLIA & LAWRENCE

|                    | Rates    | Fringes |
|--------------------|----------|---------|
| CABLE SPLICER..... | \$ 32.68 | 18.13   |
| ELECTRICIAN.....   | \$ 37.15 | 28.48   |

-----

ELEC0540-005 01/01/2024

CARROLL (Northern half, including Fox, Harrison, Rose & Washington Townships), COLUMBIANA (Knox Township), HOLMES, MAHONING (Smith Township), STARK, TUSCARAWAS (North of Auburn, Clay, Rush & York Townships), and WAYNE (South of Baughman, Chester, Green & Wayne Townships) COUNTIES

|                  | Rates    | Fringes |
|------------------|----------|---------|
| ELECTRICIAN..... | \$ 36.96 | 28.18   |

-----

ELEC0573-003 11/25/2024

ASHTABULA (Colebrook, Wayne, Williamsfield, Orwell & Windsor Townships), GEAUGA (Auburn, Middlefield, Parkman & Troy Townships), MAHONING (Milton Township), PORTAGE (Charlestown, Edinburg, Freedom, Hiram, Nelson, Palmyra, Paris & Windham Townships), and TRUMBULL (Except Liberty & Hubbard Townships)

|                  | Rates    | Fringes |
|------------------|----------|---------|
| ELECTRICIAN..... | \$ 42.20 | 23.20   |

-----

ELEC0575-001 05/29/2023

ADAMS, FAYETTE, HIGHLAND, HOCKING, JACKSON (Bloomfield, Franklin, Hamilton, Jefferson, Lick, Madison, Scioto, Coal, Jackson, Liberty, Milton & Washington Townships), PICKAWAY (Deer Creek, Perry, Pickaway, Salt Creek & Wayne Townships), PIKE (Beaver, Benton, Jackson, Mifflin, Pebble, PeePee, Perry, Seal, Camp Creek, Newton, Scioto, Sunfish, Union & Marion Townships), ROSS, SCIOTO & VINTON (Clinton, Eagle, Elk,

Harrison, Jackson, Richland &amp; Swan Townships)

W912QR25BA009\_CertF\_Specs-0004

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| ELECTRICIAN.....        | \$ 37.00 | 22.26   |
| -----                   |          |         |
| ELEC0648-001 08/26/2024 |          |         |

BUTLER and WARREN COUNTIES (Deerfield, Hamilton, Harlan,  
Massie, Salem, Turtle Creek, Union & Washington Townships)

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| CABLE SPLICER.....      | \$ 30.50 | 18.23   |
| ELECTRICIAN.....        | \$ 36.00 | 23.06   |
| -----                   |          |         |
| ELEC0673-004 12/30/2024 |          |         |

ASHTABULA (Excluding Orwell, Colebrook, Williamsfield, Wayne &  
Windsor Townships), GEAUGA (Burton, Chardon, Claridon, Hambden,  
Huntsburg, Montville, Munson, Newbury & Thompson Townships) and  
LAKE COUNTIES

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| CABLE SPLICER.....      | \$ 33.81 | 21.47   |
| ELECTRICIAN.....        | \$ 39.47 | 24.02   |
| -----                   |          |         |
| ELEC0683-002 05/27/2024 |          |         |

CHAMPAIGN, CLARK, DELAWARE, FAIRFIELD, FRANKLIN, MADISON,  
PICKAWAY (Circleville, Darby, Harrison, Jackson, Madison,  
Monroe, Muhlenberg, Scioto, Walnut & Washington Townships), and  
UNION COUNTIES

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| CABLE SPLICER.....      | \$ 41.50 | 24.19   |
| ELECTRICIAN.....        | \$ 40.50 | 25.20   |
| -----                   |          |         |
| ELEC0688-003 05/30/2022 |          |         |

ASHLAND, CRAWFORD, HURON (Richmond, New Haven, Ripley &  
Greenwich Townships), KNOX (Liberty, Clinton, Union, Howard,  
Monroe, Middleberry, Morris, Wayne, Berlin, Pike, Brown &  
Jefferson Townships), MARION, MORROW, RICHLAND and WYANDOT  
(Sycamore, Crane, Eden, Pitt, Antrim & Tymochtee Townships)  
COUNTIES

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| ELECTRICIAN.....        | \$ 32.30 | 21.83   |
| -----                   |          |         |
| ELEC0972-002 06/01/2023 |          |         |

ATHENS, MEIGS, MONROE, MORGAN, NOBLE, VINTON (Brown, Knox,  
Madison, Vinton & Wilkesville Townships), and WASHINGTON  
COUNITIES

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| CABLE SPLICER.....      | \$ 35.70 | 30.26   |
| ELECTRICIAN.....        | \$ 35.45 | 30.25   |
| -----                   |          |         |
| ELEC1105-001 05/27/2024 |          |         |

COSHOCTON, GUERNSEY, KNOX (Jackson, Clay, Morgan, Miller, Milford, Hilliar, Butler, Harrison, Pleasant & College Townships), LICKING, MUSKINGUM, PERRY, and TUSCARAWAS (Auburn, York, Clay, Jefferson, Rush, Oxford, Washington, Salem, Perry & Bucks Townships) COUNTIES

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| ELECTRICIAN.....        | \$ 39.60 | 24.41   |
| -----                   |          |         |
| ENGI0018-003 05/01/2024 |          |         |

ASHTABULA, CUYAHOGA, ERIE, GEAUGA, LAKE, LORAIN, MEDINA, PORTAGE, and SUMMIT COUNTIES

|                          | Rates    | Fringes |
|--------------------------|----------|---------|
| POWER EQUIPMENT OPERATOR |          |         |
| GROUP 1.....             | \$ 45.63 | 16.41   |
| GROUP 2.....             | \$ 45.53 | 16.41   |
| GROUP 3.....             | \$ 44.49 | 16.41   |
| GROUP 4.....             | \$ 43.27 | 16.41   |
| GROUP 5.....             | \$ 37.98 | 16.41   |
| GROUP 6.....             | \$ 46.63 | 16.41   |
| GROUP 7.....             | \$ 46.63 | 16.41   |

#### OPERATING ENGINEER CLASSIFICATIONS

GROUP 1 - Air Compressor on Steel Erection; Barrier Moving Machine; Boiler Operator on Compressor or Generator when mounted on a Rig; Cableway; Combination Concrete Mixer & Tower; Concrete Plant (over 4 yd. Capacity); Concrete Pump; Crane (All Types, Including Boom Truck, Cherry Picker); Crane-Compact, Track or Rubber over 4,000 lbs. capacity; Cranes-Self Erecting, Stationary, Track or Truck (All Configurations); Derrick; Dragline; Dredge (Dipper, Clam or Suction); Elevating Grader or Euclid Loader; Floating Equipment (All Types); Gradall; Helicopter Crew (Operator-Hoist or Winch); Hoe (all types); Hoisting Engine on Shaft or Tunnel Work; Hydraulic Gantry (Lifting System); Industrial-Type Tractor; Jet Engine Dryer (D8 or D9) Diesel Tractor; Locomotive (Standard Gauge); Maintenance Operator Class A; Mixer, Paving (Single or Double Drum); Mucking Machine; Multiple Scraper; Piledriving Machine (All Types); Power Shovel; Prentice Loader; Quad 9 (Double Pusher); Rail Tamper (with auto lifting & aligning device); Refrigerating Machine (Freezer Operation); Rotary Drill, on Caisson work; Rough Terrain Fork Lift with Winch/Hoist; Side-Boom; Slip-Form Paver; Tower Derrick; Tree Shredder; Trench Machine (Over 24" wide); Truck Mounted Concrete Pump; Tug Boat; Tunnel Machine and/or Mining Machine; Wheel Excavator; and Asphalt Plant Engineer (Cleveland District Only).

GROUP 2 - Asphalt Paver; Automatic Subgrader Machine, Self-Propelled (CMI Type); Bobcat Type and/or Skid Steer

Loader with Hoe Attachment Greater than 7,000 lbs.; Boring Machine More than 48"; Bulldozer; Endloader; Horizontal Directional Drill (Over 50,000 ft lbs thrust); Hydro Milling Machine; Kolman-type Loader (production type-Dirt); Lead Greaseman; Lighting & Traffic Signal Installation Equipment (includes all groups or classifications); Material Transfer Equipment (Shuttle Buggy) Asphalt; Pettibone-Rail Equipment; Power Grader; Power Scraper; Push Cat; Rotomill (all), Grinders & Planers of All types; Trench Machine (24" wide & under); Vermeer type Concrete Saw; and Maintenance Operators (Portage and Summit Counties Only).

GROUP 3 - A-Frame; Air Compressor on Tunnel Work (low pressure); Asphalt Plant Engineer (Portage and Summit Counties Only); Bobcat-type and/or Skid Steer Loader with or without Attachments; Highway Drills (all types); Locomotive (narrow gauge); Material Hoist/Elevator; Mixer, Concrete (more than one bag capacity); Mixer, one bag capacity (Side Loader); Power Boiler (Over 15 lbs. Pressure) Pump Operator installing & operating Well Points; Pump (4" & over discharge); Roller, Asphalt; Rotovator (lime soil stabilizer); Switch & Tie Tampers (without lifting & aligning device); Utility Operator (Small equipment); Welding Machines; and Railroad Tie Insert/Remover; Articulating/straight bed end dumps if assigned (minus \$4.00 per hour).

GROUP 4 - Backfiller; Ballast Re-locator; Bars, Joint & Mesh Installing Machine; Batch Plant; Boring Machine Operator (48" or less); Bull Floats; Burlap & Curing Machine; Concrete Plant (capacity 4 yd. & under); Concrete Saw (Multiple); Conveyor (Highway); Crusher; Deckhand; Farm-type Tractor with attachments (highway); Finishing Machine; Fireperson, Floating Equipment (all types); Forklift; Form Trencher; Hydro Hammer expect masonry; Hydro Seeder; Pavement Breaker; Plant Mixer; Post Driver; Post Hole Digger (Power Auger); Power Brush Burner; Power Form Handling Equipment; Road Widening Trencher; Roller (Brick, Grade & Macadam); Self-Propelled Power Spreader; Self-Propelled Power Subgrader; Steam Fireperson; Tractor (Pulling Sheepfoot, Roller or Grader); and Vibratory Compactor with Integral Power.

GROUP 5 - Compressor (Portable, Sewer, Heavy & Highway); Drum Fireperson (Asphalt Plant); Generator; Masonry Fork Lift; Inboard-Outboard Motor Boat Launch; Oil Heater (asphalt plant); Oiler/Helper; Power Driven Heater; Power Sweeper & Scrubber; Pump (under 4" discharge); Signalperson; Tire Repairperson; VAC/ALLS; Cranes - Compact, track or rubber under 4,000 pound capacity; fueling and greasing; and Chainmen.

GROUP 6 - Master Mechanic & Boom from 150 to 180.

GROUP 7 - Boom from 180 and over.

-----  
ENGI0018-004 05/01/2024

ADAMS, ALLEN, ASHLAND, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COSHOCTON, CRAWFORD, DARKE, DEFIANCE, DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, FULTON, GALLIA, GREENE, GUERNSEY, HAMILTON, HANCOCK, HARDIN, HARRISON, HENRY, HIGHLAND, HOCKING, HOLMES,

HURON, JACKSON, JEFFERSON, KNOX, LAWRENCE, LICKING, LOGAN, LUCAS, MADISON, MARION, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, OTTAWA, PAULDING, PERRY, PICKAWAY, PIKE, PREBLE, PUTNAM, RICHLAND, ROSS, SANDUSKY, SCIOTO, SENECA, SHELBY, STARK, TUSCARAWAS, UNION, VAN WERT, VINTON, WARREN, WASHINGTON, WAYNE, WILLIAMS, WOOD, and YANDOT COUNTIES

## Rates Fringes

### POWER EQUIPMENT OPERATOR

|              |          |       |
|--------------|----------|-------|
| GROUP 1..... | \$ 44.14 | 16.41 |
| GROUP 2..... | \$ 44.02 | 16.41 |
| GROUP 3..... | \$ 42.98 | 16.41 |
| GROUP 4..... | \$ 41.80 | 16.41 |
| GROUP 5..... | \$ 36.34 | 16.41 |
| GROUP 6..... | \$ 45.14 | 16.41 |
| GROUP 7..... | \$ 45.14 | 16.41 |

### OPERATING ENGINEER CLASSIFICATIONS

GROUP 1 - Air Compressor on Steel Erection; Barrier Moving Machine; Boiler Operator on Compressor or Generator when mounted on a Rig; Cableway; Combination Concrete Mixer & Tower; Concrete Plant (over 4 yd. Capacity); Concrete Pump; Crane (All Types, Including Boom Truck, Cherry Picker); Crane-Compact, Track or Rubber over 4,000 lbs. capacity; Cranes-Self Erecting, Stationary, Track or Truck (All Configurations); Derrick; Dragline; Dredge (Dipper, Clam or Suction); Elevating Grader or Euclid Loader; Floating Equipment (All Types); Gradall; Helicopter Crew (Operator-Hoist or Winch); Hoe (all types); Hoisting Engine on Shaft or Tunnel Work; Hydraulic Gantry (Lifting System); Industrial-Type Tractor; Jet Engine Dryer (D8 or D9) Diesel Tractor; Locomotive (Standard Gauge); Maintenance Operator Class A; Mixer, Paving (Single or Double Drum); Mucking Machine; Multiple Scraper; Piledriving Machine (All Types); Power Shovel; Prentice Loader; Quad 9 (Double Pusher); Rail Tamper (with auto lifting & aligning device); Refrigerating Machine (Freezer Operation); Rotary Drill, on Caisson work; Rough Terrain Fork Lift with Winch/Hoist; Side-Boom; Slip-Form Paver; Tower Derrick; Tree Shredder; Trench Machine (Over 24" wide); Truck Mounted Concrete Pump; Tug Boat; Tunnel Machine and/or Mining Machine; and Wheel Excavator.

GROUP 2 - Asphalt Paver; Automatic Subgrader Machine, Self-Propelled (CMI Type); Bobcat Type and/or Skid Steer Loader with Hoe Attachment Greater than 7,000 lbs.; Boring Machine More than 48"; Bulldozer; Endloader; Hydro Milling Machine; Horizontal Directional Drill (over 50,000 ft. lbs. thrust); Kolman-type Loader (production type-Dirt); Lead Greaseman; Lighting & Traffic Signal Installation Equipment (includes all groups or classifications); Material Transfer Equipment (Shuttle Buggy) Asphalt; Pettibone-Rail Equipment; Power Grader; Power Scraper; Push Cat; Rotomill (all), Grinders & Planers of All types; Trench Machine (24" wide & under); and Vermeer type Concrete Saw.

GROUP 3 - A-Frame; Air Compressor on Tunnel Work (low pressure); Asphalt Plant Engineer; Bobcat-type and/or Skid Steer Loader with or without Attachments; Highway Drills (all types); Locomotive (narrow gauge); Material Hoist/Elevator; Mixer, Concrete (more than one bag

capacity); Mixer, one bag capacity (Side Loader); Power Boiler (Over 15 lbs. Pressure) Pump Operator installing & operating Well Points; Pump (4" & over discharge); Railroad Tie Inserter/Remover; Roller, Asphalt; Rotovator (lime soil stabilizer); Switch & Tie Tampers (without lifting & aligning device); Utility Operator (Small equipment); and Welding Machines; Articulating/straight bed end dumps if assigned (minus \$4.00 per hour).

GROUP 4 - Backfiller; Ballast Re-locator; Bars, Joint & Mesh Installing Machine; Batch Plant; Boring Machine Operator (48" or less); Bull Floats; Burlap & Curing Machine; Concrete Plant (capacity 4 yd. & under); Concrete Saw (Multiple); Conveyor (Highway); Crusher; Deckhand; Farm-type Tractor with attachments (highway); Finishing Machine; Fireperson, Floating Equipment (all types); Fork Lift; Form Trencher; Hydro Hammer expect masonry; Hydro Seeder; Pavement Breaker; Plant Mixer; Post Driver; Post Hole Digger (Power Auger); Power Brush Burner; Power Form Handling Equipment; Road Widening Trencher; Roller (Brick, Grade & Macadam); Self-Propelled Power Spreader; Self-Propelled Power Subgrader; Steam Fireperson; Tractor (Pulling Sheepfoot, Roller or Grader); and Vibratory Compactor with Integral Power.

GROUP 5 - Compressor (Portable, Sewer, Heavy & Highway); Drum Fireperson (Asphalt Plant); Generator; Masonary Forklift; Inboard-Outboard Motor Boat Launch; Oil Heater (asphalt plant); Oiler/Helper; Power Driven Heater; Power Sweeper & Scrubber; Pump (under 4" discharge); Signaller; Tire Repairperson; VAC/ALLS; Cranes - Compact, track or rubber under 4,000 pound capacity; fueling and greasing; and Chainmen.

GROUP 6 - Master Mechanic & Boom from 150 to 180.

GROUP 7 - Boom from 180 and over.

-----  
ENGI0066-023 06/01/2023

COLUMBIANA, MAHONING & TRUMBULL COUNTIES

|                           | Rates    | Fringes |
|---------------------------|----------|---------|
| POWER EQUIPMENT OPERATOR  |          |         |
| ASBESTOS; HAZARDOUS/TOXIC |          |         |
| WASTE PROJECTS            |          |         |
| GROUP 1 - A & B.....      | \$ 44.63 | 24.30   |
| ASBESTOS; HAZARDOUS/TOXIC |          |         |
| WASTE PROJECTS            |          |         |
| GROUP 2 - A & B.....      | \$ 44.30 | 24.30   |
| ASBESTOS; HAZARDOUS/TOXIC |          |         |
| WASTE PROJECTS            |          |         |
| GROUP 3 - A & B.....      | \$ 38.47 | 24.30   |
| ASBESTOS; HAZARDOUS/TOXIC |          |         |
| WASTE PROJECTS            |          |         |
| GROUP 4 - A & B.....      | \$ 34.52 | 24.30   |
| ASBESTOS; HAZARDOUS/TOXIC |          |         |
| WASTE PROJECTS            |          |         |
| GROUP 5 - A & B.....      | \$ 31.13 | 24.30   |
| HAZARDOUS/TOXIC WASTE     |          |         |
| PROJECTS                  |          |         |
| GROUP 1 - C & D.....      | \$ 40.91 | 24.30   |
| HAZARDOUS/TOXIC WASTE     |          |         |

|                              |       |
|------------------------------|-------|
| PROJECTS                     |       |
| GROUP 2 - C & D.....\$ 40.61 | 24.30 |
| HAZARDOUS/TOXIC WASTE        |       |
| PROJECTS                     |       |
| GROUP 3 - C & D.....\$ 35.27 | 24.30 |
| HAZARDOUS/TOXIC WASTE        |       |
| PROJECTS                     |       |
| GROUP 4 - C & D.....\$ 31.65 | 24.30 |
| HAZARDOUS/TOXIC WASTE        |       |
| PROJECTS                     |       |
| GROUP 5 - C & D.....\$ 28.53 | 24.30 |
| ALL OTHER WORK               |       |
| GROUP 1.....\$ 37.19         | 24.30 |
| ALL OTHER WORK               |       |
| GROUP 2.....\$ 36.92         | 24.30 |
| ALL OTHER WORK               |       |
| GROUP 3.....\$ 32.06         | 24.30 |
| ALL OTHER WORK               |       |
| GROUP 4.....\$ 28.77         | 24.30 |
| ALL OTHER WORK               |       |
| GROUP 5.....\$ 25.94         | 24.30 |

GROUP 1 - Rig, Pile Driver or Caisson Type; & Rig, Pile Hydraulic Unit Attached

GROUP 2 - Asphalt Heater Planer; Backfiller with Drag Attachment; Backhoe; Backhoe with Shear attached; Backhoe-Rear Pivotal Swing; Batch Plant-Central Mix Concrete; Batch Plant, Portable concrete; Berm Builder-Automatic; Boat Derrick; Boat-Tug; Boring Machine Attached to Tractor; Bullclam; Bulldozer; C.M.I. Road Builder & Similar Type; Cable Placer & Layer; Carrier-Straddle; Carryall-Scraper or Scoop; Chicago Boom; Compactor with Blade Attached; Concrete Saw (Vermeer or similar type); Concrete Spreader Finisher; Combination, Bidwell Machine; Crane; Crane-Electric Overhead; Crane-Rough Terrain; Crane-Side Boom; Crane-Truck; Crane-Tower; Derrick-Boom; Derrick-Car; Digger-Wheel (Not trencher or road widener); Double Nine; Drag Line; Dredge; Drill-Kenny or Similar Type; Easy Pour Median Barrier Machine (or similar type); Electromatic; Frankie Pile; Gradall; Grader; Gurry; Self-Propelled; Heavy Equipment Robotics Operator/Mechanic; Hoist-Monorail; Hoist-Stationary & Mobile Tractor; Hoist, 2 or 3 drum; Horizontal Directional Drill Operator; Jackall; Jumbo Machine; Kocal & Kuhlman; Land-Seagoing Vehicle; Loader, Elevating; Loader, Front End; Loader, Skid Steer; Locomotive; Mechanic/Welder; Metro Chip Harvester with Boom; Mucking Machine; Paver-Asphalt Finishing Machine; Paver-Road Concrete; Paver-Slip Form (C.M.I. or similar); Place Crete Machine with Boom; Post Driver (Carrier mounted); Power Driven Hydraulic Pump & Jack (When used in Slip Form or Lift Slab Construction); Pump Crete Machine; Regulator-Ballast; Hydraulic Power Unit not attached to Rig for Pile Drillings; Rigs-Drilling; Roto Mill or similar Full Lane (8' Wide & Over); Roto Mill or similar type (Under 8'); Shovel; Slip Form Curb Machine; Speedwing; Spikemaster; Stonecrusher; Tie Puller & Loader; Tie Tamper; Tractor-Double Boom; Tractor with Attachments; Truck-Boom; Truck-Tire; Trench Machine; Tunnel Machine (Mark 21 Java or similar); & Whirley (or similar type)

GROUP 3 - Asphalt Plant; Bending Machine (Pipeline or similar type); Boring machine, Motor Driven; Chip Harvester without Boom; Cleaning Machine, Pipeline Type; Coating

Machine, Pipeline Type; Compactor; Concrete Belt Placer; Concrete Finisher; Concrete Planer or Asphalt; Concrete Spreader; Elevator; Fork Lift (Home building only); Fork lift & Lulls; Fork Lift Walk Behind (Hoisting over 1 buck high); Form Line Machine; Grease Truck operator; Grout Pump; Gunnite Machine; Horizontal Directional Drill Locator; Single Drum Hoist with or without Tower; Huck Bolting Machine; Hydraulic Scaffold (Hoisting building materials); Paving Breaker (Self-propelled or Ridden); Pipe Dream; Pot Fireperson (Power Agitated); Refrigeration Plant; Road Widener; Roller; Sasgen Derrick; Seeding Machine; Soil Stabilizer (Pump type); Spray Cure Machine, Self-Propelled; Straw Blower Machine; Sub-Grader; Tube Finisher or Broom C.M.I. or similar type; & Tugger Hoist

GROUP 4 - Air Curtain Destructor & Similar Type; Batch Plant-Job Related; Boiler Operator; Compressor; Conveyor; Curb Builder, self-propelled; Drill Wagon; Generator Set; Generator-Steam; Heater-Portable Power; Hydraulic Manipulator Crane; Jack-Hydraulic Power driven; Jack-Hydraulic (Railroad); Ladavator; Minor Machine Operator; Mixer-Concrete; Mulching Machine; Pin Puller; Power Broom; Pulverizer; Pump; Road Finishing Machine (Pull Type); Saw-Concrete-Self-Propelled (Highway Work); Signal Person; Spray Cure Machine-Motor Powered; Stump Cutter; Tractor; Trencher Form; Water Blaster; Steam Jenny; Syphon; Vibrator-Gasoline; & Welding Machine

GROUP 5 - Brakeperson; Fireperson; & Oiler

-----  
IRON0017-002 05/01/2024

ASHTABULA (North of Route 6, starting at the Geauga County Line, proceeding east to State Route 45), CUYAHOGA, ERIE (Eastern 2/3), GEAUGA, HURON (East of a line drawn from the north border through Monroeville & Willard), LAKE, LORAIN, MEDINA (North of Old Rte. #224), PORTAGE (West of a line from Middlefield to Shalersville to Deerfield), and SUMMIT (North of Old Rte. #224, including city limits of Barberton) COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

IRONWORKER

|                                            |          |       |
|--------------------------------------------|----------|-------|
| Ornamental, Reinforcing, & Structural..... | \$ 36.83 | 29.01 |
|--------------------------------------------|----------|-------|

-----  
IRON0017-010 05/01/2024

ASHTABULA (Eastern part from Lake Erie on the north to route #322 on the south to include Conneaut, Kingsville, Sheffield, Denmark, Dorset, Cherry Valley, Wayne, Monroe, Pierpont, Richmond, Andover & Williamsfield Townships)

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

IRONWORKER

|                                                                  |          |       |
|------------------------------------------------------------------|----------|-------|
| Structural, including metal building erection & Reinforcing..... | \$ 36.83 | 29.01 |
|------------------------------------------------------------------|----------|-------|

-----  
IRON0044-001 06/01/2024

ADAMS (Western Part), BROWN, BUTLER (Southern Part), CLERMONT, CLINTON (South of a line drawn from Blanchester to Lynchburg), HAMILTON, HIGHLAND (Excluding eastern one-fifth & portion of county inside lines drawn from Marshall to Lynchburg from the northern county line through E. Monroe to Marshall) and WARREN (South of a line drawn from Blanchester through Morrow to the west county line) COUNTIES

|                              | Rates    | Fringes |
|------------------------------|----------|---------|
| IRONWORKER, REINFORCING..... | \$ 35.87 | 23.60   |

-----  
IRON0044-002 06/01/2024

CLINTON (South of a line drawn from Blanchester to Lynchburg), HAMILTON, HIGHLAND (Excluding eastern one-fifth & portion of county inside lines drawn from Marshall to Lynchburg from the northern county line through E. Monroe to Marshall) & WARREN (South of a line drawn from Blanchester through Morrow to the west county line)

|                             | Rates    | Fringes |
|-----------------------------|----------|---------|
| IRONWORKER                  |          |         |
| Fence Erector.....          | \$ 33.60 | 23.60   |
| Ornamental; Structural..... | \$ 35.37 | 23.60   |

-----  
IRON0055-003 07/01/2024

CRAWFORD (Area Between lines drawn from where Hwy #598 & #30 meet through N. Liberty to the northern border & from said Hwy junction point due west to the border), DEFIANCE (S. of a line drawn from where Rte. #66 meets the northern line through Independence to the eastern county border), ERIE (Western 1/3), FULTON, HANCOCK, HARDIN (North of a line drawn from Maysville to a point 4 miles south of the northern line on the eastern line), HENRY, HURON (West of a line drawn from the northern border through Monroeville & Willard), LUCAS, OTTAWA, PUTNAM (East of a line drawn from the northern border down through Miller City to where #696 meets the southern border), SANDUSKY, SENECA, WILLIAMS (East of a line drawn from Pioneer through Stryker to the southern border), WOOD & WYANDOT (North of Rte. #30)

|                                        | Rates    | Fringes |
|----------------------------------------|----------|---------|
| IRONWORKER                             |          |         |
| Fence Erector.....                     | \$ 26.40 | 24.62   |
| Flat Road Mesh.....                    | \$ 29.77 | 21.30   |
| Tunnels & Caissons Under Pressure..... | \$ 29.77 | 21.30   |
| All Other Work.....                    | \$ 35.50 | 29.20   |

-----  
IRON0147-002 06/01/2024

ALLEN (Northern half), DEFIANCE (Northern part, excluding south of a line drawn from where Rte. #66 meets the northern line through Independence to the eastern county border), MERCER (Northern half), PAULDING, PUTNAM (Western part, excluding east of a line drawn from the northern border down through Miller City to where #696 meets the southern border), VAN WERT, and WILLIAMS (Western part, excluding east of a line drawn from

Pioneer through Stryker to the southern border) COUNTIES

W912QR25BA009\_CertF\_Specs-0004

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| IRONWORKER.....         | \$ 34.20 | 26.39   |
| -----                   |          |         |
| IRON0172-002 06/01/2024 |          |         |

CHAMPAIGN (Eastern one-third), CLARK (Eastern one-fourth), COSHOCTON (West of a line beginning at the northwestern county line going through Walhonding & Tunnel Hill to the southern county line), CRAWFORD (South of Rte. #30), DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, HARDIN (Excluding a line drawn from Roundhead to Maysville), HIGHLAND (Eastern one-fifth), HOCKING, JACKSON (Northern half), KNOX, LICKING, LOGAN (Eastern one-third), MADISON, MARION, MORROW, MUSKINGUM (West of a line starting at Adams Mill going to Adamsville & going from Adamsville through Blue Rock to the southern border), PERRY, PICKAWAY, PIKE (Northern half), ROSS, UNION, VINTON and WYANDOT (South of Rte. #30) COUNTIES

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| IRONWORKER.....         | \$ 36.77 | 22.85   |
| -----                   |          |         |
| IRON0207-004 06/01/2024 |          |         |

ASHTABULA (Southern part starting at the Geauga County line), COLUMBIANA (E. of a line from Damascus to Highlandtown), MAHONING (N. of Old Route #224), PORTAGE (E. of a line from Middlefield to Shalersville to Deerfield) & TRUMBULL

|                              | Rates    | Fringes |
|------------------------------|----------|---------|
| IRONWORKER                   |          |         |
| Layout; Sheeter.....         | \$ 35.83 | 27.41   |
| Ornamental; Reinforcing;     |          |         |
| Structural.....              | \$ 34.83 | 27.41   |
| Ornamental; Reinforcing..... | \$ 28.92 | 25.61   |
| -----                        |          |         |
| IRON0290-002 06/01/2024      |          |         |

ALLEN (Southern half), AUGLAIZE, BUTLER (North of a line drawn from east to the west county line going through Oxford, Darrrtown & Woodsdale), CHAMPAIGN (Excluding east of a line drawn from Catawla to the point where #68 intersects the northern county line), CLARK (Western two-thirds), CLINTON (Excluding south of a line drawn from Blanchester to Lynchburg), DARKE, GREENE, HIGHLAND (Inside lines drawn from Marshall to Lynchburg & from the northern county line through East Monroe to Marshall), LOGAN (West of a line drawn from West Liberty to where the northern county line meets the western county line of Hardin), MERCER (Southern half), MIAMI, MONTGOMERY, PREBLE, SHELBY & WARREN (Excluding south of a line drawn from Blanchester through Morrow to the western county line) COUNTIES

|                 | Rates    | Fringes |
|-----------------|----------|---------|
| IRONWORKER..... | \$ 35.39 | 24.35   |
| -----           |          |         |

IRON0549-003 12/01/2022

BELMONT, GUERNSEY, HARRISON, JEFFERSON, MONROE & MUSKINGUM  
(Excluding portion west of a line starting at Adams Mill going  
to Adamsville and going from Adamsville through Blue Rock to  
the south border)

|                 | Rates    | Fringes |
|-----------------|----------|---------|
| IRONWORKER..... | \$ 35.19 | 25.66   |

IRON0550-004 05/01/2024

ASHLAND, CARROLL, COLUMBIANA (W. of a line from Damascus to  
Highlandtown), COSHOCTON (E. of a line beginning at NW Co. line  
going through Walhonding & Tunnel Hill to the South Co. line),  
HOLMES, HURON (S. of Old Rte. #224), MAHONING (S. of Old Rte.  
#224), MEDINA (S. of Old Rte. #224), PORTAGE (S. of Old Rte.  
#224), RICHLAND, STARK, SUMMIT (S. of Old Rte. #224, Excluding  
city limits of Barberton), TUSCARAWAS, & WAYNE

|                                                            | Rates    | Fringes |
|------------------------------------------------------------|----------|---------|
| Ironworkers:Structural,<br>Ornamental and Reinforcing..... | \$ 34.70 | 22.88   |

IRON0769-004 06/01/2024

ADAMS (Eastern Half), GALLIA, JACKSON (Southern Half), LAWRENCE  
& SCIOTO

|                 | Rates    | Fringes |
|-----------------|----------|---------|
| IRONWORKER..... | \$ 37.66 | 29.24   |

IRON0787-003 06/01/2024

ATHENS, MEIGS, MORGAN, NOBLE, and WASHINGTON COUNTIES

|                 | Rates    | Fringes |
|-----------------|----------|---------|
| IRONWORKER..... | \$ 33.00 | 24.25   |

LAB00265-008 05/01/2024

|                                                                                                                                         | Rates    | Fringes |
|-----------------------------------------------------------------------------------------------------------------------------------------|----------|---------|
| LABORER                                                                                                                                 |          |         |
| ASHTABULA, ERIE, HURON,<br>LORAIN, LUCAS, MAHONING,<br>MEDINA, OTTAWA, PORTAGE,<br>SANDUSKY, STARK, SUMMIT,<br>TRUMBULL & WOOD COUNTIES |          |         |
| GROUP 1.....                                                                                                                            | \$ 35.95 | 14.45   |
| GROUP 2.....                                                                                                                            | \$ 36.12 | 14.45   |
| GROUP 3.....                                                                                                                            | \$ 36.45 | 14.45   |
| GROUP 4.....                                                                                                                            | \$ 36.90 | 14.45   |

CUYAHOGA AND GEAUGA  
COUNTIES ONLY: SEWAGE  
PLANTS, WASTE PLANTS,  
WATER TREATMENT  
FACILITIES, PUMPING

|                            |          |       |
|----------------------------|----------|-------|
| STATIONS, & ETHANOL PLANTS |          |       |
| CONSTRUCTION.....          | \$ 38.56 | 14.45 |
| CUYAHOGA, GEAUGA & LAKE    |          |       |
| COUNTIES                   |          |       |
| GROUP 1.....               | \$ 37.18 | 14.45 |
| GROUP 2.....               | \$ 37.35 | 14.45 |
| GROUP 3.....               | \$ 37.68 | 14.45 |
| GROUP 4.....               | \$ 38.13 | 14.45 |
| REMAINING COUNTIES OF OHIO |          |       |
| GROUP 1.....               | \$ 35.52 | 14.45 |
| GROUP 2.....               | \$ 35.69 | 14.45 |
| GROUP 3.....               | \$ 36.02 | 14.45 |
| GROUP 4.....               | \$ 36.47 | 14.45 |

#### LABORER CLASSIFICATIONS

GROUP 1 - Asphalt Laborer; Carpenter Tender; Concrete Curing Applicator; Dump Man (Batch Truck); Guardrail and Fence Installer; Joint Setter; Laborer (Construction); Landscape Laborer; Mesh Handlers & Placer; Right-of-way Laborer; Riprap Laborer & Grouter; Scaffold Erector; Seal Coating; Surface Treatment or Road Mix Laborer; Sign Installer; Slurry Seal; Utility Man; Bridge Man; Handyman; Waterproofing Laborer; Flagperson; Hazardous Waste (level D); Diver Tender; Zone Person & Traffic Control

GROUP 2 - Asphalt Raker; Concrete Puddler; Kettle Man Pipeline); Machine Driven Tools (Gas, Electric, Air); Mason Tender; Brick Paver; Mortar Mixer; Power Buggy or Power Wheelbarrow; Paint Stripper; Sheeting & Shoring Man; Surface Grinder Man; Plastic Fusing Machine Operator; Pug Mill Operator; & Vacuum Devices (wet or dry); Rodding Machine Operator; Diver; Screwwoman or Paver; Screed Person; Water Blast, Hand Held Wand; Pumps 4" & Under (Gas, Air or Electric) & Hazardous Waste (level C); Air Track and Wagon Drill; Bottom Person; Cofferdam (below 25 ft. deep); Concrete Saw Person; Cutting with Burning Torch; Form Setter; Hand Spiker (Railroad); Pipelayer; Tunnel Laborer (without air) & Caisson; Underground Person (working in Sewer and Waterline, Cleaning, Repairing & Reconditioning); Sandblaster Nozzle Person; & Hazardous Waste (level B)

GROUP 3 - Blaster; Mucker; Powder Person; Top Lander; Wrencher (Mechanical Joints & Utility Pipeline); Yarnier; Hazardous Waste (level A); Concrete Specialist; Concrete Crew in Tunnels (With Air-pressurized - \$1.00 premium); Curb Setter & Cutter; Grade Checker; Utility Pipeline Tapper; Waterline; and Caulker

GROUP 4 - Miner (With Air-pressurized - \$1.00 premium); & Guniting Nozzle Person

TUNNEL LABORER WITH AIR-PRESSURIZED ADD \$1.00 TO BASE RATE

SIGNAL PERSON WILL RECEIVE THE RATE EQUAL TO THE RATE PAID THE LABORER CLASSIFICATION FOR WHICH HE OR SHE IS SIGNALING.

-----  
PAIN0006-002 05/01/2023

ASHTABULA, CUYAHOGA, GEAUGA, LAKE, LORAIN, PORTAGE (N. of the East-West Turnpike) & SUMMIT (N. of the East-West Turnpike)

Rates

Fringes

## PAINTER

COMMERCIAL NEW WORK;  
REMODELING; & RENOVATIONS

|              |          |       |
|--------------|----------|-------|
| GROUP 1..... | \$ 30.75 | 18.95 |
| GROUP 2..... | \$ 31.15 | 18.95 |
| GROUP 3..... | \$ 31.45 | 18.95 |
| GROUP 4..... | \$ 37.01 | 18.95 |

## COMMERCIAL REPAINT

|              |          |       |
|--------------|----------|-------|
| GROUP 1..... | \$ 29.25 | 18.95 |
| GROUP 2..... | \$ 29.65 | 18.95 |
| GROUP 3..... | \$ 29.95 | 18.95 |

PAINTER CLASSIFICATIONS - COMMERCIAL NEW WORK; REMODELING; &  
RENOVATIONS

GROUP 1 - Brush; &amp; Roller

GROUP 2 - Sandblasting &amp; Buffing

GROUP 3 - Spray Painting; Closed Steel Above 55 feet; Bridges  
& Open Structural Steel; Tanks - Water Towers; Bridge  
Painters; Bridge Riggers; Containment Builders

GROUP 4 - Bridge Blaster

## PAINTER CLASSIFICATIONS - COMMERCIAL REPAINT

GROUP 1 - Brush; &amp; Roller

GROUP 2 - Sandblasting &amp; Buffing

GROUP 3 - Spray Painting

-----  
PAIN0007-002 07/01/2024

FULTON, HENRY, LUCAS, OTTAWA (Excluding Allen, Bay, Bono,  
Catawba Island, Clay Center, Curtice, Danbury, Eagle Beach,  
Elliston, Elmore, Erie, Fishback, Gem Beach & Genova) & WOOD

|  |       |         |
|--|-------|---------|
|  | Rates | Fringes |
|--|-------|---------|

## PAINTER

## NEW COMMERCIAL WORK

|              |          |       |
|--------------|----------|-------|
| GROUP 1..... | \$ 31.84 | 20.79 |
| GROUP 2..... | \$ 32.84 | 20.79 |
| GROUP 3..... | \$ 32.84 | 20.79 |
| GROUP 4..... | \$ 32.84 | 20.79 |
| GROUP 5..... | \$ 32.84 | 20.79 |
| GROUP 6..... | \$ 32.84 | 20.79 |
| GROUP 7..... | \$ 32.84 | 20.79 |
| GROUP 8..... | \$ 32.84 | 20.79 |
| GROUP 9..... | \$ 32.84 | 20.79 |

REPAINT IS 90% OF JR

## PAINTER CLASSIFICATIONS

GROUP 1 - Brush; Spray &amp; Sandblasting Pot Tender

GROUP 2 - Refineries & Refinery Tanks; Surfaces 30 ft. or  
over where material is applied to or labor performed on  
above ground level (exterior), floor level (interior)

GROUP 3 - Swing Stage & Chair

GROUP 4 - Lead Abatement

GROUP 5 - All Methods of Spray

GROUP 6 - Solvent-Based Catalized Epoxy Materials of 2 or More Component Materials, to include Solvent-Based Conversion Varnish (excluding water based)

GROUP 7 - Spray Solvent Based Material; Sand & Abrasive Blasting

GROUP 8 - Towers; Tanks; Bridges; Stacks Over 30 Feet

GROUP 9 - Epoxy Spray (excluding water based)

-----  
PAIN0012-008 05/01/2019

BUTLER COUNTY

|              | Rates    | Fringes |
|--------------|----------|---------|
| PAINTER      |          |         |
| GROUP 1..... | \$ 21.95 | 10.20   |
| GROUP 2..... | \$ 25.30 | 10.20   |
| GROUP 3..... | \$ 25.80 | 10.20   |
| GROUP 4..... | \$ 26.05 | 10.20   |
| GROUP 5..... | \$ 26.30 | 10.20   |

PAINTER CLASSIFICATIONS

GROUP 1: Bridge Equipment Tender; Bridge/Containment Builder

GROUP 2: Brush & Roller

GROUP 3: Spray

GROUP 4: Sandblasting; & Waterblasting

GROUP 5: Elevated Tanks; Steeplejack Work; Bridge; & Lead Abatement

-----  
PAIN0012-010 05/01/2019

BROWN, CLERMONT, CLINTON, HAMILTON & WARREN

|                                                                                                     | Rates    | Fringes |
|-----------------------------------------------------------------------------------------------------|----------|---------|
| PAINTER                                                                                             |          |         |
| HEAVY & HIGHWAY BRIDGES-<br>GUARDRAILS-LIGHTPOLES-<br>STRIPING                                      |          |         |
| Bridge Equipment Tender<br>and Containment Builder....                                              | \$ 21.95 | 10.20   |
| Bridges when highest<br>point of clearance is 60<br>feet or more; & Lead<br>Abatement Projects..... | \$ 26.30 | 10.20   |
| Brush & Roller.....                                                                                 | \$ 25.30 | 10.20   |
| Sandblasting & Hopper                                                                               |          |         |

|                             |          |       |
|-----------------------------|----------|-------|
| Tender; Water Blasting..... | \$ 26.05 | 10.20 |
| Spray.....                  | \$ 25.80 | 10.20 |

-----  
PAIN0093-001 12/01/2024ATHENS, GUERNSEY, HOCKING, MONROE, MORGAN, NOBLE and  
WASHINGTON COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

## PAINTER

|                                                                          |          |       |
|--------------------------------------------------------------------------|----------|-------|
| Bridges; Locks; Dams;<br>Tension Towers; &<br>Energized Substations..... | \$ 36.44 | 24.46 |
| Power Generating Facilities..                                            | \$ 33.29 | 24.46 |

-----  
PAIN0249-002 05/01/2024

CLARK, DARKE, GREENE, MIAMI, MONTGOMERY &amp; PREBLE

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

## PAINTER

|                                                                                                                                      |          |       |
|--------------------------------------------------------------------------------------------------------------------------------------|----------|-------|
| GROUP 1 - Brush & Roller....                                                                                                         | \$ 27.15 | 13.64 |
| GROUP 2 - Swing, Scaffold<br>Bridges; Structural Steel;<br>Open Acid Tank; High<br>Tension Electrical<br>Equipment; & Hot Pipes..... | \$ 27.15 | 13.64 |
| GROUP 3 - Spray;<br>Sandblast; Steamclean;<br>Lead Abatement.....                                                                    | \$ 27.90 | 13.64 |
| GROUP 4 - Steeplejack Work..                                                                                                         | \$ 28.10 | 13.64 |
| GROUP 5 - Coal Tar.....                                                                                                              | \$ 28.65 | 13.64 |
| GROUP 6 - Bridge Equipment<br>Tender & or Containment<br>Builder.....                                                                | \$ 35.86 | 13.64 |
| GROUP 7 - Tanks, Stacks &<br>Towers.....                                                                                             | \$ 31.09 | 13.64 |
| GROUP 8 - Bridge Blaster,<br>Rigger.....                                                                                             | \$ 38.86 | 13.64 |

-----  
PAIN0356-002 09/01/2009

KNOX, LICKING, MUSKINGUM, and PERRY

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

## PAINTER

|                                                                            |          |      |
|----------------------------------------------------------------------------|----------|------|
| Bridge Equipment Tenders<br>and Containment Builders....                   | \$ 27.93 | 7.25 |
| Bridges; Blasters;<br>and Riggers.....                                     | \$ 34.60 | 7.25 |
| Brush and Roller.....                                                      | \$ 20.93 | 7.25 |
| Sandblasting; Steam<br>Cleaning; Waterblasting;<br>and Hazardous Work..... | \$ 25.82 | 7.25 |
| Spray.....                                                                 | \$ 21.40 | 7.25 |
| Structural Steel and Swing<br>Stage.....                                   | \$ 25.42 | 7.25 |
| Tanks; Stacks; and Towers...                                               | \$ 28.63 | 7.25 |

-----  
PAIN0438-002 12/01/2023

BELMONT, HARRISON and JEFFERSON COUNTIES

W912QR25BA009\_CertF\_Specs-0004

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

## PAINTER

|                                                                         |          |       |
|-------------------------------------------------------------------------|----------|-------|
| Bridges, Locks, Dams,<br>Tension Towers & Energized<br>Substations..... | \$ 36.09 | 19.49 |
| Power Generating Facilities..                                           | \$ 32.94 | 19.49 |

-----  
PAIN0476-001 06/01/2024

COLUMBIANA, MAHONING, and TRUMBULL COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

## PAINTER

|              |          |       |
|--------------|----------|-------|
| GROUP 1..... | \$ 28.39 | 17.14 |
| GROUP 2..... | \$ 35.02 | 17.14 |
| GROUP 3..... | \$ 28.60 | 17.14 |
| GROUP 4..... | \$ 28.89 | 17.14 |
| GROUP 5..... | \$ 29.04 | 17.14 |
| GROUP 6..... | \$ 29.29 | 17.14 |
| GROUP 7..... | \$ 30.39 | 17.14 |

## PAINTER CLASSIFICATIONS:

GROUP 1: Painters, Brush &amp; Roller

GROUP 2: Bridges

GROUP 3: Structural Steel

GROUP 4: Spray, Except Bar Joist/Deck

GROUP 5: Epoxy/Mastic; Spray- Bar Joist/Deck; Working Above  
50 Feet; and Swingstages

GROUP 6: Tanks; Sandblasting

GROUP 7: Towers; Stacks

-----  
PAIN0555-002 11/01/2023

ADAMS, HIGHLAND, JACKSON, PIKE &amp; SCIOTO

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

## PAINTER

|              |          |       |
|--------------|----------|-------|
| GROUP 1..... | \$ 32.18 | 20.29 |
| GROUP 2..... | \$ 33.81 | 20.29 |
| GROUP 3..... | \$ 35.44 | 20.29 |
| GROUP 4..... | \$ 38.63 | 20.29 |

## PAINTER CLASSIFICATIONS

GROUP 1 - Containment Builder

GROUP 2 - Brush; Roller; Power Tools, Under 40 feet

GROUP 3 - Sand Blasting; Spray; Steam Cleaning; Pressure  
Washing; Epoxy & Two Component Materials; Lead Abatement;  
Hazardous Waste; Toxic Materials; Bulk & Storage Tanks of  
25,000 Gallon Capacity or More; Elevated Tanks

## GROUP 4 - Stacks; Bridges

-----  
PAIN0639-001 05/01/2011

|                             | Rates    | Fringes    |
|-----------------------------|----------|------------|
| Sign Painter & Erector..... | \$ 20.61 | 3.50+a+b+c |

FOOTNOTES: a. 7 Paid Holidays: New Year's Day; Memorial Day; July 4th; Labor Day; Thanksgiving Day; Christmas Day & 1 Floating Day

b. Vacation Pay: After 1 year's service - 5 days' paid vacation; After 2, but less than 10 years' service - 10 days' paid vacation; After 10, but less than 20 years' service - 15 days' paid vacation; After 20 years' service - 20 days' paid vacation

c. Funeral leave up to 3 days maximum paid leave for death of mother, father, brother, sister, spouse, child, mother-in-law, father-in-law, grandparent and inlaw provided employee attends funeral

-----  
PAIN0788-002 06/01/2024

ASHLAND, CRAWFORD, ERIE, HANCOCK, HURON, MARION, MORROW, OTTAWA (Allen, Bay, Bono, Catawba Island, Clay Center, Curtice, Danbury, Eagle Beach, Elliston, Elmore, Erie, Fishback, Gem Beach & Genoa), RICHLAND, SANDUSKY, SENECA & WYANDOT

|                       | Rates    | Fringes |
|-----------------------|----------|---------|
| PAINTER               |          |         |
| Brush & Roller.....   | \$ 29.13 | 17.52   |
| Structural Steel..... | \$ 30.73 | 17.52   |

WINTER REPAINT: Between December 1 to March 31 - 90%JR

\$ .50 PER HOUR SHALL BE ADDED TO THE RATE OF PAY FOR THE CLASSIFICATION OF WORK:

While working swingstage, boatswain chair, needle beam and horizontal cable. While operating sprayguns, sandblasting, cobblasting and high pressure waterblasting (4000psi).

\$1.00 PER HOUR SHALL BE ADDED TO THE RATE OF PAY FOR THE CLASSIFICATION OF WORK:

For the application of catalized epoxy, including latex epoxy that is deemed hazardous, lead abatement, or for work or material where special precautions beyond normal work duties must be taken. For working on stacks, tanks, and towers over 40 feet in height.

-----  
PAIN0813-005 12/01/2008

GALLIA, LAWRENCE, MEIGS & VINTON

|                | Rates    | Fringes |
|----------------|----------|---------|
| PAINTER        |          |         |
| Base Rate..... | \$ 24.83 | 10.00   |

Bridges, Locks, Dams &  
Tension Towers.....\$ 27.83 10.00

-----  
PAIN0841-001 06/01/2023

MEDINA, PORTAGE (South of and including Ohio Turnpike), and  
SUMMIT (South of and including Ohio Turnpike) COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

Painters:

|              |          |       |
|--------------|----------|-------|
| GROUP 1..... | \$ 30.18 | 15.50 |
| GROUP 2..... | \$ 30.83 | 15.50 |
| GROUP 3..... | \$ 30.93 | 15.50 |
| GROUP 4..... | \$ 31.03 | 15.50 |
| GROUP 5..... | \$ 31.43 | 15.50 |
| GROUP 6..... | \$ 39.20 | 11.75 |
| GROUP 7..... | \$ 31.68 | 15.50 |

PAINTER CLASSIFICATIONS:

GROUP 1 - Brush, Roller & Paperhanger

GROUP 2 - Epoxy Application

GROUP 3 - Swing Scaffold, Bosum Chair, & Window Jack

GROUP 4 - Spray Gun Operator of Any & All Coatings

GROUP 5 - Sandblast, Painting of Standpipes, etc. from  
Scaffolds, Bridge Work and/or Open Structural Steel,  
Standpipes and/or Water Towers

GROUP 6 - Public & Commerce Transportation, Steel or  
Galvanized, Bridges, Tunnels & Related Support Items  
(concrete)

GROUP 7 - Synthetic Exterior, Drywall Finisher and/or Taper,  
Drywall Finisher and Follow-up Man Using Automatic Tools

-----  
PAIN0841-002 06/01/2023

CARROLL, COSHOCTON, HOLMES, STARK, TUSCARAWAS & WAYNE

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

PAINTER

|                                                                                                  |          |       |
|--------------------------------------------------------------------------------------------------|----------|-------|
| Bridges; Towers, Poles &<br>Stacks; Sandblasting<br>Steel; Structural Steel &<br>Metalizing..... | \$ 31.43 | 15.50 |
| Brush & Roller.....                                                                              | \$ 30.18 | 15.50 |
| Spray; Tank Interior &<br>Exterior.....                                                          | \$ 31.03 | 15.50 |

-----  
PAIN1020-002 07/01/2024

ALLEN, AUGLAIZE, CHAMPAIGN, DEFIANCE, HARDIN, LOGAN, MERCER,  
PAULDING, PUTNAM, SHELBY, VAN WERT, and WILLIAMS COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

## PAINTER

|                                                              |          |       |
|--------------------------------------------------------------|----------|-------|
| Brush & Roller.....                                          | \$ 26.54 | 17.66 |
| Drywall Finishing & Taping..                                 | \$ 27.29 | 17.66 |
| Lead Abatement.....                                          | \$ 28.29 | 17.66 |
| Spray, Sandblasting<br>Pressure Cleaning, &<br>Refinery..... | \$ 27.29 | 17.66 |
| Swing Stage, Chair,<br>Spiders, & Cherry Pickers...          | \$ 26.79 | 17.66 |
| Wallcoverings.....                                           | \$ 27.29 | 17.66 |

All surfaces 40 ft. or over where material is applied to or  
labor performed on, above ground level (exterior), floor  
level (interior) - \$.50 premium

Applying Coal Tar Products - \$1.00 premium

-----  
PAIN1275-002 05/01/2024

DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, MADISON, PICKAWAY, ROSS  
& UNION

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

## PAINTER

|                                                                                             |          |       |
|---------------------------------------------------------------------------------------------|----------|-------|
| Bridges.....                                                                                | \$ 36.26 | 14.91 |
| Brush; Roller.....                                                                          | \$ 30.65 | 14.91 |
| Sandblasting;<br>Steamcleaning;<br>Waterblasting (3500 PSI or<br>Over)& Hazardous Work..... | \$ 31.35 | 14.91 |
| Spray.....                                                                                  | \$ 31.15 | 14.91 |
| Stacks; Tanks; & Towers.....                                                                | \$ 33.46 | 14.91 |
| Structural Steel & Swing<br>Stage.....                                                      | \$ 29.50 | 14.91 |

-----  
PLAS0109-001 06/01/2024

MEDINA, PORTAGE, STARK, and SUMMIT COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                |          |       |
|----------------|----------|-------|
| PLASTERER..... | \$ 31.70 | 23.63 |
|----------------|----------|-------|

-----  
PLAS0109-003 06/01/2024

CARROLL, HOLMES, TUSCARAWAS, and WAYNE COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                |          |       |
|----------------|----------|-------|
| PLASTERER..... | \$ 31.70 | 23.63 |
|----------------|----------|-------|

-----  
PLAS0132-002 07/01/2024

BROWN, BUTLER, CLERMONT, HAMILTON, HIGHLAND, WARREN COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                |          |       |
|----------------|----------|-------|
| PLASTERER..... | \$ 30.40 | 16.54 |
|----------------|----------|-------|

-----  
PLAS0404-002 05/01/2018

ASHTABULA, CUYAHOGA, GEAUGA, AND LAKE COUNTIES

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| PLASTERER.....          | \$ 29.63 | 17.11   |
| -----                   |          |         |
| PLAS0404-003 05/01/2018 |          |         |

LORAIN COUNTY

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| PLASTERER.....          | \$ 28.86 | 17.11   |
| -----                   |          |         |
| PLAS0526-022 05/01/2018 |          |         |

COLUMBIANA, MAHONING, and TRUMBULL COUNTIES

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| PLASTERER.....          | \$ 28.86 | 17.11   |
| -----                   |          |         |
| PLAS0526-023 05/01/2018 |          |         |

BELMONT, HARRISON, and JEFFERSON COUNTIES

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| PLASTERER.....          | \$ 28.21 | 17.11   |
| -----                   |          |         |
| PLAS0886-001 07/01/2024 |          |         |

FULTON, HANCOCK, HENRY, LUCAS, PUTNAM, and WOOD COUNTIES

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| PLASTERER.....          | \$ 33.73 | 23.25   |
| -----                   |          |         |
| PLAS0886-003 07/01/2024 |          |         |

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| PLASTERER.....          | \$ 33.73 | 23.25   |
| -----                   |          |         |
| PLAS0886-004 07/01/2024 |          |         |

|                         | Rates    | Fringes |
|-------------------------|----------|---------|
| PLASTERER.....          | \$ 33.73 | 23.25   |
| -----                   |          |         |
| PLUM0042-002 07/01/2024 |          |         |

ASHLAND, CRAWFORD, ERIE, HURON, KNOX, LORAIN, MORROW, RICHLAND  
& WYANDOT

|                                          | Rates    | Fringes |
|------------------------------------------|----------|---------|
| Plumber, Pipefitter,<br>Steamfitter..... | \$ 40.62 | 25.67   |
| -----                                    |          |         |
| PLUM0050-002 07/01/2024                  |          |         |

DEFIANCE, FULTON, HANCOCK, HENRY, LUCAS, OTTAWA, PAULDING,  
PUTNAM, SANDUSKY, SENECA, WILLIAMS & WOOD

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                                          |          |       |
|------------------------------------------|----------|-------|
| Plumber, Pipefitter,<br>Steamfitter..... | \$ 49.70 | 30.76 |
|------------------------------------------|----------|-------|

-----  
PLUM0055-003 05/01/2024

ASHTABULA, CUYAHOGA, GEAUGA, LAKE, MEDINA (N. of Rte. #18 & Smith Road) & SUMMIT (N. of Rte. #303, including the corporate limits of the city of Hudson)

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|              |          |       |
|--------------|----------|-------|
| PLUMBER..... | \$ 42.36 | 29.90 |
|--------------|----------|-------|

-----  
PLUM0083-001 07/01/2023

BELMONT & MONROE (North of Rte. #78)

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                              |          |       |
|------------------------------|----------|-------|
| Plumber and Steamfitter..... | \$ 35.94 | 37.35 |
|------------------------------|----------|-------|

-----  
PLUM0094-002 05/01/2024

CARROLL (Northen Half), STARK, and WAYNE COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                         |          |       |
|-------------------------|----------|-------|
| PLUMBER/PIPEFITTER..... | \$ 45.23 | 24.89 |
|-------------------------|----------|-------|

-----  
PLUM0120-002 04/29/2024

ASHTABULA, CUYAHOGA, GEAUGA, LAKE, LORAIN (the C.E.I. Power House in Avon Lake), MEDINA (N. of Rte. #18) & SUMMIT (N. of #303)

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                 |          |       |
|-----------------|----------|-------|
| PIPEFITTER..... | \$ 47.07 | 28.15 |
|-----------------|----------|-------|

-----  
PLUM0162-002 06/01/2024

CHAMPAIGN, CLARK, CLINTON, DARKE, FAYETTE, GREENE, MIAMI, MONTGOMERY & PREBLE

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                                          |          |       |
|------------------------------------------|----------|-------|
| Plumber, Pipefitter,<br>Steamfitter..... | \$ 43.05 | 27.18 |
|------------------------------------------|----------|-------|

-----  
PLUM0168-002 06/01/2024

MEIGS, MONROE (South of Rte. #78), MORGAN (South of Rte. #78) & WASHINGTON

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                         |          |       |
|-------------------------|----------|-------|
| PLUMBER/PIPEFITTER..... | \$ 39.43 | 37.29 |
|-------------------------|----------|-------|

PLUM0189-002 06/01/2024

DELAWARE, FAIRFIELD, FRANKLIN, HOCKING, LICKING, MADISON,  
MARION, PERRY, PICKAWAY, ROSS & UNION

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                                          |          |       |
|------------------------------------------|----------|-------|
| Plumber, Pipefitter,<br>Steamfitter..... | \$ 43.25 | 26.94 |
|------------------------------------------|----------|-------|

-----  
PLUM0219-002 06/01/2024

MEDINA (Rte. #18 from eastern edge of Medina Co., west to eastern corporate limits of the city of Medina, & on the county road from the west corporate limits of Medina running due west to and through community of Risley to the western edge of Medina County - All territory south of this line), PORTAGE, and SUMMIT (S. of Rte. #303) COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                              |          |       |
|------------------------------|----------|-------|
| Plumber and Steamfitter..... | \$ 45.37 | 27.64 |
|------------------------------|----------|-------|

-----  
PLUM0392-002 06/01/2024

BROWN, BUTLER, CLERMONT, HAMILTON &amp; WARREN

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                         |          |       |
|-------------------------|----------|-------|
| PLUMBER/PIPEFITTER..... | \$ 40.65 | 26.75 |
|-------------------------|----------|-------|

-----  
PLUM0396-001 06/01/2024

COLUMBIANA (Excluding Washington & Yellow Creek Townships & Liverpool Twp. - Secs. 35 & 36 - West of County Road #427), MAHONING and TRUMBULL COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                         |          |       |
|-------------------------|----------|-------|
| PLUMBER/PIPEFITTER..... | \$ 38.45 | 28.96 |
|-------------------------|----------|-------|

-----  
PLUM0495-002 06/01/2024

CARROLL (Rose, Monroe, Union, Lee, Orange, Perry & Loudon Townships), COLUMBIANA (Washington & Yellow Creek Townships & Liverpool Township, Secs. 35 & 36, West of County Rd. #427), COSHOCTON, GUERNSEY, HARRISON, HOLMES, JEFFERSON, MORGAN (South to State Rte. #78 & from McConnelville west on State Rte. #37 to the Perry County line), MUSKINGUM, NOBLE, and TUSCARAWAS COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                                          |          |       |
|------------------------------------------|----------|-------|
| Plumber, Pipefitter,<br>Steamfitter..... | \$ 37.82 | 36.70 |
|------------------------------------------|----------|-------|

-----  
PLUM0577-002 06/01/2024

ADAMS, ATHENS, GALLIA, HIGHLAND, JACKSON, LAWRENCE, PIKE,  
SCIOTO & VINTON

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                                          |          |       |
|------------------------------------------|----------|-------|
| Plumber, Pipefitter,<br>Steamfitter..... | \$ 41.65 | 27.48 |
|------------------------------------------|----------|-------|

-----  
PLUM0776-002 07/01/2024

ALLEN, AUGLAIZE, HARDIN, LOGAN, MERCER, SHELBY and VAN WERT  
COUNTIES

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|                                          |          |       |
|------------------------------------------|----------|-------|
| Plumber, Pipefitter,<br>Steamfitter..... | \$ 42.07 | 29.35 |
|------------------------------------------|----------|-------|

-----  
TEAM0377-003 05/01/2024

STATEWIDE, EXCEPT CUYAHOGA, GEAUGA & LAKE

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|              |          |       |
|--------------|----------|-------|
| TRUCK DRIVER |          |       |
| GROUP 1..... | \$ 32.54 | 16.80 |
| GROUP 2..... | \$ 32.96 | 16.80 |

#### TRUCK DRIVER CLASSIFICATIONS

GROUP 1 - Asphalt Distributor; Batch; 4- Wheel Service;  
4-Wheel Dump; Oil Distributor & Tandem

GROUP 2 - Tractor-Trailer Combination: Fuel; Pole Trailer;  
Ready Mix; Semi-Tractor; & Asphalt Oil Spraybar Man When  
Operated From Cab; 5 Axles & Over; Belly Dump; End Dump;  
Articulated Dump; Heavy Duty Equipment; Low Boy; & Truck  
Mechanic

-----  
TEAM0436-002 05/01/2024

CUYAHOGA, GEAUGA & LAKE

|  | Rates | Fringes |
|--|-------|---------|
|--|-------|---------|

|              |          |       |
|--------------|----------|-------|
| TRUCK DRIVER |          |       |
| GROUP 1..... | \$ 32.25 | 18.95 |
| GROUP 2..... | \$ 33.75 | 18.95 |

GROUP 1: Straight & Dump, Straight Fuel

GROUP 2: Semi Fuel, Semi Tractor, Euclids, Darts, Tank,  
Asphalt Spreaders, Low Boys, Carry-All, Tourna-Rockers,  
Hi-Lifts, Extra Long Trailers, Semi-Pole Trailers, Double  
Hook-Up Tractor Trailers including Team Track & Railroad  
Siding, Semi-Tractor & Tri-Axle Trailer, Tandem Tractor &  
Tandem Trailer, Tag Along Trailer, Expandable Trailer or  
Towing Requiring Road Permits, Ready-Mix (Agitator or  
Non-Agitator), Bulk Concrete Driver, Dry Batch Truck,  
Articulated End Dump

-----  
WELDERS - Receive rate prescribed for craft performing  
operation to which welding is incidental.

\*\*\*\*\*

\*\* Workers in this classification may be entitled to a higher minimum wage under Executive Order 14026 (\$17.75) or 13658 (\$13.30). Please see the Note at the top of the wage determination for more information. Please also note that the minimum wage requirements of Executive Order 14026 are not currently being enforced as to any contract or subcontract to which the states of Texas, Louisiana, or Mississippi, including their agencies, are a party.

Note: Executive Order (EO) 13706, Establishing Paid Sick Leave for Federal Contractors applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2017. If this contract is covered by the EO, the contractor must provide employees with 1 hour of paid sick leave for every 30 hours they work, up to 56 hours of paid sick leave each year. Employees must be permitted to use paid sick leave for their own illness, injury or other health-related needs, including preventive care; to assist a family member (or person who is like family to the employee) who is ill, injured, or has other health-related needs, including preventive care; or for reasons resulting from, or to assist a family member (or person who is like family to the employee) who is a victim of, domestic violence, sexual assault, or stalking. Additional information on contractor requirements and worker protections under the EO is available at <https://www.dol.gov/agencies/whd/government-contracts>.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (iii)).

-----

The body of each wage determination lists the classifications and wage rates that have been found to be prevailing for the type(s) of construction and geographic area covered by the wage determination. The classifications are listed in alphabetical order under rate identifiers indicating whether the particular rate is a union rate (current union negotiated rate), a survey rate, a weighted union average rate, a state adopted rate, or a supplemental classification rate.

#### Union Rate Identifiers

A four-letter identifier beginning with characters other than ""SU"", ""UAVG"", ?SA?, or ?SC? denotes that a union rate was prevailing for that classification in the survey. Example: PLUM0198-005 07/01/2024. PLUM is an identifier of the union whose collectively bargained rate prevailed in the survey for this classification, which in this example would be Plumbers. 0198 indicates the local union number or district council number where applicable, i.e., Plumbers Local 0198. The next number, 005 in the example, is an internal number used in processing the wage determination. The date, 07/01/2024 in the example, is the effective date of the most current negotiated rate.

Union prevailing wage rates are updated to reflect all changes over time that are reported to WHD in the rates

in the collective bargaining agreement (CBA) governing the classification.

#### Union Average Rate Identifiers

The UAVG identifier indicates that no single rate prevailed for those classifications, but that 100% of the data reported for the classifications reflected union rates. EXAMPLE:

UAVG-OH-0010 01/01/2024. UAVG indicates that the rate is a weighted union average rate. OH indicates the State of Ohio. The next number, 0010 in the example, is an internal number used in producing the wage determination. The date, 01/01/2024 in the example, indicates the date the wage determination was updated to reflect the most current union average rate.

A UAVG rate will be updated once a year, usually in January, to reflect a weighted average of the current rates in the collective bargaining agreements on which the rate is based.

#### Survey Rate Identifiers

The ""SU"" identifier indicates that either a single non-union rate prevailed (as defined in 29 CFR 1.2) for this classification in the survey or that the rate was derived by computing a weighted average rate based on all the rates reported in the survey for that classification. As a weighted average rate includes all rates reported in the survey, it may include both union and non-union rates. Example: SUFL2022-007 6/27/2024. SU indicates the rate is a single non-union prevailing rate or a weighted average of survey data for that classification. FL indicates the State of Florida. 2022 is the year of the survey on which these classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. The date, 6/27/2024 in the example, indicates the survey completion date for the classifications and rates under that identifier.

?SU? wage rates typically remain in effect until a new survey is conducted. However, the Wage and Hour Division (WHD) has the discretion to update such rates under 29 CFR 1.6(c)(1).

#### State Adopted Rate Identifiers

The ""SA"" identifier indicates that the classifications and prevailing wage rates set by a state (or local) government were adopted under 29 C.F.R 1.3(g)-(h). Example: SAME2023-007 01/03/2024. SA reflects that the rates are state adopted. ME refers to the State of Maine. 2023 is the year during which the state completed the survey on which the listed classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. The date, 01/03/2024 in the example, reflects the date on which the classifications and rates under the ?SA? identifier took effect under state law in the state from which the rates were adopted.

#### WAGE DETERMINATION APPEALS PROCESS

1) Has there been an initial decision in the matter? This can be:

- a) a survey underlying a wage determination
- b) an existing published wage determination

- c) an initial WHD letter setting forth a position on a wage determination matter
- d) an initial conformance (additional classification and rate) determination

On survey related matters, initial contact, including requests for summaries of surveys, should be directed to the WHD Branch of Wage Surveys. Requests can be submitted via email to [davisbaconinfo@dol.gov](mailto:davisbaconinfo@dol.gov) or by mail to:

Branch of Wage Surveys  
Wage and Hour Division  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

Regarding any other wage determination matter such as conformance decisions, requests for initial decisions should be directed to the WHD Branch of Construction Wage Determinations. Requests can be submitted via email to [BCWD-Office@dol.gov](mailto:BCWD-Office@dol.gov) or by mail to:

Branch of Construction Wage Determinations  
Wage and Hour Division  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

2) If an initial decision has been issued, then any interested party (those affected by the action) that disagrees with the decision can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Requests for review and reconsideration can be submitted via email to [dba.reconsideration@dol.gov](mailto:dba.reconsideration@dol.gov) or by mail to:

Wage and Hour Administrator  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210.

=====  
END OF GENERAL DECISION"

"General Decision Number: OH20250101 05/02/2025

Superseded General Decision Number: OH20240101

State: Ohio

Construction Type: Building

County: Trumbull County in Ohio.

BUILDING CONSTRUCTION PROJECTS (does not include single family homes or apartments up to and including 4 stories).

Note: Contracts subject to the Davis-Bacon Act are generally required to pay at least the applicable minimum wage rate required under Executive Order 14026 or Executive Order 13658. Please note that these Executive Orders apply to covered contracts entered into by the federal government that are subject to the Davis-Bacon Act itself, but do not apply to contracts subject only to the Davis-Bacon Related Acts, including those set forth at 29 CFR 5.1(a)(1).

|                                                                                                                                                                   |                                                                                                                                                                                                                                                                                                                                         |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| If the contract is entered into on or after January 30, 2022, or the contract is renewed or extended (e.g., an option is exercised) on or after January 30, 2022: | <ul style="list-style-type: none"> <li>. Executive Order 14026 generally applies to the contract.</li> <li>. The contractor must pay all covered workers at least \$17.75 per hour (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on the contract in 2025.</li> </ul>  |
| If the contract was awarded on or between January 1, 2015 and January 29, 2022, and the contract is not renewed or extended on or after January 30, 2022:         | <ul style="list-style-type: none"> <li>. Executive Order 13658 generally applies to the contract.</li> <li>. The contractor must pay all covered workers at least \$13.30 per hour (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on that contract in 2025.</li> </ul> |

The applicable Executive Order minimum wage rate will be adjusted annually. If this contract is covered by one of the Executive Orders and a classification considered necessary for performance of work on the contract does not appear on this wage determination, the contractor must still submit a conformance request.

Additional information on contractor requirements and worker protections under the Executive Orders is available at <http://www.dol.gov/whd/govcontracts>.

| Modification Number | Publication Date |
|---------------------|------------------|
| 0                   | 01/03/2025       |
| 1                   | 02/07/2025       |

2 02/14/2025  
 3 03/14/2025  
 4 05/02/2025

ASBE0008-010 03/01/2024

Rates Fringes

ASBESTOS WORKER/HEAT & FROST  
 INSULATOR.....\$ 34.23 21.94

BROH0008-006 06/01/2024

Rates Fringes

BRICKLAYER.....\$ 33.48 23.51

BROH0008-008 06/01/2024

Rates Fringes

BRICK POINTER/CAULKER/CLEANER....\$ 33.48 23.51

BROH0036-001 05/01/2024

Rates Fringes

TILE SETTER.....\$ 36.07 19.49

CARP0171-003 05/01/2024

Rates Fringes

CARPENTER (Includes Drywall  
 Hanging and Metal Stud  
 Installation, and Excludes  
 Form Work).....\$ 31.77 23.54

ELEC0064-004 11/25/2024

Rates Fringes

ELECTRICIAN (Excludes Low  
 Voltage Wiring).....\$ 39.80 21.03

ELEV0045-004 01/01/2025

Rates Fringes

ELEVATOR MECHANIC.....\$ 60.52 38.435+a+b

PAID HOLIDAYS:

a. New Year's Day, Memorial Day, Independence Day, Labor Day,  
 Veterans' Day, Thanksgiving Day, the Friday after  
 Thanksgiving, and Christmas Day.

b. Employer contributes 8% of regular hourly rate to vacation  
 pay credit for employee who has worked in business more  
 than 5 years; 6% for less than 5 years' service.

-----  
 ENGI0066-049 06/01/2023

Rates Fringes

## POWER EQUIPMENT OPERATOR

|                             |          |       |
|-----------------------------|----------|-------|
| Backhoe/Excavator/Trackhoe; |          |       |
| Bobcat/Skid Steer/Skid      |          |       |
| Loader; Bulldozer; Crane;   |          |       |
| Grader/Blade; Loader.....   | \$ 36.92 | 24.01 |
| Forklift.....               | \$ 32.06 | 24.01 |
| Mechanic.....               | \$ 36.92 | 24.01 |
| Oiler.....                  | \$ 28.77 | 24.01 |

-----  
IRON0207-014 06/01/2024

Rates Fringes

|                                                             |          |       |
|-------------------------------------------------------------|----------|-------|
| IRONWORKER (Ornamental,<br>Reinforcing and Structural)..... | \$ 34.83 | 27.41 |
|-------------------------------------------------------------|----------|-------|

-----  
LAB00125-004 06/01/2024

Rates Fringes

## LABORER

|                                        |          |       |
|----------------------------------------|----------|-------|
| Mason Tender -<br>Cement/Concrete..... | \$ 31.64 | 12.95 |
|----------------------------------------|----------|-------|

-----  
LAB00935-001 05/01/2021

Rates Fringes

## LABORER

|                |          |       |
|----------------|----------|-------|
| Form Work..... | \$ 29.34 | 11.80 |
|----------------|----------|-------|

-----  
LAB00935-002 06/01/2024

Rates Fringes

## LABORER

|                           |          |       |
|---------------------------|----------|-------|
| Common or General.....    | \$ 31.64 | 13.17 |
| Mason Tender - Brick..... | \$ 31.64 | 13.17 |

-----  
PAIN0847-002 06/01/2022

Rates Fringes

|              |          |       |
|--------------|----------|-------|
| GLAZIER..... | \$ 27.51 | 19.70 |
|--------------|----------|-------|

-----  
PLAS0526-016 06/01/2018

Rates Fringes

|                                   |          |       |
|-----------------------------------|----------|-------|
| CEMENT MASON/CONCRETE FINISHER... | \$ 29.65 | 18.61 |
|-----------------------------------|----------|-------|

-----  
PLUM0396-004 06/01/2024

Rates Fringes

|                                                      |          |       |
|------------------------------------------------------|----------|-------|
| PIPEFITTER (Includes HVAC<br>Pipe Installation)..... | \$ 38.45 | 28.96 |
| PLUMBER (Excludes HVAC Pipe<br>Installation).....    | \$ 38.45 | 28.96 |

-----  
\* ROOF0044-003 04/27/2025

Rates Fringes

|             |          |       |
|-------------|----------|-------|
| ROOFER..... | \$ 40.15 | 21.28 |
|-------------|----------|-------|

-----  
SHEE0033-022 06/01/2024

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

|                                                          |          |       |
|----------------------------------------------------------|----------|-------|
| SHEET METAL WORKER (HVAC Duct<br>Installation Only)..... | \$ 36.89 | 28.72 |
|----------------------------------------------------------|----------|-------|

-----  
SHEE0033-023 06/01/2024

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

|                                                               |          |       |
|---------------------------------------------------------------|----------|-------|
| SHEET METAL WORKER (Excluding<br>HVAC Duct Installation)..... | \$ 36.89 | 28.72 |
|---------------------------------------------------------------|----------|-------|

-----  
\* UAVG-OH-0029 01/01/2019

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

|                     |          |       |
|---------------------|----------|-------|
| PAINTER: Spray..... | \$ 25.62 | 13.83 |
|---------------------|----------|-------|

-----  
\* UAVG-OH-0033 01/01/2018

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

|                       |          |       |
|-----------------------|----------|-------|
| OPERATOR: Roller..... | \$ 30.65 | 19.66 |
|-----------------------|----------|-------|

-----  
\* UAVG-OH-0034 01/01/2019

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

|                                                 |          |       |
|-------------------------------------------------|----------|-------|
| PAINTER (Drywall<br>Finishing/Taping Only)..... | \$ 25.80 | 13.83 |
|-------------------------------------------------|----------|-------|

-----  
SU0H2012-103 08/29/2014

|       |         |
|-------|---------|
| Rates | Fringes |
|-------|---------|

|                                               |          |      |
|-----------------------------------------------|----------|------|
| ELECTRICIAN (Low Voltage<br>Wiring Only)..... | \$ 20.58 | 0.00 |
|-----------------------------------------------|----------|------|

|                         |          |      |
|-------------------------|----------|------|
| LABORER: Pipelayer..... | \$ 23.98 | 8.58 |
|-------------------------|----------|------|

|                                                            |          |       |
|------------------------------------------------------------|----------|-------|
| OPERATOR: Paver (Asphalt,<br>Aggregate, and Concrete)..... | \$ 30.28 | 13.29 |
|------------------------------------------------------------|----------|-------|

|                                 |          |       |
|---------------------------------|----------|-------|
| PAINTER (Brush and Roller)..... | \$ 20.52 | 10.06 |
|---------------------------------|----------|-------|

|                    |          |      |
|--------------------|----------|------|
| TILE FINISHER..... | \$ 24.24 | 9.75 |
|--------------------|----------|------|

|                                   |          |       |
|-----------------------------------|----------|-------|
| TRUCK DRIVER: Dump (All Types)... | \$ 24.32 | 11.73 |
|-----------------------------------|----------|-------|

-----  
WELDERS - Receive rate prescribed for craft performing  
operation to which welding is incidental.

=====

Note: Executive Order (EO) 13706, Establishing Paid Sick Leave for Federal Contractors applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2017. If this contract is covered by the EO, the contractor must provide employees with 1 hour of paid sick leave for every 30 hours

they work, up to 56 hours of paid sick leave each year. Employees must be permitted to use paid sick leave for their own illness, injury or other health-related needs, including preventive care; to assist a family member (or person who is like family to the employee) who is ill, injured, or has other health-related needs, including preventive care; or for reasons resulting from, or to assist a family member (or person who is like family to the employee) who is a victim of, domestic violence, sexual assault, or stalking. Additional information on contractor requirements and worker protections under the EO is available at <https://www.dol.gov/agencies/whd/government-contracts>.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (iii)).

-----

The body of each wage determination lists the classifications and wage rates that have been found to be prevailing for the type(s) of construction and geographic area covered by the wage determination. The classifications are listed in alphabetical order under rate identifiers indicating whether the particular rate is a union rate (current union negotiated rate), a survey rate, a weighted union average rate, a state adopted rate, or a supplemental classification rate.

#### Union Rate Identifiers

A four-letter identifier beginning with characters other than ""SU"", ""UAVG"", ?SA?, or ?SC? denotes that a union rate was prevailing for that classification in the survey. Example: PLUM0198-005 07/01/2024. PLUM is an identifier of the union whose collectively bargained rate prevailed in the survey for this classification, which in this example would be Plumbers. 0198 indicates the local union number or district council number where applicable, i.e., Plumbers Local 0198. The next number, 005 in the example, is an internal number used in processing the wage determination. The date, 07/01/2024 in the example, is the effective date of the most current negotiated rate.

Union prevailing wage rates are updated to reflect all changes over time that are reported to WHD in the rates in the collective bargaining agreement (CBA) governing the classification.

#### Union Average Rate Identifiers

The UAVG identifier indicates that no single rate prevailed for those classifications, but that 100% of the data reported for the classifications reflected union rates. EXAMPLE: UAVG-OH-0010 01/01/2024. UAVG indicates that the rate is a weighted union average rate. OH indicates the State of Ohio. The next number, 0010 in the example, is an internal number used in producing the wage determination. The date, 01/01/2024 in the example, indicates the date the wage determination was updated to reflect the most current union average rate.

A UAVG rate will be updated once a year, usually in January, to reflect a weighted average of the current rates in the collective bargaining agreements on which the rate is based.

## Survey Rate Identifiers

The ""SU"" identifier indicates that either a single non-union rate prevailed (as defined in 29 CFR 1.2) for this classification in the survey or that the rate was derived by computing a weighted average rate based on all the rates reported in the survey for that classification. As a weighted average rate includes all rates reported in the survey, it may include both union and non-union rates. Example: SUFL2022-007 6/27/2024. SU indicates the rate is a single non-union prevailing rate or a weighted average of survey data for that classification. FL indicates the State of Florida. 2022 is the year of the survey on which these classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. The date, 6/27/2024 in the example, indicates the survey completion date for the classifications and rates under that identifier.

?SU? wage rates typically remain in effect until a new survey is conducted. However, the Wage and Hour Division (WHD) has the discretion to update such rates under 29 CFR 1.6(c)(1).

## State Adopted Rate Identifiers

The ""SA"" identifier indicates that the classifications and prevailing wage rates set by a state (or local) government were adopted under 29 C.F.R 1.3(g)-(h). Example: SAME2023-007 01/03/2024. SA reflects that the rates are state adopted. ME refers to the State of Maine. 2023 is the year during which the state completed the survey on which the listed classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. The date, 01/03/2024 in the example, reflects the date on which the classifications and rates under the ?SA? identifier took effect under state law in the state from which the rates were adopted.

## WAGE DETERMINATION APPEALS PROCESS

1) Has there been an initial decision in the matter? This can be:

- a) a survey underlying a wage determination
- b) an existing published wage determination
- c) an initial WHD letter setting forth a position on a wage determination matter
- d) an initial conformance (additional classification and rate) determination

On survey related matters, initial contact, including requests for summaries of surveys, should be directed to the WHD Branch of Wage Surveys. Requests can be submitted via email to davisbaconinfo@dol.gov or by mail to:

Branch of Wage Surveys  
Wage and Hour Division  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

Regarding any other wage determination matter such as conformance decisions, requests for initial decisions should be

directed to the WHD Branch of Construction Wage Determinations. Requests can be submitted via email to BCWD-Office@dol.gov or by mail to:

Branch of Construction Wage Determinations  
Wage and Hour Division  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

2) If an initial decision has been issued, then any interested party (those affected by the action) that disagrees with the decision can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Requests for review and reconsideration can be submitted via email to dba.reconsideration@dol.gov or by mail to:

Wage and Hour Administrator  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board  
U.S. Department of Labor  
200 Constitution Avenue, N.W.  
Washington, DC 20210.

=====  
END OF GENERAL DECISION"

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

## SECTION 09 90 00

## PAINTS AND COATINGS

02/21

Admt. #0004

## PART 1 GENERAL

## 1.1 RELATED REQUIREMENTS

## 1.1.1 Painting Included

Where a space or surface is indicated to be painted, include the following unless indicated otherwise.

- a. Surfaces behind portable objects and surface mounted articles readily detachable by removal of fasteners, such as screws and bolts.
- b. New factory finished surfaces that require identification or color coding and factory finished surfaces that are damaged during performance of the work.
- c. Existing coated surfaces that are damaged during performance of the work.

## 1.1.1.1 Exterior Painting

Includes new surfaces of the building and appurtenances.

## 1.1.1.2 Interior Painting

Includes new surfaces of the building and appurtenances as indicated. Where a space or surface is indicated to be painted, include the following items, unless indicated otherwise.

- a. Exposed columns, girders, beams, joists, and metal deck; and
- b. Other contiguous surfaces.

## 1.1.2 Painting Excluded

Do not paint the following unless indicated otherwise.

- a. Surfaces concealed and made inaccessible by panelboards, fixed ductwork, machinery, and equipment fixed in place.
- b. Surfaces in concealed spaces. Concealed spaces are defined as enclosed spaces above suspended ceilings, furred spaces, attic spaces, crawl spaces, elevator shafts and chases.
- c. Steel to be embedded in concrete.
- d. Copper, stainless steel, aluminum, anodized aluminum, brass, and lead except existing coated surfaces.
- e. Hardware, fittings, and other factory finished items.

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

### 1.1.3 Mechanical and Electrical Painting

Includes field coating of interior new surfaces.

a. Where a space or surface is indicated to be painted, include the following items unless indicated otherwise.

- (1) Exposed piping, conduit, and ductwork;
- (2) Supports, hangers, air grilles, and registers;
- (3) Miscellaneous metalwork and insulation coverings.

b. Do not paint the following, unless indicated otherwise:

- (1) New zinc-coated, aluminum, and copper surfaces under insulation
- (2) New aluminum jacket on piping
- (3) New interior ferrous piping under insulation.

#### 1.1.3.1 Fire Extinguishing Sprinkler Systems

Clean, pretreat, prime, and paint new fire extinguishing sprinkler systems including valves, piping, conduit, hangers, supports, miscellaneous metalwork, and accessories. Apply coatings to clean, dry surfaces, using clean brushes.

### 1.1.4 Exterior Painting of Site Work Items

Field coat the following items:

|    | New Surfaces             | Existing Surfaces |
|----|--------------------------|-------------------|
| a. | Steel Doors and Frames   | N.A.              |
| b. | Exposed Structural Steel | N.A.              |

## 1.2 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

#### AMERICAN CONFERENCE OF GOVERNMENTAL INDUSTRIAL HYGIENISTS (ACGIH)

ACGIH 0100 (2017; Suppl 2020) Documentation of the Threshold Limit Values and Biological Exposure Indices

#### AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)

ASME A13.1 (2020) Scheme for the Identification of Piping Systems

#### ASTM INTERNATIONAL (ASTM)

ASTM D523 (2014; R 2018) Standard Test Method for Specular Gloss

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

|            |                                                                                                                                         |
|------------|-----------------------------------------------------------------------------------------------------------------------------------------|
| ASTM D4263 | (1983; R 2018) Standard Test Method for Indicating Moisture in Concrete by the Plastic Sheet Method                                     |
| ASTM D4444 | (2013; R 2018) Standard Test Method for Laboratory Standardization and Calibration of Hand-Held Moisture Meters                         |
| ASTM D6386 | (2016a) Standard Practice for Preparation of Zinc (Hot-Dip Galvanized) Coated Iron and Steel Product and Hardware Surfaces for Painting |
| ASTM F1869 | (2023) Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride            |

CENTERS FOR DISEASE CONTROL AND PREVENTION (CDC)

|                          |                                                                 |
|--------------------------|-----------------------------------------------------------------|
| Intelligence Bulletin 65 | (2013) Occupational Exposure to Carbon Nanotubes and Nanofibers |
|--------------------------|-----------------------------------------------------------------|

MASTER PAINTERS INSTITUTE (MPI)

|        |                                                                            |
|--------|----------------------------------------------------------------------------|
| MPI 3  | (2016) Primer, Alkali Resistant, Water Based                               |
| MPI 4  | (2016) Interior/Exterior Latex Block Filler                                |
| MPI 9  | (2016) Alkyd, Exterior Gloss (MPI Gloss Level 6)                           |
| MPI 10 | (2016) Latex, Exterior Flat (MPI Gloss Level 1)                            |
| MPI 11 | (2016) Latex, Exterior Semi-Gloss, MPI Gloss Level 5                       |
| MPI 44 | (2016) Latex, Interior, (MPI Gloss Level 2)                                |
| MPI 50 | (2015) Primer Sealer, Latex, Interior                                      |
| MPI 52 | (2016) Latex, Interior, (MPI Gloss Level 3)                                |
| MPI 54 | (2016) Latex, Interior, Semi-Gloss (MPI Gloss Level 5)                     |
| MPI 72 | (2016) Polyurethane, Two-Component, Pigmented, Gloss (MPI Gloss Level 6-7) |
| MPI 77 | (2015) Epoxy, Gloss                                                        |
| MPI 79 | (2016) Primer, Alkyd, Anti-Corrosive for Metal                             |
| MPI 94 | (2016) Alkyd, Exterior, Semi-Gloss (MPI Gloss Level 5)                     |

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

|              |                                                                                        |
|--------------|----------------------------------------------------------------------------------------|
| MPI 95       | (2015) Primer, Quick Dry, for Aluminum                                                 |
| MPI 101      | (2016) Primer, Epoxy, Anti-Corrosive, for Metal                                        |
| MPI 107      | (2016) Primer, Rust-Inhibitive, Water Based                                            |
| MPI 108      | (2015) Epoxy, High Build, Low Gloss                                                    |
| MPI 119      | (2016) Latex, Exterior, Gloss (MPI Gloss Level 6)                                      |
| MPI 134      | (2015) Primer, Galvanized, Water Based                                                 |
| MPI 138      | (2016) Latex, Interior, High Performance Architectural, (MPI Gloss Level 2)            |
| MPI 139      | (2016) Latex, Interior, High Performance Architectural, (MPI Gloss Level 3)            |
| MPI 141      | (2016) Latex, Interior, High Performance Architectural, Semi-Gloss (MPI Gloss Level 5) |
| MPI 144      | (2016) Latex, Interior, Institutional Low Odor/VOC, (MPI Gloss Level 2)                |
| MPI 145      | (2016) Latex, Interior, Institutional Low Odor/VOC, ( MPI Gloss Level 3)               |
| MPI 146      | (2016) Latex, Interior, Institutional Low Odor/VOC, (MPI Gloss Level 4)                |
| MPI 147      | (May 2016) Latex, Interior, Institutional Low Odor/VOC, Semi-Gloss (MPI Gloss Level 5) |
| MPI 149      | (2016) Primer Sealer, Interior, Institutional Low Odor/VOC                             |
| MPI 161      | (2016) Light Industrial Coating, Exterior, Water Based ( MPI Gloss Level 3)            |
| MPI 163      | (2016) Light Industrial Coating, Exterior, Water Based, Semi-Gloss (MPI Gloss Level 5) |
| MPI 164      | (2016) Light Industrial Coating, Exterior, Water Based, Gloss (MPI Gloss Level 6)      |
| MPI 214      | (2016) Latex, Exterior (MPI Gloss Level 2)                                             |
| MPI ASM      | (2019) Architectural Painting Specification Manual                                     |
| MPI GPS-1-14 | (2014) Green Performance Standard GPS-1-14                                             |
| MPI GPS-2-14 | (2014) Green Performance Standard GPS-2-14                                             |
| MPI MRM      | (2015) Maintenance Repainting Manual                                                   |

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

# SOCIETY FOR PROTECTIVE COATINGS (SSPC)

|                        |                                                                                                                                                                                             |
|------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| SSPC 7/NACE No.4       | (2007) Brush-Off Blast Cleaning                                                                                                                                                             |
| SSPC Glossary          | (2011) SSPC Protective Coatings Glossary                                                                                                                                                    |
| SSPC Guide 6           | (2021) Guide for Containing Surface Preparation Debris Generated During Paint Removal Operations                                                                                            |
| SSPC Guide 7           | (2015) Guide to the Disposal of Lead-Contaminated Surface Preparation Debris                                                                                                                |
| SSPC PA 1              | (2016) Shop, Field, and Maintenance Coating of Metals                                                                                                                                       |
| SSPC QP 1              | (2019) Standard Procedure for Evaluating the Qualifications of Industrial/Marine Painting Contractors (Field Application to Complex Industrial Steel Structures and Other Metal Components) |
| SSPC SP 1              | (2015) Solvent Cleaning                                                                                                                                                                     |
| SSPC SP 2              | (2018) Hand Tool Cleaning                                                                                                                                                                   |
| SSPC SP 3              | (2018) Power Tool Cleaning                                                                                                                                                                  |
| SSPC SP 6/NACE No.3    | (2007) Commercial Blast Cleaning                                                                                                                                                            |
| SSPC SP 10/NACE No. 2  | (2015) Near-White Blast Cleaning                                                                                                                                                            |
| SSPC VIS 1             | (2002; E 2004) Guide and Reference Photographs for Steel Surfaces Prepared by Dry Abrasive Blast Cleaning                                                                                   |
| SSPC VIS 3             | (2004) Guide and Reference Photographs for Steel Surfaces Prepared by Hand and Power Tool Cleaning                                                                                          |
| SSPC VIS 4/NACE VIS 7  | (1998; E 2000; E 2004) Guide and Reference Photographs for Steel Surfaces Prepared by Waterjetting                                                                                          |
| SSPC-SP WJ-1/NACE WJ-1 | (2012) Clean to Bare Substrate, Waterjet Cleaning of Metals                                                                                                                                 |
| SSPC-SP WJ-2/NACE WJ-2 | (2012) Very Thorough Cleaning, Waterjet Cleaning of Metals                                                                                                                                  |
| SSPC-SP WJ-3/NACE WJ-3 | (2012) Thorough Cleaning, Waterjet Cleaning of Metals                                                                                                                                       |
| SSPC-SP WJ-4/NACE WJ-4 | (2012) Light Cleaning, Waterjet Cleaning of Metals                                                                                                                                          |

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

U.S. DEPARTMENT OF DEFENSE (DOD)

MIL-STD-101 (2014; Rev C) Color Code for Pipelines and  
for Compressed Gas Cylinders

U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA)

EPA Method 24 (2000) Determination of Volatile Matter  
Content, Water Content, Density, Volume  
Solids, and Weight Solids of Surface  
Coatings

U.S. GENERAL SERVICES ADMINISTRATION (GSA)

FED-STD-313 (2018) Material Safety Data,  
Transportation Data and Disposal Data for  
Hazardous Materials Furnished to  
Government Activities

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

29 CFR 1910.1000 Air Contaminants

29 CFR 1910.1025 Lead

29 CFR 1926.62 Lead

1.3 DEFINITIONS

1.3.1 Qualification Testing

Qualification testing is the performance of all test requirements listed in the product specification. This testing is accomplished by MPI to qualify each product for the MPI Approved Product List, and may also be accomplished by Contractor's third-party testing lab if an alternative to Batch Quality Conformance Testing by MPI is desired.

1.3.2 Batch Quality Conformance Testing

Batch quality conformance testing determines that the product provided is the same as the product qualified to the appropriate product specification. This testing must be accomplished by an MPI testing lab.

1.3.3 Coating

SSPC Glossary; (1) A liquid, liquefiable, or mastic composition that is converted to a solid protective, decorative, or functional adherent film after application as a thin layer; (2) Generic term for paint, lacquer, enamel.

1.3.4 DFT or dft

Dry film thickness, the film thickness of the fully cured, dry paint or coating.

1.3.5 DSD

Degree of Surface Degradation, the MPI system of defining degree of surface degradation. Five levels are generically defined under the Assessment

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

sections in the MPI MRM, MPI Maintenance Repainting Manual.

#### 1.3.6 EXT

MPI short term designation for an exterior coating system.

#### 1.3.7 INT

MPI short term designation for an interior coating system.

#### 1.3.8 Loose Paint

Paint or coating that can be removed with a dull putty knife.

#### 1.3.9 mil / mils

The English measurement for 0.001 in or one one-thousandth of an inch.

#### 1.3.10 MPI Gloss Levels

MPI system of defining gloss. Seven gloss levels (G1 to G7) are generically defined under the Evaluation sections of the MPI Manuals. Traditionally, Flat refers to G1/G2, Eggshell refers to G3, Semigloss refers to G5, and Gloss refers to G6.

Gloss levels are defined by MPI as follows:

| Gloss Level | Description   | Units at 60<br>degree angle | Units at 80<br>degree angle |
|-------------|---------------|-----------------------------|-----------------------------|
| G1          | Matte or Flat | 0 to 5                      | 10 max                      |
| G2          | Velvet        | 0 to 10                     | 10 to 35                    |
| G3          | Eggshell      | 10 to 25                    | 10 to 35                    |
| G4          | Satin         | 20 to 35                    | 35 min                      |
| G5          | Semi-Gloss    | 35 to 70                    |                             |
| G6          | Gloss         | 70 to 85                    |                             |
| G7          | High Gloss    |                             |                             |

Gloss is tested in accordance with ASTM D523. Historically, the Government has used Flat (G1 / G2), Eggshell (G3), Semi-Gloss (G5), and Gloss (G6).

#### 1.3.11 MPI System Number

The MPI coating system number in each MPI Division found in either the MPI Architectural Painting Specification Manual or the Maintenance Repainting Manual and defined as an exterior (EXT/REX) or interior system (INT/RIN).

#### 1.3.12 Paint

SSPC Glossary; (1) Any pigmented liquid, liquefiable, or mastic composition designed for application to a substrate in a thin layer that is converted to an opaque solid film after application. Used for protection, decoration, identification, or to serve some other functional purposes; (2)

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

Application of a coating material.

#### 1.3.13 REX

MPI short term designation for an exterior coating system used in repainting projects or over existing coating systems.

#### 1.3.14 RIN

MPI short term designation for an interior coating system used in repainting projects or over existing coating systems.

#### 1.4 SCHEDULING

Allow paint, polyurethane, varnish, and wood stain installations to cure prior to the installation of materials that adsorb VOCs, including carpets, textiles, unprimed gypsum wallboard, acoustical ceiling panels,.

#### 1.5 SUBMITTALS

Government approval is required for submittals with a "G" classification. Submittals not having a "G" classification are for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

Samples of specified materials may be taken and tested for compliance with specification requirements.

##### SD-02 Shop Drawings

Piping Identification

##### SD-03 Product Data

Coating; G

Product Data Sheets

##### SD-04 Samples

Color; G

##### SD-07 Certificates

Qualification Testing laboratory for coatings

Indoor Air Quality for Paints and Primers

Indoor Air Quality for Consolidated Latex Paints

##### SD-08 Manufacturer's Instructions

Application Instructions

Mixing

Manufacturer's Safety Data Sheets

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

## SD-10 Operation and Maintenance Data

### Coatings, Data Package 1; G

#### 1.6 QUALITY ASSURANCE

##### 1.6.1 Regulatory Requirements

###### 1.6.1.1 Environmental Protection

In addition to requirements specified elsewhere for environmental protection, provide coating materials that conform to the restrictions of the local Air Pollution Control District and regional jurisdiction. Notify Contracting Officer of any paint specified herein which fails to conform.

###### 1.6.1.2 Lead Content

Do not use coatings having a lead content over 0.06 percent by weight of nonvolatile content.

###### 1.6.1.3 Chromate Content

Do not use coatings containing zinc-chromate or strontium-chromate.

###### 1.6.1.4 Asbestos Content

Provide asbestos-free materials.

###### 1.6.1.5 Mercury Content

Provide materials free of mercury or mercury compounds.

###### 1.6.1.6 Silica

Provide abrasive blast media containing no free crystalline silica.

###### 1.6.1.7 Human Carcinogens

Provide materials that do not contain ACGIH 0100 confirmed human carcinogens (A1) or suspected human carcinogens (A2).

###### 1.6.1.8 Carbon Based Fibers / Tubes

Materials must not contain carbon based fibers such as carbon nanotubes or carbon nanofibers. Intelligence Bulletin 65 ranks toxicity of carbon nanotubes on a par with asbestos.

##### 1.6.2 Coating Contractor's Qualification

Submit the name, address, telephone number, and e-mail address of the Contractor that will be performing all surface preparation and coating application. Submit evidence that key personnel have successfully performed surface preparation and application of coatings on a minimum of three similar projects within the past three years. List information by individual and include the following:

- a. Name of individual and proposed position for this work.

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

b. Information about each previous assignment including:

Position or responsibility

Employer (if other than the Contractor)

Name of facility owner

Mailing address and telephone number of facility owner

Name of individual in facility owner's organization who can be contacted as a reference

Location, size and description of structure

Dates work was carried out

Description of work carried out on structure

### 1.6.3 SSPC QP 1 Certification

Contractors that perform surface preparation or coating application on steel substrates must be certified by the Society for Protective Coatings (formerly Steel Structures Painting Council) (SSPC) to the requirements of SSPC QP 1 prior to Contract award, and must remain certified while accomplishing any surface preparation or coating application. If a Contractor's certification expires, the firm will not be allowed to perform any work until the certification is reissued. Requests for extension of time for any delay to the completion of the project due to an inactive certification will not be considered. Notify the Contracting Officer of any change in Contractor certification status. Notify the Contracting Officer of all scheduled and unannounced on-site audits from SSPC and furnish a copy of all audit reports.

### 1.6.4 Approved Products List

The current MPI, "Approved Product List" which lists paint by brand, label, product name and product code as of the date of Contract award, will be used to determine compliance with the submittal requirements of this specification. The Contractor may choose to use a subsequent MPI "Approved Product List", however, only one list may be used for the entire Contract and each coating system is to be from a single manufacturer. Provide all coats on a particular substrate from a single manufacturer. No variation from the MPI Approved Products List is acceptable.

### 1.6.5 Paints and Coatings Indoor Air Quality Certifications

Provide paint and coating products certified to meet indoor air quality requirements by MPI GPS-1-14, MPI GPS-2-14 or provide certification by other third-party programs. Provide current product certification documentation from certification body.

Provide certification of Indoor Air Quality for Paints and Primers.  
Provide certification of Indoor Air Quality for Consolidated Latex Paints.  
Submit required indoor air quality certifications in one submittal package.

### 1.6.6 Field Samples and Tests

The Contracting Officer may choose up to two coatings that have been

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

delivered to the site to be tested at no cost to the Government. Take samples of each chosen product as specified in the paragraph SAMPLING PROCEDURE. Test each chosen product as specified in the paragraph TESTING PROCEDURE. Remove products from the job site which do not conform, and replace with new products that conform to the referenced specification. Test replacement products that failed initial testing as specified in the paragraph TESTING PROCEDURE at no cost to the Government.

#### 1.6.6.1 Sampling Procedure

Select paint at random from the products that have been delivered to the job site for sample testing. The Contractor must provide one quart samples of the selected paint materials. Take samples in the presence of the Contracting Officer, and label, and identify each sample. Provide labels in accordance with the paragraph PACKAGING, LABELING, AND STORAGE.

#### 1.6.6.2 Testing Procedure

Provide Batch Quality Conformance Testing for specified products, as defined by and performed by MPI. As an alternative to Batch Quality Conformance Testing, the Contractor may provide Qualification Testing for specified products above to the appropriate MPI product specification, using the third-party laboratory approved under the paragraph QUALIFICATION TESTING laboratory for coatings. Include the backup data and summary of the test results within the qualification testing lab report. Provide a summary listing of all the reference specification requirements and the result of each test. Clearly indicate in the summary whether the tested paint meets each test requirement. Note that Qualification Testing may take 4 to 6 weeks to perform, due to the extent of testing required.

Submit name, address, telephone number, FAX number, and e-mail address of the independent third party laboratory selected to perform testing of coating samples for compliance with specification requirements. Submit documentation that laboratory is regularly engaged in testing of paint samples for conformance with specifications, and that employees performing testing are qualified. If MPI is chosen to perform the Batch Quality Conformance testing, the above submittal information is not required, only a letter is required from the Contractor stating that MPI will perform the testing.

#### 1.7 PACKAGING, LABELING, AND STORAGE

Provide paints in sealed containers that legibly show the Contract specification number, designation name, formula or specification number, batch number, color, quantity, date of manufacture, manufacturer's formulation number, manufacturer's directions including any warnings and special precautions, and name and address of manufacturer. Furnish pigmented paints in containers not larger than 5 gallons. Store paints and thinners in accordance with the manufacturer's written directions, and as a minimum, stored off the ground, under cover, with sufficient ventilation to prevent the buildup of flammable vapors, and at temperatures between 40 to 95 degrees F. Do not store paint, polyurethane, varnish, or wood stain products with materials that have a high capacity to absorb VOC emissions. Do not store paint, polyurethane, varnish, or wood stain products in occupied spaces.

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

## 1.8 SAFETY AND HEALTH

Comply with applicable Federal, State, and local laws and regulations. Include in the Activity Hazard Analysis the potential impact of painting operations on painting personnel and on others involved in and adjacent to the work zone.

### 1.8.1 Toxic Materials

To protect personnel from overexposure to toxic materials, conform to the most stringent guidance of:

- a. The applicable manufacturer's Safety Data Sheets (SDS) or local regulation.
- b. 29 CFR 1910.1000.
- c. ACGIH 0100, threshold limit values.
- d. The appropriate OSHA standard in 29 CFR 1910.1025 and 29 CFR 1926.62 for surface preparation on painted surfaces containing lead. Removal and disposal of coatings which contain lead is specified in Section 02 83 00 LEAD REMEDIATION. Additional guidance is given in SSPC Guide 6 and SSPC Guide 7. Refer to drawings for list of hazardous materials located on this project. Coordinate paint preparation activities with this specification section.

Submit manufacturer's Safety Data Sheets for coatings, solvents, and other potentially hazardous materials, as defined in FED-STD-313.

## 1.9 ENVIRONMENTAL REQUIREMENTS

Comply, at minimum, with manufacturer recommendations for space ventilation during and after installation. Isolate area of application from rest of building when applying high-emission paints or coatings.

### 1.9.1 Coatings

Do not apply coating when air or substrate conditions are:

- a. Less than 5 degrees F above dew point;
- b. Below 50 degrees F or over 95 degrees F, unless specifically pre-approved by the Contracting Officer and the product manufacturer. Do not, under any circumstances, violate the manufacturer's application recommendations.

### 1.9.2 Post-Application

Vacate space for as long as possible after application. Wait a minimum of 48 hours before occupying freshly painted rooms. Maintain one of the following ventilation conditions during the curing period, or for 72 hours after application:

- a. Supply 100 percent outside air 24 hours a day.
- b. Supply airflow at a rate of 6 air changes per hour, when outside temperatures are between 55 degrees F and 85 degrees F and humidity is between 30 percent and 60 percent.

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

- c. Supply airflow at a rate of 1.5 air changes per hour, when outside air conditions are not within the range stipulated above.

## PART 2 PRODUCTS

### 2.1 MATERIALS

Conform to the coating specifications and standards referenced in PART 3. Submit Product Data Sheets for specified coatings and solvents. Provide preprinted cleaning and maintenance instructions for all coating systems. Submit Manufacturer's Instructions on Mixing: Detailed mixing instructions, minimum and maximum application temperature and humidity, pot life, and curing and drying times between coats.

### 2.2 COLOR SELECTION OF FINISH COATS

Provide colors of finish coats as indicated or specified. Allow Contracting Officer to select colors not indicated or specified. Manufacturers' names and color identification are used for the purpose of color identification only. Named products are acceptable for use only if they conform to specified requirements. Products of other manufacturers are acceptable if the colors are approximately the colors indicated and the product conforms to specified requirements.

Provide color, texture, and pattern of wall coating systems as indicated. Submit manufacturer's samples of paint colors. Cross reference color samples to color scheme as indicated. Submit color stencil codes. Tint each coat progressively darker to enable confirmation of the number of coats.

### 2.3 CONCRETE FLOOR SURFACE SEALER

Clear concrete water based, wet look, floor sealer system in conformance with MPI ASM, No. 99.

Admt. #0004\*\*\*\*\*

### 2.4 CONCRETE FLOOR STAIN

Concrete Floor Stain: Low oror, low VOC, water-based concrete stain capable of providing translucent color variations - Basis of Design SikaColor 430 Elements.

- a. Chemical Base: Water-Based.
- b. Shelf Life: 24 months.
- c. Coverage: 200-400 sq./ft. concetrare mixed with 96oz. potable water.
- d. Color: As indicated on drawings.
- e. Preparation: Per manufacturer's written recommendations.

\*\*\*\*\*Admt. #0004

## PART 3 EXECUTION

### 3.1 PROTECTION OF AREAS AND SPACES NOT TO BE PAINTED

Prior to surface preparation and coating applications, remove, mask, or otherwise protect hardware, hardware accessories, machined surfaces, radiator covers, plates, lighting fixtures, public and private property, and other such items not to be coated that are in contact with surfaces to

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

be coated. Following completion of painting, reinstall removed items by workmen skilled in the trades. Restore surfaces contaminated by coating materials, to original condition and repair damaged items.

### 3.2 SURFACE PREPARATION

Remove dirt, splinters, loose particles, grease, oil, disintegrated coatings, and other foreign matter and substances deleterious to coating performance as specified for each substrate before application of paint or surface treatments. Remove oil and grease prior to mechanical cleaning. Schedule cleaning so that dust and other contaminants will not fall on wet, newly painted surfaces. Spot-prime exposed ferrous metals such as nail heads on or in contact with surfaces to be painted with water-thinned paints, with a suitable corrosion-inhibitive primer capable of preventing flash rusting and compatible with the coating specified for the adjacent areas. Refer to MPI ASM and MPI MRM for additional more specific substrate preparation requirements.

#### 3.2.1 Substrate Repair

- a. Repair substrate surface damaged during coating removal;
- b. Sand edges of adjacent soundly-adhered existing coatings so they are tapered as smooth as practical to areas involved with coating removal; and
- c. Clean and prime the substrate as specified.

### 3.3 PREPARATION OF METAL SURFACES

#### 3.3.1 New Ferrous Surfaces

- a. Ferrous Surfaces including Shop-coated Surfaces and Small Areas That Contain Rust, Mill Scale and Other Foreign Substances: Solvent clean or detergent wash in accordance with SSPC SP 1 to remove oil and grease. Where shop coat is missing or damaged, clean according to SSPC SP 2, SSPC SP 3, SSPC SP 6/NACE No.3, or SSPC SP 10/NACE No. 2. Brush-off blast remaining surface in accordance with SSPC 7/NACE No.4; Water jetting to SSPC-SP WJ-4/NACE WJ-4 may be used to remove loose coating and other loose materials. Use inhibitor as recommended by coating manufacturer to prevent premature rusting. Protect shop-coated ferrous surfaces from corrosion by treating and touching up corroded areas immediately upon detection.
- b. Surfaces With More Than 20 Percent Rust, Mill Scale, and Other Foreign Substances: Clean entire surface in accordance with SSPC SP 6/NACE No.3 / SSPC-SP WJ-3/NACE WJ-3SSPC SP 10/NACE No. 2 / SSPC-SP WJ-2/NACE WJ-2.

#### 3.3.2 Final Ferrous Surface Condition:

##### 3.3.2.1 Tool Cleaned Surfaces

Comply with SSPC SP 2 and SSPC SP 3. Use as a visual reference, photographs in SSPC VIS 3 for the appearance of cleaned surfaces.

##### 3.3.2.2 Abrasive Blast Cleaned Surfaces

Comply with SSPC 7/NACE No.4, SSPC SP 6/NACE No.3, and SSPC SP 10/NACE No. 2. Use as a visual reference, photographs in SSPC VIS 1 for the appearance of

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

cleaned surfaces.

### 3.3.2.3 Waterjet Cleaned Surfaces

Comply with SSPC-SP WJ-1/NACE WJ-1, SSPC-SP WJ-2/NACE WJ-2, SSPC-SP WJ-3/NACE WJ-3 or SSPC-SP WJ-4/NACE WJ-4. Use as a visual reference, photographs in SSPC VIS 4/NACE VIS 7 for the appearance of cleaned surfaces.

### 3.3.3 Galvanized Surfaces

- a. New or Existing Galvanized Surfaces With Only Dirt and Zinc Oxidation Products: Clean with solvent, or non-alkaline detergent solution in accordance with SSPC SP 1. Completely remove coating by brush-off abrasive blast if the galvanized metal has been passivated or stabilized. Do not "passivate" or "stabilize" new galvanized steel to be coated. If the absence of hexavalent stain inhibitors is not documented, test as described in ASTM D6386, Appendix X2, and remove by one of the methods described therein.
- b. Galvanized with Slight Coating Deterioration or with Little or No Rusting: Water jetting to SSPC-SP WJ-3/NACE WJ-3 to remove loose coating from surfaces with less than 20 percent coating deterioration and no blistering, peeling, or cracking. Use inhibitor as recommended by the coating manufacturer to prevent rusting.
- c. Galvanized With Severe Deteriorated Coating or Severe Rusting: Water jet to SSPC-SP WJ-3/NACE WJ-3 degree of cleanliness. Spot abrasive blast rusted areas as described for steel in SSPC SP 6/NACE No.3, and waterjet to SSPC-SP WJ-3/NACE WJ-3 to remove existing coating.

### 3.3.4 Non-Ferrous Metallic Surfaces

Aluminum and aluminum-alloy, lead, copper, and other nonferrous metal surfaces.

Surface Cleaning: Solvent clean in accordance with SSPC SP 1 and wash with mild non-alkaline detergent to remove dirt and water soluble contaminants.

## 3.4 PREPARATION OF CONCRETE AND CEMENTITIOUS SURFACE

### 3.4.1 Concrete and Masonry

- a. Curing: Allow concrete, stucco and masonry surfaces to cure at least 30 days before painting, and concrete slab on grade to cure at least 90 days before painting.
- b. Surface Cleaning: Remove the following deleterious substances.
  - (1) Dirt, Chalking, Grease, and Oil: Wash new surfaces with a solution composed of 1/2 cup trisodium phosphate, 1/4 cup household detergent, and 4 quarts of warm water. Then rinse thoroughly with fresh water. For large areas, water blasting may be used.
  - (2) Fungus and Mold: Wash new surfaces with a solution composed of 1/2 cup trisodium phosphate, 1/4 cup household detergent, one quart 5 percent sodium hypochlorite solution and 3 quarts of warm water. Rinse thoroughly with fresh water.

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

(3) Paint and Loose Particles: Remove by wire brushing.

(4) Efflorescence: Remove by scraping or wire brushing followed by washing with a 5 to 10 percent by weight aqueous solution of hydrochloric (muriatic) acid. Do not allow acid to remain on the surface for more than five minutes before rinsing with fresh water. Do not acid clean more than 4 square feet of surface, per workman, at one time.

- c. Cosmetic Repair of Minor Defects: Repair or fill mortar joints and minor defects, including but not limited to spalls, in accordance with manufacturer's recommendations and prior to coating application.
- d. Allowable Moisture Content: Latex coatings may be applied to damp surfaces, but not to surfaces with droplets of water. Do not apply epoxies to damp vertical surfaces as determined by ASTM D4263 or horizontal surfaces that exceed 3 lbs of moisture per 1000 square feet in 24 hours as determined by ASTM F1869. In all cases follow manufacturer's recommendations. Allow surfaces to cure a minimum of 30 days before painting.

### 3.4.2 Gypsum Board, Plaster, and Stucco

#### 3.4.2.1 Surface Cleaning

Verify that plaster and stucco surfaces are free from loose matter and that gypsum board is dry. Remove loose dirt and dust by brushing with a soft brush, rubbing with a dry cloth, or vacuum-cleaning prior to application of the first coat material. A damp cloth or sponge may be used if paint is water-based.

#### 3.4.2.2 Repair of Minor Defects

Prior to painting, repair joints, cracks, holes, surface irregularities, and other minor defects with patching plaster or spackling compound and sand smooth.

#### 3.4.2.3 Allowable Moisture Content

Latex coatings may be applied to damp surfaces, but not surfaces with droplets of water. Do not apply epoxies to damp surfaces as determined by ASTM D4263. Verify that new plaster to be coated has a maximum moisture content of 8 percent, when measured in accordance with ASTM D4444, Method A, unless otherwise authorized. In addition to moisture content requirements, allow new plaster to age a minimum of 30 days before preparation for painting.

### 3.5 PREPARATION OF WOOD AND PLYWOOD SURFACES

#### 3.5.1 New Plywood and Wood Surfaces, Except Floors:

- a. Surface Cleaning: Clean wood surfaces of foreign matter. Verify that surfaces are free from dust and other deleterious substances and in a condition approved by the Contracting Officer prior to receiving paint or other finish. Do not use water to clean uncoated wood. Scrape to remove loose coatings. Lightly sand to roughen the entire area of

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

previously enamel-coated wood surfaces.APPLICATION

### 3.6.1 Coating Application

- a. Comply with applicable federal, state and local laws enacted to ensure compliance with Federal Clean Air Standards. Apply coating materials in accordance with SSPC PA 1. SSPC PA 1 methods are applicable to all substrates, except as modified herein.
- b. At the time of application, paint must show no signs of deterioration. Maintain uniform suspension of pigments during application.
- c. Unless otherwise specified or recommended by the paint manufacturer, paint may be applied by brush, roller, or spray. Use trigger operated spray nozzles for water hoses. Use rollers for applying paints and enamels of a type designed for the coating to be applied and the surface to be coated. Wear protective clothing and respirators when applying oil-based paints or using spray equipment with any paints.
- d. Only apply paints, except water-thinned types, to surfaces that are completely free of moisture as determined by sight or touch.
- e. Thoroughly work coating materials into joints, crevices, and open spaces. Pay special attention to ensure that all edges, corners, crevices, welds, and rivets receive a film thickness equal to that of adjacent painted surfaces.
- f. Apply each coat of paint so that dry film is of uniform thickness and free from runs, drops, ridges, waves, pinholes or other voids, laps, brush marks, and variations in color, texture, and finish. Completely hide all blemishes.
- g. Touch up damaged coatings before applying subsequent coats. Broom clean and clear dust from interior areas before and during the application of coating material.
- g. Piping in Unfinished Areas: Provide primed surfaces with one coat of red alkyd gloss enamel (MPI 9) applied to a minimum dry film thickness of 1.0 mil in attic spaces, spaces above suspended ceilings, crawl spaces, pipe chases, mechanical equipment room, and spaces where walls or ceiling are not painted or not constructed of a prefinished material.
- h. Piping in Finished Areas: Provide primed surfaces with two coats of paint to match adjacent surfaces, except provide valves and operating accessories with one coat of red alkyd gloss enamel (MPI 9) applied to a minimum dry film thickness of 1.0 mil or two component gloss polyurethane (MPI 72) in exterior applications.
- i. Provide labeling on the surfaces of all feed and cross mains to show the pipe function such as "Sprinkler System", "Fire Department Connection", "Standpipe". For pipe sizes 4-inch and larger provide white painted stenciled letters and arrows, a minimum of 2 in in height and visible from at least two sides when viewed from the floor. For pipe sizes less than 4-inch, provide white painted stenciled letters and arrows, a minimum of 0.75 in in height and visible from the floor.
- j. All fire suppression system valves must be marked with permanent tags indicating normally open or normally closed.
- k. Drying Time: Allow time between coats, as recommended by the coating manufacturer, to permit thorough drying, but not to present topcoat adhesion problems. Provide each coat in specified condition to receive next coat.

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

- l. Primers, and Intermediate Coats: Do not allow primers or intermediate coats to dry more than 30 days, or longer than recommended by manufacturer, before applying subsequent coats. Follow manufacturer's recommendations for surface preparation if primers or intermediate coats are allowed to dry longer than recommended by manufacturers of subsequent coatings. Cover each preceding coat or surface completely by ensuring visually perceptible difference in shades of successive coats.
- m. Finished Surfaces: Provide finished surfaces free from runs, drops, ridges, waves, laps, brush marks, and variations in colors.
- n. Thermosetting Paints: Apply topcoats over thermosetting paints (epoxies and urethanes) within the overcoat window recommended by the manufacturer.
- o. Floors: For nonslip surfacing on level floors, as the intermediate coat is applied, cover wet surface completely with almandite garnet, Grit No. 36, with maximum passing U.S. Standard Sieve No. 40 less than 0.5 percent. When the coating is dry, use a soft bristle broom to sweep up excess grit, which may be reused, and vacuum up remaining residue before application of the topcoat.

### 3.6.2 Mixing and Thinning of Paints

Reduce paints to proper consistency by adding fresh paint, except when thinning is mandatory to suit surface, temperature, weather conditions, application methods, or for the type of paint being used. Obtain written permission from the Contracting Officer to use thinners. Verify that the written permission includes quantities and types of thinners to use.

When thinning is allowed, thin paints immediately prior to application with not more than one pint of suitable thinner per gallon. The use of thinner does not relieve the Contractor from obtaining complete hiding, full film thickness, or required gloss. Thinning cannot cause the paint to exceed limits on volatile organic compounds. Do not mix paints of different manufacturers.

### 3.6.3 Two-Component Systems

Mix two-component systems in accordance with manufacturer's instructions. Follow recommendation by the manufacturer for any thinning of the first coat to ensure proper penetration and sealing for each type of substrate.

### 3.6.4 Coating Systems

- a. Systems by Substrates: Apply coatings that conform to the respective specifications listed in the following Tables:

| Table for Exterior Applications |                                            |
|---------------------------------|--------------------------------------------|
| MPI Division                    | Substrate Application                      |
| MPI Division 3                  | Refer to Section 07 19 00 Water Repellents |
| MPI Division 4                  | Refer to Section 07 19 00 Water Repellents |

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

| Table for Exterior Applications |                                                                        |
|---------------------------------|------------------------------------------------------------------------|
| MPI Division 5                  | Exterior Metal, Ferrous and Non-Ferrous Paint Table                    |
| MPI Division 6                  | Exterior Wood; Dressed Lumber, Paneling, Decking, Shingles Paint Table |
| MPI Division 9                  | Exterior Stucco Paint Table                                            |
| MPI Division 10                 | Exterior Cloth Coverings and Bituminous Coated Surfaces Paint Table    |
| Table for Interior Applications |                                                                        |
| MPI Division                    | Substrate Application                                                  |
| MPI Division 3                  | Interior Concrete Paint Table                                          |
|                                 |                                                                        |
| MPI Division 5                  | Interior Metal, Ferrous and Non-Ferrous Paint Table                    |
| MPI Division 6                  | Interior Wood Paint Table                                              |
|                                 |                                                                        |
| MPI Division 9                  | Gypsum Board, Paint Table                                              |

- b. Minimum Dry Film Thickness (DFT): Apply paints, primers, varnishes, enamels, undercoats, and other coatings to a minimum dry film thickness of 1.5 mil each coat unless specified otherwise in the Tables. Coating thickness, where specified, refers to the minimum dry film thickness.
- c. Coatings for Surfaces Not Specified Otherwise: Coat unspecified surfaces the same as surfaces having similar conditions of exposure.

### 3.7 COATING SYSTEMS FOR METAL

Apply coatings of Tables in MPI Division 5 for Exterior and Interior.

- a. Apply specified ferrous metal primer to steel surfaces on the same day that surface is cleaned, to surfaces that meet all specified surface preparation requirements at time of application.
- b. Inaccessible Surfaces: Prior to erection, use one coat of specified primer on metal surfaces that will be inaccessible after erection.
- c. Shop-primed Surfaces: Touch up exposed substrates and damaged coatings to protect from rusting prior to applying field primer.
- d. Pipes and Tubing: The semitransparent film applied to some pipes and tubing at the mill is not to be considered a shop coat. Overcoat these items with the specified ferrous-metal primer prior to application of finish coats.
- e. Exposed Nails, Screws, Fasteners, and Miscellaneous Ferrous Surfaces. On surfaces to be coated with water thinned coatings, spot prime

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

exposed nails and other ferrous metal with latex primer MPI 107.

### 3.8 COATING SYSTEMS FOR CONCRETE AND CEMENTITIOUS SUBSTRATES

Apply coatings of Tables in MPI Division 3, 4 and 9 for Exterior and Interior.

### 3.9 COATING SYSTEMS FOR WOOD AND PLYWOOD

- a. Apply coatings of Tables in MPI Division 6 for Exterior and Interior.
- b. Prior to erection, apply two coats of specified primer to treat and prime wood and plywood surfaces which will be inaccessible after erection.
- c. Apply stains in accordance with manufacturer's printed instructions.

### 3.10 PIPING IDENTIFICATION

Piping Identification, Including Surfaces In Concealed Spaces: Provide in accordance with MIL-STD-101ASME A13.1. Place stenciling in clearly visible locations. On piping not covered by MIL-STD-101ASME A13.1, stencil approved names or code letters, in letters a minimum of 1/2 inch high for piping and a minimum of 2 inches high elsewhere. Stencil arrow-shaped markings on piping to indicate direction of flow using black stencil paint.

### 3.11 FIRE WALL MARKING AND IDENTIFICATION

For other than existing assemblies where there is an accessible concealed floor/ceiling or attic space, fire walls, fire barriers, smoke barriers, and smoke partitions must be permanently identified with an ink roller system within 15 feet of end of each wall, and at intervals not exceeding 30 feet measured horizontally along the wall. Include lettering not less than 3 inches in height with a minimum of 3/8 inch stroke in contrasting color. Identify the fire resistive rating as applicable.

### 3.12 INSPECTION AND ACCEPTANCE

In addition to meeting previously specified requirements, demonstrate mobility of moving components, including swinging and sliding doors, cabinets, and windows with operable sash, for inspection by the Contracting Officer. Perform this demonstration after appropriate curing and drying times of coatings have elapsed and prior to invoicing for final payment.

### 3.13 WASTE MANAGEMENT

As specified in the Waste Management Plan and as follows. Do not use kerosene or any such organic solvents to clean up water based paints. Properly dispose of paints or solvents in designated containers. Close and seal partially used containers of paint to maintain quality as necessary for reuse. Store in protected, well-ventilated, fire-safe area at moderate temperature. Place materials defined as hazardous or toxic waste in designated containers. Coordinate with manufacturer for take-back program. Set aside scrap to be returned to manufacturer for recycling into new product. When such a service is not available, contact local recyclers to reclaim the materials. Set aside extra paint for future color matches or reuse by the Government. Where local options exist for leftover paint recycling, collect all waste paint by type and provide for delivery to recycling or collection facility for reuse by local organizations.

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

### 3.14 PAINT TABLES

All DFT's are minimum values. Use only materials with a MPI GPS-1-14 green check mark having a minimum MPI "Environmentally Friendly" E2 or E3 rating based on VOC (EPA Method 24) content levels. Acceptable products are listed in the MPI Green Approved Products List, available at <http://www.specifygreen.com/APL/ProductIdxByMPInum.asp>.

#### 3.14.1 Exterior Paint Tables

##### 3.14.1.1 MPI Division 3: Exterior Concrete Paint Table

A. Concrete; No Table Refer to Section 07 19 00 Water Repellents.

(1) New concrete; vertical surfaces, including undersides of balconies and soffits but excluding tops of slabs

| Latex                                                                                  |                                |        |              |         |            |
|----------------------------------------------------------------------------------------|--------------------------------|--------|--------------|---------|------------|
| New and uncoated existing                                                              | Existing, previously painted   | Primer | Intermediate | Topcoat | System DFT |
| MPI EXT<br>3.1A-G1 (Flat)                                                              | MPI REX<br>3.1A-G1 (Flat)      | MPI 3  | MPI 10       | MPI 10  | 3.5 mils   |
| MPI EXT<br>3.1A-G2 (Velvet)                                                            | MPI REX<br>3.1A-G2 (Velvet)    | MPI 3  | MPI 214      | MPI 214 | 3.5 mils   |
| MPI EXT<br>3.1A-G5 (Semigloss)                                                         | MPI REX<br>3.1A-G5 (Semigloss) | MPI 3  | MPI 11       | MPI 11  | 3.5 mils   |
| MPI EXT<br>3.1A-G6 (Gloss)                                                             | MPI REX<br>3.1A-G6 (Gloss)     | MPI 3  | MPI 119      | MPI 119 | 3.5 mils   |
| Primer as recommended by manufacturer.<br>Topcoat: Coating to match adjacent surfaces. |                                |        |              |         |            |

##### 3.14.1.2 MPI Division 5: Exterior Metal, Ferrous and Non-Ferrous Paint Table

A. Steel / Ferrous Surfaces

(1) New Steel that has been blast-cleaned to SSPC SP 6/NACE No.3

| Option 1: Alkyd                |                             |        |              |         |            |
|--------------------------------|-----------------------------|--------|--------------|---------|------------|
| New                            | Existing, uncoated          | Primer | Intermediate | Topcoat | System DFT |
| MPI EXT<br>5.1D-G5 (Semigloss) | MPI REX 5.1D-G5 (Semigloss) | MPI 79 | MPI 94       | MPI 94  | 5.25 mils  |

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

|                                              |                            |        |       |       |           |
|----------------------------------------------|----------------------------|--------|-------|-------|-----------|
| MPI EXT<br>5.1D-G6 (Gloss)                   | MPI REX<br>5.1D-G6 (Gloss) | MPI 79 | MPI 9 | MPI 9 | 5.25 mils |
| Topcoat: Coating to match adjacent surfaces. |                            |        |       |       |           |

| Option 2: Pigmented Polyurethane             |         |              |         |            |
|----------------------------------------------|---------|--------------|---------|------------|
| Existing,<br>previously coated<br>with epoxy | Primer  | Intermediate | Topcoat | System DFT |
| MPI REX 5.1H-G6<br>(Gloss)                   | MPI 101 | MPI 108      | MPI 72  | 8.5 mils   |
| Topcoat: Coating to match adjacent surfaces. |         |              |         |            |

B. Exterior Galvanized Surfaces (only where designated as "painted" on Drawings.

(1) New Galvanized surfaces

| Waterborne Primer / Latex                    |         |              |         |            |
|----------------------------------------------|---------|--------------|---------|------------|
| New Galvanized<br>Surfaces                   | Primer  | Intermediate | Topcoat | System DFT |
| MPI EXT<br>5.3H-G1 (Flat)                    | MPI 134 | MPI 10       | MPI 10  | 4.5 mils   |
| EXT 5.3H-G5<br>(Semigloss)                   | MPI 134 | MPI 11       | MPI 11  | 4.5 mils   |
| MPI EXT<br>5.3H-G6 (Gloss)                   | MPI 134 | MPI 119      | MPI 119 | 4.5 mils   |
| Topcoat: Coating to match adjacent surfaces. |         |              |         |            |

| Waterborne Primer / Waterborne Light Industrial Coating |         |              |         |            |
|---------------------------------------------------------|---------|--------------|---------|------------|
| New Galvanized<br>Surfaces                              | Primer  | Intermediate | Topcoat | System DFT |
| MPI EXT<br>5.3J-G5<br>(Semigloss)                       | MPI 134 | MPI 163      | MPI 163 | 4.5 mils   |
| MPI EXT<br>5.3J-G6 (Gloss)                              | MPI 134 | MPI 164      | MPI 164 | 4.5 mils   |
| Topcoat: Coating to match adjacent surfaces.            |         |              |         |            |

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

| Epoxy Primer / Waterborne Light Industrial Coating |         |              |         |            |
|----------------------------------------------------|---------|--------------|---------|------------|
| New Galvanized Surfaces                            | Primer  | Intermediate | Topcoat | System DFT |
| MPI EXT<br>5.3K-G5<br>(Semigloss)                  | MPI 101 | MPI 163      | MPI 163 | 5 mils     |
| MPI EXT<br>5.3K-G6 (Gloss)                         | MPI 101 | MPI 164      | MPI 164 | 5 mils     |
| Topcoat: Coating to match adjacent surfaces.       |         |              |         |            |

| Option 1: Pigmented Polyurethane             |         |              |         |            |
|----------------------------------------------|---------|--------------|---------|------------|
| New Galvanized Surfaces                      | Primer  | Intermediate | Topcoat | System DFT |
| MPI EXT<br>5.3L-G6 (Gloss)                   | MPI 101 | N/A          | MPI 72  | 5 mils     |
| Topcoat: Coating to match adjacent surfaces. |         |              |         |            |

C. Exterior Surfaces, Other Metals (Non-Ferrous) - Only where designated as "Painted" on Drawings.

(1) Aluminum, aluminum alloy and other miscellaneous non-ferrous metal items not otherwise specified except hot metal surfaces, roof surfaces, and new prefinished equipment

| Waterborne Light Industrial Coating          |        |              |         |            |
|----------------------------------------------|--------|--------------|---------|------------|
| New Galvanized Surfaces                      | Primer | Intermediate | Topcoat | System DFT |
|                                              |        |              |         |            |
| MPI EXT<br>5.4F-G5<br>(Semigloss)            | MPI 95 | MPI 163      | MPI 163 | 5 mils     |
| MPI EXT<br>5.4F-G6 (Gloss)                   | MPI 95 | MPI 164      | MPI 164 | 5 mils     |
| Topcoat: Coating to match adjacent surfaces. |        |              |         |            |

(2) Surfaces adjacent to painted surfaces; Mechanical, Electrical, Fire extinguishing sprinkler systems including valves, conduit, hangers, supports, exposed copper piping, and miscellaneous metal items not otherwise specified except floors, hot metal surfaces, and new prefinished equipment

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

| Waterborne Light Industrial Coating                                                    |        |              |         |            |
|----------------------------------------------------------------------------------------|--------|--------------|---------|------------|
| New                                                                                    | Primer | Intermediate | Topcoat | System DFT |
| MPI EXT<br>5.1C-G3 (Eggshell)                                                          | MPI 79 | MPI 161      | MPI 161 | 5 mils     |
| MPI EXT<br>5.1C-G5 (Semigloss)                                                         | MPI 79 | MPI 163      | MPI 163 | 5 mils     |
| MPI EXT<br>5.1C-G6 (Gloss)                                                             | MPI 79 | MPI 164      | MPI 164 | 5 mils     |
| Primer as recommended by manufacturer.<br>Topcoat: Coating to match adjacent surfaces. |        |              |         |            |

### 3.14.2 Interior Paint Tables

#### 3.14.2.1 MPI Division 3: Interior Concrete Paint Table

##### A. New Concrete, vertical surfaces, not specified otherwise

| Institutional Low Odor / Low VOC Latex       |                                    |         |              |         |            |
|----------------------------------------------|------------------------------------|---------|--------------|---------|------------|
| New, uncoated<br>Existing                    | Existing,<br>previously<br>painted | Primer  | Intermediate | Topcoat | System DFT |
| MPI INT<br>3.1M-G2 (Flat)                    | MPI RIN 3.1L-G2<br>(Flat)          | MPI 149 | MPI 144      | MPI 144 | 4 mils     |
| MPI INT<br>3.1M-G3<br>(Eggshell)             | MPI RIN 3.1L-G3<br>(Eggshell)      | MPI 149 | MPI 145      | MPI 145 | 4 mils     |
| MPI INT<br>3.1M-G4 (satin)                   | MPI RIN 3.1L-G4                    | MPI 149 | MPI 146      | MPI 146 | 4 mils     |
| MPI INT<br>3.1M-G5<br>(Semigloss)            | MPI RIN 3.1L-G5<br>(Semigloss)     | MPI 149 | MPI 147      | MPI 147 | 4 mils     |
| Topcoat: Coating to match adjacent surfaces. |                                    |         |              |         |            |

##### E. New concrete floors:

| Epoxy                      |                                    |        |              |         |            |
|----------------------------|------------------------------------|--------|--------------|---------|------------|
| New, uncoated<br>Existing  | Existing,<br>previously<br>painted | Primer | Intermediate | Topcoat | System DFT |
| MPI INT<br>3.2C-G6 (Gloss) | MPI RIN 3.2C-G6<br>(Gloss)         | MPI 77 | MPI 77       | MPI 77  | 5 mils     |

P2#: 513392, YARS FIRE STATION  
AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

Note: Primer may be reduced for penetration per manufacturer's instructions.

### 3.14.2.2 MPI Division 4: Interior Concrete Masonry Units Paint Table

#### A. New Concrete Masonry

| Institutional Low Odor / Low VOC Latex |        |        |              |         |            |
|----------------------------------------|--------|--------|--------------|---------|------------|
| New, uncoated<br>Existing              | Filler | Primer | Intermediate | Topcoat | System DFT |
| MPI INT<br>4.2E-G2 (Flat)              | MPI 4  | N/A    | MPI 144      | MPI 144 | 4 mils     |
| MPI INT<br>4.2E-G3<br>(Eggshell)       | MPI 4  | N/A    | MPI 145      | MPI 145 | 4 mils     |
| MPI INT<br>4.2E-G4 (Satin)             | MPI 4  | N/A    | MPI 146      | MPI 146 | 4 mils     |
| MPI INT<br>4.2E-G5<br>(Semigloss)      | MPI 4  | N/A    | MPI 147      | MPI 147 | 4 mils     |
| Fill all holes in masonry surface      |        |        |              |         |            |

### 3.14.2.3 MPI Division 9: Interior Plaster, Gypsum Board, Textured Surfaces Paint Table - Only where designated as "Painted" on Drawings.

#### A. Interior New and Existing, previously painted not otherwise specified

| Latex                                        |                                    |        |              |         |            |
|----------------------------------------------|------------------------------------|--------|--------------|---------|------------|
| New                                          | Existing,<br>previously<br>painted | Primer | Intermediate | Topcoat | System DFT |
| MPI INT<br>9.2A-G2 (Flat)                    | RIN 9.2A-G2<br>(Flat)              | MPI 50 | MPI 44       | MPI 44  | 4 mils     |
| MPI INT<br>9.2A-G3<br>(Eggshell)             | RIN 9.2A-G3<br>(Eggshell)          | MPI 50 | MPI 52       | MPI 52  | 4 mils     |
| MPI INT<br>9.2A-G5<br>(Semigloss)            | RIN 9.2A-G5<br>(Semigloss)         | MPI 50 | MPI 54       | MPI 54  | 4 mils     |
| Topcoat: Coating to match adjacent surfaces. |                                    |        |              |         |            |

| High Performance Architectural Latex - High Traffic Areas |                                    |        |              |         |            |
|-----------------------------------------------------------|------------------------------------|--------|--------------|---------|------------|
| New                                                       | Existing,<br>previously<br>painted | Primer | Intermediate | Topcoat | System DFT |

P2#: 513392, YARS FIRE STATION  
 AIR FORCE RESERVE BASE, YOUNGSTOWN, OH

|                                              |                                |        |         |         |        |
|----------------------------------------------|--------------------------------|--------|---------|---------|--------|
| MPI INT<br>9.2B-G2 (Flat)                    | MPI RIN 9.2B-G2<br>(Flat)      | MPI 50 | MPI 138 | MPI 138 | 4 mils |
| MPI INT<br>9.2B-G3<br>(Eggshell)             | MPI RIN 9.2B-G3<br>(Eggshell)  | MPI 50 | MPI 139 | MPI 139 | 4 mils |
| MPI INT<br>9.2B-G5<br>(Semigloss)            | MPI RIN 9.2B-G5<br>(Semigloss) | MPI 50 | MPI 141 | MPI 141 | 4 mils |
| Topcoat: Coating to match adjacent surfaces. |                                |        |         |         |        |

-- End of Section --

P2#: 513392, YARS FIRE STATION  
AIR PORCE RESERVE BASE, YOUNGSTOWN, OH

## SECTION 27 20 00

### FIREFIGHTER ALERT SYSTEM

07/24

Amdt. #0004

#### PART 1 GENERAL

##### 1.1 OVERVIEW

This specification is for a Fire Station Alerting system to be installed in one or more fire stations. This new system shall be capable of interfacing to, and receiving alerts from a data network, radio network, and two-tone paging system. The system shall be based on standard EIA/TIA 568-B Category 6 data network cabling and RJ-45 Data connectors it shall be installable by a low voltage-cabling contractor. Note: Do not use Copper Clad Aluminum wire (CCA) due to this wire causes poor data connectivity. The alerting system shall accommodate connections to systems such as lighting control, telephone paging, voice radios, doorbell buttons, and other devices. These systems and their installation will be specified in other sections and provided by the owner or other trades.

##### 1.2 SECTION INCLUDES:

Fire Station Alerting system equipment with a station controller along with an optional Expansion Unit installed in a central location and peripherals consisting of Room Remotes, Message Remotes and BetaBrite message signs, Sign Remotes, Gamma Signs, Room Remote 2 (RR2), Color Indicator Remote, I/O Remotes, HDTV Remotes, other Peripherals, audio amplifiers, and speakers located throughout the Fire Station.

##### 1.3 QUALIFICATIONS

- A. Certified low-voltage system installer.
- B. Applicable state licenses.
- C. Certificate of successful completion of manufacturer's installation/training training for the equipment being proposed.

##### 1.4 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Shop Drawings; G

SD-03 Product Data

Product Data; G

SD-05 Design Data

Design Data; G

P2#: 513392, YARS FIRE STATION  
AIR PORCE RESERVE BASE, YOUNGSTOWN, OH

SD-06 Test Reports

Test Reports; G

SD-10 Operation and Maintenance Data

Maintenance Manuals; G

SD-11 Closeout Submittals

As-built Drawings; G

1.5 RELATED WORK PROVIDED IN OTHER SPECIFICATION SECTIONS

1.5.1 Unless noted otherwise, the following work is to be provided under other specification sections:

1. Installation of conduits, raceways and electrical junction boxes.
2. 120 VAC power wiring and outlets.
3. Overhead lighting.
4. Rough openings and framing for equipment cabinets and Peripherals.

1.6 System Description

System hardware shall consist of a station alerting controller and possible Expansion Module and multiple peripheral units. These peripherals shall be one or more Message Remotes with message signs, Room Remote, Sign Remotes, Color Indicator Remotes, HDTV Remotes and I/O Remotes. System speakers shall be standard audio output for non-lighted applications, red illuminated speakers for lighted applications, and weatherproof speakers for apparatus bay and outside applications.

B. All necessary equipment required meeting the intent of these specifications, whether or not enumerated within these specifications, shall be supplied and installed to provide a complete and operating fire station alerting system.

C. System firmware shall be the product of the station alerting system manufacturer with sole control over revisions and/or changes. Manufacturer shall provide, free of charge, product firmware/software upgrades for a period of one year from date of installation for any product feature enhancements. System firmware upgrades shall not require any exchange of parts and shall be capable of being executed via a laptop computer connection, a web browser, and the SSL protocol.

PART 2 PRODUCTS

2.1 MANUFACTURERS

The products specified shall be new and of the standard manufacture of a single reputable manufacturer.

2.2 CABLING

Cabling shall be in strict accordance with local codes and to the cable specifications found in the manufacturer's installation manual.

All peripheral network cabling shall be ANSI/EIA/TIA-568 Category 6 UTP plenum rated cable run as shown on drawings. Cable jacket shall be YELLOW in color. Use RJ-45 Data connectors. Certification documents shall be provided

P2#: 513392, YARS FIRE STATION  
AIR PORCE RESERVE BASE, YOUNGSTOWN, OH

for all cabling runs. Note: Do not use Copper Clad Aluminum wire (CCA).

Message remote to message sign data cable shall be flat grey 6 conductors telephone device cable with 6 conductor modular plugs attached on both ends. Wiring shall be straight through. Wiring should be supplied with the message sign.

All speaker cabling shall be Plenum rated 18 gauge, 4 conductor stranded jacketed cable. 18 gauge, 2 conductors stranded jacketed can be used just for the Audio portion or just for the LED portion.

## 2.3 SYSTEM PARTS

**Amdt. #0004\*\*\*\*\***

### 2.3.1 Fire Station Controlling Equipment

Furnish a Fire Station Alerting Controller that is rack-mounted. Each unit shall have the following features built into a single cabinet:

- A. Fire Station Controller
- B. 3 Configurable Audio Inputs and Audio Switching System
- C. 8 Port Power Audio Ethernet Mixer (POE ports)
- D. 4 x 20 Watt Audio Amplifiers
- E. **24 or** 48 vdc low-voltage lighting control
- F. 3 Auxiliary Inputs and 4 Relay Outputs
- G. Touchscreen Industrial Computer with Customer Network (WAN) connection. COM1 Serial connection for Data Radio

**\*\*\*\*\*Amdt. #0004**

### 2.3.2 Message Remote

Furnish as shown on plans, Message Remote capable of the following functions:

- A. Has 2 Channels
- B. Each Channel can Power/Control a message sign, 8 ohm speaker connection, 70V speaker connection and Speaker LED Light connection.
- C. Each Channel 70V speaker connection has a 15 Watt Audio Amplifier.
- D. Lighting Control
- E. Panel or wall-mountable
- F. Single cable connection
- G. Each Channel has 1 Dry contact Input and 1 Dry contact output NO relay.
- H. 8 Ohm speaker connection must be used with an 8ohm/70V Transformer.

**Amdt. #0004\*\*\*\*\***

### 2.3.3 Room Remote (RR)

Furnish as shown on plans, Room Remote's capable of the following functions:

- A. Integrated Message Display.
- B. 10 Watt Audio Amplifier, 1- Line Level Audio OUT, 1-8 ohm Audio OUT and 1-70V Audio OUT
- C. Lighting Control **+24 or** +48VDC output for Speaker LED Lights
- D. 1 Dry Contact Input and 1 Relay Output
- E. Flush or surface mountable.
- F. Single CAT 6 cable POE IN connection and CAT 6 POE OUT connection (for daisy-chain configuration)

P2#: 513392, YARS FIRE STATION  
AIR PORCE RESERVE BASE, YOUNGSTOWN, OH

\*\*\*\*\*Amdt. #0004

#### 2.3.4 HDTV Remote

Furnish as shown on plans, HDTV Remotes capable of the following functions:

- A. Network connection to Station Alerting Controller
- B. HDMI Output to video display
- C. Integrated Alert Message and Turnout Timer display

#### 2.3.5 Color Indicator Remote

Furnish as shown on plans, Color Indicator Remote capable of the following functions:

- A. Power and network connection to Station Alerting Controller
- B. Built-in Ethernet switch to allow up to 3 Color Indicator Remotes to be daisy-chained
- C. 8 Color LED Indicator Display

#### 2.3.6 Speaker Systems

Speaker systems shall be either 8 ohm or 70 volt, as per design documents. Speakers shall be grouped into "areas" of similar sound level and unit alerting requirements.

#### 2.3.7 Hallway/Room Speaker

Speakers may be provided by Alerting System manufacturer, or contractor. Check with System manufacturer for details.

Speakers can be audio only or include a red light visual component, see plans for application uses.

For suspended ceiling applications, provide appropriate speaker support tile bridge. For hard ceiling applications provide appropriate speaker back box.

#### 2.3.8 Apparatus Room and Outdoor Speaker

Provide loudspeakers as shown on plan. Available tap settings are 4W, 8W or 16W. They can be tied into the Station Controller 70V Speaker Output Audio Zones or connected through an amplifier.

Amdt. #0004\*\*\*\*\*

#### 2.3.9 LED Lighted Speaker

Provides low-voltage LED lighted speakers as noted on drawings along with Audio. This low-voltage lighting shall be **+24 or +48 VDC** connected to the Station Controller **24V or 48V LED Light Outputs** zones or **+24 or +48vdc** output connections on system peripherals that support that function.

\*\*\*\*\*Amdt. #0004

P2#: 513392, YARS FIRE STATION  
AIR PORCE RESERVE BASE, YOUNGSTOWN, OH

### 2.3.10 External Audio

Furnish as shown on plans

- A. Has an Audio Line Level Input from the Station Controller.
- B. Has a 70V audio output for App Bay speakers.

**Amdt. #0004**\*\*\*\*\*

### 2.3.11 LED Strobe Light

Provide low-voltage Strobe Light as noted on drawings. This low-voltage Strobe Light shall be **24 or 48 VDC**.

\*\*\*\*\***Amdt. #0004**

## 2.4 SYSTEM DIAGNOSTICS

A. All active components in the system shall be continuously supervised for both power and data to ensure proper operation and in the case of system faults to aid in troubleshooting.

B. All faults shall be displayed immediately on the associated Communications Gateway.

## PART 3 EXECUTION

### 3.1 SUPERVISION

Only factory trained installers shall install, service, and maintain the specified system.

### 3.2 ROUGH OPENINGS

A. The Station Alerting Controller only requires a rough opening if mounted exposed in a 19" rack cabinet. The controller is normally surface wall mounted.

B. Room Remote (RR) - For Flush mount option a 4 Gang Box using a rough opening of 2 ¾" H x 7 3/8" W. Installers must note on their station walk through if the RR2 will be a Surface or Flush mount application. Maximum high side reach allowed shall be 64" AFF, typical height shall be +48" AFF. Consult with manufacturer on installation instructions.

Color Indicator Remote (CIR) - For Flush/Wall mount a standard 4 Gang box is used. If installing into drop ceiling tiles a tile bridge and 4 Gang box will need to be used. Consult with manufacturer on installation instructions.

C. Provide access hatches in finished drywall ceiling areas where access is restricted to devices mounted above ceiling.

### 3.3 WIRING

A. All peripheral network cables terminate on patch panel located in the Station Controller Cabinet and on a single telecommunications outlet on the peripheral end.

Use RJ-45 Data Connectors. NOTE: DO NOT USE EZ-RJ45 Style Connectors due to it causes poor data connectivity and shorting in the connection point.

P2#: 513392, YARS FIRE STATION  
AIR PORCE RESERVE BASE, YOUNGSTOWN, OH

B. All speaker cabling shall be Plenum rated 18 gauge, 4 conductor stranded, jacketed cable. 2 conductors GRN/WHT for Audio speaker portion and 2 conductors Red/BLK for LED lighted speaker portion. 18 gauge, 2 conductor stranded jacketed cable can be used just for the Audio portion or just for the LED portion. Speaker runs that home run back to Station Controller cabinet are noted on plans.

C. Contractor shall terminate Category 6 cable on manufacturer-approved connectors, and shall test and certify all connections to Cat 6 standards. Provide all cabling test certifications after testing.

D. All wiring shall be free from shorts and faults. Wiring shall be UL listed, NEC and NFPA 70, Article 25 approved.

E. Message Sign cabling to Message Remote shall be 6 conductors flat "silver satin" type cable or equivalent. Terminate both ends with 6 conductor modular plugs utilizing straight thru wiring (DO NOT turn over conductors). Message Sign to Message Remote cabling shall not be longer than 25 feet to observe proper serial operation.

F. Message Remote with speakers attached will need an 8ohm/70V transformer inline with the Audio connection only, wire to the LED Lights is separate. Transformer plate will indicate where wire connects to the device and speaker. For a Room Remote (RR) the speaker audio and LED lights will be connected on the backside of the device, no 8ohm/70V transformer is needed with a RR2.

H. Label both ends of all network cabling and the Station Controller Cabinet end of all speaker and lighting cables. Label patch panels in the Station Controller location.

### 3.4 OUTLET BOXES AND CONDUIT

General - Provide pull string in all empty conduit installed in this section. Label conduit ends with conduit usage when practical.

A. Message Remote - In suspended ceiling locations, provide 4" metal J-box with mud ring, as indicated, above finished ceiling. Stub up 3/4" empty conduit from each Message Remote J-box to nearest accessible ceiling, cable tray, or other location as shown. In hard ceiling locations, locate J- box at nearest accessible ceiling location.

Provide 4" metal J-box with duplex mud ring as indicated for each associated message sign at +7'6" AFF typical (+13' AFF for apparatus bay). Center J-box above doorways and align with other architectural features as directed. Orient mud ring opening horizontally. Provide 3/4" empty conduit between the Message Remote J-box and each of the associated message sign J-boxes (maximum of two). Provide duplex stainless steel J-box covers with 3/4" dia. hole centered in the cover with a bushing for all junction boxes.

B. Double-sided Message Remote - Provide 4" metal J-box with mud ring, as indicated, on wall behind sign mounting location. Stub up 3/4" empty conduit from J-box to nearest accessible ceiling, cable tray, or other location as shown. Provide suitable mounting (3/4" plywood typical) behind drywall surface for mounting Double-sided Message Remote bracket. NOTE: The mounting bracket must support the entire weight of the Message Remote and attached signs.

P2#: 513392, YARS FIRE STATION  
AIR PORCE RESERVE BASE, YOUNGSTOWN, OH

D. Room Remote (RR) - Provide a 4 Gang Steel or Plastic Box, the opening of these boxes should be at least 2 ¾" H x 7 3/8" W don't exceed these dimensions, measure boxes to be certain. 3/4" empty conduit from the Box to nearest accessible ceiling, cable tray, or as shown on drawings. Box opening to be located +48" AFF typical and no more than +64" AFF.

E. Ceiling Speakers (Hard Ceiling) - Provide Ceiling Speaker Enclosures in all hard ceiling applications. Provide 3/4" empty conduit to enclosure and run to nearest accessible ceiling location, cable tray or equipment as shown. Conduit shall also be used to interconnect with other enclosures as shown on construction drawings.

F. Ceiling Speakers (Suspended Ceiling) - Provide Ceiling tile Bridge as appropriate for specified speakers. Provide ceiling speaker enclosures as required by specifying engineer or client.

G. Apparatus Bay and Outside Speakers - Provide 4" metal J-box with mud ring and cover at each speaker location with 3/4" empty conduit to Message Remote or other location as indicated. Provide a 3/4" dia. hole centered in the J-box cover with a bushing to allow speaker cable to run to speaker. Apparatus bay speakers are typically located +13' to +15' AFF, outside speakers are typically located +11' AFF. Other heights as noted on drawings.

### 3.5 SPEAKERS

A. Ceiling Speakers (Suspended Ceiling) - Install speakers through ceiling tiles and tile bridge per manufacturer's specifications. Connect speakers to Room Remotes and Message Remotes as shown. If noted for a 8 ohm speaker systems require that the 70 volt transformer be bypassed by the installer. All 8 ohm speakers shall be installed using parallel or series/parallel connections with no less than 4 ohms impedance. Otherwise connected the 70V speaker to it's corresponding audio wattage setting for 1 watt 70V system.

B. Ceiling Speakers (Hard Ceiling) - Install speakers into enclosures and connect to Room Remotes or Message Remotes as shown.

C. Apparatus Bay Speakers - Install speakers on walls or structures per the manufacturer's specifications. Connect speakers to Station Controller, External Amplifiers or Message Remotes amplifier via cable in conduit as shown. Dress cabling neatly to minimize visibility.

D. Exterior Speakers - Install speakers to structure per manufacturer's specifications. Connect speakers to correct Message Remote amplifier as shown. Provide cable boot and install drip loop in cable prior to entry into J-box. Seal entry using appropriate sealant.

### 3.6 EQUIPMENT MOUNTING

All equipment mounted to drywall shall use appropriate fasteners and drywall anchors. Equipment shall not be directly screwed into drywall using unapproved fasteners such as drywall or wood screws. Must use Toggle bolts when hanging the Station Controller/Expansion Module to the wall surface. If securing it to wood use proper size lag bolts to support 50lbs or greater.

P2#: 513392, YARS FIRE STATION  
AIR PORCE RESERVE BASE, YOUNGSTOWN, OH

### 3.7 ELECTRICAL POWER CONNECTIONS

A. It shall be the responsibility of other trades to provide the appropriate number of dedicated 120 VAC, 20A duplex outlets into the equipment cabinet rough opening. This power feed shall not have any other devices connected directly to it and shall be labeled "Station Alerting". This electrical circuit shall be connected to the fire station's emergency power system for automatic power provision during loss of utility power.

B. Connect all system power supplies and equipment cabinets to a common earth ground utilizing a 14 AWG, or larger, solid conductor which is at minimum the same conductor size as the AC feed wires.

### 3.8 ENVIRONMENTAL PROTECTION

Make certain that all central equipment is accessible for service. Contractor shall notify specifying authority if designated equipment closet does not meet manufacturer's requirements for heat, radiation or static electricity.

### 3.9 CONNECTIONS TO OTHER EQUIPMENT

A. Lighting Controller (optional) - Connect low voltage dry contact lighting controls (provided by others) to Room Remote, Message Remote or Station Controller outputs. Low voltage outputs are non-inductive load, 24VDC 1A maximum. Provide an interposing relay or contactor between the low voltage output and any 120/277 VAC lighting or other load.

B. Local Area Network - Connect the Fire Station Controller to the general purpose LAN (provided by others) located in the Fire Station. This connection shall be connected back to the central Communications Gateway to allow alerting commands to be sent from the Communications Gateway to the Fire Station Controller. In addition, the connection shall allow remote diagnostics and configuration.

C. Radio System - Connect Audio Input #1 to the dispatch voice radio system (provided by others) as necessary to provide dispatch audio. This connection shall provide a 600 ohm impedance 0 dBm level signal.

D. Telephone System Intercom (optional) - Connect Audio Input #3 to an Intercom output from the building telephone system (provided by others). This line shall be provided via a jack box located directly adjacent to the Station Alerting system equipment.

E. Other Audio Source - Connect Audio Input #4 to an audio source (provided by others). This line shall be provided via a jack box located directly adjacent to the Station Alerting system equipment.

F. Telephone System Ringdown (optional) - Connect the Ring Detector input to a telephone line (provided by others) for telephone ringing and backup alerting. This line shall be provided via a jack box located directly adjacent to the Station Alerting equipment.

G. Connections to other customer- or contractor-provided equipment shall be made using approved methods for the type of connection. Contact manufacturer for unusual applications.

### 3.10 DRAWINGS

Provide as-built drawings of all installed components and associated wiring on building plans.

-- End of Section --