

**JUSTIFICATION FOR SOLE SOURCE
(Simplified Procedures - MPT to ≤ SAT)**

Purchase Request/Document number: 1301348760

The supplies or services described herein are being solicited on a *sole source* basis and competition is precluded in accordance with *FAR 12.102(a)* for reasons indicated below. There are no substitutes available for the supplies or services.

Restricted to the following source. (Check One)

☒ **Service:**

Contractor:	Vertiv Corporation
Cage Code:	1EDC2

☐ **Supply:**

Original Manufacturer Name:	
☐ Check here if obtaining product through authorized resellers of the manufacturer.	

Description of the supplies or services required, the estimated price/cost, and required delivery date or period of performance.

The purpose of the proposed acquisition is to secure system support (power ups and power downs) and essential UPS capacitor and fans replacements in support of the Commander, Undersea Surveillance.

The contractor will provide system support and replace the following components:

Tag #	Description	Model #	Part Number	
1664259	"FANS NXL250-400WSTC"	40SA300AAAAA 17H	FANSNXLAWS TC	
1664259	"ALL AC-DC CAPS NXL250-400WSTC"	40SA300AAAAA 17H	ACDCCAPNXLA WSTC	
1664259	UPS unit power down and up	40SA300AAAAA 17H	N/A	

Labor quotation to UPS Shutdown / Restart up under Instance# 1664259. This cannot be done by NAVFAC to support MILCON P-160 this equipment was purchased by Commander, Undersea Surveillance for a mission set.

Fan/Blower Replacement Service

1. Check all nuts, bolts, screws, and connections for heat discoloration.

2. Verify new fans/blowers prior to installation.
3. Clean fan/blower assembly area of all dirt and debris.
4. Inspect wiring for loose connections and heat discoloration. Replace, if necessary.
5. Ensure all fan connections are properly done and mechanical connections properly torqued.
6. Dispose of removed fans/blowers (upon request and at time of service).
7. Review system performance with customers to address any system questions

DC Capacitor and Fan Replacement Service

1. Check all nuts, bolts, screws, and connectors for tightness and heat discoloration.
2. Verify new capacitor values prior to installation.
3. Clean capacitor decks and buss bars of all dirt, debris, and/or leakage.
4. Record AC ripple voltage and current before, and after, capacitor replacement.
5. Replace DC buss filter capacitors.
6. Inspect DC capacitor wiring for loose connections and heat discoloration. Replace, if necessary.
7. Ensure all capacitor connections are properly torqued.
8. Record new capacitor date codes.
9. Install new DC capacitors.
10. Perform thermal scan of capacitor decks and connections.
11. Dispose of removed capacitors (upon request and at time of service).
12. Review system performance with customer to address any system question

Period of Performance: 07 September 2026 – 06 September 2027

In conclusion, the requested supplies or services represent the minimum requirements of the government.

Describe in detail why only this source(s) can furnish the requirements to the exclusion of other sources. For example, what specific characteristics of the supplies or services limit the availability to a sole source (e.g., unique features, function of the item, etc.)? The following are provided as potential examples of reasons to support soliciting from a single source. If these items do not apply, the check-a-blocks may be deleted from the document. The user should include the appropriate rationale for the selected item(s). Modify accordingly for brand name justifications or for other circumstances of the contract action that deem only one source reasonably available (e.g. urgency).

Vertiv Corporation is the Original Equipment Manufacturer (Manufacturer) and the sole authorized service provider for the Liebert power product line, including the Uninterruptible Power Supply (UPS), static transfer switches, and power distribution units. To maintain equipment integrity, performance, and long-term reliability, the system requires genuine OEM parts (capacitors and fans). Utilizing a non-OEM source would risk hardware incompatibility, and compromise the engineering specifications of the critical power infrastructure.

☒ *The supplies or services must be compatible in all aspects (form, fit and function) with existing systems presently installed/performing. Describe the equipment/function you have now and how the new item/service must coordinate, connect, or interface with the existing system.*

To meet the requirement for compatibility in form, fit, and function, the new capacitors and fans must be identical to the original components within the existing Vertiv/Liebert UPS system to ensure seamless physical integration and operational safety. These parts are engineered to meet the exact dimensions and

proprietary electrical connection points of the UPS cabinet, allowing them to interface directly with internal wiring harnesses and logic boards without modification. Because these components perform critical voltage-filtering and thermal-management roles, utilizing non-OEM parts would risk hardware incompatibility, and potentially trigger system-wide faults. This integration is essential to maintaining the technical integrity of the system and ensures that all replacement hardware remains fully compatible with the diagnostic monitoring and specialized maintenance already being performed by Vertiv under contract N0018924P0220.

☒ *A patent, copyright or proprietary data limits competition.*

Vertiv Customer Engineers (CEs) are the only authorized, factory- trained and OEM-supported service providers for Vertiv equipment with access to Vertiv’s proprietary service tools and software to ensure optimal equipment performance.

Using proprietary software PPvis™, Paramset™, and WinSVT™ CEs apply Vertiv’s knowledge base to diagnose, configure and optimize the Vertiv equipment.

Vertiv is the only authorized source for critical proprietary firmware updates providing the equipment with the latest version of operational firmware to ensure equipment is running at optimal performance and efficiency levels.

Vertiv exclusively enables:

Access to OEM engineering support and product enhancements.

Optimized methods of procedure for efficient service supported by proprietary documentation.

Improved MTBR and MTTR.

Root cause forensic analysis.

Continual improvements with tested and certified updates for software and hardware improvements throughout the equipment’s lifecycle.

CEs to be equipped with proprietary service documentation that provides access to the latest method of procedures and event data to return equipment online in the most efficient manner possible.

Other information to support a sole source <or brand name> action: N/A

TECHNICAL/REQUIREMENTS CERTIFICATION:

I CERTIFY THAT THE INFORMATION PROVIDED ABOVE IS COMPLETE AND ACCURATE TO THE BEST OF MY KNOWLEDGE. I UNDERSTAND THAT THE PROCESSING OF THIS <SOLE SOURCE OR BRAND NAME> JUSTIFICATION PRECLUDES THE USE OF FULL AND OPEN COMPETITION.

