

This report is powered by Xaap, the Building Compliance Reporting Platform used by Johnson Controls.



See how your organization can leverage this smart technology for your internal inspections

Visit info.jci.com/xaap-tjc To Learn More

Johnson Controls is committed to serving our customers with the best-in-class services and technologies. Xaap is an advanced inspection reporting application that has been used by Johnson Controls on your inspections.

Xaap is a software-as-a-service (SaaS) solution that provides a streamlined and digitized approach for performing fire and life safety inspections and managing compliance reports in a single, centralized platform. The application allows inspectors to capture data for fire and life safety systems and devices while generating the required compliance reports directly from their phones. It also provides facility managers, building managers and key stakeholders with a centralized view of all building systems and deficiency data. Users can easily access, download and share historical inspection reports through Xaap.

[This Page Intentionally Left Blank]

Inspection Summary

Customer Information

Name VA Medical Center

Building Information

Name VA Medical Center

Address 1826 Veterans Blvd, Dublin, GA 31021

Contact Information

Name Daniel DiMartino

Role Monitoring Organization

E-Mail Daniel.dimartino2@va.gov

Phone 4783044664

Account Information

Service Provider Johnson Controls North America

Office Address 50 Technology Drive, Westminster, MA, US, 1441

Office Phone 470-214-7160

Office License

Inspector Name David Mills

Inspector License 4205XHP

Inspection Information

Start Date 10/08/2025

Date 10/08/2025

Inspection Type Joint Commission

Work Order# 59851798

Timezone GMT-04:00

Inspection Summary

The following Tests and Inspections have been covered in this inspection

[EP 13 - Kitchen auto extinguishing systems](#)

DEVICE DEFICIENCIES

No device deficiencies in this inspection.

INSPECTION RESULTS SUMMARY

		CURRENT INSPECTION RESULTS					PREVIOUS INSPECTION RESULTS
TEST PERFORMED	DEVICE TYPE	TOTAL	PASSED	FAILED	CANNOT INSPECT	% INSPECTED	TOTAL
EP13	Kitchen Hood Appliance	10	10	0	0	100	10
EP13	Kitchen Hood System	6	6	0	0	100	6
	TOTAL	16	16	0	0	100	16

KITCHEN AUTO EXTINGUISHING SYSTEMS

CUSTOMER NAME: VA Medical Center
BUILDING NAME: VA Medical Center
BUILDING ADDRESS: 1826 Veterans Blvd, Dublin, GA 31021
CONTACT NAME: Daniel DiMartino
CONTACT E-MAIL: Daniel.dimartino2@va.gov
CONTACT ROLE: Monitoring Organization
CONTACT PHONE: 4783044664

SERVICE PROVIDER: Johnson Controls North America
OFFICE PHONE: 470-214-7160
INSPECTOR: David Mills
INSPECTOR LICENSE: 4205XHP
INSPECTION START DATE: 10/08/2025
INSPECTION END DATE: 10/08/2025
WORK ORDER: 59851798
TIMEZONE: GMT-04:00

INSPECTION RESULTS SUMMARY

DEVICE TYPE	CURRENT INSPECTION RESULTS					PREVIOUS INSPECTION RESULTS
	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT	% INSPECTED	INVENTORY COUNT
Kitchen Hood System	6	6	0	0	100	6
Kitchen Hood Appliance	10	10	0	0	100	10

DEVICE DEFICIENCIES

No device deficiencies in this inspection.

RETIRED DEVICES

No retired devices in this inspection.

Elements of Performance #13

Every 6 months the facility tests all automatic fire extinguishing systems for the Kitchen Hoods. The completion date of the tests is documented.

Note: Discharge of the fire-extinguishing system is not required.

Automatic Kitchen Hood Systems

For additional guidance on performing the tests, see NFPA 96-2011: 11.2

Test Method

An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons.

All actuation components, including remote manual pull stations, mechanical or electrical devices, detectors, actuators, and fire-actuated dampers, shall be checked for proper operation during the inspection in accordance with the manufacturer's listed procedures.

Fusible links (including fusible links on fire damper assemblies) and automatic sprinkler heads shall be replaced at least annually or more frequently if necessary where required by the manufacturer.

Other detection devices not including fusible links and automatic sprinklers shall be serviced or replaced in accordance with the manufacturer's recommendations.

Where automatic bulb-type sprinklers or spray nozzles are used and annual examination shows no buildup of grease or other material on the sprinkler or spray nozzles, annual replacement shall not be required.

System Information							
LOCATION	DESCRIPTION	BARCODE	MANUFACTURER	MODEL	SERIAL NUMBER	SERVICE TYPE	SIZE
	Building 85	—	Ansul 1.5 gallon	—	288140	Electric	N/A
FUEL SHUT OFF TYPE		FUEL SHUT OFF 'ON'	360 FUSIBLE LINK	450 FUSIBLE LINK	500 FUSIBLE LINK	OTHER FUSIBLE LINK	# LINKS CHANGED THIS SERVICE
Electric Shunt Trip		Yes	1	N/A	N/A	N/A	1
Ventilation Equipment Information							
HOOD SIZE		PLENUM SIZE		FILTER TYPE		FILTER SIZE	
48x48		12x10		Baffle		19.5 x19.5	
SIZE OF DUCT #1		SIZE OF DUCT #2		SIZE OF DUCT #3		SIZE OF DUCT #4	
12x20		N/A		N/A		N/A	

Cooking Appliance Locations							
LOCATION	DESCRIPTION	Appliance Type	APPLIANCE SIZE	FUEL SOURCE	APPLIANCE COVERAGE	NOZZLE TYPE	NOZZLE QUANTITY
—	Building 85	Range	36x36	Electric	Pass	230	2

Maintenance Items	Results
How many 360 degree Thermal Detectors?	N/A
How many 600 degree Thermal Detectors?	N/A
Thermal Detectors Tested	N/A
All appliances properly protected with correct nozzles?	Yes
Duct and plenum protected with correct nozzles?	Yes
All nozzles properly aimed at hazard/unobstructed?	Yes
Proper separation between fryer(s) and open flame?	Yes
Nozzle blow-off caps installed (replace if needed)	Yes
Hood & duct penetrations sealed with weld or UL device?	Yes
Check cartridge weight (replace if needed)?	Yes
Test detection system from terminal detector?	Pass
Replace fusible links (every 6 months)?	Yes
Date of links	2025
Test remote manual pull station?	Pass
Test mechanical gas shut-off valve?	N/A
Test electric solenoid gas shut-off valve with reset relay?	N/A
Test electric switch for proper operation?	Pass
Clean nozzles?	Yes
System installed in accordance with mfg. UL listing?	Yes
System meets UL 300 standards?	Yes
Piping and conduit secured to rigid surface?	Yes
Tamper seal(s) installed?	Yes
Building fire alarm connected/activated?	Pass
Actuation line vacuum test performed (every 6 months)?	Yes
Distribution piping network last purged with dry air or nitrogen (every 12 months)?	Yes
Exhaust fan(s) operating?	Yes
Make-up/return air fan(s) shut down?	N/A
Air filters/spacers reinstalled?	Yes

Maintenance Items	Results
Personnel instructed in manual operation of system?	No
Class K extinguisher with placard present?	No
Last regulator test date (every 12 years)?	10/08/2025
System returned to normal operation?	Yes
Service and certification tag on system?	Yes

System Information							
LOCATION	DESCRIPTION	BARCODE	MANUFACTURER	MODEL	SERIAL NUMBER	SERVICE TYPE	SIZE
	Cafe back	—	Ansul 6 gallon	—	4210015	Electric	N/A
FUEL SHUT OFF TYPE		FUEL SHUT OFF 'ON'	360 FUSIBLE LINK	450 FUSIBLE LINK	500 FUSIBLE LINK	OTHER FUSIBLE LINK	# LINKS CHANGED THIS SERVICE
Electric Shunt Trip		Yes	4	N/A	N/A	N/A	4
Ventilation Equipment Information							
HOOD SIZE		PLENUM SIZE		FILTER TYPE		FILTER SIZE	
2-9ftx6ft		16x12		Baffle		12x20	
SIZE OF DUCT #1		SIZE OF DUCT #2		SIZE OF DUCT #3		SIZE OF DUCT #4	
20x20		20x20		N/A		N/A	

Cooking Appliance Locations							
LOCATION	DESCRIPTION	Appliance Type	APPLIANCE SIZE	FUEL SOURCE	APPLIANCE COVERAGE	NOZZLE TYPE	NOZZLE QUANTITY
—	Cafe back fryer	Fryer	12x12	Electric	Pass	3n	1
LOCATION	DESCRIPTION	Appliance Type	APPLIANCE SIZE	FUEL SOURCE	APPLIANCE COVERAGE	NOZZLE TYPE	NOZZLE QUANTITY
—	Cafe back fryer	Fryer	12x12	Electric	Pass	3n	1
LOCATION	DESCRIPTION	Appliance Type	APPLIANCE SIZE	FUEL SOURCE	APPLIANCE COVERAGE	NOZZLE TYPE	NOZZLE QUANTITY
—	Cafe back range	Range	36x24	Electric	Pass	290	2

Maintenance Items	Results
How many 360 degree Thermal Detectors?	N/A
How many 600 degree Thermal Detectors?	N/A
Thermal Detectors Tested	N/A
All appliances properly protected with correct nozzles?	Yes
Duct and plenum protected with correct nozzles?	Yes
All nozzles properly aimed at hazard/unobstructed?	Yes
Proper separation between fryer(s) and open flame?	Yes
Nozzle blow-off caps installed (replace if needed)	Yes
Hood & duct penetrations sealed with weld or UL device?	Yes
Check cartridge weight (replace if needed)?	Yes
Test detection system from terminal detector?	Pass
Replace fusible links (every 6 months)?	Yes
Date of links	2025
Test remote manual pull station?	Pass
Test mechanical gas shut-off valve?	N/A
Test electric solenoid gas shut-off valve with reset relay?	N/A
Test electric switch for proper operation?	Pass
Clean nozzles?	Yes
System installed in accordance with mfg. UL listing?	Yes
System meets UL 300 standards?	Yes
Piping and conduit secured to rigid surface?	Yes

Maintenance Items	Results
Tamper seal(s) installed?	Yes
Building fire alarm connected/activated?	Pass
Actuation line vacuum test performed (every 6 months)?	Yes
Distribution piping network last purged with dry air or nitrogen (every 12 months)?	Yes
Exhaust fan(s) operating?	Yes
Make-up/return air fan(s) shut down?	N/A
Air filters/spacers reinstalled?	Yes
Personnel instructed in manual operation of system?	No
Class K extinguisher with placard present?	Yes
Last regulator test date (every 12 years)?	10/08/2023
System returned to normal operation?	Yes
Service and certification tag on system?	Yes

System Information							
LOCATION	DESCRIPTION	BARCODE	MANUFACTURER	MODEL	SERIAL NUMBER	SERVICE TYPE	SIZE
	Cafe front	—	Ansul	—	354544	Electric	N/A
FUEL SHUT OFF TYPE		FUEL SHUT OFF 'ON'	360 FUSIBLE LINK	450 FUSIBLE LINK	500 FUSIBLE LINK	OTHER FUSIBLE LINK	# LINKS CHANGED THIS SERVICE
Electric Shunt Trip		Yes	5	N/A	N/A	N/A	5
Ventilation Equipment Information							
HOOD SIZE		PLENUM SIZE		FILTER TYPE		FILTER SIZE	
10x5		16x12		Baffle		12x20	
SIZE OF DUCT #1		SIZE OF DUCT #2		SIZE OF DUCT #3		SIZE OF DUCT #4	
20x20		N/A		N/A		N/A	

Cooking Appliance Locations							
LOCATION	DESCRIPTION	Appliance Type	APPLIANCE SIZE	FUEL SOURCE	APPLIANCE COVERAGE	NOZZLE TYPE	NOZZLE QUANTITY
—	Cafe front fryer	Fryer	21x13	Electric	Fail	3n	1
LOCATION	DESCRIPTION	Appliance Type	APPLIANCE SIZE	FUEL SOURCE	APPLIANCE COVERAGE	NOZZLE TYPE	NOZZLE QUANTITY
—	Cafe front fryer	Fryer	21x13	Electric	Pass	3n	1

Maintenance Items	Results
How many 360 degree Thermal Detectors?	N/A
How many 600 degree Thermal Detectors?	N/A
Thermal Detectors Tested	N/A
All appliances properly protected with correct nozzles?	Yes
Duct and plenum protected with correct nozzles?	Yes
All nozzles properly aimed at hazard/unobstructed?	Yes
Proper separation between fryer(s) and open flame?	Yes
Nozzle blow-off caps installed (replace if needed)	Yes
Hood & duct penetrations sealed with weld or UL device?	Yes
Check cartridge weight (replace if needed)?	Yes
Test detection system from terminal detector?	Pass
Replace fusible links (every 6 months)?	Yes
Date of links	2025
Test remote manual pull station?	Pass
Test mechanical gas shut-off valve?	N/A
Test electric solenoid gas shut-off valve with reset relay?	N/A
Test electric switch for proper operation?	Pass
Clean nozzles?	Yes
System installed in accordance with mfg. UL listing?	Yes
System meets UL 300 standards?	Yes
Piping and conduit secured to rigid surface?	Yes
Tamper seal(s) installed?	Yes
Building fire alarm connected/activated?	Pass
Actuation line vacuum test performed (every 6 months)?	Yes
Distribution piping network last purged with dry air or nitrogen (every 12 months)?	Yes

Maintenance Items	Results
Exhaust fan(s) operating?	Yes
Make-up/return air fan(s) shut down?	N/A
Air filters/spacers reinstalled?	Yes
Personnel instructed in manual operation of system?	Yes
Class K extinguisher with placard present?	Yes
Last regulator test date (every 12 years)?	10/08/2023
System returned to normal operation?	Yes
Service and certification tag on system?	Yes

System Information							
LOCATION	DESCRIPTION	BARCODE	MANUFACTURER	MODEL	SERIAL NUMBER	SERVICE TYPE	SIZE
	Main kitchen back hood	—	Ansul 6 gallon	—	132508	Electric	N/A
FUEL SHUT OFF TYPE		FUEL SHUT OFF 'ON'	360 FUSIBLE LINK	450 FUSIBLE LINK	500 FUSIBLE LINK	OTHER FUSIBLE LINK	# LINKS CHANGED THIS SERVICE
Electric Shunt Trip		Yes	4	N/A	N/A	N/A	4
Ventilation Equipment Information							
HOOD SIZE		PLENUM SIZE		FILTER TYPE		FILTER SIZE	
2- 16 ft x4 ft		24x12		Baffle		19.5 x19.5	
SIZE OF DUCT #1		SIZE OF DUCT #2		SIZE OF DUCT #3		SIZE OF DUCT #4	
20x20		20x20		N/A		N/A	

Cooking Appliance Locations							
LOCATION	DESCRIPTION	Appliance Type	APPLIANCE SIZE	FUEL SOURCE	APPLIANCE COVERAGE	NOZZLE TYPE	NOZZLE QUANTITY
—	Main back hood skillet	Tilt Skillet	21x13	Electric	Pass	3n	3

Maintenance Items	Results
How many 360 degree Thermal Detectors?	N/A
How many 600 degree Thermal Detectors?	N/A
Thermal Detectors Tested	N/A
All appliances properly protected with correct nozzles?	Yes
Duct and plenum protected with correct nozzles?	Yes
All nozzles properly aimed at hazard/unobstructed?	Yes
Proper separation between fryer(s) and open flame?	Yes
Nozzle blow-off caps installed (replace if needed)	Yes
Hood & duct penetrations sealed with weld or UL device?	Yes
Check cartridge weight (replace if needed)?	Yes
Test detection system from terminal detector?	Pass
Replace fusible links (every 6 months)?	Yes
Date of links	2025
Test remote manual pull station?	Pass
Test mechanical gas shut-off valve?	N/A
Test electric solenoid gas shut-off valve with reset relay?	N/A
Test electric switch for proper operation?	Pass
Clean nozzles?	Yes
System installed in accordance with mfg. UL listing?	Yes
System meets UL 300 standards?	Yes
Piping and conduit secured to rigid surface?	Yes
Tamper seal(s) installed?	Yes
Building fire alarm connected/activated?	Pass
Actuation line vacuum test performed (every 6 months)?	Yes
Distribution piping network last purged with dry air or nitrogen (every 12 months)?	Yes
Exhaust fan(s) operating?	Yes

Maintenance Items	Results
Make-up/return air fan(s) shut down?	N/A
Air filters/spacers reinstalled?	Yes
Personnel instructed in manual operation of system?	No
Class K extinguisher with placard present?	Yes
Last regulator test date (every 12 years)?	10/08/2023
System returned to normal operation?	Yes
Service and certification tag on system?	Yes

System Information							
LOCATION	DESCRIPTION	BARCODE	MANUFACTURER	MODEL	SERIAL NUMBER	SERVICE TYPE	SIZE
	Main kitchen front hood	—	Ansul 6 gallon	—	188162	Electric	N/A
FUEL SHUT OFF TYPE		FUEL SHUT OFF 'ON'	360 FUSIBLE LINK	450 FUSIBLE LINK	500 FUSIBLE LINK	OTHER FUSIBLE LINK	# LINKS CHANGED THIS SERVICE
Electric Shunt Trip		Yes	4	N/A	N/A	N/A	4
Ventilation Equipment Information							
HOOD SIZE		PLENUM SIZE		FILTER TYPE		FILTER SIZE	
13ftx9.5		16.24 v bank		Baffle		19.6x19.6	
SIZE OF DUCT #1		SIZE OF DUCT #2		SIZE OF DUCT #3		SIZE OF DUCT #4	
20x20		20x20		N/A		N/A	

Cooking Appliance Locations							
LOCATION	DESCRIPTION	Appliance Type	APPLIANCE SIZE	FUEL SOURCE	APPLIANCE COVERAGE	NOZZLE TYPE	NOZZLE QUANTITY
—	Front main hood fryer	Fryer	12 round	Electric	Pass	3n	1
LOCATION	DESCRIPTION	Appliance Type	APPLIANCE SIZE	FUEL SOURCE	APPLIANCE COVERAGE	NOZZLE TYPE	NOZZLE QUANTITY
—	Front main hood griddle	Griddle	36x24	Electric	Pass	1n	1

Maintenance Items	Results
How many 360 degree Thermal Detectors?	N/A
How many 600 degree Thermal Detectors?	N/A
Thermal Detectors Tested	N/A
All appliances properly protected with correct nozzles?	Yes
Duct and plenum protected with correct nozzles?	Yes
All nozzles properly aimed at hazard/unobstructed?	Yes
Proper separation between fryer(s) and open flame?	Yes
Nozzle blow-off caps installed (replace if needed)	Yes
Hood & duct penetrations sealed with weld or UL device?	Yes
Check cartridge weight (replace if needed)?	Yes
Test detection system from terminal detector?	Pass
Replace fusible links (every 6 months)?	Yes
Date of links	2025
Test remote manual pull station?	Pass
Test mechanical gas shut-off valve?	N/A
Test electric solenoid gas shut-off valve with reset relay?	N/A
Test electric switch for proper operation?	Pass
Clean nozzles?	Yes
System installed in accordance with mfg. UL listing?	Yes
System meets UL 300 standards?	Yes
Piping and conduit secured to rigid surface?	Yes
Tamper seal(s) installed?	Yes
Building fire alarm connected/activated?	Pass

Maintenance Items	Results
Actuation line vacuum test performed (every 6 months)?	Yes
Distribution piping network last purged with dry air or nitrogen (every 12 months)?	Yes
Exhaust fan(s) operating?	Yes
Make-up/return air fan(s) shut down?	N/A
Air filters/spacers reinstalled?	Yes
Personnel instructed in manual operation of system?	No
Class K extinguisher with placard present?	Yes
Last regulator test date (every 12 years)?	10/08/2023
System returned to normal operation?	Yes
Service and certification tag on system?	Yes

System Information							
LOCATION	DESCRIPTION	BARCODE	MANUFACTURER	MODEL	SERIAL NUMBER	SERVICE TYPE	SIZE
	Main kitchen serving line	—	Ansul 3 gallon	—	51117	Electric	N/A
FUEL SHUT OFF TYPE		FUEL SHUT OFF 'ON'	360 FUSIBLE LINK	450 FUSIBLE LINK	500 FUSIBLE LINK	OTHER FUSIBLE LINK	# LINKS CHANGED THIS SERVICE
Electric Shunt Trip		Yes	3	N/A	N/A	N/A	3
Ventilation Equipment Information							
HOOD SIZE		PLENUM SIZE		FILTER TYPE		FILTER SIZE	
7x4.6ft		13x10		Water wash		N/A	
SIZE OF DUCT #1		SIZE OF DUCT #2		SIZE OF DUCT #3		SIZE OF DUCT #4	
12x12		N/A		N/A		N/A	

Cooking Appliance Locations							
LOCATION	DESCRIPTION	Appliance Type	APPLIANCE SIZE	FUEL SOURCE	APPLIANCE COVERAGE	NOZZLE TYPE	NOZZLE QUANTITY
—	Serving line oven	Oven	42x36	Electric	Pass	290	2

Maintenance Items	Results
How many 360 degree Thermal Detectors?	N/A
How many 600 degree Thermal Detectors?	N/A
Thermal Detectors Tested	N/A
All appliances properly protected with correct nozzles?	Yes
Duct and plenum protected with correct nozzles?	Yes
All nozzles properly aimed at hazard/unobstructed?	Yes
Proper separation between fryer(s) and open flame?	Yes
Nozzle blow-off caps installed (replace if needed)	Yes
Hood & duct penetrations sealed with weld or UL device?	Not Answered
Check cartridge weight (replace if needed)?	Yes
Test detection system from terminal detector?	Pass
Replace fusible links (every 6 months)?	Yes
Date of links	2025
Test remote manual pull station?	Pass
Test mechanical gas shut-off valve?	N/A
Test electric solenoid gas shut-off valve with reset relay?	N/A
Test electric switch for proper operation?	Pass
Clean nozzles?	Yes
System installed in accordance with mfg. UL listing?	Yes
System meets UL 300 standards?	Yes
Piping and conduit secured to rigid surface?	Yes
Tamper seal(s) installed?	Yes
Building fire alarm connected/activated?	Pass
Actuation line vacuum test performed (every 6 months)?	Yes
Distribution piping network last purged with dry air or nitrogen (every 12 months)?	Yes
Exhaust fan(s) operating?	Yes
Make-up/return air fan(s) shut down?	N/A

Maintenance Items	Results
Air filters/spacers reinstalled?	Yes
Personnel instructed in manual operation of system?	Yes
Class K extinguisher with placard present?	Yes
Last regulator test date (every 12 years)?	10/08/2025
System returned to normal operation?	Yes
Service and certification tag on system?	Yes

Inspector Signature		Inspector Name	David Mills	Date	10/08/2025
------------------------	---	-------------------	-------------	------	------------

Terms And Conditions

1. **Limitation of Liability; Limitations Of Remedy.** It is understood and agreed by the Customer that Company is not an insurer and that insurance coverage, if any, shall be obtained by the Customer and that amounts payable to Company hereunder are based upon the value of the services and the scope of liability set forth in this agreement and are unrelated to the value of the Customer's property and the property of others located on the premises. Customer agrees to look exclusively to the Customer's insurer to recover for injuries or damage in the event of any loss or injury and that Customer releases and waives all right of recovery against Company arising by way of subrogation. Company makes no guaranty or Warranty, including any implied warranty of merchantability or fitness for a particular purpose that equipment or services supplied by Company will detect or avert occurrences or the consequences there from that the equipment or service was designed to detect or avert. It is impractical and extremely difficult to fix the actual damages, if any, which may proximately result from failure on the part of Company to perform any of its obligations under this agreement. Accordingly, Customer agrees that, Company shall be exempt from liability for any loss, damage or injury arising directly or indirectly from occurrences, or the consequences therefrom, which the equipment or service was designed to detect or avert. Should Company be found liable for any loss, damage or injury arising from a failure of the equipment or service in any respect, Company's liability shall be limited to an amount equal to the agreement price (as increased by the price for any additional work) or where the time and material payment term is selected, Customer's time and material payments to Company. Where this agreement covers multiple sites, liability shall be limited to the amount of the payments allocable to the site where the incident occurred. Such sum shall be complete and exclusive. If Customer desires Company to assume greater liability, the parties shall amend this agreement by attaching a rider setting forth the amount of additional liability and the additional amount payable by the Customer for the assumption by Company of such greater liability, provided however that such rider shall in no way be interpreted to hold Company as an insurer. IN NO EVENT SHALL COMPANY BE LIABLE FOR ANY DAMAGE, LOSS, INJURY, OR ANY OTHER CLAIM ARISING FROM ANY SERVICING, ALTERATIONS, MODIFICATIONS, CHANGES, OR MOVEMENTS OF THE COVERED SYSTEM(S) OR ANY OF ITS COMPONENT PARTS BY THE CUSTOMER OR ANY THIRD PARTY. COMPANY SHALL NOT BE LIABLE FOR INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGES OF ANY KIND, INCLUDING BUT NOT LIMITED TO DAMAGES ARISING FROM THE USE, LOSS OF THE USE, PERFORMANCE, OR FAILURE OF THE COVERED SYSTEM(S) TO PERFORM. The limitations of liability set forth in this agreement shall inure to the benefit of all parents, subsidiaries and affiliates of Company, whether direct or indirect, Company's employees, agents, officers and directors.
2. **Limited Warranty.** COMPANY WARRANTS THAT ITS WORKMANSHIP AND MATERIAL FURNISHED UNDER THIS AGREEMENT WILL BE FREE FROM DEFECTS FOR A PERIOD OF NINETY (90) DAYS FROM THE DATE OF FURNISHING. Where Company provides product or equipment of others, Company will warrant the product or equipment only to the extent warranted by such third party. EXCEPT AS EXPRESSLY SET FORTH HEREIN, COMPANY DISCLAIMS ALL WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE WITH RESPECT TO THE SERVICES PERFORMED OR THE PRODUCTS, SYSTEMS OR EQUIPMENT, IF ANY, SUPPORTED HEREUNDER. COMPANY MAKES NO WARRANTY OR REPRESENTATION, AND UNDERTAKES NO OBLIGATION TO ENSURE BY THE SERVICES PERFORMED UNDER THIS AGREEMENT, THAT COMPANY'S PRODUCTS OR THE SYSTEMS OR EQUIPMENT OF THE CUSTOMER WILL CORRECTLY HANDLE THE PROCESSING OF CALENDAR DATES BEFORE OR AFTER DECEMBER 31, 1999.
3. **Indemnity.** Customer agrees to indemnify, hold harmless and defend Company against any and all losses, damages, costs, including expert fees and costs, and expenses including reasonable defense costs, arising from any and all third party claims for personal injury, death, property damage or economic loss, including specifically any damages resulting from the exposure of workers to Hazardous Conditions whether or not Customer pre-notifies Company of the existence of said hazardous conditions, arising in any way from any act or omission of Customer or Company relating in any way to this agreement, including but not limited to the Services under this agreement, whether such claims are based upon contract, warranty, tort (including but not limited to active or passive negligence), strict liability or otherwise. Company reserves the right to select counsel to represent it in any such action.
4. **Hazardous Materials.** Customer represents that, except to the extent that Company has been given written notice of the following hazards prior to the execution of this agreement, to the best of Customer's knowledge there is no:
 - a. "permit confined space," as defined by OSHA, or space in which work must be performed that, because of its construction, location, contents or work activity therein, accumulation of a hazardous gas, vapour, dust or fume or the creation of a risk of infectious disease
 - b. need for air monitoring, respiratory protection, or other medical risk
 - c. asbestos, asbestos-containing material, formaldehyde or other potentially toxic or otherwise hazardous material contained in or on the surface of the floors, walls, ceilings, insulation or other structural components of the area of any building
 - d. All of the above are hereinafter referred to as "Hazardous Conditions". Company shall have the right to rely on the representations listed above. If hazardous conditions are encountered by Company during the course of Company's work, the discovery of such conditions shall constitute an event beyond Company's control and Company shall have no obligation to further perform in the area where the hazardous conditions exist until the area has been made safe by Customer as certified in writing by an independent testing agency, and Customer shall pay disruption expenses and re-mobilization expenses as determined by Company. This agreement does not provide for the cost of capture, containment or disposal of any hazardous waste materials, or hazardous materials, encountered in any of the Covered System(s) and/or during performance of the Services. Said materials shall at all times remain the responsibility and property of Customer. Company shall not be responsible for the testing, removal or disposal of such hazardous materials.
5. **Equipment Disconnections.** This represents Company's notice to you that the system(s)/device(s) listed on the face of this agreement as temporarily or permanently disconnected are no longer in service and, thus, cannot detect, perform and/or report
6. **General.** Unless otherwise specified, work shall be performed during company's regular business hours,, exclusive of Saturdays, Sundays and Company holidays. All work is subject to review and rebilling in accordance with the terms and conditions of Customer's agreement/contract with Company, if one is in effect. Company shall not be responsible for failure to render services due to causes beyond its control, including but not limited to material shortages, work stoppages, fires, civil disobedience or unrest, severe weather, fire or any other cause beyond the control of Company. Customer is aware that the Limitation of Liability and other provisions set forth in any existing agreement/contract, if one is in effect, or set forth above, apply to services performed and materials supplied. The terms of this agreement shall govern notwithstanding any inconsistent or additional terms and conditions in any purchase order or other document submitted by Customer.

DEVICE NOTE IMAGE APPENDICES