

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE OF PAGES 1 5		
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 05/07/2026		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)	
6. ISSUED BY AMERICAN EMBASSY MONROVIA 502 Benson Street, ATTN: GSO/PROCUREMENT MONROVIA LIBERIA		CODE		7. ADMINISTERED BY (If other than Item 6) CODE AMERICAN EMBASSY MONROVIA 502 Benson Street, ATTN: GSO/PROCUREMENT MONROVIA LIBERIA			
8. NAME AND ADDRESS OF CONTRACTOR (NO., street, city, county, State, and ZIP Code)				9a. AMENDMENT OF SOLICITATION NO. 19L16026Q0002			
				9b. DATED (SEE ITEM 11) 03/25/2026			
				10a. MODIFICATION OF CONTRACT/ORDER NO.			
				10b. DATED (SEE ITEM 13) 04/02/2025			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
☐ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended, ☐ is not extended Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning ONE copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
The purpose of this solicitation amendment is as follows: (a) Provide answers to various questions submitted in response to the original solicitation (b) Update Section 4 – Evaluation Factors (c) Extend the due date, from May 7, 2026 to May 14, 2026 (1600 GMT) Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME OF CONTRACTING OFFICER Femi Akinyemi			
15B. NAME OF CONTRACTOR/OFFEROR BY _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY  (Signature of Contracting Officer)		16C. DATE SIGNED 7 May 2026	

Amendment of Solicitation# 19L16026Q0002-0002

The purpose of this solicitation amendment is as follows:

A. Provide answers to various questions submitted in response to the original solicitation, as outline below:

1. Our company is a United States based firm and is interested in this project. We do not have a place of business or licensure to work in Liberia. Are we ineligible to bid on this project?

Ans: Yes, you are eligible, so long as you follow the procedures outlined on page#32 of the solicitation.

2. In lieu of a Bank Guaranty Letter, could the contractor provide a performance bond instead? If not, in lieu of submitting the Bank Guaranty Letter with the proposal, could the contractor provide a letter from the bank indicating that once the contract is awarded, the Bank Guaranty Letter will be provided (Otherwise, the contractor will have to set aside 50% of the contract price prior to even bidding the work.)

Ans: The RFQ requires financial security from a financial institution registered or Licensed under the Central Bank of Liberia. A Performance Bond from said institutions would be considered acceptable.

3. What are the actual tank dimensions for the three tanks? Please provide as built drawings as well

Ans: The rough dimensions of the tanks are as follow:

- (2) Raw Water Tanks ---L: 26M, W: 9M, H: 5M.
- Potable Water Tank—L: 5.7, W: 3M, H: 5M.
- No As-built drawings permissible; dimensions provide the required information

4. Is there a water source near the tanks capable of producing 8 gallons per minute?

Ans: Our nearby water source can provide maximum 2 gallons per minute.

5. What is the distance between the nearest outside door to the tank entrances?

Ans: 1 yard for tank "A" Raw water tank. 3 yards for the remaining two tanks, tank "B" raw water and Potable water tanks.

6. Are the tank entrances inside a utility room or outside on the roof? Please provide photos of the tank hatch and area around the entry.

Ans: All the tanks and hatches are indoors and clear and free of debris. The size of the hatch is 3x3 ft. Photos are not permissible.

7. Can the contractor plan to work on one raw tank and the potable tank at the same time?

Ans: Yes

8. Does work on the potable tank need to be completed outside of normal post working hours?

Ans: No, all work must be completed within normal working hours.

9. How are the tanks drained? Who is responsible for draining the tanks? Is there a sump pit in each of the tanks?

Ans: The contractor is responsible for draining the tank. Refer to the RFQ Page#6.

10. Is there a minimum cleaning procedure that must be achieved? (For example, "Pressure washing with 4,000 PSI with a rotary nozzle at 3-6" from the substrate").

Ans: The tank will need to be pressure-washed. The contractor is responsible for determining the appropriate pressure that will provide the desired results, without introducing damage or compromise.

11. Are there any special security procedures that must be followed?

Ans: No, Standard USG Access procedures.

12. What is the list of RSO vetted hotels?

Ans: The Embassy is not responsible for vetted hotels arrangements. Lodging arrangements / investigation is solely the responsibility of the contractor.

13. What are the Embassy working hours and can post accommodate longer working days?

Ans:

- 0800 – 1700 Mon – Thursday
- 0800 – 1200 Friday
- 1200 – 1300 Everyday Lunch time
- Longer working days are not accommodated.

14. In addition to NACE 3, does the coating inspector need to be SSPC Concrete Coating Inspector Level 2 certified to provide assessment of the concrete substrate?

Ans: NACE Level 3 coating inspector, a certified confined space attendant, and a general laborer are removed from the requirement. These are no longer required.

15. Can you clarify the deliverables listed in the statement of objectives? As part of the deliverables, should the contractor include a description of the criteria or standards used for inspection and assessment of the structural integrity of the tank and any existing coatings (i.e. NACE, SSPC, AMPP, ACI, ICRI, AWWA and /or NSF/ANSI). Should the report include all information and data relied upon for the assessment, conclusions about the probable cause of the current condition of the tank and coatings, and include a recommendation for repair, specification and cost estimate for any repairs and corrective actions to ensure the successful use of the tanks?

Ans: Comprehensive cleaning reports and documentation of any issues encountered (structural, civil, hydrological) should be considered removed from our statement of objectives. The contractor does not have to include a description of the criteria or standards used for inspection and assessment of the structural integrity of the tank and any existing coatings.

16. What are the liquidated damages for this project, if any and when do they begin?

Ans: No liquidated damage is applicable.

17. What is the warranty for this work?

Ans: No warranty required.

18. What is the retainage for this work?

Ans: None

19. Are we sealing the entire tanks and what materials are required for sealing?

Ans: Yes, we require the tanks to be sealed/coated with at least one layer of the product called "Sika Top 209 Reservoir Grey", or a functional equivalent.

20. Can we use pressure washing machine for the water storage tanks/reservoirs?

Ans: Refer to question# 10

21. Is there any water supply area to place the hose?

Ans: Refer to question# 4

22. Will the Embassy supply electrical power to enable us to see or to execute the SOW?

Ans: Yes

23. Is there any draining holes to drain the water after rinsing the reservoir?

Ans: Yes, however, refer to question# 9.

B. Update Section 4 – Evaluation Factors to reflect as follows:

SECTION 4 - EVALUATION FACTORS

As per the requirements of FAR 9.1, an award will be made to the lowest priced, technically acceptable and responsible quoter. The Government reserves the right to reject quotations that are unreasonably low or high in price.

Technical acceptability will be determined by assessing the offeror's technical proposal, including performance schedules, specific methods, and technical acceptability of past performance records.

Responsibility will be determined by assessing the technically acceptable past performance records for confirmation of successful project completion, as referenced, and by assessing the offeror's general requirements submissions to confirm and authenticate validity.

1. All required submissions required under Section 3
 - a. Under the listed elements of Volume III of Section "3", the Government reserves the right to authenticate all information provided and may do so through publicly available information and/or direct contact. Offerors who do not meet the contractor responsibility assessment and/or cannot be authenticated may not be considered for price evaluation:

C. Extend the due date / submission deadline, from May 7, 2026 to May 14, 2026 (1600 GMT)

End of Amendment