



MASSACHUSETTS WATER RESOURCES AUTHORITY

Chelsea Facility
2 Griffin Way
Chelsea, Massachusetts 02150

Telephone: (617) 242-6000
Facsimile: (617) 371-1604

CERTIFIED MAIL

VA Boston Healthcare System - Jamaica Plain
c/o VA Healthcare System Brockton
940 Belmont Street
Brockton, MA 02301

ISSUED: 09/04/2025

Subject: Permit #:51005733 Permit Revision: 1 re-activate 0201 Sampling Site
MWRA Category: 01 SIU
Permit Expiration Date: 08/15/2026

Attention: Mr. John Hughes

Dear Mr. Hughes:

Enclosed, please find revised pages to the Massachusetts Water Resources Authority (MWRA) Discharge Permit (permit) issued to your facility located at 150 S. Huntington Avenue, Jamaica Plain, MA 02130. Your permit is being revised for the following reason: Revision #1 to re-activate Sample Location 0201

This permit revision may contain existing requirements and/or submittals with specific due dates that may have passed based on the permit issued on 09/09/2024. These submittals and/or requirements remain in effect until the permit expiration date.

The revised permit supersedes all previous permits and is valid until its date of expiration so long as all stipulated conditions are complied with; it is subject to renewal and change as stated in the MWRA's Sewer Use Regulations, promulgated at 360 C.M.R. § 10.000 and in the MWRA's Enforcement Regulations, 360 C.M.R. § 2.00.

If you disagree with any of the terms and conditions of this permit, you may, pursuant to 360 C.M.R. §§ 2.21(1) and 10.007(8), appeal those terms and conditions by submitting a written request for reconsideration to the MWRA Toxic Reduction and Control Program within ten (10) working days from the issued date of this permit. The request shall set forth in detail the facts supporting it.

If you have any questions pertaining to the permit's terms and conditions or any information set forth in this letter, please contact Kenneth Cunningham, Industrial Coordinator, Toxic Reduction and Control, at (617) 305-5623.

Sincerely,

A handwritten signature in black ink, appearing to read "Matthew J. Dam".

Matthew J. Dam
Director of Toxic Reduction and Control

Enclosures

MASSACHUSETTS WATER RESOURCES AUTHORITY
TOXIC REDUCTION AND CONTROL

2 Griffin Way
Chelsea, Massachusetts 02150
Telephone: (617) 242-6000
Facsimile: (617) 371-1604



SEWER USE DISCHARGE PERMIT

ISSUED TO:

VA Boston Healthcare System - Jamaica Plain
150 S. Huntington Avenue S-138
Jamaica Plain, MA 02130

Permit #: 51005733, Permit Revision: 1

Issuance Date: 09/04/2025

Expiration Date: 08/15/2026

Sewer Use Discharge Permit

Table of Contents

Contents

Self-Monitoring Requirements Summary	ii
Discharge Limitations Summary	iv
Sample Location and Self-Monitoring Requirements.....	1
General Sampling and Analysis Requirements	8
Reporting Procedures for Self-Monitoring Requirements.....	9
Reports and Records You Must Submit	11
Reports, Records and Devices You Must Maintain at Your Facility	11
Additional Requirements	12
Authorized Discharge	13
Sampling Records.....	14
When You Should Notify the MWRA	14
Mailing and Email Address for Reports and Notifications	17
Most Stringent Limitations	18
MWRA Discharge Limitations	18
Specific Prohibitions.....	20
Dilution Prohibition.....	24
Pretreatment	25
Bypass Prohibition	25
Right of Entry	26
Duty to Mitigate.....	26
Enforcement/Litigation Records.....	26
Posting Requirements.....	27
Confidentiality.....	27
Signatories.....	27
Disposal of Sludge and Hazardous Wastes	27
Severability.....	27
Penalty Provisions.....	28
Request for Reconsideration	29
Definitions of Sampling and Reporting Terms	30

Sewer Use Discharge Permit SUMMARIES

Self-Monitoring Requirements Summary

Sample Location	Pollutant	Frequency
0103	Chromium (Total)	Semi-Annual
0103	Copper (Total)	Semi-Annual
0103	Flow	Semi-Annual
0103	Lead (Total)	Semi-Annual
0103	Mercury (Total)	Semi-Annual
0103	Nickel (Total)	Semi-Annual
0103	Zinc (Total)	Semi-Annual
0103	pH	Semi-Annual
0104	Chromium (Total)	Semi-Annual
0104	Copper (Total)	Semi-Annual
0104	Flow	Semi-Annual
0104	Lead (Total)	Semi-Annual
0104	Nickel (Total)	Semi-Annual
0104	Zinc (Total)	Semi-Annual
0104	pH	Semi-Annual
0105	Copper (Total)	Semi-Annual
0105	Flow	Semi-Annual
0105	Lead (Total)	Semi-Annual
0105	Nickel (Total)	Semi-Annual
0105	Zinc (Total)	Semi-Annual
0105	pH	Semi-Annual
0107	Copper (Total)	Semi-Annual
0107	Flow	Semi-Annual
0107	TTO (Extractable Organic Fraction)	Semi-Annual
0107	Zinc (Total)	Semi-Annual
0107	pH	Semi-Annual
0108	Copper (Total)	Semi-Annual
0108	Flow	Semi-Annual
0108	Lead (Total)	Semi-Annual
0108	Nickel (Total)	Semi-Annual
0108	Zinc (Total)	Semi-Annual
0108	pH	Semi-Annual
0109	Copper (Total)	Semi-Annual
0109	Flow	Semi-Annual
0109	Lead (Total)	Semi-Annual
0109	Nickel (Total)	Semi-Annual
0109	Zinc (Total)	Semi-Annual
0109	pH	Semi-Annual
0201	Copper (Total)	Semi-Annual
0201	Flow	Semi-Annual

Sewer Use Discharge Permit SUMMARIES

Sample Location	Pollutant	Frequency
0201	Formaldehyde	Semi-Annual
0201	Lead (Total)	Semi-Annual
0201	Mercury (Total)	Semi-Annual
0201	TTO (Volatile Organic Fraction)	Semi-Annual
0201	Zinc (Total)	Semi-Annual
0201	pH	Semi-Annual

Semi-annual Schedule

Collect Your Samples During:	Submit Your Report By:
January through June	July 31
July through December	January 31

Additional Industry Requirements

Requirement	Frequency
D1 Biennial Compliance Report	D1 - once/2yr

Sewer Use Discharge Permit SUMMARIES

Discharge Limitations Summary

Listed below are many of the pollutants that are regulated by the MWRA. Your daily wastewater discharge to the sewer system from the following Sample Location(s) shall not violate the limits. Your complete set of discharge limitations, including those not listed below, is found in Part B of your Discharge Permit.

Sample Location: 0103

	MWRA
Pollutant	Daily Maximum Limit (mg/l)
1,1-Dichloroethylene	0.3
Acrolein	0.15
Antimony (Total)	10.0
Arsenic (Total)	0.5
Benzene	0.3
Cadmium (Total)	0.1
Chromium (+6)	0.5
Chromium (Total)	1.0
Copper (Total)	1.0
Cyanide (Total)	0.5
Each Toxic Organic (Unless Elsewhere Limited In 360 CMR 10.000)	1.0
Formaldehyde	9.0
Hexachlorobutadiene	Prohibited
Lead (Total)	0.2
Mercury (Total)	Prohibited
Nickel (Total)	1.0
PCB's	Prohibited
Pesticides	Prohibited
Phenol	5.0
Selenium (Total)	5.0
Silver (Total)	2.0
TTO	5.0
Vinyl Chloride (Chloroethylene)	0.02
Zinc (Total)	1.0

Sample Location: 0103

	MWRA
Pollutant	Instantaneous Limit (DEG C)
Temperature	82

Sewer Use Discharge Permit SUMMARIES

Sample Location: 0103

	MWRA
Pollutant	Instantaneous Limit (S.U.)
pH	must remain between 5.5 - 12.0 standard units

Sample Location: 0103

	MWRA
Pollutant	Instantaneous Limit (mg/l)
Oil and Grease	300

Sample Location: 0104

	MWRA
Pollutant	Daily Maximum Limit (mg/l)
1,1-Dichloroethylene	0.3
Acrolein	0.15
Antimony (Total)	10.0
Arsenic (Total)	0.5
Benzene	0.3
Cadmium (Total)	0.1
Chromium (+6)	0.5
Chromium (Total)	1.0
Copper (Total)	1.0
Cyanide (Total)	0.5
Each Toxic Organic (Unless Elsewhere Limited In 360 CMR 10.000)	1.0
Formaldehyde	9.0
Hexachlorobutadiene	Prohibited
Lead (Total)	0.2
Mercury (Total)	Prohibited
Nickel (Total)	1.0
PCB's	Prohibited
Pesticides	Prohibited
Phenol	5.0
Selenium (Total)	5.0
Silver (Total)	2.0
TTO	5.0
Vinyl Chloride (Chloroethylene)	0.02
Zinc (Total)	1.0

Sample Location: 0104

	MWRA
Pollutant	Instantaneous Limit (DEG C)
Temperature	82

Sewer Use Discharge Permit SUMMARIES

Sample Location: 0104

	MWRA
Pollutant	Instantaneous Limit (S.U.)
pH	must remain between 5.5 - 12.0 standard units

Sample Location: 0104

	MWRA
Pollutant	Instantaneous Limit (mg/l)
Oil and Grease	300

Sample Location: 0105

	MWRA
Pollutant	Daily Maximum Limit (mg/l)
1,1-Dichloroethylene	0.3
Acrolein	0.15
Antimony (Total)	10.0
Arsenic (Total)	0.5
Benzene	0.3
Cadmium (Total)	0.1
Chromium (+6)	0.5
Chromium (Total)	1.0
Copper (Total)	1.0
Cyanide (Total)	0.5
Each Toxic Organic (Unless Elsewhere Limited In 360 CMR 10.000)	1.0
Formaldehyde	9.0
Hexachlorobutadiene	Prohibited
Lead (Total)	0.2
Mercury (Total)	Prohibited
Nickel (Total)	1.0
PCB's	Prohibited
Pesticides	Prohibited
Phenol	5.0
Selenium (Total)	5.0
Silver (Total)	2.0
TTO	5.0
Vinyl Chloride (Chloroethylene)	0.02
Zinc (Total)	1.0

Sample Location: 0105

	MWRA
Pollutant	Instantaneous Limit (DEG C)
Temperature	82

Sewer Use Discharge Permit SUMMARIES

Sample Location: 0105

	MWRA
Pollutant	Instantaneous Limit (S.U.)
pH	must remain between 5.5 - 12.0 standard units

Sample Location: 0105

	MWRA
Pollutant	Instantaneous Limit (mg/l)
Oil and Grease	300

Sample Location: 0107

	MWRA
Pollutant	Daily Maximum Limit (mg/l)
1,1-Dichloroethylene	0.3
Acrolein	0.15
Antimony (Total)	10.0
Arsenic (Total)	0.5
Benzene	0.3
Cadmium (Total)	0.1
Chromium (+6)	0.5
Chromium (Total)	1.0
Copper (Total)	1.0
Cyanide (Total)	0.5
Each Toxic Organic (Unless Elsewhere Limited In 360 CMR 10.000)	1.0
Formaldehyde	9.0
Hexachlorobutadiene	Prohibited
Lead (Total)	0.2
Mercury (Total)	Prohibited
Nickel (Total)	1.0
PCB's	Prohibited
Pesticides	Prohibited
Phenol	5.0
Selenium (Total)	5.0
Silver (Total)	2.0
TTO	5.0
Vinyl Chloride (Chloroethylene)	0.02
Zinc (Total)	1.0

Sample Location: 0107

	MWRA
Pollutant	Instantaneous Limit (DEG C)
Temperature	82

Sewer Use Discharge Permit SUMMARIES

Sample Location: 0107

	MWRA
Pollutant	Instantaneous Limit (S.U.)
pH	must remain between 5.5 - 12.0 standard units

Sample Location: 0107

	MWRA
Pollutant	Instantaneous Limit (mg/l)
Oil and Grease	300

Sample Location: 0108

	MWRA
Pollutant	Daily Maximum Limit (mg/l)
1,1-Dichloroethylene	0.3
Acrolein	0.15
Antimony (Total)	10.0
Arsenic (Total)	0.5
Benzene	0.3
Cadmium (Total)	0.1
Chromium (+6)	0.5
Chromium (Total)	1.0
Copper (Total)	1.0
Cyanide (Total)	0.5
Each Toxic Organic (Unless Elsewhere Limited In 360 CMR 10.000)	1.0
Formaldehyde	9.0
Hexachlorobutadiene	Prohibited
Lead (Total)	0.2
Mercury (Total)	Prohibited
Nickel (Total)	1.0
PCB's	Prohibited
Pesticides	Prohibited
Phenol	5.0
Selenium (Total)	5.0
Silver (Total)	2.0
TTO	5.0
Vinyl Chloride (Chloroethylene)	0.02
Zinc (Total)	1.0

Sample Location: 0108

	MWRA
Pollutant	Instantaneous Limit (DEG C)
Temperature	82

Sewer Use Discharge Permit SUMMARIES

Sample Location: 0108

	MWRA
Pollutant	Instantaneous Limit (S.U.)
pH	must remain between 5.5 - 12.0 standard units

Sample Location: 0108

	MWRA
Pollutant	Instantaneous Limit (mg/l)
Oil and Grease	300

Sample Location: 0109

	MWRA
Pollutant	Daily Maximum Limit (mg/l)
1,1-Dichloroethylene	0.3
Acrolein	0.15
Antimony (Total)	10.0
Arsenic (Total)	0.5
Benzene	0.3
Cadmium (Total)	0.1
Chromium (+6)	0.5
Chromium (Total)	1.0
Copper (Total)	1.0
Cyanide (Total)	0.5
Each Toxic Organic (Unless Elsewhere Limited In 360 CMR 10.000)	1.0
Formaldehyde	9.0
Hexachlorobutadiene	Prohibited
Lead (Total)	0.2
Mercury (Total)	Prohibited
Nickel (Total)	1.0
PCB's	Prohibited
Pesticides	Prohibited
Phenol	5.0
Selenium (Total)	5.0
Silver (Total)	2.0
TTO	5.0
Vinyl Chloride (Chloroethylene)	0.02
Zinc (Total)	1.0

Sample Location: 0109

	MWRA
Pollutant	Instantaneous Limit (DEG C)
Temperature	82

Sewer Use Discharge Permit SUMMARIES

Sample Location: 0109

	MWRA
Pollutant	Instantaneous Limit (S.U.)
pH	must remain between 5.5 - 12.0 standard units

Sample Location: 0109

	MWRA
Pollutant	Instantaneous Limit (mg/l)
Oil and Grease	300

Sample Location: 0201

	MWRA
Pollutant	Daily Maximum Limit (mg/l)
1,1-Dichloroethylene	0.3
Acrolein	0.15
Antimony (Total)	10.0
Arsenic (Total)	0.5
Benzene	0.3
Cadmium (Total)	0.1
Chromium (+6)	0.5
Chromium (Total)	1.0
Copper (Total)	1.0
Cyanide (Total)	0.5
Each Toxic Organic (Unless Elsewhere Limited In 360 CMR 10.000)	1.0
Formaldehyde	9.0
Hexachlorobutadiene	Prohibited
Lead (Total)	0.2
Mercury (Total)	Prohibited
Nickel (Total)	1.0
PCB's	Prohibited
Pesticides	Prohibited
Phenol	5.0
Selenium (Total)	5.0
Silver (Total)	2.0
TTO	5.0
Vinyl Chloride (Chloroethylene)	0.02
Zinc (Total)	1.0

Sample Location: 0201

	MWRA
Pollutant	Instantaneous Limit (DEG C)
Temperature	82

Sewer Use Discharge Permit SUMMARIES

Sample Location: 0201

	MWRA
Pollutant	Instantaneous Limit (S.U.)
pH	must remain between 5.5 - 12.0 standard units

Sample Location: 0201

	MWRA
Pollutant	Instantaneous Limit (mg/l)
Oil and Grease	300



MASSACHUSETTS WATER RESOURCES AUTHORITY

Permit No: 51005733 Permit Revision: 1

MWRA Category: 01 SIU

Permit Expiration Date: 08/15/2026

The Massachusetts Water Resources Authority and the Boston Water and Sewer Commission hereby jointly issue this permit. Pursuant to 360 C.M.R. 10.000 and the Boston Water and Sewer Commission Regulations Governing the Use of Sanitary and Combined Sewers and Storm Drains of the BWSC,

VA Boston Healthcare System - Jamaica Plain

150 S. Huntington Avenue

Jamaica Plain, MA 02130

is authorized to discharge wastewater into the MWRA Sewerage System through the Boston Water and Sewer Commission Sewerage System subject to the conditions set forth in this permit. The permittee shall not discharge any pollutant or pollutant properties or wastewater from any production operation, industrial process, or any source of discharge not identified in its Discharge Permit Application and this permit.

The issuance of a permit by the Authority shall not relieve the permittee of its obligation to comply with all applicable laws and regulations, including the Federal Water Pollution Control Act, 33 USC § 1251 et seq., and federal regulations promulgated thereunder, the Massachusetts Clean Waters Act, MGL c.21, § 26 et seq., and Massachusetts regulations promulgated thereunder, and 360 CMR 10.000, unless specifically modified by the permit.

Compliance with this permit does not relieve VA Boston Healthcare System - Jamaica Plain of its obligations to comply with all other applicable Local, State, and Federal pretreatment laws, regulations, standards and requirements, including those that may become effective during the term of this permit.

This permit does not relieve VA Boston Healthcare System - Jamaica Plain of its obligation to comply with the Massachusetts Department of Environmental Protection (DEP) regulations governing the classification of pretreatment systems and the certification of pretreatment system operators pursuant to 257 C.M.R. 2.00.

This Discharge Permit may be modified by the MWRA and the Municipality in accordance with 360 C.M.R. 10.007(7).


Failure to comply with any requirement of 360 C.M.R. 10.000 or any of the conditions of this permit may be cause for the MWRA to take enforcement measures pursuant to 360 C.M.R. 2.00, including but not limited to, immediate revocation of this permit.

This permit shall not be assigned or transferred without prior written approval of the MWRA and a copy of the permit is provided to the new owner or operator. If the permittee files a complete and accurate permit application for a renewal permit in accordance with 360 C.M.R. 10.007(6), a minimum of sixty (60) days prior to the expiration of the permit, the permit will not expire until a new permit is issued, the application is denied or the permit duration exceeds five years from the date of issuance, whichever occurs first. Permit applications must be hard copy and electronically by email to

TRACApplications@mwra.com.

APPROVED:

Boston Water and Sewer Commission


By: 

Francis McLaughlin

Manager of Engineering Customer Services

APPROVED:

Massachusetts Water Resources Authority

By: 

Matthew J. Dam

Director of Toxic Reduction and Control

Date: 8/27/2025

Date: 8/29/2025

Issued:

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

Sample Location and Self-Monitoring Requirements

Samples shall be taken of wastewater from the following specified locations. The permittee shall follow the sampling and reporting schedule(s) provided in this Part.

Sample Location 0103

Wastewater generated from the SPS area on the second floor of Building 1 shall be sampled from the spigot on the combined discharge line of the surgical tool cleaning devices in the SPS area, prior to mixing with any other streams.

If the permittee did not discharge wastewater to the sanitary sewer system during the required sampling period, the permittee shall submit a letter so indicating by the reporting due date.

The MWRA recommends an EPA analysis method for each pollutant listed in the Sampling and Reporting Schedule(s). The method may be one of a few that are approved by the EPA for a specific pollutant. A certified laboratory may substitute another method which is listed in 40 C.F.R. Part 136 for the pollutant being analyzed or if approved or otherwise authorized by the MWRA and EPA.

For a definition of the terms in the table, refer to the Definitions of Sampling and Reporting Terms found at the end of this permit.

Sampling and Reporting Schedule for Sample Location 0103

Pollutant/Parameter	Recommended EPA Analysis	Sample Type	Frequency	Reporting Frequency
Chromium (Total)	200.7	Composite (flow)	Semi-Annual	Semi-Annual
Copper (Total)	200.7	Composite (flow)	Semi-Annual	Semi-Annual
Flow	Field	Composite (flow)	Semi-Annual	Semi-Annual
Lead (Total)	200.7	Composite (flow)	Semi-Annual	Semi-Annual
Mercury (Total)	245.1	Composite (flow)	Semi-Annual	Semi-Annual
Nickel (Total)	200.7	Composite (flow)	Semi-Annual	Semi-Annual
Zinc (Total)	200.7	Composite (flow)	Semi-Annual	Semi-Annual
pH	SM 4500H+B	Grab	Semi-Annual	Semi-Annual

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

Sample Location 0104

Wastewater generated from the animal cage washer on the third floor of the Research Building 1A shall be sampled from the spigot on the discharge line of the animal cage washer, prior to mixing with any other streams.

If the permittee did not discharge wastewater to the sanitary sewer system during the required sampling period, the permittee shall submit a letter so indicating by the reporting due date.

The MWRA recommends an EPA analysis method for each pollutant listed in the Sampling and Reporting Schedule(s). The method may be one of a few that are approved by the EPA for a specific pollutant. A certified laboratory may substitute another method which is listed in 40 C.F.R. Part 136 for the pollutant being analyzed or if approved or otherwise authorized by the MWRA and EPA.

For a definition of the terms in the table, refer to the Definitions of Sampling and Reporting Terms found at the end of this permit.

Sampling and Reporting Schedule for Sample Location 0104

Pollutant/Parameter	Recommended EPA Analysis	Sample Type	Frequency	Reporting Frequency
Chromium (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Copper (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Flow	Field	Grab	Semi-Annual	Semi-Annual
Lead (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Nickel (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Zinc (Total)	200.7	Grab	Semi-Annual	Semi-Annual
pH	SM 4500H+B	Grab	Semi-Annual	Semi-Annual

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

Sample Location 0105

Wastewater generated from the steam sterilizer on first floor of Building 1A shall be sampled from the spigot on the discharge line of the steam sterilizer, prior to mixing with any other streams.

If the permittee did not discharge wastewater to the sanitary sewer system during the required sampling period, the permittee shall submit a letter so indicating by the reporting due date.

The MWRA recommends an EPA analysis method for each pollutant listed in the Sampling and Reporting Schedule(s). The method may be one of a few that are approved by the EPA for a specific pollutant. A certified laboratory may substitute another method which is listed in 40 C.F.R. Part 136 for the pollutant being analyzed or if approved or otherwise authorized by the MWRA and EPA.

For a definition of the terms in the table, refer to the Definitions of Sampling and Reporting Terms found at the end of this permit.

Sampling and Reporting Schedule for Sample Location 0105

Pollutant/Parameter	Recommended EPA Analysis	Sample Type	Frequency	Reporting Frequency
Copper (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Flow	Field	Grab	Semi-Annual	Semi-Annual
Lead (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Nickel (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Zinc (Total)	200.7	Grab	Semi-Annual	Semi-Annual
pH	SM 4500H+B	Grab	Semi-Annual	Semi-Annual

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

Sample Location 0107

Wastewater generated from washing endoscopy scopes in four scope washers and three pre-rinse sinks and one hand washing only sink, located in Room E5-114B on the fifth floor of Building 1, shall be sampled from the spigot situated in Room E4-112 on the fourth floor, prior to mixing with any other streams.

If the permittee did not discharge wastewater to the sanitary sewer system during the required sampling period, the permittee shall submit a letter so indicating by the reporting due date.

The MWRA recommends an EPA analysis method for each pollutant listed in the Sampling and Reporting Schedule(s). The method may be one of a few that are approved by the EPA for a specific pollutant. A certified laboratory may substitute another method which is listed in 40 C.F.R. Part 136 for the pollutant being analyzed or if approved or otherwise authorized by the MWRA and EPA.

For a definition of the terms in the table, refer to the Definitions of Sampling and Reporting Terms found at the end of this permit.

Sampling and Reporting Schedule for Sample Location 0107

Pollutant/Parameter	Recommended EPA Analysis	Sample Type	Frequency	Reporting Frequency
Copper (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Flow	Field	Grab	Semi-Annual	Semi-Annual
TTO (Extractable Organic Fraction)	625.1	Grab	Semi-Annual	Semi-Annual
Zinc (Total)	200.7	Grab	Semi-Annual	Semi-Annual
pH	SM 4500H+B	Grab	Semi-Annual	Semi-Annual

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

Sample Location 0108

Wastewater generated from the two glassware washers on first floor of Building 1A shall be sampled from the spigot on the discharge line of the two glassware washers, prior to mixing with any other streams.

If the permittee did not discharge wastewater to the sanitary sewer system during the required sampling period, the permittee shall submit a letter so indicating by the reporting due date.

The MWRA recommends an EPA analysis method for each pollutant listed in the Sampling and Reporting Schedule(s). The method may be one of a few that are approved by the EPA for a specific pollutant. A certified laboratory may substitute another method which is listed in 40 C.F.R. Part 136 for the pollutant being analyzed or if approved or otherwise authorized by the MWRA and EPA.

For a definition of the terms in the table, refer to the Definitions of Sampling and Reporting Terms found at the end of this permit.

Sampling and Reporting Schedule for Sample Location 0108

Pollutant/Parameter	Recommended EPA Analysis	Sample Type	Frequency	Reporting Frequency
Copper (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Flow	Field	Grab	Semi-Annual	Semi-Annual
Lead (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Nickel (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Zinc (Total)	200.7	Grab	Semi-Annual	Semi-Annual
pH	SM 4500H+B	Grab	Semi-Annual	Semi-Annual

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

Sample Location 0109

Wastewater generated from the Steris Amsco steam sterilizer on second floor of Building 1A shall be sampled from the spigot on the discharge line of the steam sterilizer, prior to mixing with any other streams.

If the permittee did not discharge wastewater to the sanitary sewer system during the required sampling period, the permittee shall submit a letter so indicating by the reporting due date.

The MWRA recommends an EPA analysis method for each pollutant listed in the Sampling and Reporting Schedule(s). The method may be one of a few that are approved by the EPA for a specific pollutant. A certified laboratory may substitute another method which is listed in 40 C.F.R. Part 136 for the pollutant being analyzed or if approved or otherwise authorized by the MWRA and EPA.

For a definition of the terms in the table, refer to the Definitions of Sampling and Reporting Terms found at the end of this permit.

Sampling and Reporting Schedule for Sample Location 0109

Pollutant/Parameter	Recommended EPA Analysis	Sample Type	Frequency	Reporting Frequency
Copper (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Flow	Field	Grab	Semi-Annual	Semi-Annual
Lead (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Nickel (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Zinc (Total)	200.7	Grab	Semi-Annual	Semi-Annual
pH	SM 4500H+B	Grab	Semi-Annual	Semi-Annual

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

Sample Location 0201

Wastewater generated from the clinical lab instruments in Room B2-61A on the second floor of Building 1 shall be sampled from the spigot on the combined discharge line of the instruments, prior to mixing with any other streams.

If the permittee did not discharge wastewater to the sanitary sewer system during the required sampling period, the permittee shall submit a letter so indicating by the reporting due date.

The MWRA recommends an EPA analysis method for each pollutant listed in the Sampling and Reporting Schedule(s). The method may be one of a few that are approved by the EPA for a specific pollutant. A certified laboratory may substitute another method which is listed in 40 C.F.R. Part 136 for the pollutant being analyzed or if approved or otherwise authorized by the MWRA and EPA.

For a definition of the terms in the table, refer to the Definitions of Sampling and Reporting Terms found at the end of this permit.

Sampling and Reporting Schedule for Sample Location 0201

Pollutant/Parameter	Recommended EPA Analysis	Sample Type	Frequency	Reporting Frequency
Copper (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Flow	Field	Grab	Semi-Annual	Semi-Annual
Formaldehyde *	1667A	Grab	Semi-Annual	Semi-Annual
Lead (Total)	200.7	Grab	Semi-Annual	Semi-Annual
Mercury (Total)	245.1	Grab	Semi-Annual	Semi-Annual
TTO (Volatile Organic Fraction)	624.1	Grab	Semi-Annual	Semi-Annual
Zinc (Total)	200.7	Grab	Semi-Annual	Semi-Annual
pH	150.2	Grab	Semi-Annual	Semi-Annual

*Formaldehyde must be analyzed using MWRA's High Performance Liquid Chromatography (HPLC) method.

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

General Sampling and Analysis Requirements

Sampling

All samples and measurements collected for the purpose of this permit shall be representative of the typical volume and nature of the permittee's discharge. The discharge shall be free of any uncontaminated water, sanitary wastes, or other non-process water. Samples shall be collected, preserved, and handled in accordance with the procedures established in 40 C.F.R. Part 136 and amendments.

The permittee shall not manipulate its sampling schedule to avoid taking samples that may contain discharge violations, such as on days of higher or lower production, on days of unusual production, or when the permittee otherwise has or should have information that violations may occur.

Sampling required by the MWRA shall be performed by an independent laboratory with DEP certification or accreditation from the EPA's National Environmental Laboratory Accreditation Program (NELAP).

All samples collected for the purpose of this permit shall be transported to the laboratory accompanied by completed MWRA chain of custody forms that have been filled out by the individual who collected the samples.

Sample locations shall be safely located and accessible to MWRA staff and monitoring equipment. Wastewater measuring devices, which the MWRA reserves the right to approve, shall be compatible with MWRA monitoring equipment. In addition, the devices shall be properly maintained and calibrated at all times to ensure measurement accuracy.

If the permittee samples more frequently than required in this permit, for any pollutant being discharged, using test procedures prescribed in 40 C.F.R. Part 136 or other United States Environmental Protection Agency (EPA) approved methods, the results of such monitoring shall be submitted to the MWRA, in accordance with the procedures required for submitting sampling reports.

Certification that a Grab Sample is Representative

The following is an exception to the composite(VOA), composite(Cr+6) and composite(CN) requirements (see Definitions of Sampling and Reporting Terms found at the end of this permit):

You may submit the analysis of a single grab sample for TTO(volatil organic fraction), cyanide, and hexavalent chromium, if you believe that a single grab sample is representative of the daily process discharge at the sample location. **Please be aware that if you submit the analysis of a single grab sample to the MWRA for TTO (volatile organic fraction), hexavalent chromium, and/or cyanide, the submittal of the chain of custody will serve as certification from you that a grab sample is representative of your daily discharge at the sample location.** If you provide such certification, the MWRA reserves the right to take one grab sample to measure compliance with the limit for that pollutant/parameter.

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

Analysis

Analysis required by the MWRA shall be performed by a DEP certified independent or NELAP accredited laboratory that is fully certified for the pollutants being analyzed unless otherwise specified or approved by the MWRA. The use of a laboratory with provisional DEP certification is prohibited for the parameters for which it has provisional certification, unless the Authority determines that the factors resulting in the provisional certification should not adversely affect the quality of the analyses the laboratory may submit. A sample analysis performed by a laboratory without DEP certification or NELAP accreditation for the parameter may be submitted with the approval of the Authority. The Authority may grant such approval where DEP does not certify and NELAP does not accredit for the parameter to be analyzed, there is no DEP certified or NELAP accredited laboratory in Massachusetts or an adjoining state that performs the required test method, or in other extraordinary circumstances. The Authority may require a Permittee to submit a copy of the "Massachusetts Certification for Chemical Analysis of Waters" or the NELAP Certification of Accreditation, whichever is applicable, for each laboratory that performs an analysis submitted to the Authority by or on behalf of the Permittee. The Authority may limit the laboratories a Permittee may use for any report required by the Authority. The Authority may specify the quality assurance/quality control methods to be performed by a laboratory for any report required by the Authority. Analysis for wastewater pollutants and parameters shall be conducted in accordance with applicable procedures approved by the United States Environmental Protection Agency (EPA) included in 40 C.F.R. Part 136, unless otherwise authorized or required by the Authority and EPA. If there is no applicable EPA approved procedure, the Authority may specify a procedure to be used.

Reporting Procedures for Self-Monitoring Requirements

All analyses done pursuant to this permit must be submitted to the MWRA. A report not submitted as required by this reporting procedure shall be considered a non-report, subjecting the permittee to enforcement action. The Authority may require that analytical data and reports, including a complete data package, be submitted to it directly by the laboratory that performed that analyses (See 360 C.M.R. 10.008(2)(g)).

Electronic Submittal of Self-Monitoring Results

All wastewater sampling and analysis reports required by this permit must be submitted to the MWRA electronically by the permittee or its laboratory, utilizing the Pretreatment Information Management System Web Self-Monitoring Report (Web SMR) available at <http://websmr.mwra.com/>.

Chains of Custody/Field Forms

The chains of custody/field forms enclosed with this permit shall be copied and used to document pertinent sampling information. The chains of custody/field forms shall be completed by the person who took the samples and then accompany the samples to the laboratory for analysis. Any time the samples are transferred from one individual to another during the transport and laboratory analysis of the samples, the person relinquishing the samples shall sign his/her name and indicate his/her name and the date and time the samples were relinquished, on

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

the bottom of the form. The receiving person must also sign and date the forms in the appropriate box. There should be one chain of custody/field form for grab samples collected and one chain of custody/field form for composite samples collected for each sample location.

Wastewater Sampling Analysis Reports Submittal/Laboratory Certification Forms

The permittee must: a) assure that the laboratory provides the permittee with a copy of the data and corresponding chains of custody/field forms the laboratory submits to the MWRA, no later than the day the laboratory submits the electronic report to the MWRA; and b) shall have on file with the MWRA a current Sample Analyses and Reporting Certification Form provided by the MWRA (copy attached), signed and dated by the Authorized Representative of the permittee, authorizing the electronic data submittal from a laboratory and certifying the results. The permittee must thereafter submit a newly signed and dated certification form whenever it changes its Authorized Representative.

Certification Form/Authorized Representative

The permittee shall submit the Sample Analyses and Reporting Certification Form required by this permit. Each certification form shall be signed and dated by an Authorized Representative of the permittee. An Authorized Representative is a:

- (a) Responsible corporate officer, if the permittee is a corporation. For the purpose of this requirement, a responsible corporate officer means a president, secretary, treasurer, or vice president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or the manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiate and direct other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; can ensure that the necessary systems are established or actions taken to gather complete and accurate information for the permit requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
- (b) General partner or proprietor if the permittee is a partnership or sole proprietorship respectively.
- (c) Duly authorized representative of the individual designated in (a) or (b) of this section if:
 - i) the authorization is made in writing by the individual described in (a) or (b);
 - ii) the authorization specifies either an individual or a position having responsibility for the overall operation of the facility from which the industrial discharge originates, such as the position of plant manager, operator of a well, or well field superintendent, or a position of equivalent responsibility, or having overall responsibility for environmental matters for the company;
 - iii) the written authorization is submitted to the MWRA

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, or overall responsibility for environmental matters for the permittee, a new authorization satisfying the requirements of this section must be submitted to the MWRA prior to or together with the next report required of the permittee.

Reports and Records You Must Submit

Facility-Wide:

D1 Biennial Compliance Report

D1 Biennial Compliance Report:

The permittee shall submit a Biennial Compliance Report for Dental Dischargers to the MWRA by April 30 every two years, on even calendar years, on a report provided by the MWRA. The MWRA will provide the report by March 15 every two years. You must contact the MWRA by March 31 if you do not receive the Compliance Report so that a form may be provided to you.

Reports, Records and Devices You Must Maintain at Your Facility

Facility-Wide:

Laboratory Chemicals Management Plan:

The permittee shall have and implement a written laboratory chemicals management plan to control the discharge of regulated materials to the sewer system. Regulated materials are those that contain pollutants regulated by the MWRA at 360 C.M.R. § 10.021-10.024. At a minimum, the plan shall include procedures to:

- A. Ensure that regulated materials do not spill or leak into the sewer system;
- B. Eliminate or minimize the disposal of regulated materials to the sewer system so that MWRA discharge limits are met;
- C. Properly handle, store, collect, and dispose of laboratory chemicals and maintain disposal manifests;
- D. Train laboratory employees in proper laboratory chemical usage and disposal; and,
- E. Ensure that the laboratory chemicals management plan is followed by, among other measures, posting appropriate notices of proper chemicals usage and disposal practices at sinks where laboratory chemicals are used.

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

Hazardous Waste Manifests:

The permittee shall maintain copies of manifests for hazardous waste hauled away from the premises for a period of three (3) years. They shall be made available and copies shall be provided to the MWRA upon request.

Slug Control Plan:

The permittee shall have and implement a written Slug Control Plan to control slug discharges to the sewer system. For the purpose of this requirement, a slug is any discharge of a non-routine, episodic nature, including but not limited to an accidental spill or a non-customary batch discharge. The plan shall contain, at a minimum, the following elements:

- A) Description of discharge practices, including non-routine batch discharges;
- B) Description of stored chemicals;
- C) Procedures for immediately notifying the MWRA of slug discharges, including any discharge that would violate a prohibition under 40 CFR 403.5(b), with procedures for follow-up written notification within five (5) days;
- D) If necessary, procedures to prevent adverse impact from accidental spills, including inspection and maintenance of storage areas, handling and transfer of materials, loading and unloading operations, control of plant site run-off, worker training, building of containment structures or equipment, measures for containing toxic organic pollutants (including solvents), and/or measures and equipment for emergency response.

Additional Requirements

Facility-Wide:

Other

Authorization to Discharge:

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

In addition to the wastewater discharged via Sample Locations 0103, 0104, 0105, 0107, 0108, and 0109, the MWRA authorizes the permittee to discharge, via sanitary sewer, process wastewater from the patient dialysis in Building 7. Currently, the MWRA has determined that this wastewater do not contain regulated pollutants that would potentially violate 360 C.M.R. 10.023- 10.024; therefore, the permittee is not required to conduct regular sampling of the wastewater. The MWRA may require the permittee to sample and analyze the identified wastewater to determine compliance with 360 C.M.R. 10.023- 10.024.

Authorized Discharge

Facility-Wide:

Reverse Osmosis Reject/Filter Backwash Discharge:

Pursuant to 360 C.M.R. 10.023(2)(a) and 10.023(19), and effective permit issuance, the MWRA granted authorization to the permittee to discharge RO reject water and sandfilter backwash to the sanitary sewer. The analytical results submitted with the permittee's request indicated that the discharge does not violate MWRA limits. Options for recycling/reuse of the stream do not exist and discharge to a storm drain or surface water body is not an option. Therefore, MWRA hereby accepts the discharge of the RO reject water and sandfilter backwash.

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

Sampling Records

VA Boston Healthcare System - Jamaica Plain shall maintain accurate records of all monitoring activities including:

- a. date, exact place, time, and methods of sampling or measurements, and sample preservation techniques or procedures;
- b. name of the person performing the sampling or measurements;
- c. date(s) analyses were performed;
- d. name of person performing the analysis;
- e. analytical techniques or methods used, detection limit, analysis/extraction date;
- f. results of the analyses; and
- g. laboratory quality control/quality assurance documentation for the analysis performed.

The permittee shall retain records of all monitoring activities for at least three years. This includes calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of reports required by this permit, and information used to complete the Permit Application. This period may be extended by notice from the MWRA at any time. In addition, the MWRA may examine or require the submittal of records upon request in accordance with 360 C.M.R. 10.010(3).

When You Should Notify the MWRA

Notification of Discharge of Hazardous Waste

The permittee shall provide the notifications required by 40 CFR 403.12(p) by the dates indicated in that section. This requires certain written reports by the permittee if it discharges into the MWRA Sewer System certain substances which if otherwise disposed of would be a hazardous waste under 40 CFR Part 261.

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

Giving Notice and Resampling in the Event of a Violation

If sampling performed by the permittee pursuant to this permit indicates a violation of the discharge limits and prohibitions, the permittee shall notify the MWRA at (617) 242-6000, and request Toxic Reduction and Control within 24 hours of becoming aware of the violation that it has noted the existence of the violation. The permittee shall submit to the MWRA the report containing the violation. The permittee shall also repeat the sampling and analysis and submit the results of the repeat analysis to the MWRA within 30 days of becoming aware of the violation, except the permittee is not required to resample if: (a) the MWRA samples the permittee at least once a month; or (b) the MWRA sampled the permittee between the time of the sampling that contained the violation and the time the permittee received the results of the sampling showing the violation. If the permittee believes it meets an exception to resampling, it shall request confirmation from the MWRA and shall resample unless confirmation is given.

Notification of Upsets

The permittee shall notify the MWRA and the Municipality within 24 hours of becoming aware of an Upset at its facility. During normal business hours the MWRA should be notified by telephone at (617) 242-6000, and request Toxic Reduction and Control. At all other times the MWRA should be notified by telephone at (617) 305-5940 after 5:00 p.m. Monday - Friday or weekends and holidays. This notification shall be followed, within 5 days of the date of occurrence, by a detailed written statement to the MWRA and the Municipality describing the causes of such discharge and the measures being taken to prevent future occurrence.

For the purposes of this section, Upset means an exceptional incident in which there is unintentional and temporary noncompliance with the discharge standards of 360 CMR 10.000, or any permit thereunder, because of factors beyond the reasonable control of the permittee. An Upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. An Upset shall constitute an affirmative defense to an action brought for noncompliance with categorical Pretreatment Standards if the requirements of paragraph below are met.

A permittee who wishes to establish the affirmative defense of Upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An Upset occurred and the permittee can identify the cause(s) of the Upset;
- (2) The facility was at the time being operated in a prudent and workman-like manner and in compliance with applicable operation and maintenance procedures;
- (3) The permittee has submitted the following information to the MWRA and the Municipality within 24 hours of becoming aware of the Upset (if this information is provided orally, a written submission must be provided within five days):
 - (i) A description of the discharge and cause of noncompliance;

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

(ii) The period of noncompliance, including exact dates and times or, if not corrected, the anticipated time the noncompliance is expected to continue;

(iii) Steps being taken and/or planned to reduce, eliminate and prevent recurrence of the noncompliance.

In any enforcement proceeding the permittee seeking to establish the occurrence of an Upset shall have the burden of proof.

In the usual exercise of prosecutorial discretion, MWRA enforcement personnel should review any claims that non-compliance was caused by an Upset. No determinations made in the course of the review constitute final MWRA action subject to judicial review. The permittee will have the opportunity for a judicial determination on any claim of Upset only in an enforcement action brought for noncompliance with 360 CMR 10.000.

The permittee shall control production or all discharges to the extent necessary to maintain compliance with 360 CMR 10.000 upon reduction, loss, or failure of its treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost or fails.

Notification of Noncomplying Discharges (Accidents, Slug Loads, Spills)

The permittee shall notify the MWRA and the Municipality immediately by telephone upon the occurrence of an accidental discharge of substances prohibited or limited by this permit or by 360 C.M.R. 10.021 - 10.024, or of any slug loads or spills that may reasonably be expected to enter the sanitary sewer from the permittee's facility. During normal business hours the MWRA should be notified by telephone at (617) 242-6000, and request Toxic Reduction and Control. At all other times the MWRA should be notified by telephone at (617) 305-5940 after 5:00 p.m. Monday - Friday or weekends and holidays. The notification shall include location of the discharge, date and time thereof, type of waste, including concentration and volume, and corrective actions taken. The permittee's notification of accidental release in accordance with this section does not relieve it of other reporting requirements that arise under local, State, or Federal laws, regulations, or this permit.

This notification shall be followed, within 15 calendar days of the date of occurrence, by a detailed written statement to the MWRA and the Municipality describing the causes of such discharge and the measures being taken to prevent future occurrence.

The notification shall provide the following information:

- (1) Description of the discharge, type of waste, concentration and volume.
- (2) Duration of noncompliance, including exact dates and, if the noncompliance continues, the time by which compliance is reasonably expected to occur.

Sewer Use Discharge Permit

PART A – SAMPLING, REPORTING AND OTHER REQUIREMENTS

- (3) All steps taken or to be taken to reduce, eliminate, and prevent recurrence of such a condition of noncompliance.

Duty to Notify of Actions which May Substantially change the Volume or Nature of a Discharge

The permittee shall provide at least 30 days advance written notification to the Authority before taking any action which may substantially change the volume or nature of its discharge, including a substantial change in the volume or character of pollutants in its discharge, from any compliance measurement location, or from any sewer connection. Such actions may include, but not be limited to, the following:

- a) substantial expansion or contraction of the facility from which the discharge originates;
- b) substantial increase or decrease in production;
- c) modification of any process;
- d) alteration of the Pretreatment system or the operation of the Pretreatment system; or
- e) discharge from a different or relocated sewer connection.
- f) changes that require the permittee to modify or implement a plan to control slug discharges as defined by 40 C.F.R. §403.8

Mailing and Email Address for Reports and Notifications

All documents and materials required to be submitted shall be mailed to:

Massachusetts Water Resources Authority
2 Griffin Way
Chelsea, MA 02150
Attn.: Toxic Reduction and Control

In addition to your hard copy submittal, all reports and materials required by your permit shall also be submitted as an attachment to an email submitted to:

TRACPermits@mwra.com

The electronic copy of each individual report required by your permit must be submitted as a single pdf file. The file name must include your permit number, the report type (i.e., pH log, Compliance Report), and the sampling location number and the date range covered in the report where applicable (example file names are: 12345678_pHlog_101_0321to0421.pdf and 12345678_ComplianceReport.pdf). The same information (permit number, report type, sample location, and date range) should be included in the subject line of your email. **Do not** send a single pdf that includes multiple documents (for example, a flow log and a pH log). Each report should be submitted as an individual file. If the files are too large to email, please send an email to TRACPermits@mwra.com and request a link to the MWRA file share.

All submittals shall include a completed TRAC submittal form. A copy of the TRAC submittal form is attached to this permit. It should be photocopied as needed.

Sewer Use Discharge Permit

PART B DISCHARGE LIMITATIONS

The permittee shall comply with the most stringent of the EPA National Categorical Pretreatment Standards, State or Local requirements, or the limits and prohibitions contained in 360 C.M.R. 10.023 and 10.024. If the National Categorical Pretreatment Standards includes a monthly, weekly or production based limit, that limit must be met in addition to the most stringent of the maximum for one day and daily average limits.

Most Stringent Limitations

Sample Location : 0103, 0104, 0105, 0107, 0108, 0109, 0201

The MWRA has determined that the sample location(s) are not subject to the National Categorical Pretreatment Standards as set by the EPA. MWRA limits apply as the most stringent limits.

MWRA Discharge Limitations

The Permittee shall comply with the Specific Discharge Limitations/Local Limits contained in the MWRA Sewer Use Rules and Regulations, 360 C.M.R. 10.024, and listed below, at all sample locations where these limits are designated as the most stringent limits.

Pollutant	Daily Maximum Limit (mg/l)
1,1-Dichloroethylene	0.3
Acrolein	0.15
Antimony (Total)	10.0
Arsenic (Total)	0.5
Benzene	0.3
Cadmium (Total)	0.1
Chromium (+6)	0.5
Chromium (Total)	1.0
Copper (Total)	1.0
Cyanide (Total)	0.5
Each Toxic Organic (Unless Elsewhere Limited In 360 CMR 10.000)	1.0
Formaldehyde	9.0
Hexachlorobutadiene	Prohibited
Lead (Total)	0.2
Mercury (Total)	Prohibited
Nickel (Total)	1.0
PCB's	Prohibited
Pesticides	Prohibited
Phenol	5.0
Selenium (Total)	5.0
Silver (Total)	2.0
TTO	5.0
Vinyl Chloride (Chloroethylene)	0.02
Zinc (Total)	1.0

Sewer Use Discharge Permit**PART B DISCHARGE LIMITATIONS**

Pollutant	Instantaneous Limit (DEG C)
Temperature	82

Pollutant	Instantaneous Limit (S.U.)
pH	must remain between 5.5 - 12.0 standard units

Pollutant	Instantaneous Limit (mg/l)
Oil and Grease	300

The permittee shall comply with the limits and prohibitions set forth in Part B according to the sample type required by the Sampling and Reporting Schedules of Part A.

Sewer Use Discharge Permit

PART B DISCHARGE LIMITATIONS

Specific Prohibitions

The permittee shall comply with all the Specific Prohibitions contained in the MWRA Sewer Use Regulations, 360 C.M.R. 10.023.

No Person shall discharge, or cause or allow to be discharged, directly or indirectly, into the Authority Sewerage System, any of the following:

1. Groundwater, storm water, surface water, roof or surface runoff, tidewater, or subsurface drainage, except construction site dewatering in a combined sewer area when permitted by the Authority and municipality.
2. Non-contact Cooling Water, non-contact industrial process water, uncontaminated Contact Cooling Water and uncontaminated industrial process water, except:
 - a) as permitted by the Authority when the discharger has taken all reasonable efforts to eliminate and minimize the flow, there is not reasonable access to a storm sewer, surface water, or another disposal alternative, and the amount to be discharged will not have an actual or potential adverse impact on the sewer system, the treatment plant, the quality of the receiving water, or the Authority's ability to meet its obligations under any law, regulation, permit, or order; and
 - b) cooling tower blowdown.
3. Fuel oil, crude oil, lubricating oil, or any other oil or grease of hydrocarbon or petroleum origin except:
 - a) in compliance with the limit for fats, wax, oil and grease in 360 CMR 10.023(10);
 - b) in compliance with the prohibitions and limits in 360 CMR 10.024;
 - c) when discharged:
 - i) incidental to an industrial process in Industrial Waste authorized to be discharged by a permit issued by the Authority;
 - ii) incidental to the appropriate use of a gas/oil separator that is in compliance with 360 CMR 10.016 when a permit is not required by 360 CMR 10.000; or
 - iii) in de minimis amounts and not from the disposal of waste, used, excess, or unwanted oil or grease when neither a permit nor a gas/oil separator are required by 360 CMR 10.000; and
 - d) otherwise in compliance with 360 CMR 10.000.
4. Any liquid, solid or gas, including, but not limited to, gasoline, kerosene, naphtha, benzene, toluene, xylene, ethers, alcohols, ketones, aldehydes, peroxides, and methyl ethyl ketone, which by reason of its nature or quantity is, or may be sufficient either alone or by interaction with other substances to create a fire or explosion hazard or to be otherwise injurious to a Municipal Sewerage System, the Authority Sewerage System, Treatment System, or to Receiving Waters, including:
 - a) Wastewater with a closed cup flashpoint of less than 140°F (60°C) using the test methods specified in 40 CFR 261.21, and measured at the point of indirect discharge to the Authority Sewerage System, or at such other place as the Authority determines; or

Sewer Use Discharge Permit

PART B DISCHARGE LIMITATIONS

- b) Any Pollutant which causes an exceedance of 10% of the lower explosive limit as measured by an explosimeter at the point of discharge to the sewer or at any point within the Sewer.
5. Any noxious or malodorous liquid, gas, or solid or any other pollutant which either singly or by interaction with other Waste causes or contributes to the creation of a public nuisance, makes it dangerous for personnel or equipment to enter the Sewer for purposes of maintenance, repair, inspection, sampling, or any other similar activity, or which results in the presence of toxic gases, vapors, or fumes within the Authority Sewerage System or Municipal Sewer in a quantity that may cause acute worker health and safety problems.
 6. Any Water or Wastewater with a pH lower than 5.5 or higher than 12.0 or with any corrosive or injurious property which may cause damage or be hazardous to the Sewer, the Sewerage System, the Treatment System, or any person.
 If a Person continuously measures the pH of its wastewater by a properly located, installed, calibrated, maintained, and operated pH measurement system, the pH of the wastewater shall be maintained as required by the Authority, except excursions below a pH of 5.5 are permitted subject to the following limitations:
 - a) The total time during which the pH values are below 5.5 shall not exceed seven hours in any calendar month;
 - b) No individual excursion from the range of required pH values shall exceed 60 minutes; and
 - c) The excursion may not be below a pH of 5.0.
 For purposes of 360 CMR 10.023(6), an excursion is an unintentional and temporary incident in which the pH value of discharged wastewater is below the range required by the Authority. The Authority may, by permit or order, reduce the permissible excursion times or eliminate the right to an excursion, as it deems appropriate, based on the treatment system, flow, sewer system needs, and discharge history of the Person.
 7. Any water or Wastewater, not otherwise governed by 360 CMR 10.000, containing pollutants at levels which may adversely affect the Authority's ability to process and/or dispose of its Wastewater Residuals in an environmentally sound and economic manner in accordance with applicable state and federal requirements.
 8. Any solid or viscous substance in an amount or size which obstructs or may obstruct the flow in any Sewers, or which causes or may cause an interference including but not limited to: sand, mud, metal, glass, wood, plastics, Improperly Shredded Garbage, rubber, latex, lime or other slurries, grease, animal guts or tissues, bones, hair, hides or fleshings, entrails, feathers, ashes, cinders, stone or marble dust, straw, shavings, grass clippings, rags, spent grains, spent hops, tar, asphalt residues, residues from refining or processing fuel or lubrication oil, or glass grinding or polishing Wastes.
 9. Any liquid or vapor with a temperature higher than 180°F (82°C), unless the Authority approves an alternative temperature limit; however, in no case may any Person discharge heat in such quantity that it causes or may cause the temperature at the Authority's Sewage Treatment Facility to exceed 104°F (40°C).

Sewer Use Discharge Permit

PART B DISCHARGE LIMITATIONS

10. Any water or Waste containing fats, wax, oil, and grease, in excess of 300 mg/l (based on the materials recovered in the applicable EPA approved procedure, unless otherwise authorized or required by the Authority and EPA), or containing any substance which may solidify or become viscous at temperatures between 32°F (0°C) and 180°F (82°C). Waters or Wastes containing such substances, excluding normal household Waste, shall exclude all visible floating oils, fats and greases. The use of chemical, biological, or physical means to bypass or to release fats, wax, oil, and grease into the sewer is prohibited. If a Person is unable to comply with the 300 mg/l requirement after reasonable pretreatment measures, the Authority may increase the limit on a case by case basis if the Authority and appropriate Municipality are satisfied that such increase will not contribute to nuisance conditions or an adverse impact on the Sewerage System, Receiving Waters, or the Authority's Wastewater Residuals program. In no circumstance will the Authority increase the limit to allow a discharge of more than 300 mg/l of oil or grease of hydrocarbon or petroleum origin, including fuel oil, crude oil, and lubricating oil. The Authority may apply a monetary charge to any increase in the 300 mg/l limit to recover the costs it reasonably expects to incur as a result of the increase.
11. Waste or Wastewater discharged through a Bypass, unless such discharge through the Bypass was approved in advance by the Authority, or the discharge through the Bypass is allowed by 40 CFR 403.17 and the Person using the Bypass provided to the Authority the notices required by 40 CFR 403.17. Specific requirements are described in Part C of this permit.
12. Any radioactive Waste or isotope with a half-life or concentration in excess of any limit established by federal or state law.
13. Any Sludge, except from:
 - (a) a water treatment plant owned and operated by a municipality, or by a water district created by a special or general act of the Massachusetts Legislature, and when specifically permitted by the Authority pursuant to 360 CMR 10.057; or
 - (b) a Reclaimed Water System, provided the Reclaimed Water System:
 1. treats only Wastewater that does not require an active permit as described in 360 CMR 10.007(1)(a), (e), (f), (g), (h), or (i) for discharge into the Authority's Sewerage System,
 2. has a Discharge into a Municipal Sewer within the Authority Sewerage District,
 3. has been issued a permit pursuant to 314 CMR 20.00: *Reclaimed Water Permit Program and Standards*, and
 4. has been specifically permitted by the Authority and the Municipality into which it discharges pursuant to 360 CMR 10.051 through 10.056.
14. Any substance, including dye water or any vegetable tanning solution, which causes turbidity or discoloration such that the color of the wastewater at the Authority Sewage Treatment Facility changes noticeably.
15. Any Slug.
16. Any Hazardous Waste, or any Wastewater which results from the treatment of Hazardous Waste, and is discharged to the Authority Sewerage System by dedicated pipe, truck, rail, or by other method.

Sewer Use Discharge Permit

PART B DISCHARGE LIMITATIONS

17. Septage containing Hazardous Waste, Septage from haulers other than those permitted under 360 CMR 10.000, or Septage discharged at a location not designated as a Septage discharge location in the Municipal permit issued by the Authority to the Municipality where the discharge took place.
18. Any substance containing pathogenic organisms in such quantities as determined by local, state and/or federal law as hazardous to the public health or the environment, including but not limited to any "Infectious or Physically Dangerous Medical or Biological Waste" as defined and identified by the Massachusetts Department of Public Health in 105 CMR 480.010: *Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste, State Sanitary Code Chapter VIII*, and whose disposal via the municipal Sewerage System or via a septic system is prohibited by 105 CMR 480.200.
19. Any filter backwash not specifically authorized to be discharged by a permit issued to the discharger by the Authority; any filter backwash that is not treated to meet the limits and prohibitions of 360 CMR 10.000; or, any filter backwash which causes or contributes to a violation of 360 CMR 10.021 through 10.025.
20. Any trucked or hauled pollutants except at discharge points designated by the Authority in a permit issued by the Authority for the discharge.
21. Wastes or Wastewater from outside the Authority Sewerage District, unless the wastes or wastewater is discharged with the Authority's approval and pursuant to the Authority policy for sewer connections serving property partially located in a non-Authority community or for requests for sewer service to locations outside MWRA's sewer service area, including, where necessary, a general or special law authorizing the discharge from a location outside the MWRA sewer service area.
22. Oxygen-demanding pollutants (BOD *etc.*), released in a flow rate and/or pollutant concentration which, either singly or by interaction with other pollutants, will cause interference with the POTW.

Boston Water and Sewer Commission Regulations

Boston Water and Sewer Commission has established regulations which apply to dischargers into Boston's city sewers; these regulations may be more stringent than the MWRA regulations, and the permittee should contact Boston Water and Sewer Commission to ensure that it is in compliance with these requirements.

The Permittee shall comply with the following Boston Water and Sewer Commission Regulations:

1. Grease traps approved by the Boston Water and Sewer Commission are required on building sewers into which significant amounts of animal or vegetable fat, oil or grease are discharged, so that a discharge concentration does not exceed 100 milligrams per liter.
2. Any garbage containing particles larger than one-half inch (1.27 centimeters) in any dimension or particles which will not be carried freely in the wastewater system are prohibited.

Sewer Use Discharge Permit

PART B DISCHARGE LIMITATIONS

Dilution Prohibition

The attempt to achieve compliance with the discharge limitations of these regulations by dilution, including increased use of process water, as a substitution for adequate treatment is prohibited.

Sewer Use Discharge Permit

PART C REGULATORY NOTICES

The permittee shall comply with all requirements contained in the MWRA Sewer Use Regulations, 360 C.M.R. 10.000. Those requirements include, but are not limited to, compliance with:

Pretreatment

The permittee shall provide pretreatment as is required to comply with this permit. When a pretreatment facility is required, it shall be constructed and maintained continuously in satisfactory and effective operation by the permittee at its own expense.

Operators of individual Wastewater Pretreatment facilities must possess the appropriate operators' licenses required by applicable state law or regulations including, without limitation, 257 C.M.R. 2.00.

Bypass Prohibition

A bypass is an intentional or negligent diversion of a wastestream to the MWRA sewer system (by direct or indirect means) from any portion of the permittee's pretreatment facility, or from any industrial process or other source of wastewater prior to pretreatment. A bypass is prohibited unless it meets the criteria listed in 40 CFR § 403.17, described below. Further, no pretreatment facility, production line, or other source of wastewater shall be designed, installed, modified, or operated to allow for a bypass of all or a portion of its pretreatment equipment.

40 CFR § 403.17 provides as follows:

(a) Definitions.

- (1) Bypass means the intentional diversion of wastestreams from any portion of the Permittee's treatment facility.
- (2) Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

(b) Bypass not violating applicable Pretreatment Standards or Requirements. The Permittee may allow any bypass to occur which does not cause Pretreatment Standards or Requirements to be violated, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provision of paragraphs (c) and (d) of this section.

(c) Notice.

- (1) If the Permittee knows in advance of the need for a bypass, it shall submit prior notice to the Authority, if possible at least ten days before the date of the bypass.
- (2) The Permittee shall submit oral notice of an unanticipated bypass that exceeds applicable Pretreatment Standards to the MWRA within 24 hours from the time the

Sewer Use Discharge Permit

PART C REGULATORY NOTICES

Permittee becomes aware of the bypass. A written submission shall also be provided within 5 days of the time the Permittee becomes aware of the bypass. The written submission shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times, and, if the bypass has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass. The MWRA may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

(d) Prohibition of bypass.

(1) Bypass is prohibited, and the MWRA may take enforcement action against the Permittee for a bypass, unless:

- (i) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- (ii) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance; and
- (iii) The Permittee submitted notices as required under paragraph (c) of this section.

(2) The MWRA may approve an anticipated bypass, after considering its adverse effects, if the MWRA determines that it will meet the three conditions listed in paragraph (d)(1) of this section.

Right of Entry

The permittee shall allow representatives of the MWRA, Municipality, DEP, and EPA ready access during business hours and any other reasonable time to all parts of the premises where wastewater is generated or discharged or in which records are required to be kept under 40 C.F.R. 403.12(o), or 360 CMR 10.010 for inspection, sampling or record examination and copying, or in performance of any of their duties.

Duty to Mitigate

The permittee shall take all reasonable steps to minimize or correct any adverse impact to the MWRA treatment plants or the environment resulting from noncompliance with this permit, including such accelerated or additional monitoring as necessary to determine the nature and impact of the noncomplying discharge.

Enforcement/Litigation Records

All records that pertain to matters that are the subject of special orders or any other enforcement or litigation activities brought by the MWRA shall be retained and preserved by the permittee for a minimum of three years or until all enforcement activities have concluded and all periods of limitation with respect to any and all appeals have expired, whichever is longer.

Sewer Use Discharge Permit

PART C REGULATORY NOTICES

Posting Requirements

The permittee shall inform its employees of the existence of the MWRA Sewer Use Rules and Regulations, 360 C.M.R. 10.000, and this permit, and at least one copy of each shall be permanently posted on the permittee's bulletin board. The permittee shall permanently post a notice clearly visible at all times on the permittee's bulletin board, which lists the individual responsible for compliance with MWRA regulations and whom should be notified of any upsets or noncomplying discharges. The permittee shall distribute a copy of this Permit to each employee working in pretreatment operations.

Confidentiality

In accordance with 40 C.F.R. 403.14 and 360 CMR 10.011, information and data provided in this permit and the reports submitted in accordance with this permit which identifies the nature and frequency of discharge shall be available to the public without restriction. Requests for confidential treatment of other information shall be governed by procedures specified in 360 CMR 10.011.

Signatories

All applications for permits, monitoring, discharge, and compliance reports and all other notifications required under this permit shall be signed by an Authorized Representative of the permittee as described in 40 CFR 403.12(l).

Disposal of Sludge and Hazardous Wastes

The permittee shall comply with the State and Federal regulations: Section 405 of the Clean Water Act, Subtitle C and D of the Resource Conservation and Recovery Act and Massachusetts Hazardous Waste Regulations 310 C.M.R. 30.000 with respect to the disposal of all spent chemicals, solutions and sludge generated from the operation of wastewater pretreatment systems or industrial processes.

Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

Sewer Use Discharge Permit

PART C REGULATORY NOTICES

Penalty Provisions

Pursuant to St. 1984, c. 372, s. 6(e), any permittee who violates any provision of 360 C.M.R. 10.000 or any permit or approval, or any User who knowingly makes any false statement or representation in any record, report, plan, or other document filed with any Municipality or the MWRA, or who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required under this permit may be punished by a fine or civil penalty not to exceed \$10,000.00 per day for each violation. The MWRA may issue a notice of noncompliance and assess penalties for such noncompliance in accordance with its Enforcement Administrative Penalties Regulations found at 360 C.M.R. 2.00.

Fraudulent and false statements made by the permittee in reports and other documents required to be submitted or maintained pursuant to 40 CFR Part 403.12 are subject to:

- 1) The provisions of 18 U.S.C. section 1001 relating to fraud and false statements;
- 2) The provisions of sections 309(c)(4) of the Clean Water Act, as amended, governing false statements, representation or certification; and
- 3) The provisions of section 309(c)(6) of the Clean Water Act, as amended, regarding responsible corporate officers.

This means there is the possibility of civil and criminal penalties for providing false information, failing to provide required information, or otherwise violating this permit or EPA or MWRA regulations.

Sewer Use Discharge Permit

PART D HOW TO APPEAL THIS PERMIT

Request for Reconsideration

This permit may be appealed by submitting a written request for reconsideration to the MWRA. The request for reconsideration must be received by the MWRA within ten working days of the issuance date of this permit. The request shall set forth in detail the facts supporting it. The regulations on appealing a permit are found at 360 C.M.R. § 2.21.

If this is a permit modification, only the terms being modified are subject to appeal. In addition, there is no appeal from the MWRA's action issuing, denying, revoking, suspending, modifying, or refusing to renew a permit when the MWRA took the action to implement the terms of a settlement agreement between the MWRA and the permittee, a ruling on request for reconsideration, a final decision in an adjudicatory proceeding, or a court action. A request for reconsideration of this permit shall be addressed to:

Massachusetts Water Resources Authority
Toxic Reduction and Control
Attention: Permit Appeal
2 Griffin Way
Chelsea, MA 02150

Sewer Use Discharge Permit

DEFINITIONS

Definitions of Sampling and Reporting Terms

Sample Type

Grab - A grab sample is an individual sample which is taken on a one time basis without regard to the flow of the wastestream and without consideration of time to represent a wastestream.

Composite(time) - A composite(time) sample is a combination of a series of aliquots taken on a time proportional basis over a period of time.

Composite(flow) - A composite(flow) sample is a combination of a series of aliquots taken on a flow proportional basis over a period of time.

Composite(batch) - A composite(batch) sample is a combination of three grab samples, collected at the beginning, middle, and end of the batch discharge of wastewater.

Sampling Frequency Periods

Annually - Samples shall be taken once a year between January and December.

Semiannually - Samples shall be taken twice a year, once during each six month period of January to June and July to December.

Quarterly - Samples shall be taken four times a year, once during each three month period of January to March, April to June, July to September, and October to December.

Monthly - Samples shall be taken once each month, during each of the twelve months.

Reporting Frequency

Sample results for each sampling frequency period must be received by the MWRA no later than one month after the close of the sampling frequency period, as indicated:

Annually - Sampling results shall be submitted for each annual sampling period by January 31.

Semiannually - Sampling results shall be submitted for each semi-annual sampling period. For the January to June period, the results are due by July 31. For the July to December period, they are due by January 31.

Quarterly - Sampling results shall be submitted for each quarterly sampling period. For the January to March sampling period, the results are due by April 30. For the April to June period, they are due by July 31. For the July to September period, they are due by October 31. For the October to December period, they are due by January 31.

Monthly - Sampling results shall be submitted for each monthly sampling period. For each monthly sampling period, the results are due the last day of the following month. (e.g. for the sampling period for the month of December the report forms are due by January 31.)

Sewer Use Discharge Permit

DEFINITIONS

Flow Terms

Measured Flow - The total discharge flow shall be measured, in gallons discharged that day, at the sample location on each day a sample is taken. The chain of custody form shall include the method by which the flow was measured.

Estimated Flow - The total discharge flow shall be estimated, in gallons discharged that day, at the sample location on each day a sample is taken. The chain of custody form shall include the method by which the flow was estimated.

Note: When reporting the flow for a composite sample collected with automatic sampling equipment, report the flow for the day the automatic sampler collected the samples, which may not necessarily be the same day the samples were retrieved from the automatic sampler by sampling personnel

Sewer Use Discharge Permit**SAMPLE ANALYSES AND REPORTING CERTIFICATION
FOR SUBMISSION DIRECTLY FROM THE LABORATORY**

The permittee must have a current signed and dated copy of this form on file with the MWRA.

Industry Name: VA Boston Healthcare System - Jamaica Plain

Permit #: 51005733

I hereby certify that I have engaged an independent laboratory (which is certified by the Massachusetts Department of Environmental Protection to perform wastewater analyses) to submit to the MWRA, via its Pretreatment Information Management System Web Self-Monitoring Report (Web SMR) available at <http://websmr.mwra.com/>, the reports of the analyses of sampling required by the MWRA. I certify under penalty of law that the information submitted through the MWRA's web-based program, and accompanying chain of custody forms, provided to the MWRA by the laboratory, were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information to be submitted by the laboratory will be, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I certify that I have instructed the laboratory to provide me with a copy of each report it submits to the MWRA on my behalf, no later than the day it submits the report to the MWRA. I understand that I am responsible to assure that such reports are timely submitted to me and to the MWRA.

I understand that this certification applies to the laboratory I now use and to any laboratory, I may use in the future.

Signature of Authorized Representative

Date

(Print name and title of Authorized Representative)

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: GRAB

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0103
Description: Wastewater generated from the SPS area on the second floor of Building 1 shall be sampled from the spigot on the combined discharge line of the surgical tool cleaning devices in the SPS area, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow:

FIELD pH: s.u.(pH must be measured on-site)

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:

GRAB SAMPLE Date (mm/dd/yy): SAMPLE Time (military, hh:mm):

Table with 5 columns: PARAMETERS Sampled, Type of Preservative Added, Preserved to What pH?, When Was Preservative Added? *, Comments: (Y=Yes, N=No). Rows include parameters like VOA, PHC (TPH), Cr (VI), FOG, CN (Total), ABN (Semi-Volatiles), Metals, Pest/PCB, TSS, and Other.

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

Table with 2 columns for signature and date/time. Rows include: SAMPLED BY (print name), (sign name), Sampling Company Name, and three sets of RELINQUISHED BY/COMPANY NAME, DATE/TIME, RECEIVED BY/COMPANY NAME, DATE/TIME.

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: MANUAL COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0103
Description: Wastewater generated from the SPS area on the second floor of Building 1 shall be sampled from the spigot on the combined discharge line of the surgical tool cleaning devices in the SPS area, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS
FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED
Method used to measure/estimate flow:

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:
COMPOSITE BY MANUAL SAMPLING TECHNIQUE

Start Date (mm/dd/yy) Start Time (military - hh:mm)
Sample #1 Time Sample #2 Time Sample #3 Time
Sample #4 Time Sample #5 Time Sample #6 Time
Sample #7 Time Sample #8 Time (attach additional sheets if more than 8 samples taken)
End Date (mm/dd/yy) End Time (military - hh:mm)

Number of aliquots taken: Interval between aliquots: ()Minutes ()Hours ()Gallons

Table with 5 columns: PARAMETERS Sampled, Type of Preservative Added, Preserved to What pH?, When Was Preservative Added? *, Comments: (Y=Yes, N=No). Rows include parameters like VOA, Cr (VI), CN (Total), ABN (Semi-Volatiles), Metals, and Pest/PCB, TSS, Other.

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

Form sections for SAMPLED BY, RECEIVED BY, and RELINQUISHED BY, each with fields for name, date, time, and company name.

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: AUTOMATIC COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0103
Description: Wastewater generated from the SPS area on the second floor of Building 1 shall be sampled from the spigot on the combined discharge line of the surgical tool cleaning devices in the SPS area, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow:

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:

COMPOSITE BY AUTOMATIC SAMPLING DEVICE

Start Date (mm/dd/yy) Start Time (military - hh:mm)

End Date (mm/dd/yy) End Time (military - hh:mm)

Number of aliquots taken: Interval between aliquots: () Minutes () Hours () Gallons

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Cr (VI)				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: GRAB

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0104
Description: Wastewater generated from the animal cage washer on the third floor of the Research Building 1A shall be sampled from the spigot on the discharge line of the animal cage washer, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time: _____

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: _____ gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow: _____

FIELD pH: _____ s.u.(pH must be measured on-site)

FIELD TEMPERATURE: _____ FIELD COLOR: _____ FIELD ODOR: _____

GRAB SAMPLE Date (mm/dd/yy): __/__/__ SAMPLE Time (military, hh:mm): __/__/__

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() PHC (TPH)				
() Cr (VI)				
() FOG				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: MANUAL COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0104
Description: Wastewater generated from the animal cage washer on the third floor of the Research Building 1A shall be sampled from the spigot on the discharge line of the animal cage washer, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS
FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED
Method used to measure/estimate flow:

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:
COMPOSITE BY MANUAL SAMPLING TECHNIQUE

Start Date (mm/dd/yy) Start Time (military - hh:mm)
Sample #1 Time Sample #2 Time Sample #3 Time
Sample #4 Time Sample #5 Time Sample #6 Time
Sample #7 Time Sample #8 Time (attach additional sheets if more than 8 samples taken)
End Date (mm/dd/yy) End Time (military - hh:mm)

Number of aliquots taken: Interval between aliquots: ()Minutes ()Hours ()Gallons

Table with 5 columns: PARAMETERS Sampled, Type of Preservative Added, Preserved to What pH?, When Was Preservative Added? *, Comments: (Y=Yes, N=No). Rows include parameters like VOA, Cr (VI), CN (Total), ABN (Semi-Volatiles), Metals, and Pest/PCB.

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

Form section for signatures and company information, including fields for SAMPLED BY, RECEIVED BY, RELINQUISHED BY, and COMPANY NAME.

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: AUTOMATIC COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0104
Description: Wastewater generated from the animal cage washer on the third floor of the Research Building 1A shall be sampled from the spigot on the discharge line of the animal cage washer, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow:

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:

COMPOSITE BY AUTOMATIC SAMPLING DEVICE

Start Date (mm/dd/yy) Start Time (military - hh:mm)

End Date (mm/dd/yy) End Time (military - hh:mm)

Number of aliquots taken: Interval between aliquots: () Minutes () Hours () Gallons

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Cr (VI)				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: GRAB

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0105
Description: Wastewater generated from the steam sterilizer on first floor of Building 1A shall be sampled from the spigot on the discharge line of the steam sterilizer, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time: _____

DISCHARGE TYPE: ☐ BATCH **or** ☐ CONTINUOUS

FLOW on sampling day: _____ gpd The **FLOW** was: ☐ MEASURED ☐ ESTIMATED

Method used to measure/estimate flow: _____

FIELD pH: _____ s.u.(pH **must** be measured on-site)

FIELD TEMPERATURE: _____ **FIELD COLOR:** _____ **FIELD ODOR:** _____

GRAB **SAMPLE** Date (mm/dd/yy): __/__/__ **SAMPLE** Time (military, hh:mm): __/__/__

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
☐ VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
☐ PHC (TPH)				
☐ Cr (VI)				
☐ FOG				
☐ CN (Total)				Sulfides or Oxidizers Detected?
☐ ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
☐ Metals**				
**List Metals:				
☐ Pest/PCB				
☐ TSS				
☐ Other:				
☐ Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form SAMPLE TYPE: MANUAL COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0105
Description: Wastewater generated from the steam sterilizer on first floor of Building 1A shall be sampled from the spigot on the discharge line of the steam sterilizer, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time: _____

DISCHARGE TYPE: () BATCH **or** () CONTINUOUS
FLOW on sampling day: _____ gpd The **FLOW** was: () MEASURED () ESTIMATED
Method used to measure/estimate flow: _____

FIELD TEMPERATURE: _____ **FIELD COLOR:** _____ **FIELD ODOR:** _____
COMPOSITE BY MANUAL SAMPLING TECHNIQUE

Start Date (mm/dd/yy) ____/____/____ **Start Time (military - hh:mm)** ____:____
Sample #1 Time ____:____ **Sample #2 Time** ____:____ **Sample #3 Time** ____:____
Sample #4 Time ____:____ **Sample #5 Time** ____:____ **Sample #6 Time** ____:____
Sample #7 Time ____:____ **Sample #8 Time** ____:____ (attach additional sheets if more than 8 samples taken)
End Date (mm/dd/yy) ____/____/____ **End Time (military - hh:mm)** ____:____

Number of aliquots taken: _____ Interval between aliquots: () Minutes () Hours () Gallons

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Cr (VI)				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: AUTOMATIC COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0105
Description: Wastewater generated from the steam sterilizer on first floor of Building 1A shall be sampled from the spigot on the discharge line of the steam sterilizer, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time: _____

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: _____ gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow: _____

FIELD TEMPERATURE: _____ FIELD COLOR: _____ FIELD ODOR: _____

COMPOSITE BY AUTOMATIC SAMPLING DEVICE

Start Date (mm/dd/yy) ____/____/____ Start Time (military - hh:mm) ____:____

End Date (mm/dd/yy) ____/____/____ End Time (military - hh:mm) ____:____

Number of aliquots taken: _____ Interval between aliquots: () Minutes () Hours () Gallons

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Cr (VI)				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):			
(sign name):			
Sampling Company Name:			
RELINQUISHED BY:	COMPANY NAME:		
DATE:	TIME:		
RECEIVED BY:	COMPANY NAME:		
DATE:	TIME:		
RELINQUISHED BY:	COMPANY NAME:		
DATE:	TIME:		
RECEIVED BY:	COMPANY NAME:		
DATE:	TIME:		

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: GRAB

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0107
Description: Wastewater generated from washing endoscopy scopes in four scope washers and three pre-rinse sinks and one hand washing only sink, located in Room E5-114B on the fifth floor of Building 1, shall be sampled from the spigot situated in Room E4-112 on the fourth floor, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow:

FIELD pH: s.u.(pH must be measured on-site)

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:

GRAB SAMPLE Date (mm/dd/yy): __/__/__ SAMPLE Time (military, hh:mm): __/__/__

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
()VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
()PHC (TPH)				
()Cr (VI)				
()FOG				
()CN (Total)				Sulfides or Oxidizers Detected?
()ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
()Pest/PCB				
()TSS				
()Other:				
()Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: MANUAL COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0107
Description: Wastewater generated from washing endoscopy scopes in four scope washers and three pre-rinse sinks and one hand washing only sink, located in Room E5-114B on the fifth floor of Building 1, shall be sampled from the spigot situated in Room E4-112 on the fourth floor, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow:

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:
COMPOSITE BY MANUAL SAMPLING TECHNIQUE

Start Date (mm/dd/yy) Start Time (military - hh:mm)
Sample #1 Time Sample #2 Time Sample #3 Time
Sample #4 Time Sample #5 Time Sample #6 Time
Sample #7 Time Sample #8 Time (attach additional sheets if more than 8 samples taken)
End Date (mm/dd/yy) End Time (military - hh:mm)

Number of aliquots taken: Interval between aliquots: ()Minutes ()Hours ()Gallons

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Cr (VI)				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: AUTOMATIC COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0107
Description: Wastewater generated from washing endoscopy scopes in four scope washers and three pre-rinse sinks and one hand washing only sink, located in Room E5-114B on the fifth floor of Building 1, shall be sampled from the spigot situated in Room E4-112 on the fourth floor, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time: _____

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: _____ gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow: _____

FIELD TEMPERATURE: _____ FIELD COLOR: _____ FIELD ODOR: _____

COMPOSITE BY AUTOMATIC SAMPLING DEVICE

Start Date (mm/dd/yy) __/__/__ Start Time (military - hh:mm) __:__

End Date (mm/dd/yy) __/__/__ End Time (military - hh:mm) __:__

Number of aliquots taken: _____ Interval between aliquots: () Minutes () Hours () Gallons

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
()VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
()Cr (VI)				
()CN (Total)				Sulfides or Oxidizers Detected?
()ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
()Metals**				
**List Metals:				
()Pest/PCB				
()TSS				
()Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: GRAB

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0108
Description: Wastewater generated from the two glassware washers on first floor of Building 1A shall be sampled from the spigot on the discharge line of the two glassware washers, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow:

FIELD pH: s.u.(pH must be measured on-site)

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:

GRAB SAMPLE Date (mm/dd/yy): / / SAMPLE Time (military, hh:mm): / /

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() PHC (TPH)				
() Cr (VI)				
() FOG				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: MANUAL COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0108
Description: Wastewater generated from the two glassware washers on first floor of Building 1A shall be sampled from the spigot on the discharge line of the two glassware washers, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS
FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED
Method used to measure/estimate flow:

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:
COMPOSITE BY MANUAL SAMPLING TECHNIQUE

Start Date (mm/dd/yy) Start Time (military - hh:mm)
Sample #1 Time Sample #2 Time Sample #3 Time
Sample #4 Time Sample #5 Time Sample #6 Time
Sample #7 Time Sample #8 Time (attach additional sheets if more than 8 samples taken)
End Date (mm/dd/yy) End Time (military - hh:mm)

Number of aliquots taken: Interval between aliquots: ()Minutes ()Hours ()Gallons

Table with 5 columns: PARAMETERS Sampled, Type of Preservative Added, Preserved to What pH?, When Was Preservative Added? *, Comments: (Y=Yes, N=No). Rows include parameters like VOA, Cr (VI), CN (Total), ABN (Semi-Volatiles), Metals, and Pest/PCB.

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

Form section for signatures and dates. Includes fields for SAMPLED BY (print name), (sign name), Sampling Company Name, and multiple rows for RELINQUISHED BY, DATE, RECEIVED BY, and COMPANY NAME.

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: AUTOMATIC COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0108
Description: Wastewater generated from the two glassware washers on first floor of Building 1A shall be sampled from the spigot on the discharge line of the two glassware washers, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow:

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:

COMPOSITE BY AUTOMATIC SAMPLING DEVICE

Start Date (mm/dd/yy) _ _ / _ _ / _ _ Start Time (military - hh:mm) _ _ : _ _

End Date (mm/dd/yy) _ _ / _ _ / _ _ End Time (military - hh:mm) _ _ : _ _

Number of aliquots taken: Interval between aliquots: () Minutes () Hours () Gallons

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Cr (VI)				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: GRAB

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0109
Description: Wastewater generated from the Steris Amsco steam sterilizer on second floor of Building 1A shall be sampled from the spigot on the discharge line of the steam sterilizer, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time: _____

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: _____ gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow: _____

FIELD pH: _____ s.u.(pH must be measured on-site)

FIELD TEMPERATURE: _____ FIELD COLOR: _____ FIELD ODOR: _____

GRAB SAMPLE Date (mm/dd/yy): __/__/__ SAMPLE Time (military, hh:mm): __/__/__

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() PHC (TPH)				
() Cr (VI)				
() FOG				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: MANUAL COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0109
Description: Wastewater generated from the Steris Amsco steam sterilizer on second floor of Building 1A shall be sampled from the spigot on the discharge line of the steam sterilizer, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS
FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED
Method used to measure/estimate flow:

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:
COMPOSITE BY MANUAL SAMPLING TECHNIQUE

Start Date (mm/dd/yy) Start Time (military - hh:mm)
Sample #1 Time Sample #2 Time Sample #3 Time
Sample #4 Time Sample #5 Time Sample #6 Time
Sample #7 Time Sample #8 Time (attach additional sheets if more than 8 samples taken)
End Date (mm/dd/yy) End Time (military - hh:mm)

Number of aliquots taken: Interval between aliquots: ()Minutes ()Hours ()Gallons

Table with 5 columns: PARAMETERS Sampled, Type of Preservative Added, Preserved to What pH?, When Was Preservative Added? *, Comments: (Y=Yes, N=No). Rows include parameters like VOA, Cr (VI), CN (Total), ABN (Semi-Volatiles), Metals, Pest/PCB, TSS, and Other.

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

Form section for signatures and company information, including fields for SAMPLED BY, RECEIVED BY, RELINQUISHED BY, and COMPANY NAME.

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: AUTOMATIC COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0109
Description: Wastewater generated from the Steris Amsco steam sterilizer on second floor of Building 1A shall be sampled from the spigot on the discharge line of the steam sterilizer, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow:

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:

COMPOSITE BY AUTOMATIC SAMPLING DEVICE

Start Date (mm/dd/yy) _ _ / _ _ / _ _ Start Time (military - hh:mm) _ _ : _ _

End Date (mm/dd/yy) _ _ / _ _ / _ _ End Time (military - hh:mm) _ _ : _ _

Number of aliquots taken: Interval between aliquots: () Minutes () Hours () Gallons

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Cr (VI)				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):			
(sign name):			
Sampling Company Name:			
RELINQUISHED BY:	COMPANY NAME:		
DATE:	TIME:		
RECEIVED BY:	COMPANY NAME:		
DATE:	TIME:		
RELINQUISHED BY:	COMPANY NAME:		
DATE:	TIME:		
RECEIVED BY:	COMPANY NAME:		
DATE:	TIME:		

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: GRAB

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0201
Description: Wastewater generated from the clinical lab instruments in Room B2-61A on the second floor of Building 1 shall be sampled from the spigot on the combined discharge line of the instruments, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time: _____

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: _____ gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow: _____

FIELD pH: _____ s.u.(pH must be measured on-site)

FIELD TEMPERATURE: _____ FIELD COLOR: _____ FIELD ODOR: _____

GRAB SAMPLE Date (mm/dd/yy): __/__/__ SAMPLE Time (military, hh:mm): __/__/__

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() PHC (TPH)				
() Cr (VI)				
() FOG				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):	
(sign name):	
Sampling Company Name:	
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:
RELINQUISHED BY:	COMPANY NAME:
DATE:	TIME:
RECEIVED BY:	COMPANY NAME:
DATE:	TIME:

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: MANUAL COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0201
Description: Wastewater generated from the clinical lab instruments in Room B2-61A on the second floor of Building 1 shall be sampled from the spigot on the combined discharge line of the instruments, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS
FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED
Method used to measure/estimate flow:

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:
COMPOSITE BY MANUAL SAMPLING TECHNIQUE

Start Date (mm/dd/yy) Start Time (military - hh:mm)
Sample #1 Time Sample #2 Time Sample #3 Time
Sample #4 Time Sample #5 Time Sample #6 Time
Sample #7 Time Sample #8 Time (attach additional sheets if more than 8 samples taken)
End Date (mm/dd/yy) End Time (military - hh:mm)

Number of aliquots taken: Interval between aliquots: ()Minutes ()Hours ()Gallons

Table with 5 columns: PARAMETERS Sampled, Type of Preservative Added, Preserved to What pH?, When Was Preservative Added? *, Comments: (Y=Yes, N=No). Rows include parameters like VOA, Cr (VI), CN (Total), ABN (Semi-Volatiles), Metals, and Pest/PCB.

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

Form section for signatures and dates. Includes fields for SAMPLED BY (print name), (sign name), Sampling Company Name, and multiple rows for RELINQUISHED BY, DATE, RECEIVED BY, and COMPANY NAME.

Sewer Use Discharge Permit

MWRA Industrial User Sampling Chain of Custody/Field Form
SAMPLE TYPE: AUTOMATIC COMPOSITE

Industry Name: VA Boston Healthcare System - Jamaica Plain
Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130
Sample Location Number: 0201
Description: Wastewater generated from the clinical lab instruments in Room B2-61A on the second floor of Building 1 shall be sampled from the spigot on the combined discharge line of the instruments, prior to mixing with any other streams.

Briefly describe the process(es) discharging during sample time:

DISCHARGE TYPE: () BATCH or () CONTINUOUS

FLOW on sampling day: gpd The FLOW was: () MEASURED () ESTIMATED

Method used to measure/estimate flow:

FIELD TEMPERATURE: FIELD COLOR: FIELD ODOR:

COMPOSITE BY AUTOMATIC SAMPLING DEVICE

Start Date (mm/dd/yy) Start Time (military - hh:mm)

End Date (mm/dd/yy) End Time (military - hh:mm)

Number of aliquots taken: Interval between aliquots: () Minutes () Hours () Gallons

PARAMETERS Sampled:	Type of Preservative Added	Preserved to What pH?	When Was Preservative Added? *	Comments: (Y=Yes, N=No)
() VOA				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Cr (VI)				
() CN (Total)				Sulfides or Oxidizers Detected?
() ABN (Semi-Volatiles)				Cl ₂ Detected? Amt Na ₂ S ₂ O ₃ Added:
() Metals**				
**List Metals:				
() Pest/PCB				
() TSS				
() Other:				

* Prepreserved=P Field Preserved=F Preserved When Sample Delivered to Lab=L

SAMPLED BY (print name):			
(sign name):			
Sampling Company Name:			
RELINQUISHED BY:	COMPANY NAME:		
DATE:	TIME:		
RECEIVED BY:	COMPANY NAME:		
DATE:	TIME:		
RELINQUISHED BY:	COMPANY NAME:		
DATE:	TIME:		
RECEIVED BY:	COMPANY NAME:		
DATE:	TIME:		

Sewer Use Discharge Permit



MWRA Submittal Form

Date: _____

Company Name: VA Boston Healthcare System - Jamaica Plain

Facility Address: 150 S. Huntington Avenue, Jamaica Plain, MA 02130

Permit Number: 51005733

<u>Type of Submittal</u>	<u>Due Date</u>			<u>Sample Location #</u>				
	Month	Day	Year					
	01	01	16	0 1 0 1				
<u>REPORTS</u>								
Self-Monitoring Report	____	/	____	/	____	____	____	____
Pretreatment Report	____	/	____	/	____	____	____	____
Servicing Invoice/Report Type:	____	/	____	/	____	____	____	____
Plans/Schematics	____	/	____	/	____	____	____	____
Filter Backwash/RO Reject Report	____	/	____	/	____	____	____	____
Spill/Slug Control Plan	____	/	____	/	____	____	____	____
Photo Processing/Printing Report	____	/	____	/	____	____	____	____
<u>SCHEDULES</u>								
SRU Maintenance	____	/	____	/	____	____	____	____
Trap/Separator Maintenance	____	/	____	/	____	____	____	____
Non-Contact Cooling Water Removal	____	/	____	/	____	____	____	____
<u>LOGS</u>								
Flow Logs	____	/	____	/	____	____	____	____
pH Logs	____	/	____	/	____	____	____	____
Pretreatment System Log	____	/	____	/	____	____	____	____
<u>CERTIFICATIONS</u>								
Category 4 Certification	____	/	____	/	____	____	____	____
TOMP Certification	____	/	____	/	____	____	____	____
Lab Certification	____	/	____	/	____	____	____	____
Notice of Location not Discharging During								
Sampling Period	____	/	____	/	____	____	____	____
Other: _____	____	/	____	/	____	____	____	____
(please specify)								

Comments: _____

Sewer Use Discharge Permit

Instructions for Completing MWRA Submittal Form

This form has been developed to help route information submitted directly by a permitted industrial user to the appropriate MWRA department. Laboratories submitting data on behalf of an industry need not use this form. Its intent is to ensure that the information affecting more than one department, but submitted in one package, reaches all of the people who need to see it. You can help by including this form with each submittal to the MWRA.

Each submittal to the MWRA must be identified on this form.

Using the Form

Check the appropriate box in the appropriate category, or select *Other*, and identify exactly what it is you are including.

Multiple Submittals

You may check off as many boxes as you have submittals. If what you are submitting has no box to check off, use the box marked *Other*, and clearly identify what you are submitting. Each item you are submitting must be identified so that it can be routed to the appropriate person.

Due Date

It is important that the due date be included so that you can be credited for making your submittal on time. Refer to your permit to determine when your reports are due.

Sample Location

Many submittals will be reporting on a specific Sample Location. Please include this information in the second column marked *Sample Location #*. Refer to your permit to obtain the correct Sample Location number.

Important! If you are submitting *Notice of Location not Discharging*, you **MUST:**

1. Indicate the Sample Location #
2. Include a letter clarifying when and why the location was/is not discharging - Checking off the box on the Submittal Form will **NOT** be considered adequate notice; A letter **MUST** be included
3. State whether or not the situation is permanent

YOU MUST INCLUDE YOUR PERMIT NUMBER ON THE FIRST PAGE OF EACH ITEM THAT YOU ARE SUBMITTING. MWRA MAY RETURN TO A COMPANY WITH MULTIPLE FACILITIES, ANY REPORT SUBMITTED WITHOUT A PERMIT NUMBER.

Please make copies of this form and attach a completed form to each submittal.