

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		1. CONTRACT ID CODE		PAGE OF PAGES	
				1	14
2. AMENDMENT/MODIFICATION NUMBER		3. EFFECTIVE DATE		4. REQUISITION/PURCHASE REQUISITION NUMBER	
1333ND26RNB1900090002		MAY 01, 2026		NB194000-26-00784	
6. ISSUED BY		7. ADMINISTERED BY (If other than Item 6)		5. PROJECT NUMBER (If applicable)	
NATIONAL INST OF STDS AND TECHNOLOGY		See Block 6			
325 BROADWAY					
BOULDER CO 80305-3328					
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)		(X)		9A. AMENDMENT OF SOLICITATION NUMBER	
				1333ND26RNB190009	
		(X)		9B. DATED (SEE ITEM 11)	
				APR 07, 2026	
				10A. MODIFICATION OF CONTRACT/ORDER NUMBER	
				10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended. ☐ is not extended.					
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:					
(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
See Schedule					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.					
CHECK ONE					
☐ A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.					
☐ B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
☐ C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
☐ D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
See Attachment Page.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TRAVIS C. ZOELLNER CONTRACTING OFFICER, NIST		
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA	
				16C. DATE SIGNED	
				1 MAY 2026	
(Signature of person authorized to sign)		(Signature of Contracting Officer)			

The purpose of this amendment (0002) is to incorporate the following changes:

- A. Questions and Answers (#1 - 30) is hereby incorporated.
- B. Sign-In sheet from the April 23, 2026 site visit is attached.
- C. The Offer Due Date is extended from May 6, 2026 to May 11, 2026, no later than 5:00 PM (MT).
- D. FAR Clause 52.222-90 is incorporated into this solicitation.
- E. No other changes occur as a result of this amendment.

Questions and Answers

1. Can you confirm how many stairs are being replaced? Building 1 Wing 3 and Wing 6 dock stairs only, or Building 1 Wing 3, Building 22 and Building 1 Wing 6 stairs?

The stairs to be replaced are Building 1 Wing 3 and Building 1 Wing 6: reference SOW Task 1.9

2. Can you confirm that removal of bottom rails for snow removal requirements will still meet ADA compliance? How will blind personnel using a cane confirm location of rail while walking?

According to 2010 Americans with Disabilities Act (ADA) Standards for Accessible Design, Sections 505.3, 505.4, 505.5, 505.7, 505.8, and 505.10: there is no requirement for a bottom rail.

3. Is there a required height range for the new midrails?

Halfway from the top of the rail

4. Will NIST want a handrail shop drawing submittal?

Yes

5. If more economical, and/or more constructable, is it acceptable to just replace the entire handrail system rather than remove just the bottom of the existing and replace with midrail?

Please add this as an option in your proposal

6. Impacts to trench drains at stair replacement is unknown. Is the contractor responsible for any needed replacement/repair of trench drains?

Yes, the contractor is responsible for damage to the drain and must repair/replace.

7. Will there be NIST specific health and safety training that construction personnel will need to attend?

No, all safety training will be the responsibility of the contractor

8. Please further explain requirements for health hazard assessments and medical evaluations mentioned on page 5 of the SOW.

The contractor will be responsible for their employees and subcontractors' health hazard assessments and medical evaluations. The government will not pay to have these done.

9. Can you explain the anticipated background check process that will be required for the contractor/subcontractors? How much time will the process take?

The badging process generally takes one month but depending on the workload of the badging office it could take longer. If your employees/subcontractors are foreign nationals this process could take up to two months. No illegal immigrants will be allowed to work on the NIST site.

10. Will ID badges, if required, be provided by NIST?

Yes, badging will be provided by NIST.

11. Will the final construction schedule actually need to be cost loaded as stated on page 6 of the SOW?

No, a cost loaded schedule is not necessary for this construction project

12. Is there a sequence, according to work area, that NIST would like followed for construction?

No, unless there is other construction in the area, but this can be coordinated with the other project (if applicable)

13. Is it acceptable for a qualified superintendent to also serve the role as site safety manager and QC manager?

Yes, he will need to be the designated competent person in the Site Specific Safety Plan.

14. Will power and water be available? If no power, will mobile generators be allowed?

Yes, depending on the work area. Mobile generators are acceptable.

15. Are there any storm water / erosion control requirements for this project?

Yes, they are stated in "General Instructions for Conducting Work at the NIST Boulder Campus" portion of the contract in Section 2.9

16. Will Procore be able to be utilized for submittals, RFIs, and daily reports?

Yes

17. Could you provide the official site visitation attendance log?

The site visit attendance log is attached.

18. What is the pricing range of magnitude for this project?

Between \$100,000 and \$250,000.

19. Will handrails need to be extended to the bottom of the longer ramp at Building 1 Annex D and the ramp at Building 22 dock area?

Please add this as an option in your proposal

20. Will Building 1 Annex D side entrance require replacement of concrete ramp? In its current state, it is not level at the top landing and the foundation is broken in several places. Given current condition of concrete, warranty of new handrail installation may not be attainable.

Please add this as an option in your proposal

21. Will holes in concrete steps of Building 1 Wing 3 from previous shifting of rails need to be filled in?

Contractor shall replace the concrete staircase (7 risers × 8-foot run × 7-foot width) with a new concrete staircase matching the existing slope and design.

22. What is the process for obtaining hot work permits? Can one work permit cover multiple locations and/or multiple days? What is the turnaround time for a hot work permit to be approved?

Hot Work permits should be requested 48 hours in advance. One permit per location will be issued. Turn around is typically 24 hours depending on the Safety Office's workload.

23. Could you provide a sitemap that identifies all building and wing numbers?

Yes

24. During construction on stairs at Building 1 Wing 3 and 6 loading docks, do loading docks need to stay operational? Can work on both areas take place at the same time?

NIST will coordinate with the with the bottle service contractor and inform the construction contractor of the delivery schedule. This way the laboratories can still have gas bottles delivered to support their science. Both docks can be worked on if planned properly.

25. Could you verify the width of the new stairs being installed at the loading dock for Wing 6? If the width is increasing, please provide direction on tying this back into existing curb line.

The new concrete staircase shall match the existing slope and design.

26. At Building 1 Wing 3 stair replacement it appears that the landing area at the bottom of the stairs and trench drain within will be impacted. Will removal and replacement of the of the landing and trench drain be required?

No, if damaged during construction of the B1W3 staircase, the contractor will be responsible for repairing or replacing.

27. At Building 1 Wing 3 stair replacement, as shown in the images below there will be a mismatch between the required style of curb design provided in the SOW and the extant section of curb. Please clarify how you wish the transition between these two curb designs to be constructed. Please note: 1.9.4 Contractor shall replace the concrete curb section with a new concrete curb section to match the existing curb.



Please follow: 1.9.4 Contractor shall replace the concrete curb section with a new concrete curb section to match the existing curb. Disregard

the CDOT reference “Curb and Gutter Standards Type 2 CDOT Curb and Gutter Standards” in the SOW. This is our standard for the roads.

28. At Building 1 Wing 6 stair replacement it appears that the landing area at the bottom of the stairs and trench drain within will be impacted. Will removal and replacement of the landing and trench drain be required?

No, if damaged during construction of the B1W3 staircase, the contractor will be responsible for repairing or replacing.

29. In reference to the concrete mix design, are you requesting compaction factor test method?

Yes

30. Do you have an approximate linear footage of the handrails?

No, contractor is responsible for verifying measurements in the field

Table of Contents

SECTION I CONTRACT CLAUSES..... 9

 I.1 52.222-90 Addressing DEI Discrimination by Federa.....9

SECTION J LIST OF ATTACHMENTS..... 11

 J.1 NIST Boulder Campus Map.....11

 J.2 Site Visit Sign-In Sheet.....12

SECTION I
CONTRACT CLAUSES

I.1 52.222-90 Addressing DEI Discrimination by Federa

52.222-90 Addressing DEI Discrimination by Federal Contractors. (DEVIATION April 2026)

(a) Definitions. As used in this clause—

Program participation means membership or participation in, or access or admission to: training, mentoring, or leadership development programs; educational opportunities; clubs; associations; or similar opportunities that are sponsored or established by the contractor or subcontractor.

Racially discriminatory diversity, equity, and inclusion (DEI) activities means disparate treatment based on race or ethnicity in the recruitment, employment (e.g., hiring, promotions), contracting (e.g., vendor agreements), program participation, or allocation or deployment of an entity's resources.


(b) In connection with the performance of work under this contract, the Contractor agrees as follows:

- (1) The Contractor will not engage in any racially discriminatory DEI activities;
- (2) The Contractor will furnish all information and reports, including providing access to books, records, and accounts, as required by the Contracting Officer, for purposes of ascertaining compliance with this clause;
- (3) In the event of the Contractor's or a subcontractor's noncompliance with this clause, this contract may be canceled, terminated, or suspended in whole or in part, and the Contractor or subcontractor may be declared ineligible for further Government contracts;
- (4) The Contractor will report any subcontractor's known or reasonably knowable conduct that may violate this clause to the Contracting Officer and take any appropriate remedial actions directed by the Contracting Officer; and
- (5) The Contractor will inform the Contracting Officer if a subcontractor sues the Contractor and the suit puts at issue, in any way, the validity of this clause.
- (6) The Contractor recognizes that compliance with the requirements of this clause are material to the Government's payment decisions for purposes of 31 U.S.C. 3729(b)(4).

(c) The Contractor must include the substance of this clause, including this paragraph (c), in subcontracts at any tier, including those for commercial products and commercial services, except those where the place of delivery or performance is outside the United States.

(End of clause)

J.1 NIST Boulder Campus Map



J.2 Site Visit Sign-In Sheet

Brewster, Randon	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Thalhammer, Conrad Barl	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Mercado, Fernando	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Rogers, Troy Eldon	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Bradburry, William Chad	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Randall, Nathan Burley	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Johnston, Devin Edward	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Falmoe, Erik Andrew	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Lawrence, Robert Clyde	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Morkes, Daniel Patrick	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Bakken, Chad William	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Tuomey, Raymond Steph	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Szlyk, Paul Richard	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Nafziger, Dillon Pierce Ca	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Hueber, John Paul	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Mathews, Ryan James	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
O'Brien, Ashley Marie	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Kent, Robert William	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered
Schuch, William James	Lopez, Lauren	Lopez, Lauren	04/23/2026	04/23/2026	Registered

Everett Kramer

Zachariah S. Arias

CINDY GONZALEZ
MARCO TORRES

ER

FAR SOLUTIONS

Rob and Forge Welding

Matt Hare	olgonik	mhare@olgonik.com	925-415-1746
Raul Martinez	olgonik	rmart@olgonik.com	719-766-1565
Max Saunders	olgonik	msaunders@olgonik.com	719-358-3165
Drew Davidio	"	ddavidio@olgonik.com	(702) 495-4757

