

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF PAGES 6
2. AMENDMENT/MODIFICATION NUMBER 0002		3. EFFECTIVE DATE 05-05-2026		4. REQUISITION/PURCHASE REQ. NUMBER	
5. PROJECT NUMBER (if applicable)		6. ISSUED BY CODE Department of Veterans Affairs 36C252 115 South 84th Street, Suite 101 Milwaukee WI 53214-1476		7. ADMINISTERED BY (If other than Item 6) CODE Department of Veterans Affairs 36C252 Great Lakes Acquisition Center - HC 115 South 84th Street, Suite 101 Milwaukee WI 53214-1476	
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders		☒ 9A. AMENDMENT OF SOLICITATION NUMBER 36C25226Q0368		☐ 9B. DATED (SEE ITEM 11)	
CODE		☒ 10A. MODIFICATION OF CONTRACT/ORDER NUMBER		☐ 10B. DATED (SEE ITEM 13)	
FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required) See CONTINUATION Page					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).				
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
☐	D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor ☐ is not, ☒ is required to sign this document and return <u>1</u> copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to address questions received in response to the Solicitation and to post an inventory list of equipment. See Continuation Pages.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Robert Ruska Contracting Officer			
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	
				16C. DATE SIGNED	

Amendment 0002 for Solicitation 36C25226Q0368 for Medical Gas System Inspection and Testing for the Captain James A. Lovell Federal Health Care Center in North Chicago, IL.

Questions and Answers:

1. Could you please provide the outlet count?

A: See Medical Gas Inventory list below.

2. Can you please provide us with an inventory or count of all items to be tested: the number of source equipment, alarms, outlets/inlets, zone valves, etc.? If available, a previous inspection report would be helpful as it would contain these items.

A: See Medical Gas Inventory list below.

Captain James A. Lovell Federal Health Care Center

Medical Gas Inventory

ZONE VALVES FOR BUILDINGS 133/133-CA/133-EF

Building	Area Type	Gases	critical or non-critical
133 A - Ward	PR (patient rooms)	O2, MA, VAC	Non-critical care
133 A - Ward	PR	O2, MA, VAC	Non-critical care
133 A - Ward	PR	O2, MA, VAC	Non-critical care
133 A - SIDE	ONCOLOGY	O2, MA, VAC	Non-critical care
133 B - SIDE	GI PRE/POST	O2, MA, VAC	Non-critical care
133 B - SIDE	GI	O2, MA, N2O, N2, VAC	Non-critical care
133 B - SIDE	GI	O2, MA, CO2, VAC	Non-critical care
133 B - SIDE	GI	O2, MA, CO2, VAC	Non-critical care
133 A - SIDE	Pre-Op	O2, MA, VAC	Critical Care
133 C - SIDE	Anesthesia work room	O2, MA, VAC	Non-critical care
A-B SIDE	Pre-Op	O2, MA, VAC	Non-critical care
133	SURGERY	O2, MA, N2O, N2, WAGD, VAC	Critical Care
133	SURGERY	O2, MA, N2O, N2, WAGD, VAC	Critical Care
133	SURGERY	O2, MA, N2O, N2, WAGD, VAC	Critical Care
133	SURGERY	O2, MA, N2O, N2, WAGD, VAC	Critical Care
133	Hemodialysis	O2, MA, VAC	Non-critical care
133-CA	RADIOLOGY	O2, MA, VAC	Non-critical care
133-CA	RADIOLOGY	O2, VAC	Non-critical care
133-CA	RADIOLOGY	O2, MA, VAC	Non-critical care
133-CA	RADIOLOGY	O2, VAC	Non-critical care
133-CA	RADIOLOGY	O2, MA	Non-critical care
133-CA	RADIOLOGY	O2, MA, VAC	Non -critical care
133-CA	CCU	O2, MA, VAC	Critical Care
133-CA	ECT & PROC ROOM	O2, MA, VAC	Critical Care

133-CA	ER	O2, MA, VAC	Critical Care
133CA-BD	REHAB	O2, MA, VAC	Non-critical care
133-CA D	OUTPATIENT CLINIC	O2, MA, VAC	Non-critical care
133-CA BA	DENTAL; BIOMED	DENTAL A, O2, MA, VAC	Non-critical care
133CA-BA	DENTAL; BIOMED	DENTAL A, O2, MA, VAC	Non-critical care
133-EF	VASCULAR	O2, MA, VAC	Non-critical care
133-EF	EXAM	O2, MA, VAC	Non-critical care
133-EF	TRTMN RM VEST FNCT	O2, MA, VAC	Non-critical care
133-EF	CYSTO	O2, MA, VAC	Non-critical care
133-EF	CYSTO	O2, MA, VAC	Non-critical care
133-EF	NEUROLOGY	O2, MA, VAC	Non-critical care
133-EF	CARDIOLOGY	O2, MA, VAC	Non-critical care
133-EF	CARDIOLOGY	O2, MA, VAC	Non-critical care
133-EF	PEDS: PROC & TREATMENT	O2, MA, VAC	Non-critical care
133-EF	WOMENS: ULTRASOUND & MAMMOGRAPHY	O2, MA, VAC	Non-critical care
133-EF	INTERNAL MEDICINE PROCEDURE ROOM	O2, MA, VAC	Non-critical care
133-EF	INTERNAL MEDICINE TRMENT RM, PROC RM	O2, MA, VAC	Non-critical care
133-EF	IMMUNIZATION	O2, VAC	Non-critical care
133-EF	TREATMENT ROOM	O2, MA, VAC	Non-critical care
133-EF	TREATMENT ROOM	O2, MA, VAC	Non-critical care
133-EF	OFFICE	O2, MA, VAC	Non-critical care
133-EF	CAST ROOM	O2, MA, VAC	Non-critical care
133-EF	OPHTHAMOLOGY: LASER, FIELD, OFC	O2, MA, VAC	Non-critical care

COMBINATION ALARM/ZONE VALVE BOX (BUILDING 133)

Description
VALVE BOX (VB-1/AAP-1)
VALVE BOX (VB-2/AAP-2)

COMBINATION ALARM/ZONE VALVE BOX (BUILDING 134)

Building only has OXYGEN and feed is from a medical gas cylinder room

Description	Manufacturer/Model
COMBINATION ALARM/ZONE VALVE BOX	BEACON MEDAES / SSB-825-01
COMBINATION ALARM/ZONE VALVE BOX	BEACON MEDAES / SSB-825-01
AREA ALARM PANEL VALVE BOX	BEACON MEDAES / SSB-825-01

SOURCE

Floor & building	Description	Comment
133-EF, 2nd floor	N2 Beacon Lifeline Manifold: 1X1	Serves Urology
133, 2nd floor	N2 Amico Manifold: 2X2	Serves Ors & Cath Labs
133, 2nd floor	N2O Amico Manifold: 3X3	Serves Ors & Cath Labs
133, 2nd floor	CO2 Amico Manifold: 2X2	Serves Ors & Cath Labs
133, 3rd floor	N2O Amico Manifold: 2X2	Serves GI
133, 3rd floor	CO2 Amico Manifold: 2X2	Serves GI
134, Loading dock	O2 Beacon Manifold: 3X3	
131, basement	Duplex Vacuum System: 2 Hp/460V, lubed sliding vane pumps	
131, basement	Duplex Medical air system: 10 Hp/460V reciprocating compressors with duplex desiccant dryers	
133, basement	Duplex Vacuum System: 10 Hp/460V, lubed sliding vane pumps	
133, basement	Duplex Medical air system: 10 Hp/460V reciprocating compressors with duplex desiccant dryers	
133	Duplex Medical air system: 20 Hp/460V reciprocating compressors with duplex refrigerant dryers	Used as a backup
133	Duplex Vacuum System: 10 Hp/460V, lubed sliding vane pumps	
133	Duplex Medical air system: 20 Hp/460V reciprocating compressors with duplex desiccant dryers	
133-EF	Duplex Vacuum System: 3 Hp/460V, lubed sliding vane pumps	
133-EF	Duplex Medical air system: 3 Hp/460V reciprocating compressors with duplex desiccant dryers	

MASTER ALARMS

Location	Description	Comment
Police Station 1A-100A	Beacon Infinity	two alarm panels
188 Rm 108	Beacon Infinity	two alarm panels

PATIENT TERMINAL OUTLET TOTAL

Approximately 872 *(Based on current construction / remodel)*

MEDICAL GAS SHUTOFF VALVE TOTAL

Approximately 131 *(Based on current construction / remodel)*

BULK OXYGEN FARM

TYPE OF SYSTEM INSTALLED:

1. Respiratory only
2. Messer Company owned
3. Dual Liquid Primary / Liquid Reserve

EQUIPMENT INFORMATION:

1. Primary Tank Size: 1500
2. Reserve Tank Size: 260

MEDICAL AIR COMPRESSORS 4

8 EACH (as separate compressors heads)

MEDICAL VACUUM PUMPS 4

8 EACH (as separate pump heads)

DENTAL VACUUM PUMPS

3 EACH

DENTAL AIR COMPRESSORS

3 EACH