

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE 1 OF 4 PAGES		
2. AMENDMENT/MODIFICATION NUMBER 0001		3. EFFECTIVE DATE 04/16/2026		4. REQUISITION/PURCHASE REQUISITION NUMBER		5. PROJECT NUMBER (If applicable)	
6. ISSUED BY CODE PDS NPS, DSC Contracting Services Div 1 Denver Federal Center, Building 50 P.O. Box 25287 Denver CO 80225-0287				7. ADMINISTERED BY (If other than Item 6) CODE PDS DOI, NPS, DSC Contracting Services 1 Denver Federal Center, Building 50 P.O. Box 25287 Denver CO 80225-0287			
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)				9A. AMENDMENT OF SOLICITATION NUMBER ☒ 140P2026R0038			
				9B. DATED (SEE ITEM 11) ☒ 04/16/2026			
				10A. MODIFICATION OF CONTRACT/ORDER NUMBER			
				10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended. ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

See continuation page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
		Rachel Dyer	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

Previous edition unusable

CONTINUATION SHEET	REFERENCE NO. OF DOCUMENT BEING CONTINUED	PAGES
	140P2026R0038/0001	PAGE 2 OF 4

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	The purpose of amendment 0001 is to answer questions and extend the due date. 1. The due date of proposals is hereby extended from June 2, 2026, to June 3, 2026, due at 9:00am MT to Rachel Dyer via email at Rachel_dyer@ios.doi.gov. 2. Question 1: Refer to Solicitation Section L, paragraph F.3. Please confirm the requirement for Certified Cost and Pricing Data (Refer to clause 52.215-20), as part of the technical proposal. This is typically required for change orders after a contract is awarded or a sole source contract, not a competitive bid. 3. Answer 1: This is now required in all our contracts. We cannot remove it. 4. Question 2: Refer to section 01 40 00, paragraph 1.5.B.1 & 2. Please confirm if the site supervisor can perform other duties, including the quality control manager/quality control supervisor and site safety health officer. If not, please confirm if the QCM can also perform SSHO duties. The reference specification is contradictory. 5. Answer 2: The Site Supervisor can perform all duties with the exception of the quality control manager. 6. Question 3: Please confirm if concrete reinforcing mesh, bars, dowels, etc. should be galvanized or epoxy coated. Spec section 32 13 13 and detail D/C6.1 doesn't specify a coating/finish. NYCDOT Section #2.25 (referenced in detail) also does not specify a coating/finish. 7. Answer 3: Please use Epoxy Coated Reinforcing Bars and Dowels. Epoxy coating shall conform to ASTM A775 (fusion bonded epoxy coated steel reinforcement) or ASTM A934 (epoxy coated prefabricated steel reinforcement). Please use Epoxy Coated Welded Wire Reinforcement (WWR) Epoxy coating for welded wire reinforcement shall conform to ASTM Continued...				

CONTINUATION SHEET	REFERENCE NO. OF DOCUMENT BEING CONTINUED	PAGES
	140P2026R0038/0001	PAGE 3 OF 4

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	A1060 (epoxy-coated welded wire reinforcement). 8. Question 4: Is there a basis of design for the vehicle barrier gate system? 9. Answer 4: No there is not. Please see the detail on C6.8. The gate shall be off the shelf from a manuf. and shall have a replaceable arm. It shall be able to connect with different types of infrastructure. 10. Question 5: Please highlight the areas of work to be included in CLIN 0002 - ABA Accessibility. Is it all the areas associated with the blue dashed line on C2.1? 11. Answer 5: CLIN 2 covers all concrete work shown in areas related to the blue Proposed Accessible Pedestrian Pathway line on C2.1. Refer to the contract line-item definition chart on G1.3: CLIN 2 ABA Accessibility includes "The demolition of existing pavements & proposed placement of cast in place concrete improvements to meet ABA Accessibility at walks, ramps, and crossings". 12. Question 6: Please confirm quantity of selective removal of 6" reinforced concrete pavement shown on D1.4 & D1.5. Notes states to assume removal of 50% of 58,385 SF (approx. 29,192SF), but C2.5 and 2.6 keynote and legend appear to be 100% replacement. Please confirm. 13. Answer 6: The areas shown for selective concrete replacement are overall areas of concern. The concrete in these areas is to be evaluated on a panel-by-panel basis (refer to jointing plan shown) for selective replacement. All concrete replacements are to be full panel replacements (joint to joint). For bidding, assume 50% of the panels will be removed and replaced. 14. Question 7: Please confirm quantity of selective removal of 4" reinforced concrete pavement shown on D1.7. Notes states to assume Continued...				

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	removal of 50% of 10,673 SF (approx. 5,337SF). C2.8 also states to assume 50% replacement, but of 10,725SF. Please confirm if the entire area gets replaced or 50% of the area. 15. Answer 7: The areas shown for selective concrete replacement are overall areas of concern. The concrete in these areas is to be evaluated on a panel-by-panel basis (refer to jointing plan shown) for selective replacement. All concrete replacements are to be full panel replacements (joint to joint). For bidding, assume 50% of the panels will be removed and replaced.				