

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF 3	PAGES
2. AMENDMENT/MODIFICATION NUMBER 0001		3. EFFECTIVE DATE 03-27-2026		4. REQUISITION/PURCHASE REQ. NUMBER		
5. PROJECT NUMBER (if applicable)						
6. ISSUED BY Department of Veterans Affairs Network Contracting Office 8 (NCO 8) Orlando VA Healthcare System 13800 Veterans Way Orlando FL 32827		CODE 36C248	7. ADMINISTERED BY (If other than Item 6) Department of Veterans Affairs Network Contracting Office 8 (NCO 8) Orlando VA Healthcare System 13800 Veterans Way Orlando FL 32827		CODE 36C248	
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders		(X)		9A. AMENDMENT OF SOLICITATION NUMBER 36C24826Q0404		
		☒		9B. DATED (SEE ITEM 11) 03/18/2026		
		☐		10A. MODIFICATION OF CONTRACT/ORDER NUMBER		
				10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended, ☐ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. ** HOUR & DATE for Receipt of Offers is EXTENDED to: 04-13-2026 3:00 PM EDT						
12. ACCOUNTING AND APPROPRIATION DATA (If required) See CONTINUATION Page						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
☐	D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor ☐ is not, ☒ is required to sign this document and return <u>1</u> copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to change offer due date, provide responses to questions and schedule site visit. A. The offer due date is hereby extended from 04/01/2026 at 15:00 hours EST to 04/13/2026 at 15:00 hours EST. B. Submitted quotes to Contract Specialist carl.myers3@va.gov by email no later than 04/13/2026 at 15:00 EST. C. Site visit is scheduled for 04/06/2026 at 9:00 AM at Lake Nona VA Medical Center, 13800 Veterans Way, Orlando, FL 32827. VA Point of Contact (POC): Daniel Shepherd 321-332-2731 Daniel.Shepherd@va.gov D. Meet at Piano entrance information desk.						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)				
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)		16C. DATE SIGNED

CONTINUATION PAGE

RFQ 36C24826Q0404 QUESTIONS & RESPONSES

Q1. Can we schedule a site visit to review the installation and electrical scope?

A1. Yes. Site visit is set for 04.06/2026.

Q2. Are you open to an equipment-only bid (including commissioning)?

A2. No. Install and commissioning equipment must be included.

Q3. The specs call for redundancy—can you confirm there will be two compressors each for the dental clinic and the hospital lab?

A3. Yes. The minimum, properly sized compressors would require at the least two compressors on the packaged unit. This does not mean two completely separate packages. This redundancy is to meet NFPA99 5.1.3.6.3.9 (B).

Q4. Do you plan to have the tanks installed on the pad as well, or just the compressors?

A4. Tanks and Air Dryer assemblies will need to be mounted directly to the existing equipment pad.

Q5. Can we get detailed pictures of the existing unit along with the room where it is installed?

A5. See attached pictures. This question can be answered at the site visit to see other possible limitations such as elevator sizes and any other limitations.

Q6. May we know in detail what is considered as MUST be oil and moisture free?

A6. The compressors shall be belt or direct driven oil-less rotary screw or rotary scroll, single stage, air-cooled construction. The compressor will need no oil needed for operation. Oilless or Oil Free reciprocating piston systems will not meet the requirement.

Q7. Must provide clean medical grade air?

A7. Specifics for Medical Air can be found in (NFPA) National Fire Protection Code 99 2018 in 5.1.3.6.

Q8. I need to review pictures of your current compressed air system and the room where it is located.

A8. See attached pictures. This question can be answered at the site visit to see other possible limitations such as elevator sizes and any other limitations.

Q9. Provide the manufacturer p/n for the compressors currently being used by the Orlando VA.

A9. - Current Dental Compressor: Powerex MPT1508S5122708

- Current Hospital Lab/SPS Compressor: Powerex MTD0504S5122708