

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE 1 OF 6 PAGES			
2. AMENDMENT/MODIFICATION NUMBER 0003		3. EFFECTIVE DATE 05/07/2026		4. REQUISITION/PURCHASE REQUISITION NUMBER		5. PROJECT NUMBER (If applicable)		
6. ISSUED BY CODE LMA BLM MT-STATE OFC(MT935) 5001 SOUTHGATE DR. BILLINGS MT 59101				7. ADMINISTERED BY (If other than Item 6) CODE LMA BLM MT STATE OFC(MT935) 5001 SOUTHGATE DR. BILLINGS MT 59101				
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)				9A. AMENDMENT OF SOLICITATION NUMBER (X) 140L3626Q0023				
				9B. DATED (SEE ITEM 11) (X) 05/04/2026				
				10A. MODIFICATION OF CONTRACT/ORDER NUMBER				
				10B. DATED (SEE ITEM 13)				
CODE		FACILITY CODE						

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

See continuation page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
		Jorge Alvarez	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

Previous edition unusable

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	See amendment information in the pages below Period of Performance: 05/11/2026 to 06/30/2026				

Description of Changes - This amendment incorporates the following information:

1. The Government is providing the Questions received from interested offerors and the associated Answers provided by the Government.
2. Added Attachment 3 - Pompey's Water System Information and Attachment 4 – Water System Submittal.

Acknowledgement - Sign the SF30, Section 15A - 15C, to acknowledge this amendment.

New Questions and Answers

Question 7. Existing iron filter tank details, including manufacturer, model, diameter, height, pressure rating, connection sizes, and any available photos or as-built drawings.

Answer 7. See attachment 3 and 4.

Question 8. Existing iron filter tank details, including manufacturer, model, diameter, height, pressure rating, connection sizes, and any available photos or as-built drawings.

Answer 8. See attachment 3 and 4.

Questions and Answers

Question 4. The current filter media type, required media quantity, bed depth, gravel support layers, and whether the Government requires the same media or will accept a contractor-recommended equivalent suitable for iron and manganese removal.

Answer 4. Contractors shall base their quote on the existing system configuration and assume replacement in kind, including the current filter media type, media quantity, bed depth, and gravel support layers, to the extent information is available in the contract documents or can be reasonably inferred from site conditions.

Where specific parameters are not defined, contractors shall assume industry-standard design criteria appropriate for iron and manganese removal in groundwater filtration systems. The intent is to establish a common basis for bidding; therefore, no deviations from the specified or assumed baseline design shall be included in the initial proposal.

Contractor-recommended alternatives (e.g., equivalent or enhanced filter media) may be submitted after contract award for Government consideration. Any such recommendations must:

- Include sufficient technical justification demonstrating equal or improved performance for iron and manganese removal
- Be compatible with the existing infrastructure (e.g., vessel configuration, hydraulic loading rates, backwash requirements)
- Not introduce increased operational complexity, maintenance burden, or lifecycle cost without clear benefit

Contractors are advised that any deviation from the existing system configuration may be subject to regulatory review and approval. As such, acceptance of proposed alternatives could result in additional review time and potential delays to implementation. The Contractor shall account for this risk, and no schedule or cost adjustments will be considered unless expressly authorized through a formal contract modification.

All deviations are subject to Government evaluation and approval, and no changes shall be implemented without prior written authorization from the Contracting Officer.

Question 5. Whether the two hydropneumatic tanks are required to be fully replaced, or whether rehabilitation is acceptable if inspection determines they are serviceable.

Answer 5. Both hydropneumatic tanks shall be fully removed and replaced under this contract. Rehabilitation, reuse, or continued service of the existing tanks is not acceptable, regardless of inspection results or perceived condition.

Contractors shall base their proposals on complete replacement and shall include all labor, materials, and incidental work necessary to provide fully operational and integrated tanks within the existing system.

This requirement reflects the Government's intent to ensure long-term reliability, regulatory compliance, and consistency of system performance. Accordingly, no deviations from this requirement shall be included in the contractor's proposal.

Post-award requests to deviate from full replacement will not be routinely considered and would require compelling justification. Any such request, if submitted, remains subject to Government evaluation and approval at the sole discretion of the Contracting Officer through a formal contract modification.

Question 6. Analytical results further confirm treatment deficiencies, with manganese concentrations measured at 0.552 mg/L at the clearwell effluent - well above the recommended level of 0.05 mg/L - and 0.074 mg/L at the entry point to the system. Can the effluent be discharged into the septic tank drain? Or will the high concentration of manganese discharged need to be sent into a separate holding tank and trucked off the site once full?

Answer 6. Use of the onsite septic system for disposal of liquid waste generated under this contract is not permitted.

All waste materials, including liquid waste, shall be managed, transported, and disposed of in accordance with all applicable federal, state, and local laws and regulations. Disposal shall be the sole responsibility of the Contractor.

The Contractor shall assume that offsite disposal at an appropriately licensed facility is required and shall include all associated costs in their proposal, including handling, transportation, treatment, and disposal.

Questions and Answers

Question 1. What are the dimensions of the room where the tanks and treatment systems are located?

Answer 1. Approximately 20' X 20'

Question 2. What are the water demands of the system? Is the system supplying campgrounds?, housing?

Answer 2. Average demand of 1300 gallon per day with max demand of 6000 gallon per day. System supplies the Pompey's Pillar Interpretive Center.

Question 3. What are the specs on the current well and pump in place?

Answer 3. The existing pump is a Goulds 33GS20 with an Aquavara AVII Variable speed pump controller. The pump supplies 35GPM to the filtration system. The well has a total depth of 33 ft with a static water level of 4.5 ft.