

CUI

CUI

Performance Work Statement (PWS)

for

**21st Logistics Readiness Squadron Fire Bottle Inspection at
Peterson SFB CO**

29 April 2026

CUI

1. GENERAL REQUIREMENTS

- 1.1. Conduct all work in accordance with the Performance Work Statement (PWS) herein and all applicable codes. The Government requires the use of recycled and recovered materials, bio-based products, energy, and water saving products, and environmentally preferable products.
- 1.2. The contractor shall provide all personnel, equipment, tools, materials, supervision, and other items and services necessary to perform inspection and servicing of Peterson Space Force Base's flight line fire bottles as defined in this PWS.
- 1.3. The contractor shall inspect, service, and repair the fire bottles, as applicable. 6-year inspection requirements include the removal of the extinguishing agent, inspection and repair of bottle components, reassembly, and servicing the bottle. In addition, all work procedures and materials shall be approved by 21 LRS prior to the start of work. The contractor shall coordinate and perform all operations in a manner that will result in a professionally and expeditiously completed project.
- 1.4. The contractor shall maintain an active National Fire Protection Association (NFPA)10 Certification and be licensed in the State of Colorado. Documentation of certification must be provided to the Contracting Officer for review and approval before the contract can be accepted.
- 1.5. The Contractor is responsible to verify measurements, quantities, and materials needed to complete this project prior to submitting a proposal.
- 1.6. All work, equipment, tools, and materials required for this contract shall be performed at 235 Duluth Ave, Bldg 218, Peterson SFB, CO, 80914 or an area coordinated with 21 LRS personnel or Government designated representative (i.e., Contracting Officer, Project Manager). The performance area will not interfere with building operations or access to Peterson Space Force Base (PSFB).
- 1.7. The project shall conform to all applicable Federal, State, and local laws, regulations and base-specific standards and applicable Unified Facilities Criteria (UFC). Where there is a conflict between the referenced standards, the most stringent shall take precedence.

2. PROJECT SCOPE

2.1. GENERAL SCOPE

- 2.2. The 21st Logistics Readiness Squadron (21 LRS) requires 46 annual and 2 six-year periodic inspection and servicing of flight line fire bottles to ensure they are fully operational and comply with all applicable safety regulations for continued and unimpeded airfield operations.

2.3. The contractor shall inspect, service, and repair the fire bottles, as applicable. The 6-year inspection requirements include the removal of the extinguishing agent, inspection and repair of bottle components, reassembly, and servicing the bottle.

2.3.1. Fire Bottle managers will deliver bottles to the inspection site. Fire Bottle managers will rotate bottles once inspections are complete.

2.3.2. 6 Year Inspection: 6-yr inspections are required to be completed outside of a Building 218 with a proper catch system or taken-off installation to a facility of the contractor's choice. The contractor will be responsible for providing the workspace required, along with the tools (scale, recovery tank, compressor, Defender 2000) needed for the fire bottle inspections.

2.3.3. Contractor shall affix updated, punched inspection tags or stickers (compliant with NFPA 10) and provide a completed DD Form 1574 (Serviceable Tag) or equivalent documentation to the Fire Bottle Program Managers.

2.3.4. The contractor shall perform the following tasks to include but not limited to:

- 48 total fire bottles require inspections (See appendix A for make, model, and inspection interval requirements).
- Perform a complete inspection of each fire bottle in accordance with the 1-year and 6-year inspection requirements for each fire bottle.
- Remove the extinguishing agent.
- Inspect and repair any items on the bottle not covered under warranty.
- Reassemble and service the bottle.
- Perform equipment wipe down, serviceability inspection, and parts lubrication.

3. ENVIRONMENTAL AND HAZARDOUS MATERIAL HANDLING

3.1. The Contractor shall provide submittal of materials used in the performance of this contract. If any materials used in the performance of this contract are considered hazardous; the Contractor shall follow all local, state, and federal laws for proper management or transport of said hazardous waste. All potentially hazardous materials/toxics found or identified at PSFB while executing this work will immediately be reported to 21_CES_CEIE.DISTRO@us.af.mil or David Wooten in 21 CES Environmental Section at 719-556-8412.

3.2. Ensure employees handle any hazardous materials according to federal, state, or local laws and emergency response requirements. If required, a license for employees handling of hazardous materials shall be the Contractor's responsibility and at their expense. Report any instances of spills, leaks, and/or inadvertent release of hazardous materials to 21_CES_CEIE.DISTRO@us.af.mil or Sandra Ingrassia at 719-556-1478 and Environmental Section as soon as the event occurs.

- 3.3. The Contractor will submit an AF Form 3952, Chemical/Hazardous Material Request Authorization, for all materials used on PSFB. The Contractor shall have the form submitted back to 21 CES at least 10 business days prior to the start of work.
- 3.4. The Contractor shall contact 21st CES prior to generating any waste that is determined to be hazardous per the SDS. The Contractor is encouraged to contact 21 CES_CEIE.DISTRO@us.af.mil or Sandra Ingrassia at 719-556-1478 and Environmental Section if assistance is needed in making a waste determination.
- 3.5. The Contractor shall submit copies of any records showing quantities of disposed hazardous materials and/or recycled materials to 21st CES within 5 business days of disposal.
- 3.6. The Contractor shall comply with 5 CCR 1001-26 when sourcing any materials that produce gas emissions or contain any type of refrigerant as imposed by the Air Quality Control Commission in the state of Colorado.

4. WORK SCHEDULE

- 4.1. The Contractor shall perform services required under this PWS during the hours of 0730 through 1600 Monday through Friday. Requests to work beyond or and/or outside of these hours shall be submitted to Contracting Officer for approval. If there is a special event that comes up during the hours of 0730 through 1600, the contractor will be notified as soon as possible but the contractor should be prepared to stop work on a short notice.

5. WORK AREA ACCESS

- 5.1. This worksite is located on PSFB and all contractors must have proper authorization. The customer will be responsible for coordinating base access for all contractor personnel. Upon acceptance of this contract, the contractor shall complete and submit a PSFB Visitor Request to 21st LRS. All PSFB Visitor Pass requests shall be submitted no later than 5 business days prior to the first day of work. The Contractor shall coordinate EAL processing with the 21st LRS Contracting Officer Representative. The contractor shall provide personnel that can pass a background check for installation access (Last Name, First Name, Date of Birth, Driver's License Number, Issuing State). Any contractor who fails to pass a background check will not be permitted to work on the installation.

6. PROTECTION OF GOVERNMENT PROPERTY

- 6.1. The Contractor shall use reasonable care to avoid damaging existing buildings, equipment, and vegetation on the government installation. If the Contractor fails to use reasonable care and causes damage to any of this property, the Contractor shall replace or repair the damage at no expense to the Government.

7. SITE MAINTENANCE AND CLEANUP

- 7.1. The Contractor shall protect the work area, and if necessary adjacent areas, from dust, dirt, or other materials. Work areas shall be maintained in a neat, clean, and safe condition and shall, at a minimum, be cleaned at the end of each shift. All passageways in/or adjacent to the site shall always remain free of project generated trash and debris

8. INSPECTION AND ACCEPTANCE

- 8.1. The Government, through the designated Quality Assurance personnel, will perform inspection and acceptance of the services rendered to ensure compliance.

Appendix A

Extinguisher ID	Type	Serial Number	Make	Status	Model	Agent	Annual Insp Due	6 Year Insp Due
1	Halon	AA1083990	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
2	Halon	AA1084042	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
3	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
4	Halon	AA1100517	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
5	Halon	AA1100521	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
6	Halon	AA1096703	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Jan-28
7	Halon	AA1100515	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Jan-28
8	Halon	AA1100519	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
9	Halon	AA1094005	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
10	Halon	AA1096709	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Jan-28
11	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
12	Halon	AA1084029	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
13	Halon	AA981887	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-May-26
14	Halon	AA1100513	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
15	Halon	AA1084015	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
16	Halon	AA1084041	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
17	Halon	AA1084032	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
18	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
19	Halon	AA1084016	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
20	Halon	AA1096702	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Jan-28
21	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
22	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-May-26
23	Halon	AA1084011	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
24	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
25	Halon	AA1100480	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
26	Halon	AA1100514	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
27	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
28	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Jan-28
29	Halon	AA1096723	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
30	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Jan-28
31	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
32	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
33	Halon	AA1100523	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
34	Halon	AA1100483	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
35	Halon	AA1100509	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
36	Halon	AA1100489	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
37	Halon	AA1100485	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
38	Halon	AA1100490	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
39	Halon	AA1084006	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Nov-27
40	Halon	AA1100486	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
41	Halon	AA1096725	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Jan-28
42	Halon	AA1096724	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Jan-28
43	Halon	AA1100520	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
44	Halon	AA1096690	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Jan-28
45	Halon	AA1100524	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
46	Halon		AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
47	Halon	AA1100502	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
48	Halon	AA1100481	AMEREX	IN SERVICE	600	Halon 1211	28-May-26	1-Feb-28
				1-Yr Inspections = 46 Total				
				6-Yr Inspections = 2 Total				