

SUMMARY OF CHANGES

PROJECT: WHITETAIL ROAD 224 CONSTRUCTION PROJECT
Nebraska National Forest and Grasslands, Bessey Ranger District
Solicitation Number: 1240LT26Q0048

AMENDMENT ONE (Amend 0001):

The purpose of Amendment One (Amend 0001) is as follows:

- 1) To provide the Site Visit's Attendee's List from April 28, 2026;
- 2) To provide questions to contractor's questions;
- 3) All other terms and conditions remain the same.

The due date for quotes remains as: June 3, 2026, at 9:00 a.m. Central Time. Questions are due no later than May 6, 2026, at 9:00 a.m. Central Time.

Email addresses for submission of questions and quotes: Janice King, Contract Specialist, at janice.king@usda.gov **and** Lucas Dahlman, Contracting Officer, at lucas.dahlman@usda.gov. **In the subject line of your emailed quote submission, include the following: WHITETAIL ROAD 224 CONSTRUCTION PROJECT - 1240LT26Q0048**

Attendee's List from the Site Visit held on April 28, 2026

1240LT26Q0048 Whitetail Road 224 Construction Bessey Ranger District – Halsey, NE Nebraska National Forests & Grasslands Pre-Bid Site Visit Sign-In			
NAME	COMPANY	PHONE NUMBER	EMAIL
Howdy Munnik Jeremy Ross Tyler Ross	JFRECONSTRUCTION		Jeremy@JFRECONSTRUCTION.COM TYLER@JFRECONSTRUCTION.COM
Gabe Gosselin	HPM inc		gabe.gosselin@HPMcontracting.com
CHAD DEISLEY	MHERS CONSTRUCTION LLC		chad.deisley@mherconstruction.com

Questions and Answers

(The Government's answers to the questions below are in **red** font.)

1. Is there a local water source available for this project?
 - **Yes, there is a fill station at the District Shop approximately 10 miles away along State Highway 86B. There is no cost for the water provided.**

2. What seeding method is required?
 - Specific seeding method is not specified, only that the correct seeding rate is utilized for the method selected. *NOTE* Arrow Seed in Broken Bow, NE where the mix is from is now called Star Seed.
3. What is required for an erosion control plan?
 - No permitting is required, include information for how potential issues could be mitigated in the technical approach.
4. What fire equipment is required to be on-site?
 - Fire Plan - Before starting any operations on the project, the Contractor shall prepare a fire plan in cooperation with the Contracting Officer Representative for the prevention and control of fires in the project area. The Contractor shall certify compliance with fire protection and suppression requirements before beginning operations during the fire period and closed season and shall update such certification when operations change.
5. Are there any culverts planned for this project?
 - No, that was taken out in during project development, but the spec was not removed from the specifications document.
6. Will CAD files be supplied for survey work for a GPS or is that something that the contractor will have to do?
 - Government is not supplying any such documents, the work will be staked on the ground by the government and confirmation of all work will be done visually by the government. The contractor does not have to supply CAD or GPS documentation to the Government.
7. What compaction method is required?
 - All compaction for excavation and aggregate placement will be Compaction Method 3. from Section 209.10 Compacting.
8. In the design it calls for 12.5' wide roadway but only 10' of geogrid for stabilization. For ease of installation, it would be best to widen that geogrid to the standard roll width of the geogrid at 12.5'.
 - The purpose of having only 10' wide geogrid beneath the aggregate is so that maintenance equipment does not catch the outer margins of the geogrid during shoulder pulling.