

Solicitation: 127EAX26Q0008 Amendment 0001
Project Name: Hopewell Campsite Recreation Improvements
Location: Carson National Forest, New Mexico
NAICS: 238990

REQUEST FOR INFORMATION QUESTIONS

1. Is this a brand new contract OR if there is (was) an incumbent performing these services, please provide their information and contract number.

RESPONSE: This is a brand new requirement.

2. Has there been any soils testing or boring results for water line or other improvements? An inclusion has been made for bedding material in trenching for waterline that is the prompting for the question.

RESPONSE: No soils testing has been conducted. Adhere to bedding/backfill requirements for utility lines.

3. Is well information available, static water level, pump setting depth, drop pipe size, # of screens, pump size, capacity testing, pumping water depth, bottom of well, casing type and size, essentially as built etc...

RESPONSE:

- a. Total well depth = 500 ft.
 - b. Static water depth = 58 ft.
 - c. Pump depth = 248 ft.
 - d. Every 5 sticks of drop pipe, there is a check valve.
 - e. Casing = 5-inch nominal diameter PVC casing installed from a depth.
 - f. Well production test yielded approximately 6 gallon per minute (gpm) when connected to an adequate power source. On the existing solar power system, the well is producing ~ 1-2 gpm.
 - g. The well has a galvanized steel pipe sanitary seal consisting of 6-inch steel casing to a depth of 25 ft.
 - h. Exact # of screens cannot be provided, but perforated pipe is installed from a depth of 400 ft to 500 ft.
4. Will the owner have their own representative on site inspecting, or will the Contracting Officer's Representative (COR) be the Request For Information (RFI) coordinator?

RESPONSE: The COR will be the inspector on site on behalf of the Federal Government. Additional Government Technical Monitors (GTM's) may be assigned to the project for inspection purposes as well.

5. Does the enclosure need insulation?

RESPONSE: No

6. When was the last tank inspection and condition as a potable water storage?

Solicitation: 127EAX26Q0008 Amendment 0001
Project Name: Hopewell Campsite Recreation Improvements
Location: Carson National Forest, New Mexico
NAICS: 238990

RESPONSE: Not Applicable (N/A) to the scope of this contract.

7. Does the water storage tank have a separate inlet and outlet?

RESPONSE: Yes

8. Is there any as-built information on the storage tank?

RESPONSE: No

9. Will the Forest Service provide the permanent signage mentioned in the Specs and Drawings, or will they provide a preferred vendor for the signage?

RESPONSE: The drawings provide guidance throughout pertaining to which existing signs are to be removed and what they are to be replaced with. Additionally, the drawings call out many locations for new sign installations. Section 101110 - BULLETIN BOARD & Section 101400 - SIGNS specify the requirements for any/all new signs in the contract and are cross referenced in the bid schedule for associated quantities. Section D in the Drawings lists the signs required. The Federal Government is not providing signs for installation via this contract.

10. What is the name of the special permit needed if we camp on site while construction is ongoing?

RESPONSE: The approval for camping longer than 14 days will be at the discretion of the District Ranger. Should the District Ranger approve this request, the USDA Forest Service will coordinate this process and will provide the awarded contractor with the required documentation needed for extended camping on site.

11. Will the entire site be closed during construction or does the Forest Service prefer closure in phases? The entry way work is concerning due to it being the only vehicular entry.

RESPONSE: The entire site is slated for complete closure with an exemption for a private land owner who has easement through the day use area for property access. The Awardee will be required to submit a construction schedule prior to starting work for clear communication between parties that need access to the site.

12. Does this job have any domestic requirements such as AIS, Buy American, or BABAA?

RESPONSE: Yes, the Solicitation includes FAR 52.225-9 Buy American-Construction Materials (Nov 2025) and FAR 52.225-10 Notice of Buy American Requirement-Construction Materials (May 2014). American Iron and Steel (AIS) does not apply to this project. Build American Buy American Act (BABAA) does not apply to this project.

Solicitation: 127EAX26Q0008 Amendment 0001
Project Name: Hopewell Campsite Recreation Improvements
Location: Carson National Forest, New Mexico
NAICS: 238990

13. Regarding the enclosure: the model number, plans, and specs have differing numbers, indicating either a single door or a double door. How many doors are preferred?

RESPONSE: Sheet E1 specified an enclosure from Power Design Inc. with Model No. ME-1-72-2681-L1-MG. Section 262716-2.1 specifies the same Model No. A little further down in section 262716-2, item 1.j a double door entry on one side of the enclosure shall be split hinge type.

2.1 FIBERGLASS ENCLOSURE

- A. Power Design Inc. (Odell, Oregon; 541-354-3222): Model ME-1-72-2681-L1-MG, Dimensions 6'-0" x 6'-0" x 7'-9", as shown on the drawings, or an approved equal.



ENCLOSURE SHOWN IS MODEL NO.
ME-1-72-2681-L1-MG

5'-0"