



**DEPARTMENT OF THE AIR FORCE
HEADQUARTERS 88TH AIR BASE WING (AFLCMC)
WRIGHT-PATTERSON AIR FORCE BASE OHIO**

4 May 2026

Questions and Answers Document

CONTRACTING ACTIVITY/AGENCY: Operational Contracting Division, Directorate of Contracting, Air Force Life Cycle Management Center (AFLCMC), Air Force Material Command (AFMC), Department of the Air Force.

AFLCMC/PZIBB
2275 D Street, Area B, Bldg. 16 Room 150
Wright-Patterson AFB, OH 45433

QUESTIONS

Inquiry One (1): *One of our electrical subcontractors has requested the opportunity to visit the site in order to better understand the project details before finalizing pricing. Could you please confirm whether a pre-quote site visit can be scheduled for this requirement? If a site visit is available, please provide the available date/time, meeting location, and any base access requirements. We can provide the attendee names, company information, phone numbers, and email addresses as needed for coordination.*

ANSWER:

- A Site Visit will be permitted Wednesday, May 6, 2026, at 11am.
- POC Mike Bates 937-231-0584
- Meet: 2721 Sacramento St, WPAFB, OH, 45433

For contractors without base access, I will need name, driver's license number and state.

Inquiry Two (2): *I am currently preparing a quotation for the PDU relocation requirement at Wright-Patterson AFB and wanted to clarify a few items to ensure full alignment with the scope of work:*

1. *Can you confirm whether subfloor modifications (including stands, anchors, and structural adjustments) are fully within the contractor's scope, or if any portion will be government-supported?*
ANSWER: Government cannot supply flooring parts. Please provide all parts and the labor to install the parts.
2. *Are there confirmed weight and dimensional specifications available for PDU 9 to support rigging and equipment planning?* **ANSWER: Please see attached user guide from Leibert, page 4. Document states it's rated at 2500#**
3. *Is the expectation that the work be performed continuously, or will the project be phased over the period of performance?* **ANSWER: Yes. Work is to be performed continuously.**
4. *For the electrical portion, can you confirm whether all wiring, terminations, and reconnections are fully contractor-provided, or if any components/materials are government-furnished?* **ANSWER: Gov is not providing any additional material or equipment.**

Curtis V. Thomas III
Contracting Officer
AFLCMC/PZIBB

Strength Through Support