

Question	Answer
To proceed, we require detailed power specifications for the equipment. Please provide the requirements for the following: a. Inverter System: i. DC Input: -48V DC with Maintenance Bypass Panel (MBP) ii. AC Input: 208V, 3-Phase iii. AC Output: 208/120V, 3-Phase b. DC Power Plant: i. AC Input: 208V, 3-Phase	The system is 3 phase 208/120V in and out
New DC Plant, does the new DC plant connect to the MDP? Or is a distribution cabinet required. Site drawing shows New Rectifier Cabinet 1 and 2 but only calls for 1 DC Plant –	Bid as Shown, Plans show panels being reused
What is the bonding requirement?	No bonding is required for this project
Is the 30-day submittal process apart of the period of performance?	
Is this contract a part 12, 36 or Hybrid.	This is a Part 12 action.
The site visit was yesterday, when is the deadline for RFIs/questions?	The deadline for questions is today Monday 4/20/2026
Minimal information was provided for what is expected to be provided with the bid package - please confirm that a completed Reps and Certs and price breakout schedule are the only requirements for an acceptable bid submission.	Yes only the Reps and Certs page and the Price break out schedule are the only items required to be submitted
Is the bidding date & time remains the same? Apr. 24, 1PM	Yes
• Can I ask for a copy of the site visit attendees / planholders list?	Posted to SAM
• Is there any addendum aside from addendum 1 posted on sam?	as of right now the only Amendment is the Amendment 001
How much will be the project estimated cost? If not available, can you provide me a rough range?	\$1,000,000.00- \$5,000,000.00
Will escort availability be guaranteed during all allowable work hours? If not, will delays caused by lack of escort support justify time extensions?	Escorts will be provided from 0730-1630 Monday-Friday. If weekend work is needed prior coordination will need to take place with the NEC.
No division 1 submittals were provided - please confirm there are no division 1 requirements required (i.e. QC, Schedule, etc.)	

Will there be a requirement for a full-time site safety & health officer (SSHO)? There is a reference to EM 385-1-1 but no specific requirements in regard to key personnel.
