

SALIENT CHARACTERISTICS & PRICING SCHEDULE

FOR

Transformer Upgrade Supplies

Rev 01

April 2026

**Salient Characteristics & Pricing
Schedule For
Transformer Upgrade Supplies**

Rev 01

1. **BACKGROUND:** Fairchild AFB, WA
The 92 CES requires supplies to repair and upgrade the transformer in the Structures Shop.
2. **OBJECTIVES:**
Upgrading the transformer will provide the 92 CE Structures shop with a stable and robust power supply, capable of handling high-draw equipment. This ensures mission readiness and prevents damage to critical tools and infrastructure
3. **REQUIREMENTS:**
Contractor shall provide and deliver the parts listed below as **Brand Name or Equal** in salient characteristics.
4. **PARTS LIST:**

ITEM #	PART NUMBER <u>or</u> <u>EQUAL</u>	DESCRIPTION <u>or</u> <u>EQUAL</u>	QTY	Unit	Unit \$	Total \$
1	980020020304	4"EMT 90 Degree Elbow	2	Ea		
2	784564104694	4" EMT Set Screw Coupling	10	Ea		
3	783510145170	36"x36"x14" Nema 3R Enclosure, screw cover	1	Ea		
4	980010020109	4" EMT Conduit, Steel, 10' length	100	Ea		
5	702316501027	Deep strut, elongated holes, steel pre-galvanized, 1-5/8"x1-5/8"x10'	20	Ea		
6	702316501164	Two Hole End angle, steel electro-galvanized, 9/16", 8 bolt	8	Ea		
7	702316528925	All Threaded rod, Zinc-plated, 3/8"x10'	20	Ea		
8	784564104595	4" EMT Set Screw Connector	4	Ea		
9	980010001108	4" Rigid Steel Conduit, 10' length	20	Ea		
10	783669005684	Mechanical Lug, 1-hole, 2 conductor, 2AWG-600 MCM, 1/2" stud size, aluminum	4	Ea		
11	616013140819	Universal Strut Strap, 4", Hot dipped, galvanized	10	Ea		
12	048243539062	400 MCM THHN/THWN-2 Stranded Copper, Black 2500'	1280	Ea		