

#	CONTRACTOR QUESTION	GOVERNMENT RESPONSE
1	Process Data (Min - Normal Operation - Max): • Fluid: Propane • Flowrate: • Density: • Viscosity: • Pressure: • Temperature:	Fluid: Liquid Propane Flow Rate: Unknown Density: Varies depending on temp and humidity Viscosity: Varies depending on temperature Pressure: Unknown Temperature: Varies with outside weather; training conducted between 1 April and 31 October
2	Meter Requirements: • Connection size and type: 2 1/2" • Power supply required: • Area classification (meter): • Area classification (display): • Mounting preference (Remote or Local): • Communication protocol: • Cable length requirement:	Connection: 2 1/2" Schedule 40 Power: Depends on the meter, 24V DC ideal Area Classification: Class 1 Division 2 Area Classification: Class 1 Division 2 Mounting Preference: Local Communication Protocol: No preference Cable Length: Depends on the location of the meter compared to power source (if needed)
3	Face-to-face meter length requirement (if applicable)	Not sure what you are talking about
4	What is the estimated flow of the gas?	Unknown
5	What is the operating pressure?	Unknown
6	Pipe Size & Material?	2 1/2" Schedule 40
7	What is the maximum expected flow during pump testing?	There isn't pump testing
8	Do you require an electronic output in addition to the non-resettable totalizer?	No

#	CONTRACTOR QUESTION	GOVERNMENT RESPONSE
9	What is the straight run between the elbow and the flange?	Approximately 70" (See attached photos)
10	What is the direction of the flow?	Going from a 10,000 Gallon Propane Tank to the Fire Department Training Tower for use. (See attached photos)
11	Are 150# RF flanges required, or another type?	No, Class 300 rating (if needing a flange)
12	What is the expected temperature range in the pipe?	Unknown. Dependent on outside temperature. Training typically conducted between 1 April and 31 October
13	What is the expected pressure range in the pipe?	Unknown. Depends on outside temperature.
14	What are the minimum, normal, and maximum flow rates expected?	Unknown.
15	Is Class 1 Div 1 or Class 1 Div 2 required?	Class 1 Division 2
16	What output signals are required (besides the non-resettable totalizer)?	Only requiring a non-resettable totalizer with the ability to be calibrated.
17	What is the required voltage for the meter?	Depends on the meter. 24V DC is ideal.