

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF 3	PAGES
2. AMENDMENT/MODIFICATION NUMBER 0002		3. EFFECTIVE DATE 05-06-2026	4. REQUISITION/PURCHASE REQ. NUMBER		5. PROJECT NUMBER (if applicable) 631-26-010	
6. ISSUED BY CODE Department of Veterans Affairs Network Contracting Office 1 VA CENTRAL WESTERN MASSACHUSETTS HCS 421 North Main Street Leeds MA 01053-9764		36C241	7. ADMINISTERED BY (If other than Item 6) CODE Department of Veterans Affairs Network Contracting Office 1 VA CENTRAL WESTERN MASSACHUSETTS HCS 421 North Main Street Leeds MA 01053-9764		36C241	
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders			(X)	9A. AMENDMENT OF SOLICITATION NUMBER 36C24126Q0357		
			X	9B. DATED (SEE ITEM 11)		
				10A. MODIFICATION OF CONTRACT/ORDER NUMBER		
				10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended, ☐ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. ** HOUR & DATE for Receipt of Offers is EXTENDED to: 06-05-2026 1:00PM EDT						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
☐	D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is as follows: 1. Provide responses to RFIs received. 2. Provide site visit sign-in sheet from 4/22/2026. 3. Notice of 2nd site visit on 5/14/2026, 11:00AM (EST). Meet on North side of Building 60 (Chapel) near the entrance. 4. Notice of RFI extension to 5/21/2026, 1:00PM (EST).						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)		16C. DATE SIGNED	

631-26-010 Abate and Upgrade Bldg 1 Common Area
Responses to RFIs Received

1. Upon review of the contract documents, it appears that the asbestos-containing material (ACM) quantities indicated in the drawings and/or specifications may be inconsistent with conditions observed during the site visit on April 22, 2026. Specifically, quantities for areas other than the 1st floor main corridor (east) appear to be potentially inaccurate. Can you please confirm quantities?

VA Response:

VA has reviewed the quantities and is not making any changes.

2. Can the abatement contractor leave the 40-yard closed container in parking lot M. For the duration of abatement.

VA Response:

Location of container to be approved after contract award. Lot N or laydown area closer to Building 1 will most likely have availability during the assumed contract period.

3. Will the VA be responsible for all TEM's clearances minimum (7) including the courier service with 3-hour turnarounds? For weekend abatements.

VA Response:

VA to manage VPIH for TEM clearances. TEMs require 24hrs for processing, VA is accounting for having TEMs completed on weekends.

4. Will the Electrical panels on both the floors be able to be used for a 3 phase 50-amp pig tail.

VA Response:

Generator must be provided. In some instances, building power may be available. If pigtails are installed, they must be removed prior to hospital operating hours and additional work may be performed to keep the panel secured during use.

5. Can those panels handle the added load?

VA Response:

See answer to #4. Panels must be investigated with VA prior to use.

6. Are the windows operable for neg air exhaust throughout the building? If not, please let inform us of what windows do work. Are there other options. The VA can suggest?

VA Response:

Attachment A shows all windows that are unavailable for use (crossed out in red). Windows for exhaust must be coordinated with COR.

7. When do the off hours begin on Friday afternoons?

VA Response:

Off hours begin at 17:30 on Fridays.

ATTACHMENTS

See attached document: S06_Attch A-B1 Common Areas Windows.

See attached document: S06_site visit sign-in sheet 4-22-26_631-26-010.