

OFFEROR'S QUESTIONS

Question No	Contractor Question	Government Response
1	Hoping you could tell me the arrangement of the current batteries so I can quote the correct accessories. A picture would be best or let me know how many jars wide by how many high.	The batteries are installed in racks, laying on their sides, so that connections are accessible. Both UPS rooms have a combined total of 240 batteries, one rack is 6 batteries high by 4 wide. 5 racks per row total of 120 batteries, two rows 240. Authorized distributors can receive picture/technical drawing information from the OEM.
2	could you please confirm the required voltage configuration/system arrangement? We would like to verify how the 480 cells are intended to be configured in order to ensure we provide the correct quotation and system setup.	The batteries are installed in racks, laying on their sides, so that connections are accessible. Both UPS rooms have a combined total of 240 batteries, one rack is 6 batteries high by 4 wide. 5 racks per row total of 120 batteries, two rows 240.
3	Please find below the response received from our supplier for your review and guidance:“Because we have previous experience with these products, EnerSys will not provide a quotation unless all required technical drawings are supplied to determine the correct connectors. Once the drawings are available, we can proceed with obtaining a quotation from our factory representative.”Kindly advise how you would like us to proceed or if the required technical drawings can be made available to facilitate the quotation process.	The OEM EnerSys can provide the required drawings. Authorized distributors can receive picture/technical drawing information from the OEM.

4	Do you know what the system voltage is? Can you clarify “certificates”? Do they want them capacity tested? On site, or at the factory? Also what is a “certificate of inspection”	240 Batteries per unit, installed in series. We do not require testing of the batteries on site. Each battery should come with a certificate that they will do what the manufacturer advertises.
5	Can you clarify “certificates”? Do they want them capacity tested? On	YES. 240 *2V BATTERIES IN SERIES. 20 WIDE X 6, HIGH BACK TO BACK THE BATTERIES ARE A STANDARD SIZE AND ARE REPLACING INSTALLED BATTERIES. ENERSYS PROVIDED THE RACK AND HAS THE DRAWINGS.
6	"Below is the response received from the OEM: To accurately quote the connector kits, we will need the battery system configuration. Please also confirm whether the batteries will be installed using the existing racks."	The OEM Enersys can provide the required drawings. Authorized distributors can receive picture/technical drawing information from the OEM. Batteries will be installed using existing racks.
7		
8		
9		
10		
11		
12		