

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 3 PAGES		
2. AMENDMENT/MODIFICATION NUMBER 0001			3. EFFECTIVE DATE 04/21/2026		4. REQUISITION/PURCHASE REQUISITION NUMBER		5. PROJECT NUMBER (If applicable)	
6. ISSUED BY BLM OR-ST OFC PROC MGMT BR(OR952) 1220 SW 3rd Avenue, 12th Floor PORTLAND OR 97204			CODE LHA		7. ADMINISTERED BY (If other than Item 6) CODE			
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)					9A. AMENDMENT OF SOLICITATION NUMBER (X) 140L4326Q0054			
					9B. DATED (SEE ITEM 11) (X) 04/21/2026			
					10A. MODIFICATION OF CONTRACT/ORDER NUMBER			
					10B. DATED (SEE ITEM 13)			
CODE					FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended. ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
☐	
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
See continuation page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
		Matthew Duane	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	RDO_2026 CHIP AGGREGATE, Roseburg District BLM, Oregon Amendment 0001 is to release vendor questions and answers and extend the quotation due date. Please see Amendment 0001 Attachment 1 for the questions and answers. The quotation due date is extended to May 8, 2026 at 11:00 am pacific time. Period of Performance: 06/01/2026 to 07/31/2026				

Solicitation: 140L4326Q0054; Amendment 0001
Vendor Questions and Answers

Amendment 0001 is to release Vendor Questions and Answers regarding the subject solicitation. This amendment extends the quotation due date to Friday May 4, 2026 at 11:00 am Pacific Time.

Vendor Questions and Answers

1. The specifications call for Chip Seal Aggregate, and I would like to know if pea gravel would be acceptable as a functional equivalent.
 - a. No, pea gravel is not acceptable. The vendor must follow the gradation in the specifications which is the only acceptable form of chip aggregate. See Page 5 of the solicitation for material specifications, including the following table:

TABLE 1
Grading Requirements for Crushed Aggregate
with Percentage by Weight Passing Square Mesh Sieves
Using AASHTO T-11 and T-27

Sieve <u>Designation</u>	Percent <u>Passing</u>
1/2"	100
3/8"	80-100
1/4"	10-40
No. 4	----
No. 8	0-6
No. 30	0-2
No. 200*	0-2

*Value is from washed gradation.