

1. Scope of Work (Federal Contract-Ready)

The Contractor shall provide all labor, materials, tools, equipment, and transportation necessary to perform troubleshooting, diagnostic testing, and repair services on Cummins generator, Model **DSFAA-8746821**. The work shall address the reported condition of no power to the panel and failure to start, which has been preliminarily attributed to a defective control board. The Contractor shall remove and replace the control board, Part Number **327-1379-02** (PCB ASSY BASEBOARD (CAN/J1 ONAN)), and perform all associated tasks required to restore the generator to full operational status in accordance with the manufacturer's specifications. All work shall be performed in compliance with applicable federal, state, and local regulations, as well as the original equipment manufacturer's (OEM) service procedures and quality standards.

2. Performance Work Statement (PWS)

Title: Repair of Cummins Generator Model DSFAA-8746821

1.0 Scope The Contractor shall furnish all labor, materials, equipment, tools, and transportation necessary to perform troubleshooting, diagnostic testing, and repair services on Cummins generator, Model **DSFAA-8746821**. The work shall address the reported condition of no power to the panel and failure to start, which has been preliminarily attributed to a defective control board. The Contractor shall remove and replace the control board, Part Number **327-1379-02** (PCB ASSY BASEBOARD (CAN/J1 ONAN)), and perform all associated tasks required to restore the generator to full operational status in accordance with the manufacturer's specifications.

2.0 Applicable Documents The Contractor shall comply with all applicable federal, state, and local regulations, as well as the original equipment manufacturer's (OEM) service procedures and quality standards.

3.0 Performance Requirements

- Perform all work in accordance with OEM specifications.
- Ensure all replaced components are new and meet OEM standards.
- Conduct operational testing after repairs to verify full functionality.
- Provide a written service report detailing diagnostics, repairs performed, and test results.

4.0 Period of Performance The Contractor shall complete all work within the period specified in the awarded contract.

5.0 Place of Performance Work shall be performed at the location designated in the contract award.

6.0 Deliverables

- Service report including diagnostic findings, parts replaced, and final operational status.

- Warranty documentation for all parts and labor.

3. Statement of Objectives (SOO)

Title: Repair of Cummins Generator Model DSFAA-8746821

1.0 Purpose The purpose of this requirement is to restore the Cummins generator, Model **DSFAA-8746821**, to full operational status to ensure reliable power generation capability.

2.0 Objectives

- Diagnose the cause of the generator's failure to start and lack of power to the panel.
- Replace the defective control board, Part Number **327-1379-02** (PCB ASSY BASEBOARD (CAN/J1 ONAN)), with a new OEM-compliant component.
- Conduct post-repair operational testing to confirm the generator meets manufacturer performance standards.
- Provide documentation of all work performed, including diagnostics, repairs, and test results.

3.0 Desired Outcomes

- Generator is fully operational and capable of meeting its intended power output requirements.
- All repairs are completed in compliance with OEM specifications and applicable regulations.
- The Government receives complete service documentation and warranty coverage for parts and labor.