

Q1: Is this replacing an existing system?

A1: Yes, an old unit needs removed.

Q2: Will you accept an alternative brand with comparable specs and varying product dimensions?

A2: Yes.

Q3: What is the timeline for this project?

A3: May 1, 2026.

Q4: What is the total CFM required? Would you accept increased cfm?

A4: Required CFM is 87.0, anything over 87 is acceptable but not below.

Q5: Does your site allow increased weight for air compressors or is there a limit?

A5: We are looking for a weight of 739 lbs, however, weight is not an issue as it will be installed onto a concrete pad.

Q6: Pictures of the site where unit will be installed?

A6:



Q7: Complete shipping address?

A7: 5165 Ellsworth Ave BLDG 61685 Nellis AFB NV 89191.

Q8: Does this include removal and installation of the preexisting and new compressor?

A8: Yes, please see PWS in the solicitation.