



United States Department of the Interior

BUREAU OF INDIAN EDUCATION

Division of Acquisitions

1011 Indian School Road NW

Albuquerque, New Mexico 87104

Questions & Answers for RFQ # 140A2326Q0060 – Greenhouse - JES

1. Can I get a map of where proposed greenhouse will go, and where nearest electrical hookup is, and where nearest water hookup is located? Any additional information would be great, such as size of water main etc. Do you single or 3phase power there?

There is a single phase power near the greenhouse sight. Water source is from the water tower water via a spigot. The map of the proposed location:

