

127EAW26Q0018 - Frazier Mt. Road Paving

RFI responses will be responded to as necessary in amendment format which will be posted to the solicitation via beta.SAM.gov. All Request for Information (RFI's) shall be submitted ONLY to the Contracting Officer at Gregory.Cunningham@usda.gov, in writing using attached RFI log

Telephone requests for information will not be accepted or returned

Updated

5/4/2026 8:10

RFI #	RFI Question	Government RFI Response	Notes
1	There is a low area at gate at main office location. Do we need to Patch this area before slurry coat?	Yes, this area will need to be sawcut and hot patched prior to slurry coat. Approximately 10'x10'	
2	I searched for liquidated damages and I didn't see it in the documents. Is there liquidated damages and if so what is amount?	There are no liquidated damages for this project.	
3	Just to clarify the road will be going back to the current width and we do not need to rebuild the road to widths on bid form	Correct, the width was a conservative measurement due to various changes in width throughout. All widths stay the same as existing.	
4	Just to clarify the class 2 base bid item is just in case we need to add base to existing road if grinded up asphalt doesn't appear to have enough base in certain areas?	Correct, the thickness throughout could vary and this is estimated to make up for any thin areas of asphalt.	
5	Sourcing the class two base for this project. Can we use a Caltrans recycled Class 2 base, or does it need to be Native Aggregate?	Yes.	
6	For cracks larger than 1.5 Inches and smaller than 6 inches, can the contractor install mastic crack sealant in lieu of wide crack patching with AC?	Yes, that would be acceptable. Any Crack over 6" width would still be hot patched.	
7	Can the contractor close Fraizer Mountain Road to install the slurry seal?	Yes, this is a Forest Service Road so we can close it with barricades and by informing the public via social media. The upper section can be closed by the existing gate.	