



Embassy of the United States of America

U.S. Embassy Tegucigalpa
May 4, 2026

Dear Prospective Quoter:

Subject: Request for Quotations number **19H08026Q0035 – Preventive Maintenance Service Contract for Mechanical Equipment.**

Enclosed is a Request for Quotations (RFQ) for Preventive Maintenance Service Contract for Mechanical Equipment. If you would like to submit a quotation, follow the instructions in Section 3 of the solicitation, complete the required portions of the attached document, and submit it to the address shown on Standard Form 18 that follows this letter.

The U.S. Government intends to award a contract to the responsible company submitting an acceptable quote at the lowest price. We intend to award a contract based on initial quotations, without holding discussions, although we may hold discussions with companies in the competitive range if there is a need to do so.

Quotations are due by **Monday, May 18, 2025** at 10:00 am (local time). No quotations will be accepted after this time. Quotations must be in English and incomplete Quotations will not be accepted.

Your quotation must be submitted electronically to TguBids@State.gov. Please name subject of your email “**RFQ 19H08026Q0035 – Quotation Enclosed – Company Name**” It is important to make sure the submission is made in specific size and format; in MS-Word 2007/2010 or MSExcel 2007/2010 or Adobe Acrobat (pdf) file format. The file size must not exceed 30MB. If the file size should exceed 30MB, the submission must be made in separate files and attached to separate emails with less than 30MB each.

In order for a quotation to be considered, you must also complete and submit the following:

1. SF-18
2. Section I, Pricing
3. Section 5 Representations and Certifications
4. Additional information as required in Section 3
5. Proof of SAM Registration

Direct any questions regarding this solicitation to e-mail TguBids@State.gov no later than **Tuesday, May 12, 2025, at 10:00 am (local time)**. Please name the e-mail subject as “**RFQ 19H08026Q0035 - Questions - Company Name**”

Offerors are strongly encouraged to complete their registration in SAM at <https://www.sam.gov>



Embassy of the United States of America

Any issues or concerns regarding registration should be communicated to tgubids@state.gov no later than the questions due date.

The selected awardee must obtain active SAM registration within the first six months of the contract's period of performance and maintain active SAM status for the entire duration of the contract. Failure to secure or maintain active SAM registration as required may result in the contractor being deemed ineligible for continued performance, payment, contract modifications, or the exercise of options, as applicable.

At the time of proposal submission, offerors are required to provide an active NCAGE Code. Failure to provide an active NCAGE Code at submission may result in a determination of nonresponsibility, and the proposal will not receive further consideration.

Lack of active SAM registration may be taken into account during the solicitation and procurement process.

Sincerely,

Beckman, Richard (BeckmanRY@state.gov)
04/28/2026 22:08 GMT



Richard Beckman
Contracting Officer

TABLE OF CONTENTS

SECTION 1 - THE SCHEDULE

- SF 18 cover sheet
- Continuation To SF-18, RFQ Number 19H08026Q0035, Prices, Block 11
- Continuation To SF-18, RFQ Number 19H08026Q0035 , Schedule Of Supplies/Services, Block 11 Description/Specifications/Work Statement
- Attachment 1 to Description/Specifications/Performance Work Statement, Government Furnished Property.
- Attachment 2 to Description/Specifications/Performance Work Statement Contractor Furnished Property.

SECTION 2 - CONTRACT CLAUSES

- Contract Clauses
- Addendum to Contract Clauses - FAR and DOSAR Clauses not Prescribed in Part 12

SECTION 3 - SOLICITATION PROVISIONS

- Solicitation Provisions
- Addendum to Solicitation Provisions - FAR and DOSAR Provisions not Prescribed in Part 12

SECTION 4 - EVALUATION FACTORS

- Evaluation Factors
- Addendum to Evaluation Factors - FAR and DOSAR Provisions not Prescribed in Part 12

SECTION 5 - REPRESENTATIONS AND CERTIFICATIONS

- Offeror Representations and Certifications
- Addendum to Offeror Representations and Certifications - FAR and DOSAR Provisions not Prescribed in Part 12

REQUEST FOR QUOTATION (THIS IS NOT AN ORDER)		THIS RFQ ☐ IS ☒ IS NOT A SMALL BUSINESS SET-ASIDE		PAGE 1 OF 57 PAGES	
1. REQUEST NO. 19H08026Q0035	2. DATE ISSUED 05/04/2026	3. REQUISITION/PURCHASE REQUEST NO. PR15948487	4. CERT. FOR NAT. DEF. UNDER BDSA REG. 2 AND/OR DMS REG. 1	RATING	
5a. ISSUED BY AMERICAN EMBASSY TEGUCIGALPA GSO, ACQUISITIONS UNIT, ATTN: GSO TEGUCIGALPA HONDURAS			6. DELIVER BY (Date) 05/12/2026		
5b. FOR INFORMATION CALL (NO COLLECT CALLS)			7. DELIVERY		
NAME Jorge D. Morales		TELEPHONE NUMBER		☐ FOB DESTINATION ☐ OTHER (See Schedule)	
		AREA CODE	NUMBER	9. DESTINATION	
8. TO:			a. NAME OF CONSIGNEE AMERICAN EMBASSY TEGUCIGALPA		
a. NAME	b. COMPANY		b. STREET ADDRESS APARTADO POSTAL NO. 3453, ATTN: GSO		
c. STREET ADDRESS			c. CITY TEGUCIGALPA		
d. CITY	e. STATE	f. ZIP CODE	d. STATE	e. ZIP CODE	
10. PLEASE FURNISH QUOTATIONS TO THE ISSUING OFFICE IN BLOCK 5a ON OR BEFORE CLOSE OF BUSINESS (Date) 05/18/2026 at 10:00 am		IMPORTANT: This is a request for information and quotations furnished are not offers. If you are unable to quote, please so indicate on this form and return it to the address in Block 5a. This request does not commit the Government to pay any costs incurred in the preparation of the submission of this quotation or to contract for supplies or service. Supplies are of domestic origin unless otherwise indicated by quoter. Any representations and/or certifications attached to this Request for Quotation must be completed by the quoter.			
11. SCHEDULE (Include applicable Federal, State and local taxes)					
ITEM NO. (a)	SUPPLIES/ SERVICES (b)	QUANTITY (c)	UNIT (d)	UNIT PRICE (e)	AMOUNT (f)
1	Preventive Maintenance for Mechanical Equipment	1	yr		\$
12. DISCOUNT FOR PROMPT PAYMENT		a. 10 CALENDAR DAYS (%)	b. 20 CALENDAR DAYS (%)	c. 30 CALENDAR DAYS (%)	d. CALENDAR DAYS NUMBER PERCENTAGE
NOTE: Additional provisions and representations ☐ are ☐ are not attached.					
13. NAME AND ADDRESS OF QUOTER			14. SIGNATURE OF PERSON AUTHORIZED TO SIGN QUOTATION		15. DATE OF QUOTATION
a. NAME OF QUOTER					
b. STREET ADDRESS			16. SIGNER		
c. COUNTY			a. NAME (Type or print)	b. TELEPHONE	
				AREA CODE	
d. CITY	e. STATE	f. ZIP CODE	c. TITLE (Type or print)	NUMBER	

SECTION 1 - THE SCHEDULE
CONTINUATION TO SF-18
RFQ NUMBER 19H08026Q0035
PRICES, BLOCK 11

I. PERFORMANCE WORK STATEMENT

- A. The U.S Embassy at Tegucigalpa requires professional services from a contractor to perform preventive maintenance services for: Modular Chillers, associated Pump Module, Central station Air-Handling Units, Ventilation Fans, associated VFD's, VAV Air terminals, Exhaust Fans, Electric Water Heater, Domestic Booster Pump and Storage Tank located inside CAA areas. These services shall result in all systems being serviced under this agreement being in good operational condition when activated. This work is to be performed on systems accessing the PCC/CAA areas of the building. Please see section 1.4.5 for security requirements.
- B. This is a firm fixed price contract payable entirely in dollars. Prices for all Contract Line-Item Numbers (CLIN) shall include proper disposal of toxic substances as per Item 5.3 where applicable, travel costs and insurance values
 - a. No additional sums will be payable for any escalation in the cost of materials, equipment or labor, or because of the contractor's failure to properly estimate or accurately predict the cost or difficulty of achieving the results required. The contract price will not be adjusted due to fluctuations in currency exchange rates.
- C. The contract will be for a one-year period from the date of the contract award, with a maximum of one one-year optional period of performance and will be expected to commence no later than September 03, 2026.
- D. The offer must be submitted in English
- E. All Offers must be priced in US Dollars (USD)
- F. All offers must be valid for 60 days
- G. Place of performance: **New Embassy Compound (NEC) Avenida Los Proceres / Calle Bustamante y Rivero Tegucigalpa, Honduras**

II. PRICING

The rates below include all costs associated with providing preventive maintenance services in accordance with the attached scope of work, and the manufacturer's warranty including materials, labor, insurance (see FAR 52.228-4 and 52.228-5), overhead, profit and GST (if applicable).

Base Year. The Contractor shall provide the services shown below for the base period of the contract and continuing for a period of 12 months.

CLIN	Description	Quantity of Equipment	Type of services	No. of service	Unit price / service (\$)	Total per year (\$)
0001	Maintenance Service for Modular Scroll Air-Cooled Chiller (three - 60 Ton modules approx.), One Primary Pump Module (two- 50 HP), and one Heat Exchanger Module, 460 V/60 H/ 3PH, R-410.	5	Quarterly	4		
0002	Maintenance Service for 50 HP Pump Motor Starter and AHU's/Variable Frequency Drive	3	Annual	1		
0003	Chiller Panel, Electric Controls	1	Annual	1		
0004	Hydronic Water Treatment System	1	Quarterly	4		
0005	Maintenance Service for Central Station Air-Handling Units; V-AHU-51 and V-AHU-52	2	Quarterly	4		
0006	Maintenance service for Fan Coil Units: N-FCU-16, N-FCU-18, N-FCU-20, V-FCU-1A, V-FCU-1B, V-FCU-2A, V-FCU-2B, V-FCU-3A, V-FCU-3B, V-FCU-4A, V-FCU-4B, V-FCU-5A, V-FCU-5B , V-FCU-6 and V-FCU-7	15	Quarterly	4		
0007	VAV air terminal V-TB-14	1	Annual	1		
0008	Exhaust Fans, V-EF-01, V-EF-02, V-EF-03 and V-EF-04.	2	Annual	1		
0009	Heater, Water V-EWH-01	1	Annual	1		
0010	Domestic Water Booster Pump, Storage Tank and Pump Controller.	1	Annual	1		
0011	DBA	1	Annual	1		
Total Base Year						

Option Year 1. The Contractor shall provide the services shown below for Option Year 1 of the contract and continuing for a period of 12 months.

CLIN	Description	Quantity of Equipment	Type of services	No. of service	Unit price / service (\$)	Total per year (\$)
1001	Maintenance Service for Modular Scroll Air-Cooled Chiller (three - 60 Ton modules approx.), One Primary Pump Module (two- 50 HP), and one Heat Exchanger Module, 460 V/60 H/ 3PH, R-410.	5	Quarterly	4		
1002	Maintenance Service for 50 HP Pump Motor Starter and AHU's/Variable Frequency Drive	3	Annual	1		
1003	Chiller Panel, Electric Controls	1	Annual	1		
1004	Hydronic Water Treatment System	1	Quarterly	4		
1005	Maintenance Service for Central Station Air-Handling Units; V-AHU-51 and V-AHU-52	2	Quarterly	4		
1006	Maintenance service for Fan Coil Units: N-FCU-16, N-FCU-18, N-FCU-20, V-FCU-1A, V-FCU-1B, V-FCU-2A, V-FCU-2B, V-FCU-3A, V-FCU-3B, V-FCU-4A, V-FCU-4B, V-FCU-5A, V-FCU-5B , V-FCU-6 and V-FCU-7	15	Quarterly	4		
1007	VAV air terminal V-TB-14	1	Annual	1		
1008	Exhaust Fans, V-EF-01, V-EF-02, V-EF-03 and V-EF-04.	2	Annual	1		
1009	Heater, Water V-EWH-01	1	Annual	1		
1010	Domestic Water Booster Pump, Storage Tank and Pump Controller.	1	Annual	1		
1011	DBA	1	Annual	1		
Total Option Year 1						

GRAND TOTAL OF BASE + OPTION YEAR 1	
Base Year Total	\$
Option Year 1 Total	\$
GRAND TOTAL	\$

Repair Option. Repairs are NOT included under this agreement (see 3.4) and are to be done outside this contract. However, the Government desires current labor rates if there is an issue discovered during the preventive maintenance of the specified equipment. Please provide your current labor rates in the Repair Option fields below. As stated in 3.4 any necessary repairs or parts will be submitted for approval and then billed against a separate Purchase Order. The Contractor is not approved to do any additional work without specific authorization from the Contracting Officer.

Repair Labor Rates	
Base Year \$/hr :	
Option Year \$/hr:	

III. VALUE ADDED TAX

Value Added Tax (VAT) is not applicable to this contract and shall not be included in the CLIN rates or Invoices because the U.S. Embassy has a tax exemption certificate from the host government.

IV. QUOTES AND PAYMENT IN U.S. DOLLARS

U.S. firms are eligible to be paid in U.S. dollars. U.S. firms desiring to pay in U.S. dollars should commit their quotes in U.S. dollars. A U.S. firm is defined as a company which operates as a corporation incorporate under the laws of a state within the United States. Any firm, which is not a U.S. firm, is a foreign firm. Any firm that does not meet the above definition of U.S. firm shall submit its prices and receive payment in local currency.

V. NOTICE TO PROCEED

After Contract award and submission of acceptable insurance certificates and copies of all applicable licenses and permits, the Contracting Officer will issue a notification to begin work. A statement about the start will be included (a minimum of ten (10) days from date of Contract award unless the Contractor agrees to an earlier date) on which performance shall start.

CONTINUATION TO SF-18,
RFQ NUMBER 19H08026Q0035
SCHEDULE OF SUPPLIES/SERVICES, BLOCK 11
DESCRIPTION/SPECIFICATIONS/WORK STATEMENT

I. SCOPE OF WORK

The purpose of this fixed-priced contract is to obtain preventive maintenance services for mechanical equipment managed by the U.S Embassy Tegucigalpa, Honduras. The Contractor should maintain the following equipment in a safe, reliable and efficient operating conditions. Please see equipment list included in the STATEMENT OF WORK.

- Three Modular Scroll Air-Cooled Chiller, 60 Ton each, Multistack, located at NOB Building Roof.
- One Primary Pump Module (2- 50 HP Single Primary/Standby), located at NOB Building Roof.
- One- 50 HP Pump Motor Starter /Variable Frequency Drive.
- One Heat Exchanger Module), located at NOB Building Roof.
- Fifteen Fan Coil Units, 3 to 10 Tons approx.
- One VAV terminal Unit.
- Four Exhaust Fans, 500 to 1500 CFM approx.
- One Electric Water Heater
- One Domestic Water Booster Pump Skid, Storage Tank and Pump Controller.

The Contractor shall provide all necessary managerial, administrative and direct labor personnel, as well as all transportation, equipment, tools, supplies and materials required to perform inspection, maintenance, and component replacement as required to maintain the systems in accordance with this work statement. Under this Contract the Contractor shall provide:

The services of trained and qualified technicians to inspect, adjust, and perform scheduled preventive maintenance.

The equipment shall be clean and in good operating condition upon completion of the service. The preventive maintenance service shall result in the parts of the system serviced being in a condition to operate efficiently and effectively.

1.3. Hours of performance

The Contractor shall maintain work schedules. The schedules shall take into consideration the hours that the staff can effectively perform their services without placing a burden on the security personnel of the Post. The Contractor shall deliver services on weekends, Holidays or whenever stipulated by Post.

1.4. Access to government building and standards of conduct

- 1.4.1. General. The Contractor shall designate a representative who shall supervise the Contractor's technicians and be the Contractor's liaison with the American Embassy Tegucigalpa. The Contractor's employees shall be on-site only for contractual duties and not for any other business or purpose. Contractor employees will be given

access to the equipment and equipment areas and will be escorted by Embassy personnel.

1.4.2. Personnel Security. The Government reserves the right to deny access to U.S.-owned and U.S.-operated facilities to any individual. The Contractor shall provide the names, biographic data and police clearance on all Contractor personnel who to be used on this Contract prior to their utilization. Submission of information shall be made within 30 days of award of contract. No technician will be allowed on site without prior authorization. Note: this may include cleared personnel if advance notice of visit is not given at least one week before the scheduled visit.

1.4.3. Vehicles. Contractor vehicles will not be permitted inside the embassy compound without prior approval. If vehicle access is necessary, submit contractor vehicle information (Make, Model, License Plate #) along with a written justification as to why access is necessary. This shall be submitted to the Facility Manager at least one (1) week prior to the visit.

1.4.4. Government shall issue identity cards to Contractor personnel, after they are approved. Contractor personnel shall display identity card(s) on the uniform at all times while providing services under this contract. These identity cards are the property of the US Government. The Contractor is responsible for their return at the end of the contract, when an employee leaves Contractor service, or at the **request** of the Government. The Government reserves the right to deny access to U.S.-owned and U.S.-operated facilities to any individual.

1.4.5. Security Clearances. All Work under this contract are designated CAA and PCC areas and shall be performed by cleared American personnel as needed to complete the services. The Contractor shall work closely with the COR, the Post Facility Manager (FM) or the General Services Officer (GSO).

1.5. Standards of Conduct

1.5.1. General. The Contractor shall maintain satisfactory standards of employee competency, conduct, cleanliness, appearance, and integrity and shall be responsible for taking such disciplinary action with respect to employees as may be necessary. Each Contractor employee shall adhere to standards of conduct that reflect credit on themselves, their employer, and the United States Government. The Government reserves the right to direct the Contractor to remove an employee from the worksite for failure to comply with the standards of conduct.

The Contractor shall immediately replace such an employee to maintain continuity of services at no additional cost to the Government.

1.5.2. Neglect of Duties. Neglect of duties is unacceptable. This includes sleeping while on duty, unreasonable delays or failures to carry out assigned tasks, conducting personal affairs during duty hours and refusing to render assistance or cooperate in upholding the integrity of the worksite security.

1.5.3. Disorderly Conduct. The Contractor shall not condone disorderly conduct, use of abusive or offensive language, quarreling, and intimidation by words, actions, or fighting. Also included is participation in disruptive activities that interfere with normal and efficient Government operations.

1.5.4. Intoxicants and Narcotics. The Contractor shall not allow its employees while on duty to possess, sell, consume, or be under the influence of intoxicants, drugs or substances which produce similar effects.

1.5.5. Criminal Actions. Contractor employees may be subject to criminal actions as allowed by law in certain circumstances. These circumstances include but are not limited to the following actions: falsification or unlawful concealment, removal, mutilation, or destruction of any official documents or records or concealment of material facts by willful omission from official documents or records; unauthorized use of Government property, theft, vandalism, or immoral conduct; unethical or improper use of official authority or credentials; security violations; organizing or participating in gambling in any form; and misuse of weapons.

1.5.6. Key Control. The Contractor will not be issued any keys. The keys will be checked out by a "Cleared American" escort on the day of service requirements.

1.5.7. Notice to the Government of Labor Disputes. The Contractor shall inform the COR of any actual or potential labor dispute that is delaying or threatening to delay the timely performance of this contract.

II. SCOPE OF WORK: MECHANICAL EQUIPMENT PREVENTIVE MAINTENANCE

Contractor shall provide all materials, supervision, labor, tools and equipment to perform preventive maintenance services of the facility's Chiller, Associated VFD, AHU, Fancoils, VAV's, Electric Water Heater, Exhaust, Fans, Domestic Water booster Pump, Storage tank and associated controller as outline in this SOW and required by manufacturer. The technician shall sign off on every task specified in the Statement of Work and manufacturer maintenance manual. The contractor will provide a typewritten copy of their report to the COR or the COR's designate within five business days of each maintenance visit.

SCOPE OF WORK - - CHILLERS MAINTENANCE

Contractor shall provide all materials, supervision, labor, tools and equipment to perform preventive maintenance. In addition, contractor must provide the appropriate tools, testing equipment, safety shoes and apparel for technicians, personal protective equipment (hands, hearing, eye protection), MSDS, cleaning material and oil spill containment kits. All personnel working in the vicinity shall wear and /or use safety protection while all work is performed. Any questions or injuries shall be brought to the attention of the Post Occupation Safety and Health Officer (POSHO) immediately. Material Safety Data Sheets (MSDS) shall be provided by the Contractor for all HAZMAT materials. Copies shall be provided to the COR for approval.

The Contractor shall inventory expendable parts (e.g., filters, belts, hoses, gaskets) that have become worn down due to wear and tear. The Contractor shall maintain a supply of expendable

and common parts on site so that these are readily available for normal maintenance to include: hoses, belts, oil, chemicals, coolant, filters (Air, Fuel, Oil), grease, sealant, thermostat, fuses. The contractor should inventory the supply after each visit and provide the FM a quote for replacement supplies and have them delivered on site.

Maintenance materials shall be unused and are to be industry standard and intended for the task to be performed. Parts are to be OEM approved. Refrigerants are to meet the AHRI_Standard_700-2015 or most recent AHRI Standards.

Refrigerants, parts and maintenance materials delivered to the post are to be new and unused. Reclaimed refrigerants are not to be delivered to posts. Reclaimed refrigerants within post compounds are to be retained and stored and may be used if not contaminated. Refrigerants shall be stored in containers clearly indicating the refrigerant type.

SAFETY AND SPECIAL INSTRUCTIONS:

1. Follow site safety procedures and supervisor's instructions.
2. Schedule outage with operating personnel.
3. Use extreme caution when climbing access ladders.
4. Perform applicable lockout/tag out steps of site safety procedures.
5. Lockout and disconnect the main power before tightening the main supply lugs in order to avoid the hazard of electrical shock, which could result in serious personal injury or death.
6. Record and report equipment damage or deficiencies.
7. Review and follow the manufacturer's O&M instructions.
8. Record results in the equipment history log.
9. Allow only qualified personnel to do maintenance work on this equipment.
10. Record results in the equipment history log.
11. Check manufacturer's specifications for the maximum number of plugged tubes.
12. Allow only qualified personnel to do maintenance work on this equipment.

Chillers

MAINTENANCE PROCEDURES:

ITEM 1- Quarterly (Each Module)

1. Disconnect power source and lock out. Check electrical wiring and connections; tighten loose connections.
2. Thoroughly clean (wash) condenser coils, be sure to wash the debris out from the backside of the coils to avoid further compacting debris into the coils.
3. Clean (wash) filter strainers in the chilled water inlet header and system strainers.
4. Inspect plumbing and valves for leaks, adjust as necessary.
5. Check oil level in oil separator sight glass. Add oil as necessary.
2. Connect power source, check unit for proper operation, excessive noise or vibration.
3. Check liquid line sight glass, oil, and refrigerant pressures.
4. Record system operating temperatures and pressures in the checklist.
5. Check programmable operating set points and safety cutouts. Assure they are correct for the application.
6. Verify fan and compressor motors amperage load limit.

7. Check compressor crankcase heater operation.
8. Check and record refrigerant subcooling and superheat.
9. Clean chiller and surrounding area.
10. Fill out maintenance checklist and report deficiencies.
11. Inspect all electrical Components:
 - Check all external interlocks.
 - Inspect compressor terminals.
 - Check compressor crankcase heater operation.
 - Tighten all contactors, relay and circuit breaker terminals. Inspect all contactors for pitting and corrosion replace as necessary.
 - Check and calibrate all compressor safety controls.
 - Check and record voltages and amperages for compressors.
 - Check and record amperages for pumps and condenser fans.
 - Check and calibrate low ambient/ fan cycling controls.
 - Check all fuses to make sure that they are sized correctly with proper amp rating.
12. Inspect all cabinet screws nuts and bolts, fan motor mount bolts, fan blade set screws, shell and tube evaporator mounting, end cap bolts and connection bolts, brazed plate evaporator mounting bolts as well as compressor and pump mounting bolts for tightness as well as anti-vibration and isolator pads, replace if any missing part.
13. Check all refrigerant pressures and inspect compressor in operation – look for signs of overheating, oil leaks or refrigerant leaks.
14. Inspect compressor terminals when powered down for pitting, corrosion and loose connections.
15. Tighten all Rota-Lock nuts at the Compressors, Receivers and accumulators. Torque is per manufacturer's recommendations.
16. Check crank crankcase heaters to verify proper operation.
17. Conduct leak check of entire refrigerant piping system.
18. Inspect all refrigeration lines for secure mountings. Take corrective measures necessary to prevent piping from rubbing the frame etc.
19. Check that pressure switches correct cut-in and cut-out settings.
20. Inspect all insulation on piping and control sensors. Repair and replace as necessary. Inspect entire plumbing system for leaks.
21. Check operating pressures and temperatures and evaluate whether the system has a full refrigerant charge.
22. Check and record refrigerant subcooling and superheat.
23. Check liquid solenoid valves.
24. Check expansion valve and sensing bulb connections.
25. Take a refrigerant sample and analyze with tube type moisture/acid analyzer.
26. Check operating pressures and temperatures and evaluate whether the system has a full refrigerant charge.
27. Check and record the fan motor amp draws and voltage. Make sure of proper rotation and lubricate if required.
28. Check and record amp draw of the pumps and voltage. Check for signs of leakage at pump seal and suction and discharge connections.
29. Record G.P.M. water flow and compare to design specifications.
30. Check that the pump(s) overload settings match the nameplate(s) and that they work properly.
31. Thoroughly clean condenser coils, be sure to wash the debris out from the backside of the coils to avoid further compacting debris into the coils.
32. Clean filter strainers in the chilled water inlet header and system strainers.
33. Ensure that the condensing unit is clean and clear of surrounding debris and that panels are clear.

34. Inspect, exercise (two full cycles) and clean, all Motorize Valves in Chiller, Heat Exchanger and other modules associated to the system.
35. Review logged alarms and look for repeat trends.
36. Document the preventive maintenance task that have been completed and submit to the Government.

50 HP Pump Motor Starter and AHU's /Variable Frequency Drive

MAINTENANCE PROCEDURES:

ITEM 2- Annually:

1. Vacuum dust and dirt from heat sink fins
2. Check ventilation fans for proper operation and clean as needed.
3. Check line voltage, motor & output phase balance
4. Complete RCM Procedure CM-0002 (Qualitative Infrared Testing).
5. Visually inspect for broken parts, contact arcing, or any evidence of overheating.
6. Check motor nameplate for current rating and controller manufacturer's recommended heater size (report discrepancy to supervisor).
7. Check line and load connections for tightness (check manufacturer's instructions for torque specifications).
8. Check heater mounting screws for tightness.
9. Check all control wiring connections for tightness.
10. On units equipped with motor reversing capacity, check mechanical interlock.
11. On units equipped with two-stage starting, check dash pots and timing controls for proper operation. Adjust as required.
12. On units equipped with variable speed starters:
 - a. Record the VFD parameter settings using MCT-10
 - b. Confirm the VFD doors and covers are in place and properly closed.
 - c. Check tightness of connections to resistor bank.
 - d. Check resistor coils and plates for cracking, broken wires, mounting and signs of overheating. Clean as required.
 - e. Check tightness of connections to drum controller.
 - f. Check contacts of drum controller for arcing and overheating. Apply a thin film of lubricant to drum controller contacts and to rotating surfaces.
13. Check starter contact connections by applying a thin film of black contact grease to line and load stabs, operate contacts and check surface contact.
14. Lubricate all moving parts with proper lubricant.
15. Clean interior of cabinet.
16. Clean exterior of cabinet.
17. Energize circuit and check operation of starter and any pilot lights. Replace as required.

Chiller Panel, Electric Controls:

MAINTENANCE PROCEDURES:

ITEM 3- Annually

1. Clean panel interior.

2. Verify functionality of supported devices.
3. Clean ventilation filter and fan (if applicable).
4. Record and report equipment damage or deficiencies.
5. Record results in the equipment history log

Complete Spare Parts and Expendables Inventory list with quantities shall be provided by the contractor to the US government including part number and vendor contact.

Expendables contractor shall procure are: Coil cleaner compatible with aluminum and copper (according to manufacturer's recommendation), pipe exterior jacketing, elastomeric insulation, adhesives compatible with insulation, foam tape, refrigerant, all lubricants and grease types (electrical contacts, fan and pump grease for bearings etc.), compressor oil, sealant, all type of screws, nuts and bolts required for chiller electrical or mechanical components (including VFD, electrical and control panel, etc.)

Hydronic Water Treatment Preventive Maintenance (PM)

Water Treatment System, Closed Loop

MAINTENANCE PROCEDURES:

ITEM 4- Quarterly:

1. Draw a sample from a point where water is circulating. Flush the line until the sample is clear.
2. Flush a clean sample bottle with the water from the closed loop system three times to remove any contamination from the bottle, and then collect the sample.
3. Use the Molybdenum Test Kit to test for the proper levels of Molybdenum in the closed loop system.
4. If Molybdenum is less than 20 ppm add GI#370 (or approved equal) to the shot feeder to increase the treatment level.
5. If Molybdenum is more than 60 ppm drain a small amount of closed loop water from the system to lower treatment level.
6. Test for the proper levels of chemicals in the closed loop system and adjust chemical feeds as necessary to maintain optimal conditions in the system as specified in Table A.
7. Record all test results in a logbook and provide the results to the COR in a typewritten and signed report.
8. Use the conductivity meter to test for total solids and plot in a logbook. If your Molybdenum levels drop your conductivity should drop also. This would indicate a loss of water from the Closed Loop System. If your Molybdenum levels stay constant without having to add treatment to the Closed Loop System, and your conductivity increases you may have air in the system causing iron oxide corrosion. If this is the case, you will see your iron levels increase also. You need to check your air vents for proper operation and remove any trapped air from the piping system and check for bacteria levels.
9. Check the total conductivity of the system with a conductivity meter. Record results in a logbook and typewritten report.

10. Check pH with the pH test strips and/or pH meter. Record results in a logbook and typewritten report.
11. Clean sample bottles and wipe down all chemical treatment equipment.
12. **Provide new and change old corrosion coupons. Send used coupons to the laboratory for analysis. Quarterly Laboratory analysis for these coupons shall be included by the contractor. Contractor shall direct the Embassy Tegucigalpa Facilities staff to make any changes to the treatment plant operations to reestablish effective and efficient HVAC water treatment to meet water quality standards based on coupon Laboratory analysis.**

Process Instrumentation Engineer Checks and Adjustments

1. Visual inspection of the controller, sensor, pumps, tubing and other accessories
2. Testing of the chemical parameters
 - a. pH
 - b. Total dissolved solids
 - c. Conductivity
 - d. Aerobic Plate Count
 - e. Corrosion Inhibitor Level
 - f. Biocide dosage/s
 - g. Test supply water for base conditions (iron, manganese, alkalinity, total hardness, silica chloride)
3. Calibration of all the sensor/s with known standard
4. Process calibration of conductivity by a calibrated instrument with a known standard
5. Make sure that the controller is functioning properly.
6. Make sure that the solenoid valves, contact water meter, inhibitor pump and biocide pumps are physically functioning properly as per the settings in the controller.
7. Make sure that the chemical is dosed only as per the specification
8. Submit a typewritten and signed service report with detailed description of errors and causes (if any) and corrective action taken.

The water treatment Contractor shall determine the dosage levels of chemicals and stay within the specified operating parameters as shown in Table A.

Filter Hydronic Bypass

MAINTENANCE PROCEDURES:|

ITEM 4- Quarterly:

1. Draw a sample from a point where water is circulating. Flush the line until the sample is clear.
2. Flush a clean sample bottle with the water from the closed loop system three times to remove any contamination from the bottle, and then collect the sample.

3. Use the Molybdenum Test Kit to test for the proper levels of Molybdenum in the closed loop system.

Process Instrumentation Engineer Checks and Adjustments

1. Visual inspection of the controller, sensor, pumps, tubing and other accessories
2. Testing of the chemical parameters
 - a. pH
 - b. Total dissolved solids
 - c. Conductivity
 - d. Aerobic Plate Count
 - e. Corrosion Inhibitor Level
 - f. Biocide dosage/s
 - g. Test supply water for base conditions (iron, manganese, alkalinity, total hardness, silica chloride)
3. Calibration of all the sensor/s with known standard
4. Process calibration of conductivity by a calibrated instrument with a known standard
5. Make sure that the controller is functioning properly.
6. Make sure that the solenoid valves, contact water meter, inhibitor pump and biocide pumps are physically functioning properly as per the settings in the controller.
7. Make sure that the chemical is dosed only as per the specification.
8. Submit a typewritten and signed service report with detailed description of errors and causes (if any) and corrective action taken.

The water treatment Contractor shall determine the dosage levels of chemicals and stay within the specified operating parameters as shown in Table A.

Table A

	Open Loops to & from Cooling Tower	Closed Loops without inhibited glycol	Closed Loops with >25% inhibited glycol
pH	>7 & <9	>7 & <9	>7 & <9
Total Dissolved Solids (TDS)	<1000ppm	<1000ppm	1000-10,000 ppm
Conductivity	Based on Cycles of Concentration (COC)	1,000-15,000 ppm	1,000-15,000 ppm
Hardness as CaCO ₃	30-500 ppm	30-500 ppm	30-500 ppm
Alkalinity as CaCO ₃	30-500 ppm	>500 ppm	>500 ppm
Chlorides	<200 ppm	<200 ppm	<200 ppm
Sulfates	<200 ppm	<200 ppm	<200 ppm
If applicable: Glycol % Dowfrost or approved equivalent	n/a	n/a	>30% The max. amount up to a max. of 50% is dependent on lowest OA temperature the CHW loop is exposed to.
Micro Biological Fouling	Total Aerobic Count: < 10,000/ml	Total Aerobic Count: < 10,000/ml	Total Aerobic Count: < 10,000/ml
Coupon Rack System Parameters			
Corrosion on Mild Steel in mils/year	< 2.0 mpy	< 0.5 mpy	< 0.5 mpy
Pitting on Mild Steel	None	None	None
Corrosion on Copper Alloys	< 0.2 mpy	< 0.1 mpy	< 0.1 mpy
Corrosion on Stainless Steel	<0.1		
Scaling & Deposition	None	None	None

Air Handling Units

MAINTENANCE PROCEDURES:

ITEM 5 - Quarterly

1. Check the cleanliness of the air filters (flat, angle, rigid, bag, HEPA & HEGA) and replace or clean as required.
2. Verify filter gauge and/or switch function properly.
3. Check filter frames (filter tracks) for residual contaminants and clean as necessary.
4. Check drive kit for damage, loose parts, wear, dirt and alignment.
5. Check belt tension (If applicable).
6. Check condition of extended lubrication lines when present.
7. Clean dampers.
8. Check and Clean condensate, interior drain pan, drain lines and traps. Apply condensate pan treatment tablets appropriate for this application.
9. Clean (wash) heat exchanger coil, Condensate traps, interior housing and exterior housing.

10. Install any missing screws, nut, bolts or any other mechanical joints requires on equipment housing or supports.
11. Visually inspect or remotely monitor the outdoor air dampers and actuators for proper function.
12. Inspect air hoods and air louvers for damage and debris (if applicable).
13. Visually inspect outdoor air intake louvers, bird screens, and adjacent areas for cleanliness and integrity. Clean, when necessary (if applicable).
14. Verify sensors used for dynamic minimum outdoor air control accuracy and recalibrate or replace as necessary.
15. Clean (wash) Y-strainers in hydronic system.
16. Check, clean and calibrate hydronic controls (motorized ball valve, gages thermometers etc.).
17. Visually inspect drain pans and other adjacent surfaces subject to wetting for cleanliness and microbial growth and clean when fouling is observed.
18. Clean exterior of air handler cabinet.
19. Inspect doors, handles, latches and hinges for proper operation.
20. Inspect door gaskets for damage and proper seal.
21. Inspect panels for damage.
22. Clean fan segment and fan assembly (supply, return, exhaust).
23. Check fan housing, wheel, shaft, frame, inlet vanes and bearings for damage, wear, loose parts, dirt and debris.
24. Check fan base, vibration isolators and thrust restraints for damage, wear, loose parts, dirt and debris.
25. Check duct flex connector for damage and wear, repair if leaks are present.
26. Lubricate fan bearings.
27. Clean variable inlet vanes.
28. Check adjustable fan motor base and mounting hardware for loose parts.
29. Check adjustable fan motor base for damage.
30. Check fan motor for leaky bearing seals.
31. Check fan for motor damage.
32. Check for dirt, dust & debris in air vents on fan motor housing.
33. Clean condensates drain pan, trap, drain line and adjacent wetted surfaces.
34. Check Energy Recovery Wheel, clean media, adjust seals, replace belt, if applicable.
35. Keep clear the space provided for routine maintenance and inspection around ventilation equipment for equipment component accessibility.
36. Investigate and rectify the visible microbial contamination.
37. Investigate and rectify the water intrusion or accumulation.

Expendables contractor shall procure are: Coil cleaner compatible with aluminum and copper (according to manufacturer's recommendation), pipe jacketing, condensate drain pan tablets, elastomeric insulation, adhesives compatible with insulation, foam tape, all lubricants and grease types (electrical contacts, fan grease for bearings etc.), sealant, all type of screws, nuts and bolts required for AHU's electrical or mechanical components (including VFD, electrical and control panel, etc.),

Fan Coil Units

MAINTENANCE PROCEDURES:

ITEM 6- Quarterly

1. Check the cleanliness of the air filters and replace or clean as required.
2. Check filter frames (filter tracks) for residual contaminants and clean as necessary.
3. Check drive kit for damage, loose parts, wear, dirt and alignment.
4. Check belt tension (If applicable).
5. Check and Clean condensate, interior drain pan, drain lines and traps. Apply condensate pan treatment tablets appropriate for this application.
6. Check clean auxiliary drain pan and verify safety switch correct operation.
7. Clean condensate pump (if applicable), drain lines and traps.
8. Clean interior housing and exterior housing.
9. Check correct operation of motorized ball valve and actuator.
10. Install any missing screws, nut, bolts or any other mechanical joints required on equipment housing or supports.
11. Clean (wash) Y-strainers in hydronic system.
12. Check, clean and calibrate hydronic controls (motorized ball valve, gages thermometers etc.).
13. Visually inspect drain pans and other adjacent surfaces subject to wetting for cleanliness and microbial growth and clean when fouling is observed.
14. Inspect doors, handles, latches and hinges for proper operation.
15. Inspect door gaskets and flexible duct connector for air leaks and repair if necessary.
16. Clean fan segment and fan assembly (supply, return, exhaust).
17. Check duct flex connector for damage and wear and repair if necessary.
18. Lubricate fan bearings.
19. Clean (wash) heat exchanger coil, interior housing and exterior housing.
20. Check fan motor base and mounting hardware for loose parts.
21. Check fan motor for leaky bearing seals.
22. Check fan for motor damage.
23. Keep clear the space provided for routine maintenance and inspection around ventilation equipment for equipment component accessibility.
24. Investigate and rectify the visible microbial contamination.
25. Investigate and rectify the water intrusion or accumulation.

Expendables contractor shall procure are: Coil cleaner compatible with aluminum and copper (according to manufacturer's recommendation), condensate drain pan tablets, elastomeric insulation, adhesives compatible with insulation, foam tape, all lubricants and grease types (electrical contacts, fan grease for bearings etc.), sealant, all type of screws, nuts and bolts required for FCU's electrical or mechanical components (including, electrical and control panel, etc.),

VAV Air Terminal Unit

MAINTENANCE PROCEDURES:

ITEM 7- Annually

1. Check VAV for operation for excessive vibration, noise, and evidence of air leakage.
2. Inspect exterior of VAV Dampers. Clean built-up dirt and grime from shaft and actuator.
3. Tighten actuator collar lock nuts.
4. Take manual control of actuator and move damper to full open and shut positions. Check for smooth
5. movement and no apparent slippage at the actuator collar.
6. Check electrical connections for tightness and any signs of overheating.
7. Check continuity of electric heating elements with a multimeter.
8. Check contactors for signs of overheating. Be sure there is freedom of movement.
9. Measure and record temperature rise across the electric coil with the reheat energized.
10. Observe and log voltage and amperage of each heating element stage.
11. Return unit to service.
12. Check for signs of air leaks.

HVAC Ventilators

MAINTENANCE PROCEDURES:

ITEM 8- Annually

1. Start fan and run for 30 minutes.
2. Check for unusual noise, vibration, or evidence of other problems.
3. Wipe down unit.
4. Submit a Work Order to correct deficiencies.
5. Fan:
 - a. Tag out unit.
 - b. Thoroughly clean unit.
 - c. Check fan blades for dust buildup and clean if necessary.
 - d. Check fan blades and moving parts for excessive wear. Clean as needed.
 - e. Check fan RPM to design specifications.
 - f. Check bearing collar set screws on fan shaft to make sure they are tight.
 - g. Check fan wheel for bent or damaged vanes.
 - h. Vacuum interior of unit if accessible. Clean exterior.
 - i. Check belts for wear and age related deterioration, adjust tension or alignment, and replace belts
 - j. when necessary. Multiple belt drives should be replaced with matched sets.
 - k. Check structural members, vibration eliminators and flexible connections.
 - l. Check that hold down bolts are secure.
 - m. Test fan operation.
 - n. Remove all trash and clean area around fan.

6. Lubricate fan shaft bearings while unit is running. Add grease slowly until slight bleeding is noted from the seals. Do not over lubricate. Remove old or excess lubricant.
7. Motors:
 - a. Check ventilation ports for soil accumulation, clean if necessary.
 - b. Clean exterior of motor surfaces of soil accumulation.
 - c. Lubricate bearings: (1) Remove filler and drain plugs (use zerk fittings if installed). (2) Free drain hole
 - d. of any hard grease. (3) Add grease - use good grade lithium base grease unless otherwise noted.
 - e. Check motor windings for accumulation of soil. Vacuum if required.
 - f. Check hold down bolts and grounding straps for tightness.
 - g. Meggar check motors and record results.
 - h. Remove tags and return to service. Check for unusual noise or vibration. Check for evidence of overheating. Make sure unit actually works.

Electric Water Heaters

MAINTENANCE PROCEDURES:

ITEM 9- Annually:

1. Clean and inspect the water heater.
 - a. Clean away dirt, dust, and other contaminants.
 - b. Inspect for corrosion/chipping, and repaint as necessary.
 - c. Check the condition of the insulation on the heat exchanger and holding tank. Repair, replace and paint as necessary.
 - d. Inspect plumbing connections for evidence of leaks.
 - e. Inspect coils for damage/security.
 - f. Exercise valves two full cycles.
 - g. Inspect and clean control panel.
 - h. Check and tighten electrical connections.
 - i. Manually operate the safety relief valve. Check for ease of operation. Verify pressure is relieved.
 - j. Bleed air where equipped.
 - k. Inspect anode and replace if center wire is visible.
2. Operational test of the water heater.
 - a. Remove tags/locks and put water heater on line.
 - b. Test the water heater under operational conditions, and observe for unusual noise and signs of leaks.
 - c. Check operation and setting of thermostat.
 - d. Return the unit to service.

Booster Pumps

MAINTENANCE PROCEDURES:

ITEM 10- Annually

1. Lock out and Tag out unit.
2. Clean and inspect pump.
 - a. Clean accumulated dirt and grime from pump casing, shaft coupling, and motor.
 - b. Inspect electrical wiring, motor, and controls for signs of over-heating, broken insulation, loose or corroded connections, or damaged conduit.
 - c. Check for evidence of leaks.
 - d. Check alignment of coupling and security of base-plate mounting bolts.
3. Lubricate pump (if applicable).
4. Conduct operational test of the circulating pump.
 - a. Start pump. Check flanges and fittings for leaks.
 - b. Check for unusual noise or vibration.
 - c. Return the unit to service.
5. Check the motor.
 - a. Inspect electrical wiring, motor, and controls for signs of over-heating, broken insulation, loose or corroded connections, or damaged conduit.
 - b. Meggar check motor, record results.
 - c. Check running current and voltage for each phase, record results. Make sure it is less than the name plate value.
6. Lubricate the motor (if applicable). NOTES: DO NOT OVERGREASE THE MOTOR. USE MOTOR RATED GREASE. DO NOT USE PUMP GREASE IN THE MOTOR.

Water Tanks with Controls

MAINTENANCE PROCEDURES:

ITEM 10- Annually

1. Examine visible interior of tank including fittings, hatches for signs of corrosion, and correct as indicated.
2. Clean, test and inspect sight glasses, valves, fittings, drains and controls.
3. Clean and inspect tank level control panel.
 - a. Clean exterior of panel and inspect front panel components for damage.
 - b. Clean interior panel components of dust and foreign material.
 - c. Inspect electrical wiring for damage and loose connections.
 - d. Inspect relays for damaged contacts and signs of over-heating.
4. Operational Test panel/electronic control units and mechanical level control equipment.
 - a. Verify that all alarm, control, and communication circuits operate correctly.
 - b. Verify that mechanical level-indicating and control devices are functioning properly.
5. Look for presence of contamination (bugs, frogs, snakes, paper, plastic, etc.). Notify the post if found.

6. Return system to service.

III. SCHEDULED PREVENTIVE MAINTENANCE

- 3.1 The Contractor shall perform preventive maintenance as outlined in STATEMENT OF WORK. The objective of scheduled preventive maintenance is to eliminate system malfunction, breakdown and deterioration when units are activated/running.
- 3.2 All materials and consumables are excluded from this contract. During first visit, the contractor will provide a survey of the system, materials onsite, and determine usage rates. This will be used to provide a separate proposal for recommended consumables and spare parts.
- 3.3 Refrigerants, parts and maintenance materials delivered to the post are to be new and unused. Reclaimed refrigerants are not to be delivered to posts. Reclaimed refrigerants within post compounds are to be retained and stored and may be used if not contaminated. Refrigerants shall be stored in containers clearly indicating the refrigerant type.
- 3.4 Exclusion. This contract does NOT include repair of equipment and replacement of hardware (e.g. bearings, pistons, piston rings, crankshaft, gears.) Hardware replacements will be separately priced out by the Contractor for the Government's approval and acceptance. The Government has the option to accept or reject the Contractor's quote for parts and reserves the right to obtain similar spare parts from other competitive sources. If required by the Government, the Contractor shall utilize Government-purchased spare parts, if awarded the work. Such repairs/replacements will be accomplished by a separate purchase order. However, this exclusion does not apply if the repair is to correct damage caused by Contractor negligence.
- 3.5 Replacement/repair of any electronic or electrical parts shall be approved by the COR prior to installation of the part. If the Contractor proceeds to replace any electronic or electrical parts without COR approval, the Contractor shall de-install the parts at no cost to the Government.
- 3.6 Stocking of recommended repair parts is at the discretion of the Facility Manager and is dependent upon the nearest location of the Equipment manufacturer, distributor or dealer. A recommended spare parts list shall be obtained by the contractor from the manufacturer or distributor and provided to the Facility Manager to procure.
- 3.7 Parts/materials/tools procurement and delivery for the CAA/PCC areas shall be at the discretion of the Regional Security Officer (RSO).
- 3.8 Checklist Approval

- 3.8.1 The Contractor shall submit to the COR a schedule and description of preventive maintenance tasks which the Contractor plans to perform. The Contractor shall prepare this schedule and task description in a checklist format for the COR's approval prior to contract work commencement.
- 3.8.2 The Contractor shall provide trained technicians to perform the service at frequencies stated in Exhibit A and on the equipment called out in this SOW. The technician shall sign off on every item of the checklist and leave a copy of this signed checklist with the COR or the COR's designate after each maintenance visit.
- 3.8.3 It is the responsibility of the Contractor to perform all manufacturers' recommended preventive maintenance including preventive maintenance recommended by the manufacturers' technical manuals for the respective equipment.
- 3.8.4 Additionally, the maintenance contractor shall obtain and keep at the post O&M binders provided by the manufacturers. These binders shall be placed in a location accessible to post personnel to review as needed.

IV. SAFETY AND SPECIAL INSTRUCTIONS

- 4.1. Contractor shall provide all materials, supervision, labor, tools and equipment to perform preventive maintenance. All personnel working in the vicinity should wear and /or use safety protection while all work is done. Any questions or injuries shall be brought to the attention of the Post Occupation Safety and Health Officer (POSHO) immediately. Material Safety Data Sheets (MSDS) shall be provided by the Contractor for all HAZMAT materials. Copies shall be provided to the COR for approval.
 - 4.1.1. Follow site safety procedures and supervisor's instructions.
 - 4.1.2. Schedule outage with operating personnel.
 - 4.1.3. Use extreme caution when climbing access ladders.
 - 4.1.4. Perform applicable lockout/tag out steps of site safety procedures.
 - 4.1.5. Lockout and disconnect the main power before tightening the main supply lugs in order to avoid the hazard of electrical shock, which could result in serious personal injury or death.
 - 4.1.6. Record and report equipment damage or deficiencies.
 - 4.1.7. Review and follow the manufacturer's O&M instructions.
 - 4.1.8. Record results in the equipment history log.
 - 4.1.9. Allow only qualified personnel to do maintenance work on this equipment.
 - 4.1.10. Record results in the equipment history log.
 - 4.1.11. Check manufacturer's specifications for the maximum number of plugged tubes.
- 4.2. Allow only qualified personnel to do maintenance work on this equipment.

V. PERSONNEL, TOOLS, CONSUMABLE MATERIALS AND SUPPLIES

The Contractor shall provide trained technicians with the appropriate tools and testing equipment for scheduled maintenance, safety inspection, and safety testing as required by this Contract. The Contractor shall provide all of the necessary materials and supplies to maintain, service, inspect and test all the systems to be maintained.

- 5.1. Contractor furnished materials include but are not limited to appropriate tools, testing equipment, safety shoes and apparel for technicians, hands, hearing and eye protection, MSDS, cleaning material and oil spill containment kit. Expendable/consumable items (e.g. hoses, belts, oil, chemicals, coolant, filters (Fuel, Oil), generator starting batteries, grease, sealant, thermostat, fuse), shall be maintained in the onsite inventory. See 3.2.
- 5.2. Repairs are not included in this contract. See 3.4. Exclusions.
- 5.3. Disposal of used oil, fuel, battery and other toxic substances. The Contractor is responsible for proper disposal of toxic/hazardous substances. All material shall be disposed of according to Government and Local law. After proper disposal the contractor must show proof of authorized disposal of these toxic/hazardous substances.

VI. SOFTWARE, LICENSES AND PASSWORDS

Copies of any and all software and licenses needed to control or to adjust the communications module shall be given to the post upon completion of the work.

VII. DELIVERABLES

Provide per every maintenance visit, a typewritten report to Post Facilities Manager containing following:

- a) System information (make, model, all devices types)
- b) Pass/Fail of each feature and type of component tested. If a device fails, note device type, address and location within Post.
- c) Check lists of maintenance activities on every equipment.
- d) Any comments on system (or device) condition pertaining to service life and dependability.
- e) Full printout of test from system printer
- f) Testing of exhaust gas by Gas Analyzer (if applicable).

The following items shall be delivered under this contract:

Description	QTY	Delivery Date	Deliver to
Names, biographic data, police clearance on Contractor personnel (#6.2)	1	30 days after contract award	COR
Certificate of Insurance (#11.2)	1	30 days after contract award	CO
PM Checklist signed by Contractor's employee (#7.2.1)	1	After completion of each maintenance service	COR

Invoice (#15)	1	After completion of each maintenance service	COR
---------------	---	--	-----

VIII. INSURANCE REQUIREMENTS

8.1. Personal Injury, Property Loss or Damage (Liability). The Contractor assumes absolute responsibility and liability for any and all personal injuries or death and property damage or losses suffered due to negligence of the Contractor's personnel in the performance of this Contract.

8.2. The Contractor's assumption of absolute liability is independent of any insurance policies.

8.3. Insurance. The Contractor, at its own expense, shall provide and maintain during the entire period of performance of this Contract, whatever insurance is legally necessary. **The Contractor shall carry the following minimum insurance:**

Public Liability Insurance

- Bodily Injury stated in US Dollars:
- Per Occurrence \$ 1,000.00
- Cumulative \$ 2,000.00

Property Damage stated in US Dollars:

- Per Occurrence \$ 1,000.00
- Cumulative \$ 2,000.00

Workers' Compensation and Employer's Liability

8.4. Worker's Compensation Insurance. The Contractor agrees to provide all employees with worker's compensation benefits as required under local laws (see FAR 52.228-4 "Worker's Compensation and War-Hazard Insurance Overseas").

IX. LOCAL LAW REGISTRATION

If the local law or decree requires that one or both parties to the contract register the contract with the designated authorities to insure compliance with this law or decree, the entire burden of this registration shall rest upon the Contractor. Any local or other taxes which may be assessed against the Contract shall be payable by the Contractor without Government reimbursement.

X. QUALITY ASSURANCE AND SURVEILLANCE PLAN (QASP)

This plan provides an effective method to promote satisfactory contractor performance. The QASP provides a method for the Contracting Officer's Representative (COR) to monitor Contractor performance, advise the Contractor of unsatisfactory performance, and notify the Contracting Officer of continued unsatisfactory performance. The Contractor, not the Government, is responsible for management and quality control to meet the terms of the contract. The role of the Government is to monitor quality to ensure that contract standards are achieved.

Performance Objective	Scope of Work Paragraphs	Performance Threshold
<u>Services.</u> Performs all services set forth in the Statement of Work (SOW).	__ I _ thru IX ____	All required services are performed and no more than one (1) customer complaint is received per month.

10.1. SURVEILLANCE. The COR will receive and document all complaints from Government personnel regarding the services provided. If appropriate, the COR will send the complaints to the Contractor for corrective action.

10.2. STANDARD. The performance standard is that the Government receives no more than one (1) customer complaint per month. The COR shall notify the Contracting Officer of the complaints so that the Contracting Officer may take appropriate action to enforce the inspection clause ([FAR 52.212.4](#), Contract Terms and Conditions - Commercial Products and Commercial Services (NOV 2023), if any of the services exceed the standard.

10.3. PROCEDURES.

- (a) If any Government personnel observe unacceptable services, either incomplete work or required services not being performed they should immediately contact the COR.
- (b) The COR will complete appropriate documentation to record the complaint.
- (c) If the COR determines the complaint is invalid, the COR will advise the complainant. The COR will retain the annotated copy of the written complaint for his/her files.
- (d) If the COR determines the complaint is valid, the COR will inform the Contractor and give the Contractor additional time to correct the defect, if additional time is available. The COR shall determine how much time is reasonable.
- (e) The COR shall, as a minimum, orally notify the Contractor of any valid complaints.
- (f) If the Contractor disagrees with the complaint after investigation of the site and challenges the validity of the complaint, the Contractor will notify the COR. The COR will review the matter to determine the validity of the complaint.
- (g) The COR will consider complaints as resolved unless notified otherwise by the complainant.
- (h) Repeat customer complaints are not permitted for any services. If a repeat customer complaint is received for the same deficiency during the service period, the COR will contact the Contracting Officer for appropriate action under the Inspection clause.

XI. TRANSITIONS/CONTACTS

Within 30 days after contract award, the Contracting Officer may ask the contractor to develop a plan for preparing the contractor to assume all responsibilities for preventive maintenance services. The plan shall establish the projected period for completion of all clearances of contractor personnel, and the projected start date for performance of all services required under this contract. The plan shall assign priority to the selection of all supervisors to be used under the contract.

11.1 On site contact. The following are the designated contact personnel between the US Embassy Tegucigalpa and the Contractor:

COR
– Facility Manager

The Post Control Officer (PCO) will be the contractor's point of contact at the U.S. Embassy Tegucigalpa. All questions concerning coordination of service activities while at post shall be directed to the Post Control Officer, with weekly reporting to the COR:

PCO
– Facility Manager

XII. SUBMISSION OF INVOICES

The Contractor shall submit an invoice after each preventive maintenance service has been performed. Invoices must be accompanied by a signed copy of the Maintenance Checklist for the work performed including parts replacement and break down calls, if any. No invoice for preventive maintenance services will be considered for payment unless accompanied by the relevant documentation.

The Contractor should expect payment 30 days after completion of service or 30 days after receipt of *electronic* invoice at the Embassy Tegucigalpa payment office, whichever is later. Invoices shall be sent electronically to:

Upload into the MyILMS online platform

SECTION 2 - CONTRACT CLAUSES

52.212-4 CONTRACT TERMS AND CONDITIONS – COMMERCIAL ITEMS (2026) IS INCORPORATED BY REFERENCE.

“None”

FAR 52.212-5 [Reserved] (Jan 2026)

ADD THE FOLLOWING CLAUSE IN FULL TEXT:

52.229-12 TAX ON CERTAIN FOREIGN PROCUREMENTS—NOTICE AND REPRESENTATION (FEB 2021)

(a) *Definitions.* As used in this clause—

Foreign person means any person other than a United States person.

United States person, as defined in [26 U.S.C. 7701\(a\)\(30\)](#), means—

- (1) A citizen or resident of the United States;
- (2) A domestic partnership;
- (3) A domestic corporation;
- (4) Any estate (other than a foreign estate, within the meaning of [26 U.S.C. 7701\(a\)\(31\)](#)); and

(5) Any trust if-

(i) A court within the United States is able to exercise primary supervision over the administration of the trust; and

(ii) One or more United States persons have the authority to control all substantial decisions of the trust.

(b) This clause applies only to foreign persons. It implements [26 U.S.C. 5000C](#) and its implementing regulations at 26 CFR 1.5000C-1 through 1.5000C-7.

(c)

(1) If the Contractor is a foreign person and has only a partial or no exemption to the withholding, the Contractor shall include the Department of the Treasury Internal Revenue Service Form W-14, Certificate of Foreign Contracting Party Receiving Federal Procurement Payments, with each voucher or invoice submitted under this contract throughout the period in

which this status is applicable. The excise tax withholding is applied at the payment level, not at the contract level. The Contractor should revise each IRS Form W-14 submission to reflect the exemption (if any) that applies to that particular invoice, such as a different exemption applying. In the absence of a completed IRS Form W-14 accompanying a payment request, the default withholding percentage is 2 percent for the section 5000C withholding for that payment request. Information about IRS Form W-14 and its separate instructions is available via the internet at www.irs.gov/w14.

(2) If the Contractor is a foreign person and has indicated in its offer in the provision [52.229-11](#), Tax on Certain Foreign Procurements—Notice and Representation, that it is fully exempt from the withholding, and certified the full exemption on the IRS Form W-14, and if that full exemption no longer applies due to a change in circumstances during the performance of the contract that causes the Contractor to become subject to the withholding for the 2 percent excise tax then the Contractor shall—

(i) Notify the Contracting Officer within 30 days of a change in circumstances that causes the Contractor to be subject to the excise tax withholding under [26 U.S.C. 5000C](#); and

(ii) Comply with paragraph (c)(1) of this clause.

(d) The Government will withhold a full 2 percent of each payment unless the Contractor claims an exemption. If the Contractor enters a ratio in Line 12 of the IRS Form W-14, the result of Line 11 divided by Line 10, the Government will withhold from each payment an amount equal to 2 percent multiplied by the contract ratio. If the Contractor marks box 9 of the IRS Form W-14 (rather than completes Lines 10 through 12), the Contractor must identify and enter the specific exempt and nonexempt amounts in Line 15 of the IRS Form W-14; the Government will then withhold 2 percent only from the nonexempt amount. See the IRS Form W-14 and its instructions.

(e) Exemptions from the withholding under this clause are described at 26 CFR 1.5000C-1(d)(5) through (7). Any exemption claimed and self-certified on the IRS Form W-14 is subject to audit by the IRS. Any disputes regarding the imposition and collection of the [26 U.S.C. 5000C](#) tax are adjudicated by the IRS as the [26 U.S.C. 5000C](#) tax is a tax matter, not a contract issue.

(f) Taxes imposed under [26 U.S.C. 5000C](#) may not be—

(1) Included in the contract price; nor

(2) Reimbursed.

(g) A taxpayer may, for a fee, seek advice from the Internal Revenue Service (IRS) as to the proper tax treatment of a transaction. This is called a private letter ruling. Also, the IRS may publish a revenue ruling, which is an official interpretation by the IRS of the Internal Revenue

Code, related statutes, tax treaties, and regulations. A revenue ruling is the conclusion of the IRS on how the law is applied to a specific set of facts. For questions relating to the interpretation of the IRS regulations go to <https://www.irs.gov/help/tax-law-questions>.

(End of clause)

ADDENDUM TO CONTRACT CLAUSES
FAR AND DOSAR CLAUSES NOT PRESCRIBED IN PART 12

52.252-2 CLAUSES INCORPORATED BY REFERENCE (FEB 1998)

This contract incorporates one or more clauses by reference, with the same force and effect as if they were given in full text. Upon request, the Contracting Officer will make their full text available. In addition, the full text of a clause may be accessed electronically at: Acquisition.gov this address is subject to change.

If the Federal Acquisition Regulation (FAR) is not available at the location indicated above, use the Department of State Acquisition website at e-CFR to see the links to the FAR. You may also use an Internet “search engine” (for example, Google, Yahoo or Excite) to obtain the latest location of the most current FAR.

THE FOLLOWING FEDERAL ACQUISITION REGULATIONS (FAR) CLAUSES ARE
INCORPORATED BY REFERENCE:

<u>CLAUSE</u>	<u>TITLE AND DATE</u>
52.203-17	CONTRACTOR EMPLOYEE WHISTLEBLOWER RIGHTS (NOV 2023)
52.203-19	PROHIBITION ON REQUIRING CERTAIN INTERNAL CONFIDENTIALITY AGREEMENTS OR STATEMENTS.(Jan 2017)
52.204-9	PERSONAL IDENTITY VERIFICATION OF CONTRACTOR PERSONNEL (JAN 2011)
52.204-13	SYSTEM FOR AWARD MANAGEMENT MAINTENANCE (JAN 2026)
52.204-18	[Reserved] (2026)
52.204-25	[Reserved] (2026)
52.204-27	[Reserved] (2026)
52.209-10	PROHIBITION ON CONTRACTING WITH INVERTED DOMESTIC CORPORATIONS (2026)
52.219-4	NOTICE OF PRICE EVALUATION PREFERENCE FOR HUBZONE SMALL BUSINESS CONCERNS (2026)
52.222-19	CHILD LABOR-COOPERATION WITH AUTHORITIES AND REMEDIES (2026)
52.222-50	COMBATING TRAFFICKING IN PERSONS (2026)
52.225-14	INCONSISTENCY BETWEEN ENGLISH VERSION AND TRANSLATION OF CONTRACT (FEB 2000)

- 52.226-8 ENCOURAGING CONTRACTOR POLICIES TO BAN TEXT MESSAGING WHILE DRIVING (MAY 2024)
- 52.228-3 WORKERS' COMPENSATION INSURANCE (DEFENSE BASE ACT) (JUL 2014)
- 52.228-4 WORKER'S COMPENSATION AND WAR-HAZARD INSURANCE OVERSEAS (APRIL 1984)
- 52.228-5 INSURANCE - WORK ON A GOVERNMENT INSTALLATION (JAN 1997)
- 52.229-6 TAXES - FOREIGN FIXED PRICE CONTRACTS (FEB 2013)
- 52.232-33 PAYMENT BY ELECTRONIC FUNDS TRANSFER-SYSTEM FOR AWARD MANAGEMENT (OCT 2018)
- 52.232-39 UNENFORCEABILITY OF UNAUTHORIZED OBLIGATIONS (JUNE 2013)
- 52.232-40 PROVIDING ACCELERATED PAYMENTS TO SMALL BUSINESS SUBCONTRACTORS (MAR 2023)
- 52.233-3 PROTEST AFTER AWARD (2026)
- 52.233-4 APPLICABLE LAW FOR BREACH OF CONTRACT CLAIM (2026)
- 52.244-6 SUBCONTRACTS FOR COMMERCIAL PRODUCTS AND COMMERCIAL SERVICES (2026)

THE FOLLOWING FAR CLAUSES ARE PROVIDED IN FULL TEXT:

52.217-8 OPTION TO EXTEND SERVICES (NOV 1999)

The Government may require continued performance of any services within the limits and at the rates specified in the contract. The option provision may be exercised more than once, but the total extension of performance hereunder shall not exceed 6 months. The Contracting Officer may exercise the option by written notice to the Contractor within the performance period of the contract.

(End of clause)

52.217-9 OPTION TO EXTEND THE TERM OF THE CONTRACT (MAR 2000)

(a) The Government may extend the term of this contract by written notice to the Contractor within the performance period of the contract or within 30 days after funds for the option year become available, whichever is later.

(b) If the Government exercises this option, the extended contract shall be considered to include this option clause.

(c) The total duration of this contract, including the exercise of any options under this clause, shall not exceed 24 months..

(End of clause)

52.232-19 AVAILABILITY OF FUNDS FOR THE NEXT FISCAL YEAR (APR 1984)

Funds are not presently available for performance under this contract beyond September 30 of the current calendar year. The Government's obligation for performance of this contract beyond that date is contingent upon the availability of appropriated funds from which payment for contract purposes can be made. No legal liability on the part of the Government for any payment may arise for performance under this contract beyond September 30 of the current calendar year, until funds are made available to the Contracting Officer for performance and until the Contractor receives notice of availability, to be confirmed in writing by the Contracting Officer.

(End of clause)

THE FOLLOWING DOSAR CLAUSES ARE PROVIDED IN FULL TEXT:

652.204-70 DEPARTMENT OF STATE PERSONAL IDENTIFICATION CARD ISSUANCE (FEB 2015)

(a) The Contractor shall comply with the Department of State (DOS) Personal Identification Card Policy and Procedures for all employees performing under this contract who require frequent and continuing access to DOS facilities, or information systems. The Contractor shall insert the substance of this clause in all subcontracts when the subcontractor's employees will require frequent and continuing access to DOS facilities, or information systems.

(b) The DOS Personal Identification Card Policy and Procedures may be accessed at <http://www.state.gov/m/ds/rls/rpt/c21664.htm>.

(End of clause)

CONTRACTOR IDENTIFICATION (JULY 2008)

Contract performance may require contractor personnel to attend meetings with government personnel and the public, work within government offices, and/or utilize government email.

Contractor personnel must take the following actions to identify themselves as non-federal employees:

- 1) Use an email signature block that shows name, the office being supported and company affiliation (e.g. “John Smith, Office of Human Resources, ACME Corporation Support Contractor”);
- 2) Clearly identify themselves and their contractor affiliation in meetings;
- 3) Identify their contractor affiliation in Departmental e-mail and phone listings whenever contractor personnel are included in those listings; and
- 4) Contractor personnel may not utilize Department of State logos or indicia on business cards.

(End of clause)

652.215-70 EXAMINATION OF RECORDS

(a) With respect to matters related to this contract or a subcontract hereunder, the Department of State Office of the Inspector General, or an authorized representative, shall have upon request:

(1) Complete, prompt, and free access to all Contractor and Subcontractor files (in any format), documents, records, data, premises, and employees, except as limited by law; and

(2) The right to interview any current Contractor and Subcontractor personnel, individually and directly, with respect to such matters.

(b) This clause may not be construed to require the contractor or any subcontractor to create or maintain any record that the contractor or subcontractor does not maintain in the ordinary course of business or pursuant to a provision of law.

(c) The Contractor shall insert a clause containing all the terms of this clause, including this [paragraph \(c\)](#), in all subcontracts under this contract other than acquisitions described in Federal Acquisition Regulation 15.209(b)(1).

652.229-70 EXCISE TAX EXEMPTION STATEMENT FOR CONTRACTORS WITHIN THE UNITED STATES (JUL 1988)

This is to certify that the item(s) covered by this contract is/are for export solely for the use of the U.S. Foreign Service Post identified in the contract schedule.

The Contractor shall use a photocopy of this contract as evidence of intent to export. Final proof of exportation may be obtained from the agent handling the shipment. Such proof shall be accepted in lieu of payment of excise tax.

(End of clause)

652.232-70 PAYMENT SCHEDULE AND INVOICE SUBMISSION (FIXED-PRICE)
(AUG 1999)

(a) General. The Government shall pay the Contractor as full compensation for all work required, performed, and accepted under this contract the firm fixed-price stated in this contract.

(b) Invoice Submission. The Contractor shall submit invoices as detailed below: The contractor shall submit the digital invoice on PDF files for the Embassy in the vendor portal. The invoice must be legible, it is recommended to scan in black and white, type [text], resolution [300 dpi], this should generate a file of no more than 100kb per page.

To constitute a proper invoice, the invoice shall include all the items required by FAR 32.905(e).

The title of the email (Subject) must be the same name as the electronic invoice:
PRNumber_Vendor Name_InvoiceNumber

For an invoice to be valid it must contain the following information: Company name, telephone number and correspondence address, Invoice number and Date, Requisition Number and/or Contract Number, Description, quantity, unit of measure, and unit price of the commodities or services provided in accordance with the Contract. Only send one email by Invoice and Contract Number. You will receive a message of receipt of the same in the following seven working days.

(c) Contractor Remittance Address. The Government will make payment to the contractor's address stated on the cover page of this contract, unless a separate remittance address is shown below:

(End of clause)

652.236-70 ADDITIONAL SAFETY MEASURES (OCT 2017)

In addition to the safety/accident prevention requirements of FAR 52.236-13, Accident Prevention Alternate I, the contractor shall comply with the following additional safety measures.

(a) *High Risk Activities*. If the project contains any of the following high risk activities, the contractor shall follow the section in the latest edition, as of the date of the solicitation, of the U.S. Army Corps of Engineers Safety and Health manual, EM 385-1-1, that corresponds to the high risk activity. Before work may proceed, the contractor must obtain approval from the COR of the written safety plan required by FAR 52.236-13, Accident Prevention Alternate I (see paragraph (f) below), containing specific hazard mitigation and control techniques.

- (1) Scaffolding;
- (2) Work at heights above 1.8 meters;
- (3) Trenching or other excavation greater than one (1) meter in depth;
- (4) Earth-moving equipment and other large vehicles;
- (5) Cranes and rigging;
- (6) Welding or cutting and other hot work;
- (7) Partial or total demolition of a structure;
- (8) Temporary wiring, use of portable electric tools, or other recognized electrical hazards. Temporary wiring and portable electric tools require the use of a ground fault circuit interrupter (GFCI) in the affected circuits; other electrical hazards may also require the use of a GFCI;
- (9) Work in confined spaces (limited exits, potential for oxygen less than 19.5 percent or combustible atmosphere, potential for solid or liquid engulfment, or other hazards considered to be immediately dangerous to life or health such as water tanks, transformer vaults, sewers, cisterns, etc.);
- (10) Hazardous materials - a material with a physical or health hazard including but not limited to, flammable, explosive, corrosive, toxic, reactive or unstable, or any operations, which creates any kind of contamination inside an occupied building such as dust from demolition activities, paints, solvents, etc.; or
- (11) Hazardous noise levels as required in EM 385-1 Section 5B or local standards if more restrictive.

(b) *Safety and Health Requirements.* The contractor and all subcontractors shall comply with the latest edition of the U.S. Army Corps of Engineers Safety and Health manual EM 385-1-1, or OSHA 29 CFR parts 1910 or 1926 if no EM 385-1-1 requirements are applicable, and the accepted contractor's written safety program.

(c) *Mishap Reporting.* The contractor is required to report immediately all mishaps to the COR and the contracting officer. A "mishap" is any event causing injury, disease or illness, death, material loss or property damage, or incident causing environmental contamination. The mishap reporting requirement shall include fires, explosions, hazardous materials contamination, and other similar incidents that may threaten people, property, and equipment.

(d) *Records.* The contractor shall maintain an accurate record on all mishaps incident to work performed under this contract resulting in death, traumatic injury, occupational disease, or damage to or theft of property, materials, supplies, or equipment. The contractor shall report this data in the manner prescribed by the contracting officer.

(e) *Subcontracts.* The contractor shall insert this clause, including this paragraph (e), with appropriate changes in the designation of the parties, in subcontracts.

(f) *Written program.* The plan required by paragraph (f)(1) of the clause entitled "Accident Prevention Alternate I" shall be known as the Site Safety and Health Plan (SSHP) and shall address any activities listed in paragraph (a) of this clause, or as otherwise required by the contracting officer/COR.

(1) The SSHP shall be submitted at least 10 working days prior to commencing any activity at the site.

(2) The plan must address developing activity hazard analyses (AHAs) for specific tasks. The AHAs shall define the activities being performed and identify the work sequences, the specific anticipated hazards, site conditions, equipment, materials, and the control measures to be implemented to eliminate or reduce each hazard to an acceptable level of risk. Work shall not begin until the AHA for the work activity has been accepted by the COR and discussed with all engaged in the activity, including the Contractor, subcontractor(s), and Government on-site representatives.

(3) The names of the Competent/Qualified Person(s) required for a particular activity (for example, excavations, scaffolding, fall protection, other activities as specified by EM 385-1-1) shall be identified and included in the AHA. Proof of their competency/qualification shall be submitted to the contracting officer or COR for acceptance prior to the start of that work activity. The AHA shall be reviewed and modified as necessary to address changing site conditions, operations, or change of competent/qualified person(s).

(End of clause)

652.237-72 OBSERVANCE OF LEGAL HOLIDAYS AND ADMINISTRATIVE LEAVE
(FEB 2015)

(a) The Department of State observes the following days as holidays:

New Year's Day
Martin Luther King's Birthday
Washington's Birthday
Holy Thursday
Good Friday
Easter Saturday
Honduran Labor Day
Memorial Day
Juneteenth Day
US Independence Day
Labor Day
Central American Independence Day
Francisco Morazan's Birthday
Discovery of America
Honduran Armed Forces Day
Columbus Day
Veterans Day
Thanksgiving Day
Christmas Day

Any other day designated by Federal law, Executive Order, or Presidential Proclamation.

(b) When New Year's Day, Independence Day, Veterans Day or Christmas Day falls on a Sunday, the following Monday is observed; if it falls on Saturday the preceding Friday is observed. Observance of such days by Government personnel shall not be cause for additional period of performance or entitlement to compensation except as set forth in the contract. If the

contractor's personnel work on a holiday, no form of holiday or other premium compensation will be reimbursed either as a direct or indirect cost, unless authorized pursuant to an overtime clause elsewhere in this contract.

(c) When the Department of State grants administrative leave to its Government employees, assigned contractor personnel in Government facilities shall also be dismissed. However, the contractor agrees to continue to provide sufficient personnel to perform round-the-clock requirements of critical tasks already in operation or scheduled, and shall be guided by the instructions issued by the contracting officer or his/her duly authorized representative.

(d) For fixed-price contracts, if services are not required or provided because the building is closed due to inclement weather, unanticipated holidays declared by the President, failure of Congress to appropriate funds, or similar reasons, deductions will be computed as follows:

(1) The deduction rate in dollars per day will be equal to the per month contract price divided by 21 days per month.

(2) The deduction rate in dollars per day will be multiplied by the number of days services are not required or provided.

If services are provided for portions of days, appropriate adjustment will be made by the contracting officer to ensure that the contractor is compensated for services provided.

(e) If administrative leave is granted to contractor personnel as a result of conditions stipulated in any "Excusable Delays" clause of this contract, it will be without loss to the contractor. The cost of salaries and wages to the contractor for the period of any such excused absence shall be a reimbursable item of direct cost hereunder for employees whose regular time is normally charged, and a reimbursable item of indirect cost for employees whose time is normally charged indirectly in accordance with the contractors accounting policy.

(End of clause)

652.242-70 CONTRACTING OFFICER'S REPRESENTATIVE (COR) AUG 1999)

(a) The Contracting Officer may designate in writing one or more Government employees, by name or position title, to take action for the Contracting Officer under this contract. Each designee shall be identified as a Contracting Officer's Representative (COR). Such designation(s) shall specify the scope and limitations of the authority so delegated; provided, that the designee shall not change the terms or conditions of the contract, unless the COR is a warranted Contracting Officer and this authority is delegated in the designation.

(a) The COR for this contract is:

"Name provided at award"

(End of clause)

652.242-73 AUTHORIZATION AND PERFORMANCE (AUG 1999)

(a) The Contractor warrants the following:

- (1) That it has obtained authorization to operate and do business in the country or countries in which this contract will be performed;
- (2) That it has obtained all necessary licenses and permits required to perform this contract; and,
- (3) That it shall comply fully with all laws, decrees, labor standards, and regulations of said country or countries during the performance of this contract.

(b) If the party actually performing the work will be a subcontractor or joint venture partner, then such subcontractor or joint venture partner agrees to the requirements of paragraph (a) of this clause.

652.243-70 NOTICES (AUG 1999)

Any notice or request relating to this contract given by either party to the other shall be in writing. Said notice or request shall be mailed or delivered by hand to the other party at the address provided in the schedule of the contract. All modifications to the contract must be made in writing by the Contracting Officer.

SECTION 3 - SOLICITATION PROVISIONS

52.212-1 INSTRUCTIONS TO OFFERORS -- COMMERCIAL PRODUCTS AND COMMERCIAL SERVICES (2026)

(a) *Submission of offers.* Submit signed and dated offers to the office specified in this solicitation at or before the exact time specified in this solicitation. As a minimum, offers shall include—

- (1) The solicitation number;
- (2) The name, address, telephone number of the Offeror;
- (3) The Offeror's Unique Entity Identifier (UEI) and, if applicable, Electronic Funds Transfer (EFT) indicator;
- (4) Information necessary to evaluate the factors contained in the provision at 52.212-2 or as described in the solicitation;
- (5) Responses to provisions that require Offeror completion of information, representations, and certifications (other than those collected via the System for Award Management (SAM)).
- (6) A statement specifying the extent of agreement with all terms, conditions, and provisions included in the solicitation and any solicitation amendments.
- (7) A completed solicitation, in which the SF-18 cover page (blocks 11,13,14,15,16 as appropriate), and Section 1 has been filled out and all required items are provided in a timely manner. Failure to comply with these instructions will result in no further consideration

The Offeror shall include Defense Base Act (DBA) insurance premium costs covering employees. The offeror may obtain DBA insurance directly from any Department of Labor approved providers at the DOL website at <http://www.dol.gov/owcp/dlhwc/lscarrier.htm>

(8) List of clients over the past 3 years, demonstrating prior experience with relevant past performance information and references (provide dates of contracts, places of performance, value of contracts, contact names, telephone and fax numbers and email addresses). If the offeror has not performed comparable services in Honduras then the offeror shall provide its international experience. Offerors are advised that the past performance information requested above may be discussed with the client's contact person. In addition, the client's contact person may be asked to comment on the offeror's:

- Quality of services provided under the contract;

- Compliance with contract terms and conditions;
- Effectiveness of management;
- Willingness to cooperate with and assist the customer in routine matters, and when confronted by unexpected difficulties; and
- Business integrity / business conduct.

The Government will use past performance information primarily to assess an offeror's capability to meet the solicitation performance requirements, including the relevance and successful performance of the offeror's work experience. The Government may also use this data to evaluate the credibility of the offeror's proposal. In addition, the Contracting Officer may use past performance information in making a determination of responsibility.

(9) The offeror shall address its plan to obtain all licenses and permits required by local law (see DOSAR 652.242-73 in Section 2). If offeror already possesses the locally required licenses and permits, a copy shall be provided.

(10) The offeror's strategic plan for Preventive Services for Mechanical Equipment services to include but not limited to:

(a) A work plan taking into account all work elements in Section 1, Performance Work Statement.

(b) Identify types and quantities of equipment, supplies and materials required for performance of services under this contract. Identify if the offeror already possesses the listed items and their condition for suitability and if not already possessed or inadequate for use how and when the items will be obtained;

(c) Plan of ensuring quality of services including but not limited to contract administration and oversight; and

(d) (1) If insurance is required by the solicitation, a copy of the Certificate of Insurance(s),

or (2) a statement that the contractor will get the required insurance, and the name of the insurance provider to be used.

(11) Evidence Quoter technicians have security clearance required to access CAA and PCC spaces inside USG buildings where equipment to be maintained are installed.

(b) *Period for acceptance of offers.* The Offeror agrees to hold the prices in its offer firm for 60 calendar days from the date specified for receipt of offers, unless another time period is specified in an addendum to the solicitation.

(c) *Late submissions, modifications, revisions, and withdrawals of offers.*

(1) Offerors are responsible for submitting offers and any modifications or revisions to the Government office designated in the solicitation by the time specified in the solicitation.

(2) Any offer, modification, or revision received after the time specified for receipt of offers is "late" and will not be considered unless it is received before award is made and the Contracting Officer determines that accepting the late offer would not unduly delay the acquisition. However, a late modification of an otherwise successful offer that makes its terms

more favorable to the Government will be considered at any time it is received and may be accepted.

(3) If an emergency or unanticipated event interrupts normal Government processes so that offers cannot be received at the Government office designated for receipt of offers by the exact time specified in the solicitation, and urgent Government requirements preclude amendment of the solicitation or other notice of an extension of the closing date, the time specified for receipt of offers will be deemed to be extended to the same time of day specified in the solicitation on the first work day on which normal Government processes resume.

(4) Offerors may withdraw their offers by written notice to the Government received at any time before award.

(d) *Contract award (not applicable to Invitation for Bids)*. The Government intends to evaluate offers and award a contract without discussions with Offerors. Therefore, the Offeror's initial offer should contain the Offeror's best terms. However, the Government reserves the right to conduct discussions, if necessary. The Government may reject any or all offers if such action is in the public interest, accept other than the lowest offer, and waive informalities and minor irregularities in offers received.

(e) *Debriefings*. If a postaward debriefing is given to requesting Offerors, the Government will disclose the following information, if applicable:

(1) The agency's evaluation of the significant weak or deficient factors in the debriefed Offeror's offer.

(2) The overall evaluated cost or price and technical rating of the successful Offeror and the debriefed Offeror and past performance information on the debriefed Offeror.

(3) The overall ranking of all Offerors when any ranking was developed by the agency during source selection.

(4) A summary of the rationale for award.

(5) For acquisitions of commercial products, the make and model of the product to be delivered by the successful Offeror.

(6) Reasonable responses to relevant questions posed by the debriefed Offeror as to whether the agency followed source-selection procedures set forth in the solicitation, applicable regulations, and other applicable authorities.

(End of provision)

ADDENDUM TO SOLICITATION PROVISIONS
FAR AND DOSAR PROVISIONS NOT PRESCRIBED IN PART 12

52.252-1 SOLICITATION PROVISIONS INCORPORATED BY REFERENCE
(FEB 1998)

This solicitation incorporates one or more solicitation provisions by reference, with the same force and effect as if they were given in full text. Upon request, the Contracting Officer will make their full text available. The offeror is cautioned that the listed provisions may include blocks that must be completed by the offeror and submitted with its quotation or offer. In lieu of submitting the full text of those provisions, the offeror may identify the provision by paragraph identifier and provide the appropriate information with its quotation or offer. Also, the full text of a solicitation provision may be accessed electronically at this/these address(es):

<https://www.acquisition.gov/far-overhaul/far-part-deviation-guide>

THE FOLLOWING FEDERAL ACQUISITION REGULATION SOLICITATION
PROVISIONS ARE INCORPORATED BY REFERENCE:

PROVISION TITLE AND DATE

52.203-11	CERTIFICATION AND DISCLOSURE REGARDING PAYMENTS TO INFLUENCE CERTAIN FEDERAL TRANSACTIONS
52.203-18	PROHIBITION ON CONTRACTING WITH ENTITIES THAT REQUIRE CERTAIN INTERNAL CONFIDENTIALITY AGREEMENTS OR STATEMENTS-REPRESENTATION
52.204-7	SYSTEM FOR AWARD MANAGEMENT (2026)
52.204-16	[Reserved] (2026)
52.204-90	OFFEROR IDENTIFICATION
52.211-1	[Reserved] (2026)
52.212-1	INSTRUCTIONS TO OFFERORS -- COMMERCIAL PRODUCTS AND COMMERCIAL SERVICES (2026)
52.214-34	SUBMISSION OF OFFERS IN THE ENGLISH LANGUAGE (APR 1991)
52.222-56	CERTIFICATION REGARDING TRAFFICKING IN PERSONS (2026)

THE FOLLOWING DOSAR PROVISION(S) IS/ARE PROVIDED IN FULL TEXT:

652.206-70 ADVOCATE FOR COMPETITION/OMBUDSMAN (FEB 2015)

(a) The Department of State's Advocate for Competition is responsible for assisting industry in removing restrictive requirements from Department of State solicitations and removing barriers

to full and open competition and use of commercial items. If such a solicitation is considered competitively restrictive or does not appear properly conducive to competition and commercial practices, potential offerors are encouraged first to contact the contracting office for the solicitation. If concerns remain unresolved, contact:

(1) For solicitations issued by the Office of Acquisition Management (A/GA/AMD) or a Regional Procurement Support Office, the A/GA/AMD Advocate for Competition, at AQMCompetitionAdvocate@state.gov.

(2) For all others, the Department of State Advocate for Competition at cat@state.gov.

(b) The Department of State's Acquisition Ombudsman has been appointed to hear concerns from potential offerors and contractors during the pre-award and post-award phases of this acquisition. The role of the ombudsman is not to diminish the authority of the contracting officer, the Technical Evaluation Panel or Source Evaluation Board, or the selection official. The purpose of the ombudsman is to facilitate the communication of concerns, issues, disagreements, and recommendations of interested parties to the appropriate Government personnel, and work to resolve them. When requested and appropriate, the ombudsman will maintain strict confidentiality as to the source of the concern. The ombudsman does not participate in the evaluation of proposals, the source selection process, or the adjudication of formal contract disputes. Interested parties are invited to contact the contracting activity ombudsman, Management Counsellor, at 2236-9320. For an American Embassy or overseas post, refer to the numbers below for the Department Acquisition Ombudsman. Concerns, issues, disagreements, and recommendations which cannot be resolved at a contracting activity level may be referred to the Department of State Acquisition Ombudsman at (703) 516-1696 or write to: Department of State, Acquisition Ombudsman, Office of Global Acquisitions (A/GA), Suite 1060, SA-15, Washington, DC 20520.

(End of provision)

SECTION 4 - EVALUATION FACTORS

52.212-2 Evaluation—Commercial Products and Commercial Services (2026)

(a) Evaluation factors. The Government will award a contract resulting from this solicitation to the responsible Offeror whose offer is the Lowest Priced Technically Acceptable Offer. The following factors will be used to evaluate offers:

- Award will be made to the lowest priced, acceptable, responsible offeror. The quoter shall submit a completed solicitation, including Sections 1 and 5.
- The lowest price will be determined by multiplying the offered prices times the estimated quantities in “Prices - Continuation of SF-18, block 11”, and arriving at a grand total, including all options. The Government reserves the right to reject quotations that are unreasonably low or high in price.
- The Government will determine acceptability by assessing the offeror's compliance with the terms of the RFQ **to include the technical information required by Section 3.**
- The Government will determine contractor responsibility by analyzing whether the apparent successful offeror complies with the requirements of FAR 9.1, including:
 - Adequate financial resources or the ability to obtain them;
 - Ability to comply with the required performance period, taking into consideration all existing commercial and governmental business commitments;
 - Satisfactory record of integrity and business ethics;
 - Necessary organization, experience, and skills or the ability to obtain them;
 - Necessary equipment and facilities or the ability to obtain them; and
 - Be otherwise qualified and eligible to receive an award under applicable laws and regulations.

(b) *Options (if applicable)*. The Government will evaluate offers for award purposes by adding the total price for all options to the total price for the basic requirement. The Government may determine that an offer is unacceptable if the option prices are significantly unbalanced. The evaluation of options does not obligate the Government to exercise the option(s).

(c) Notice of award. A written notice of award or acceptance of an offer furnished to the successful Offeror within the time for acceptance specified in the offer, shall result in a binding contract without further action by either party. Before the offer's specified expiration time, the Government may accept an offer (or part of an offer), whether or not there are negotiations after its receipt, unless a written notice of withdrawal is received before award.

(End of provision)

ADDENDUM TO EVALUATION FACTORS
FAR AND DOSAR PROVISION(S) NOT PRESCRIBED IN PART 12

THE FOLLOWING FAR PROVISION(S) IS/ARE PROVIDED IN FULL TEXT:

52.217-5 EVALUATION OF OPTIONS (2026)

Except when it is determined in accordance with FAR 17.202(b) not to be in the Government's best interests, the Government will evaluate offers for award purposes by adding the total price for all options to the total price for the basic requirement. Evaluation of options will not obligate the Government to exercise the option(s).

(End of provision)

52.225-17 EVALUATION OF FOREIGN CURRENCY OFFERS (FEB 2000)

If the Government receives offers in more than one currency, the Government will evaluate offers by converting the foreign currency to United States currency using the exchange rate used by the Embassy in effect as follows:

- (a) For acquisitions conducted using sealed bidding procedures, on the date of bid opening.
- (b) For acquisitions conducted using negotiation procedures—
 - (1) On the date specified for receipt of offers, if award is based on initial offers; otherwise
 - (2) On the date specified for receipt of proposal revisions.

SECTION 5 - REPRESENTATIONS AND CERTIFICATIONS

52.204-24 [Reserved] (2026)

52.204-26 [Reserved] (2026)

52.212-3 [Reserved] (2026)

52.229-11 TAX ON CERTAIN FOREIGN PROCUREMENTS – NOTICE AND REPRESENTATION (JUN 2020)

(a) *Definitions.* As used in this provision—

Foreign person means any person other than a United States person.

Specified Federal procurement payment means any payment made pursuant to a contract with a foreign contracting party that is for goods, manufactured or produced, or services provided in a foreign country that is not a party to an international procurement agreement with the United States. For purposes of the prior sentence, a foreign country does not include an outlying area.

United States person as defined in 26 U.S.C. 7701(a)(30) means—

- (1) A citizen or resident of the United States;
- (2) A domestic partnership;
- (3) A domestic corporation;
- (4) Any estate (other than a foreign estate, within the meaning of 26 U.S.C. 701(a)(31)); and
- (5) Any trust if—

(i) A court within the United States is able to exercise primary supervision over the administration of the trust; and

(ii) One or more United States persons have the authority to control all substantial decisions of the trust.

(b) Unless exempted, there is a 2 percent tax of the amount of a specified Federal procurement payment on any foreign person receiving such payment. See 26 U.S.C. 5000C and its implementing regulations at 26 CFR 1.5000C-1 through 1.5000C-7.

(c) Exemptions from withholding under this provision are described at 26 CFR 1.5000C-1(d)(5) through (7). The Offeror would claim an exemption from the withholding by using the Department of the Treasury Internal Revenue Service Form W-14, Certificate of Foreign Contracting Party Receiving Federal Procurement Payments, available via the internet at www.irs.gov/w14. Any exemption claimed and self-certified on the IRS Form W-14 is subject to audit by the IRS. Any disputes regarding the imposition and collection of the 26 U.S.C. 5000C

tax are adjudicated by the IRS as the 26 U.S.C. 5000C tax is a tax matter, not a contract issue. The IRS Form W-14 is provided to the acquiring agency rather than to the IRS.

(d) For purposes of withholding under 26 U.S.C. 5000C, the Offeror represents that—

(1) It ☐ is ☐ is not a foreign person; and

(2) If the Offeror indicates “is” in paragraph (d)(1) of this provision, then the Offeror represents that—I am claiming on the IRS Form W-14 ☐ a full exemption, or ☐ partial or no exemption [*Offeror shall select one*] from the excise tax.

(e) If the Offeror represents it is a foreign person in paragraph (d)(1) of this provision, then—

(1) The clause at FAR 52.229-12, Tax on Certain Foreign Procurements, will be included in any resulting contract; and

(2) The Offeror shall submit with its offer the IRS Form W-14. If the IRS Form W-14 is not submitted with the offer, exemptions will not be applied to any resulting contract and the Government will withhold a full 2 percent of each payment.

(f) If the Offeror selects “is” in paragraph (d)(1) and “partial or no exemption” in paragraph (d)(2) of this provision, the Offeror will be subject to withholding in accordance with the clause at FAR 52.229-12, Tax on Certain Foreign Procurements, in any resulting contract.

(g) A taxpayer may, for a fee, seek advice from the Internal Revenue Service (IRS) as to the proper tax treatment of a transaction. This is called a private letter ruling. Also, the IRS may publish a revenue ruling, which is an official interpretation by the IRS of the Internal Revenue Code, related statutes, tax treaties, and regulations. A revenue ruling is the conclusion of the IRS on how the law is applied to a specific set of facts. **For questions relating to the interpretation of the IRS regulations go to <https://www.irs.gov/help/tax-law-questions>.**

(End of provision)

52.240-90 SECURITY PROHIBITIONS AND EXCLUSIONS REPRESENTATIONS AND CERTIFICATIONS (2026)

(a) *Definitions.* As used in this provision—

Backhaul, covered article, covered telecommunications equipment or services, critical technology, FASCSA order, Intelligence community, interconnection arrangements, national security system, roaming, sensitive compartmented information, sensitive compartmented information system, source, and substantial or essential component have the meanings provided in the clause 52.240-91, Security Prohibitions and Exclusions.

Business operations means engaging in commerce in any form, including by acquiring, developing, maintaining, owning, selling, possessing, leasing, or operating equipment, facilities, personnel, products, services, personal property, real property, or any other apparatus of business or commerce.

Marginalized populations of Sudan means—

(1) Adversely affected groups in regions authorized to receive assistance under section 8(c) of the Darfur Peace and Accountability Act (Pub. L. 109-344) (50 U.S.C. 1701 note); and

(2) Marginalized areas in Northern Sudan described in section 4(9) of such Act.

Restricted business operations means business operations in Sudan that include power production activities, mineral extraction activities, oil-related activities, or the production of military equipment, as those terms are defined in the Sudan Accountability and Divestment Act of 2007 (Pub. L. 110-174). Restricted business operations do not include business operations that the person (as that term is defined in Section 2 of the Sudan Accountability and Divestment Act of 2007) conducting the business can demonstrate—

(1) Are conducted under contract directly and exclusively with the regional government of southern Sudan;

(2) Are conducted under specific authorization from the Office of Foreign Assets Control in the Department of the Treasury, or are expressly exempted under Federal law from the requirement to be conducted under such authorization;

(3) Consist of providing goods or services to marginalized populations of Sudan;

(4) Consist of providing goods or services to an internationally recognized peacekeeping force or humanitarian organization;

(5) Consist of providing goods or services that are used only to promote health or education;
or

(6) Have been voluntarily suspended.

Sensitive technology—

(1) Means hardware, software, telecommunications equipment, or any other technology that is to be used specifically—

(i) To restrict the free flow of unbiased information in Iran; or

(ii) To disrupt, monitor, or otherwise restrict speech of the people of Iran; and

(2) Does not include information or informational materials the export of which the President does not have the authority to regulate or prohibit pursuant to section 203(b)(3) of the International Emergency Economic Powers Act (50 U.S.C. 1702(b)(3)).

(b) *Procedures.*

(1) *Covered telecommunications and video surveillance.* The Offeror shall review the list of excluded parties in the System for Award Management (SAM) at <https://www.sam.gov> for

entities excluded from receiving federal awards for “covered telecommunications equipment or services.”

(2) *FASCSA Orders.*

(i) The Offeror shall search in SAM for the phrase “FASCSA order” for any covered article, or any products or services produced or provided by a source, if there is an applicable FASCSA order described in paragraph (e) of FAR 52.240-91, Security Prohibitions and Exclusions.

(ii) The Offeror shall review the solicitation for any FASCSA orders that are not in SAM but are effective and apply to the solicitation and resultant contract (see FAR 40.204-1(c)(2)).

(iii) FASCSA orders issued after the date of solicitation do not apply unless added by an amendment to the solicitation.

(c) *Covered telecommunications equipment or services representations.* By submission of its offer, the Offeror represents that, after conducting a reasonable inquiry (that looks at any information in the Offeror’s possession but does not need to include an internal or third-party audit)—

(1) It will not provide covered telecommunications equipment or services to the Government in the performance of any contract, subcontract or other contractual instrument resulting from this solicitation, except as waived by the solicitation, or as disclosed in paragraph (g); and

(2) It does not use covered telecommunications equipment or services, or use any equipment, system, or service that uses covered telecommunications equipment or services, except as waived by the solicitation, or as disclosed in paragraph (g).

(d) *FASCSA Representation.* By submission of this offer, the offeror represents that it has conducted a reasonable inquiry, and that the offeror does not propose to provide or use in response to this solicitation any covered article, or any products or services produced or provided by a source, if the covered article or the source is prohibited by an applicable FASCSA order in effect on the date the solicitation was issued, except as waived by the solicitation, or as disclosed in paragraph (g). A reasonable inquiry will look at any information in the offeror’s possession but does not need to include an internal or third-party audit.

(e) *Sudan certification.* By submission of its offer, the offeror certifies, after conducting a reasonable inquiry (that looks at any information in the offeror’s possession but does not need to include an internal or third-party audit), that the offeror does not conduct any restricted business operations in Sudan.

(f) *Iran Representation and Certifications.*

(1) Except as provided in paragraph (f)(2) of this provision or if a waiver has been granted in accordance with FAR 40.203-3, the offeror, after conducting a reasonable inquiry (that looks at any information in the offeror’s possession but does not need to include an internal or third-party audit), by submission of its offer—

(i) Represents, to the best of its knowledge and belief, that the offeror does not export any sensitive technology to the government of Iran or any entities or individuals owned or controlled by, or acting on behalf or at the direction of, the government of Iran;

(ii) Certifies that the offeror, or any person (as defined at section 15 of the Iran Sanctions Act of 1996, Pub. L. 104-172, 50 U.S.C. 1701 note) owned or controlled by the offeror, does not engage in any activities for which sanctions may be imposed under section 5 of the Act. These sanctioned activities are in the areas of development of the petroleum resources of Iran, production of refined petroleum products in Iran, sale and provision of refined petroleum products to Iran, and contributing to Iran's ability to acquire or develop certain weapons or technologies; and

(iii) Certifies that the offeror, and any person owned or controlled by the offeror, does not knowingly engage in any transaction that exceeds \$15,000 with Iran's Revolutionary Guard Corps or any of its officials, agents, or affiliates, the property and interests in property of which are blocked pursuant to the International Emergency Economic Powers Act (50 U.S.C. 1701 et seq.) (see OFAC's Specially Designated Nationals and Blocked Persons List at <https://www.treasury.gov/resource-center/sanctions/SDN-List/Pages/default.aspx>)

(2) Exception for trade agreements. The representation and certification requirements of paragraph (f)(1) of this provision do not apply if—

(i) This solicitation includes a trade agreements notice or certification (e.g., 52.225-6, Trade Agreements Certificate); and

(ii) The offeror has certified that all the offered products to be supplied are designated country end products or designated country construction material.

(iii) The offeror shall email questions concerning sensitive technology to the Department of State at CISADA106@state.gov.

(g) *Disclosure.*

(1) If the Offeror is not able to represent compliance with the prohibitions in paragraphs (c) or (d), then the Offeror shall disclose within 72 hours to the contracting office identified in paragraph (g)(2) the following information for each product or service not compliant:

(i) Contract number and order number, if applicable;

(ii) Identification of whether this disclosure relates to paragraph (c) on covered telecommunication equipment or services, or to paragraph (d) on FASCSA orders;

(iii) A description of the products or services that the Contractor identifies or has reason to suspect is prohibited (include brand; model number, such as the original equipment manufacturer (OEM) number, manufacturer part number, or wholesaler number; and item description, as applicable);

(iv) The entity that produced the product or service (include entity name, unique entity identifier, Contractor and Government Entity (CAGE) code, facilities responsible for design,

fabrication, assembly, packaging, and test of the product, and whether the entity was the OEM or a distributor (provide manufacturer codes and distributor codes used for the product));

(v) Description of the functionality of the product or service and how that functionality impacts the risk to the product or service;

(vi) An explanation of any factors relevant to determining if the product or service should be permitted by an applicable exception, exemption, or waiver (if the offeror would like the Government to consider a waiver);

(vii) Whether alternative products or services are available that would be compliant with the prohibition;

(viii) If the product or service is related to item maintenance, include the following information on the item being maintained:

(A) Brand;

(B) Model number, OEM number, manufacturer part number, or wholesaler number; and

(C) Item description, as applicable.

(ix) Any readily available information about mitigation actions undertaken or recommended.

(2) If a disclosure is required to be submitted to a contracting office, the offeror shall submit the disclosure as follows:

(i) If a Department of Defense contracting office, the offeror shall submit the disclosure to the website at <https://dibnet.dod.mil>.

(ii) For all other contracting offices, the Offeror shall submit the disclosure to the Contracting Officer.

(3) If the disclosure provided does not contain any of the information required by paragraph (1), and the Offeror later discovers new information that is required by paragraph (1), then the Offeror shall submit a subsequent disclosure within 72 hours of discovering the new information.

(h) *Executive agency review of disclosures.* The Contracting Officer will review disclosures provided in paragraph (g) to determine if any applicable waiver may be sought. The Contracting Officer may choose not to pursue a waiver and may instead make an award to an Offeror that does not require a waiver.

(End of provision)

52.240-91 SECURITY PROHIBITIONS AND EXCLUSIONS (2026)

(a) *Definitions.* As used in this provision—

Backhaul, covered article, covered telecommunications equipment or services, critical technology, FASCSA order, Intelligence community, interconnection arrangements, national security system, roaming, sensitive compartmented information, sensitive compartmented information system, source, and substantial or essential component have the meanings provided in the clause 52.240-91, Security Prohibitions and Exclusions.

Business operations means engaging in commerce in any form, including by acquiring, developing, maintaining, owning, selling, possessing, leasing, or operating equipment, facilities, personnel, products, services, personal property, real property, or any other apparatus of business or commerce.

Marginalized populations of Sudan means—

(1) Adversely affected groups in regions authorized to receive assistance under section 8(c) of the Darfur Peace and Accountability Act (Pub. L. 109-344) (50 U.S.C. 1701 note); and

(2) Marginalized areas in Northern Sudan described in section 4(9) of such Act.

Restricted business operations means business operations in Sudan that include power production activities, mineral extraction activities, oil-related activities, or the production of military equipment, as those terms are defined in the Sudan Accountability and Divestment Act of 2007 (Pub. L. 110-174). Restricted business operations do not include business operations that the person (as that term is defined in Section 2 of the Sudan Accountability and Divestment Act of 2007) conducting the business can demonstrate—

(1) Are conducted under contract directly and exclusively with the regional government of southern Sudan;

(2) Are conducted under specific authorization from the Office of Foreign Assets Control in the Department of the Treasury, or are expressly exempted under Federal law from the requirement to be conducted under such authorization;

(3) Consist of providing goods or services to marginalized populations of Sudan;

(4) Consist of providing goods or services to an internationally recognized peacekeeping force or humanitarian organization;

(5) Consist of providing goods or services that are used only to promote health or education;
or

(6) Have been voluntarily suspended.

Sensitive technology—

(1) Means hardware, software, telecommunications equipment, or any other technology that is to be used specifically—

(i) To restrict the free flow of unbiased information in Iran; or

(ii) To disrupt, monitor, or otherwise restrict speech of the people of Iran; and

(2) Does not include information or informational materials the export of which the President does not have the authority to regulate or prohibit pursuant to section 203(b)(3) of the International Emergency Economic Powers Act (50 U.S.C. 1702(b)(3)).

(b) *Procedures.*

(1) *Covered telecommunications and video surveillance.* The Offeror shall review the list of excluded parties in the System for Award Management (SAM) at <https://www.sam.gov> for entities excluded from receiving federal awards for “covered telecommunications equipment or services.”

(2) *FASCSA Orders.*

(i) The Offeror shall search in SAM for the phrase “FASCSA order” for any covered article, or any products or services produced or provided by a source, if there is an applicable FASCSA order described in paragraph (e) of FAR 52.240-91, Security Prohibitions and Exclusions.

(ii) The Offeror shall review the solicitation for any FASCSA orders that are not in SAM but are effective and apply to the solicitation and resultant contract (see FAR 40.204-1(c)(2)).

(iii) FASCSA orders issued after the date of solicitation do not apply unless added by an amendment to the solicitation.

(c) *Covered telecommunications equipment or services representations.* By submission of its offer, the Offeror represents that, after conducting a reasonable inquiry (that looks at any information in the Offeror’s possession but does not need to include an internal or third-party audit)—

(1) It will not provide covered telecommunications equipment or services to the Government in the performance of any contract, subcontract or other contractual instrument resulting from this solicitation, except as waived by the solicitation, or as disclosed in paragraph (g); and

(2) It does not use covered telecommunications equipment or services, or use any equipment, system, or service that uses covered telecommunications equipment or services, except as waived by the solicitation, or as disclosed in paragraph (g).

(d) *FASCSA Representation.* By submission of this offer, the offeror represents that it has conducted a reasonable inquiry, and that the offeror does not propose to provide or use in response to this solicitation any covered article, or any products or services produced or provided by a source, if the covered article or the source is prohibited by an applicable FASCSA order in

effect on the date the solicitation was issued, except as waived by the solicitation, or as disclosed in paragraph (g). A reasonable inquiry will look at any information in the offeror's possession but does not need to include an internal or third-party audit.

(e) *Sudan certification.* By submission of its offer, the offeror certifies, after conducting a reasonable inquiry (that looks at any information in the offeror's possession but does not need to include an internal or third-party audit), that the offeror does not conduct any restricted business operations in Sudan.

(f) *Iran Representation and Certifications.*

(1) Except as provided in paragraph (f)(2) of this provision or if a waiver has been granted in accordance with FAR 40.203-3, the offeror, after conducting a reasonable inquiry (that looks at any information in the offeror's possession but does not need to include an internal or third-party audit), by submission of its offer—

(i) Represents, to the best of its knowledge and belief, that the offeror does not export any sensitive technology to the government of Iran or any entities or individuals owned or controlled by, or acting on behalf or at the direction of, the government of Iran;

(ii) Certifies that the offeror, or any person (as defined at section 15 of the Iran Sanctions Act of 1996, Pub. L. 104-172, 50 U.S.C. 1701 note) owned or controlled by the offeror, does not engage in any activities for which sanctions may be imposed under section 5 of the Act. These sanctioned activities are in the areas of development of the petroleum resources of Iran, production of refined petroleum products in Iran, sale and provision of refined petroleum products to Iran, and contributing to Iran's ability to acquire or develop certain weapons or technologies; and

(iii) Certifies that the offeror, and any person owned or controlled by the offeror, does not knowingly engage in any transaction that exceeds \$15,000 with Iran's Revolutionary Guard Corps or any of its officials, agents, or affiliates, the property and interests in property of which are blocked pursuant to the International Emergency Economic Powers Act (50 U.S.C. 1701 et seq.) (see OFAC's Specially Designated Nationals and Blocked Persons List at <https://www.treasury.gov/resource-center/sanctions/SDN-List/Pages/default.aspx>)

(2) Exception for trade agreements. The representation and certification requirements of paragraph (f)(1) of this provision do not apply if—

(i) This solicitation includes a trade agreements notice or certification (e.g., 52.225-6, Trade Agreements Certificate); and

(ii) The offeror has certified that all the offered products to be supplied are designated country end products or designated country construction material.

(iii) The offeror shall email questions concerning sensitive technology to the Department of State at CISADA106@state.gov.

(g) *Disclosure.*

(1) If the Offeror is not able to represent compliance with the prohibitions in paragraphs (c) or (d), then the Offeror shall disclose within 72 hours to the contracting office identified in paragraph (g)(2) the following information for each product or service not compliant:

(i) Contract number and order number, if applicable;

(ii) Identification of whether this disclosure relates to paragraph (c) on covered telecommunication equipment or services, or to paragraph (d) on FASCSA orders;

(iii) A description of the products or services that the Contractor identifies or has reason to suspect is prohibited (include brand; model number, such as the original equipment manufacturer (OEM) number, manufacturer part number, or wholesaler number; and item description, as applicable);

(iv) The entity that produced the product or service (include entity name, unique entity identifier, Contractor and Government Entity (CAGE) code, facilities responsible for design, fabrication, assembly, packaging, and test of the product, and whether the entity was the OEM or a distributor (provide manufacturer codes and distributor codes used for the product));

(v) Description of the functionality of the product or service and how that functionality impacts the risk to the product or service;

(vi) An explanation of any factors relevant to determining if the product or service should be permitted by an applicable exception, exemption, or waiver (if the offeror would like the Government to consider a waiver);

(vii) Whether alternative products or services are available that would be compliant with the prohibition;

(viii) If the product or service is related to item maintenance, include the following information on the item being maintained:

(A) Brand;

(B) Model number, OEM number, manufacturer part number, or wholesaler number; and

(C) Item description, as applicable.

(ix) Any readily available information about mitigation actions undertaken or recommended.

(2) If a disclosure is required to be submitted to a contracting office, the offeror shall submit the disclosure as follows:

(i) If a Department of Defense contracting office, the offeror shall submit the disclosure to the website at <https://dibnet.dod.mil>.

(ii) For all other contracting offices, the Offeror shall submit the disclosure to the Contracting Officer.

(3) If the disclosure provided does not contain any of the information required by paragraph (1), and the Offeror later discovers new information that is required by paragraph (1), then the Offeror shall submit a subsequent disclosure within 72 hours of discovering the new information.

(h) *Executive agency review of disclosures.* The Contracting Officer will review disclosures provided in paragraph (g) to determine if any applicable waiver may be sought. The Contracting Officer may choose not to pursue a waiver and may instead make an award to an Offeror that does not require a waiver.

(End of provision)

THE FOLLOWING DOSAR PROVISION IS PROVIDED IN FULL TEXT:

ADDENDUM TO SOLICITATION PROVISIONS
FAR AND DOSAR PROVISIONS NOT PRESCRIBED IN PART 12

THE FOLLOWING FEDERAL ACQUISITION REGULATION SOLICITATION
PROVISIONS ARE INCORPORATED BY REFERENCE:

52.225-25 [Reserved] (Jan 2026)