

SOLICITATION, OFFER, AND AWARD

1. This Contract is a Rated Order under the Defense Priorities and Allocations System (DPAS) - Code of Federal Regulations - at 15 CFR 700.

RATING

PAGE OF PAGES

2. CONTRACT NUMBER

3. SOLICITATION NUMBER

4. TYPE OF SOLICITATION

- ☐
- SEALED BID (IFB) INVITATION FOR BID
-
- ☐
- NEGOTIATED (RFP) REQUEST FOR PROPOSAL

5. DATE ISSUED

6. REQUISITION/PURCHASE NUMBER

7. ISSUED BY

CODE

8. ADDRESS OFFER TO (If other than item 7)

NOTE: In sealed bid solicitations "offer" and "offeror" mean "bid" and "bidder".**SOLICITATION**

9. Sealed offers in original and _____ copies for furnishings the supplies or services in the Schedule will be received at the place specified in item 8, or if hand carried, in the depository located in _____ until _____ local time _____ (Hour) _____ (Date)

CAUTION - LATE Submissions, Modifications, and Withdrawals: See Section L, Provision Number 52.214-7 or 52.215-1. All offers are subject to all terms and conditions contained in this solicitation.

10. FOR INFORMATION CALL: 	A. NAME		B. TELEPHONE (NO COLLECT CALLS)		C. EMAIL ADDRESS
	AREA CODE	NUMBER	EXTENSION		

11. TABLE OF CONTENTS

(X)	SECTION	DESCRIPTION	PAGE(S)	(X)	SECTION	DESCRIPTION	PAGE(S)
		PART I - THE SCHEDULE				PART II - CONTRACT CLAUSES	
	A	SOLICITATION/CONTRACT FORM			I	CONTRACT CLAUSES	
	B	SUPPLIES OR SERVICES AND PRICES/COSTS				PART III - LIST OF DOCUMENTS, EXHIBITS AND OTHER ATTACHMENTS	
	C	DESCRIPTION/SPECIFICATIONS/WORK STATEMENT			J	LIST OF ATTACHMENTS	
	D	PACKAGING AND MARKING				PART IV - REPRESENTATIONS AND INSTRUCTIONS	
	E	INSPECTION AND ACCEPTANCE			K	REPRESENTATIONS, CERTIFICATIONS AND OTHER STATEMENTS OF OFFERORS	
	F	DELIVERIES OR PERFORMANCE			L	INSTRUCTIONS, CONDITIONS, AND NOTICES TO OFFERORS	
	G	CONTRACT ADMINISTRATION DATA			M	EVALUATION FACTORS FOR AWARD	
	H	SPECIAL CONTRACT REQUIREMENTS					

OFFER (Must be fully completed by offeror)

NOTE: Item 12 does not apply if the solicitation includes the provisions at 52.214-16, Minimum Bid Acceptance Period.

12. In compliance with the above, the undersigned agrees, if this offer is accepted within _____ calendar days (60 calendar days unless a different period is inserted by the offeror) from the date for receipt of offers specified above, to furnish any or all items upon which prices are offered at the set opposite each item, delivered at the designated point(s), within the time specified in the schedule.

13. DISCOUNT FOR PROMPT PAYMENT (See Section I, Clause Number 52.232-8) 	10 CALENDAR DAYS (%)	20 CALENDAR DAYS (%)	30 CALENDAR DAYS (%)	CALENDAR DAYS (%)
14. ACKNOWLEDGMENT OF AMENDMENTS (The offeror acknowledges receipt of amendments to the SOLICITATION for offerors and related documents numbered and dated):	AMENDMENT NUMBER	DATE	AMENDMENT NUMBER	DATE
15A. NAME AND ADDRESS OF OFFEROR	CODE	FACILITY	16. NAME AND THE TITLE OF PERSON AUTHORIZED TO SIGN OFFER (Type or print)	
15B. TELEPHONE NUMBER	15C. CHECK IF REMITTANCE ADDRESS IS DIFFERENT FROM ABOVE - ENTER SUCH ADDRESS IN SCHEDULE. ☐		17. SIGNATURE	18. OFFER DATE
AREA CODE	NUMBER	EXTENSION		

AWARD (To be completed by Government)

19. ACCEPTED AS TO ITEMS NUMBERED	20. AMOUNT	21. ACCOUNTING AND APPROPRIATION
22. AUTHORITY FOR USING OTHER THAN FULL OPEN COMPETITION UNDER THE UNITED STATES CODE AT: ☐ 10 U.S.C. 3204(a) ☐ 41 U.S.C. 3304(a) ()	23. SUBMIT INVOICES TO ADDRESS SHOWN IN (4 copies unless otherwise specified) 	ITEM
24. ADMINISTERED BY (If other than Item 7)	25. PAYMENT WILL BE MADE BY	CODE
26. NAME OF CONTRACTING OFFICER (Type or print)	27. UNITED STATES OF AMERICA (Signature of Contracting Officer)	28. AWARD DATE

IMPORTANT - Award will be made on this Form, or on Standard Form 26, or by other authorized official written notice.

AUTHORIZED FOR LOCAL REPRODUCTION
Previous edition is unusable

STANDARD FORM 33 (REV. 12/2022)
Prescribed by GSA - FAR (48 CFR) 53.214 (c)

Section A - Solicitation/Contract Form

Fire Suppression Support

GENERAL INFORMATION

RESIDENT OFFICER IN CHARGE OF
CONSTRUCTION (ROICC) NAVAL
FACILITIES ENGINEERING SYSTEMS COMMAND
NAVFAC 1107A BIRCH STREET
CAMP LEJEUNE, NC 28547-2521

NAVFAC Solicitation Number N40085-26-R-0052

NOTICE: PROPOSALS ARE DUE BY:27 May 2026 Time EST: 2:30 PM

All inquiries concerning any phase of the specification shall be made, in writing to Sharon E. Humphrey by email at sharon.e.humphrey.civ@us.navy.mil and Regenia D. Guest via email at Regenia.d.guest.civ@us.navy.mil. Proposals must be received by the established due date and time in order to be considered for award. No email and no facsimile proposals will be accepted.

A.1 Contract Title: Fire Suppression Systems, Marine Corps Base Camp Lejeune, NC.

A.2 Contract Type: This is a combination Firm-Fixed Price (FFP), Indefinite Delivery/Indefinite Quantity (IDIQ) contract with a one (1)-year base period and four (4) 12 months option years.

A.3 Delivery: The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform preventative maintenance, inspections, testing and repair of fire suppression systems located at various locations described in the scope of work in accordance with Section C.

A.4 Set-Aside Information: This acquisition is a total 100% small business set-aside and the offeror must be a Small Business type.

A.5 The NAICS Code assigned to this procurement is 561621, Security Systems Services, with a small business size standard of \$25 Million.

1. Offerors shall ensure current registration in the System for Award Management at <https://sam.gov>, including Annual Representations and Certifications are complete and updated for this procurement. This registration and correct NAICS must be completed prior to the proposal's due date.

2. Complete the Representation and Certification required by Section K of the RFP and provide a copy of the active SAM Representation and Certification in your price proposal.

A.6 Minimum Guarantee: The Firm Fixed Price portion of the base period only is the minimum guarantee for this contract.

A.7 Proposal Submission: See Section L provision 52.215-1 Instructions to Offerors- Competitive Acquisition (Nov 2021) and Section M for detailed instructions. Offeror shall complete and return DFARS clause 252.225-7059 in order to be eligible for award.

A.8 Evaluation: See Basis for Award in Section M, offerors will be evaluated on the Factors as stated.

A.9 Wage Determination: The Service Contract Act by Direction of the Secretary of Labor are included in this

solicitation. Refer to Section J, attachments.

A.10 Contract Term: This procurement contains provisions for a base period of twelve (12) months with four, one (1) year option periods. The total contract period of performance shall not exceed 60 months.

A.11 Period of Performance: The period of performance will be determined at the time of award. Any extension will be the sole discretion the Government.

A.12 Offerors shall provide their Unique Entity ID, CAGE code, and Federal Tax ID number with proposal.

A.13 Offerors are advised that Funding may not become Available: If funds are not available, no award will be made as a result of this solicitation. Offerors will not be reimbursed for any effort or proposal costs resulting from this solicitation. See FAR Clause 52.232-18.

A.14 Site Visit: Pending (TBD).

A.15 For Additional Information: Submit all questions in writing no later than 11 May 2026 time EST 2:30 PM. The Government does not intend to respond to inquiries/questions submitted after this date. When submitting questions, please include the solicitation number: N40085-26-R-0052, to Sharon E. Humphrey by email at sharon.e.humphrey.civ@us.navy.mil and Regenia D. Guest by email only at Regenia.d.guest.civ@us.navy.mil.

Section B - Supplies or Services & Prices or Costs

Additional Information/Notes

Item	Supplies/Service	Estimated Quantity	Unit	Unit Price	Amount
Option Line Item 0001	Base Year- The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform fire alarm, detection, suppression systems, preventative maintenance, inspection, testing and repairs services at various locations as detailed in the Scope of Work (SOW). The price for CLIN 0001 will be the sum of Exhibit Line-Item Numbers (ELIN's) A00101 - A001BP for the Firm-Fixed Price portion for the base year. Pricing Arrangement: Firm Fixed Price				
0002	IDIQ Base Year - The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform fire alarm, detection, suppression systems, preventative maintenance, inspection, testing and repairs services at various locations as detailed in the Scope of Work (SOW). The price for CLIN 0002 will be the sum of Exhibit Line-Item Numbers (ELIN's) A00201 -A00202 for the Indefinite Delivery/Indefinite Quantity portion for the base year. Provide all materials and equipment to perform Unit Priced Labor. Per each Task Order. (NTE extended price per year) Pricing Arrangement: Firm Fixed Price				
Option Line Item 0003	Option Year 1 The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform fire alarm, detection, suppression systems, preventative maintenance, inspection, testing and repairs services at various locations as detailed in the Scope of Work (SOW). The price for CLIN 0003 will be the sum of Exhibit Line-Item Numbers (ELIN's) B001AA - B001BP for the Firm-Fixed Price portion for the base year.				
0004	IDIQ Option Year 1 - The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform fire alarm, detection, suppression systems, preventative maintenance, inspection, testing and repairs services at various locations as detailed in the Scope of Work (SOW). The price for CLIN 0004 will be the sum of Exhibit Line-Item Numbers (ELIN's) B00401 - B00401 for the Indefinite Delivery/indefinite Quantity portion for the base year.				
	Option Year 2- The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform fire alarm, detection, suppression				

Option Line Item 0005	systems, preventative maintenance, inspection, testing and repairs services at various locations as detailed in the Scope of Work (SOW). The price for CLIN 0005 will be the sum of Exhibit Line-Item Numbers (ELIN's) C00101 - C001BP for the Firm-Fixed Price portion for the base year.				
0006	IDIQ Option Year 2 - The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform fire alarm, detection, suppression systems, preventative maintenance, inspection, testing and repairs services at various locations as detailed in the Scope of Work (SOW). The price for CLIN 0006 will be the sum of Exhibit Line-Item Numbers (ELIN's) C00601 -C00602 for the Indefinite Delivery/Indefinite Quantity portion for the base year. Provide all materials and equipment to perform Unit Priced Labor. Per each Task Order. (NTE extended price per year)				
Option Line Item 0007	Option Year 3 - The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform fire alarm, detection, suppression systems, preventative maintenance, inspection, testing and repairs services at various locations as detailed in the Scope of Work (SOW). The price for CLIN 0007 will be the sum of Exhibit Line-Item Numbers (ELIN's) D00101- D001BP for the Firm-Fixed Price portion for the base year.				
0008	IDIQ Option Year 3 - The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform fire alarm, detection, suppression systems, preventative maintenance, inspection, testing and repairs services at various locations as detailed in the Scope of Work (SOW). The price for CLIN 0008 will be the sum of Exhibit Line-Item Numbers (ELIN's) D701 - D702 for the Indefinite Delivery/indefinite Quantity portion for the base year.				
Option Line Item 0009	Option YEAR 4 - The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform fire alarm, detection, suppression systems, preventative maintenance, inspection, testing and repairs services at various locations as detailed in the Scope of Work (SOW). The price for CLIN 0009 will be the sum of Exhibit Line-Item Numbers (ELIN's) E00101 - E001BP for the Firm-Fixed Price portion for the base year.				
	IDIQ Option Year 4 - The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform fire alarm, detection, suppression systems, preventative maintenance, inspection,				

0010	testing and repairs services at various locations as detailed in the Scope of Work (SOW). The price for CLIN 00010 will be the sum of Exhibit Line-Item Numbers (ELIN's) E01001 -E01002 for the Indefinite Delivery/indefinite Quantity portion for the base year.				
------	--	--	--	--	--

Section C - Description/Specifications/Statement of Work

Refer to SECTION J Attachments for Specification Items

Number	Attachment Name	Attachment Description	Reference Identifier	Date
01	0100000 C General Information ver 2.1	Specification	Refer to Section "J" Attachment	02 April 2026
02	0200000 C Management and Administration v2.9	Specification	Refer to Section "J" Attachment	02 April 2026
03	15020000 C Facility Management (updated)	Specification	Refer to Section "J" Attachment	02 April 2026

The Contractor shall provide inspection, testing, maintenance and repair services to ensure that the fire protection system will function on demand and accurate documentation of serviceability. See Section J for the Statement of Work (SOW)

Requirements

Fire Suppression Support

Section D - Packaging and Marking

Section E - Inspection and Acceptance

Supplies/services will be inspected/accepted at:

CLIN	INSPECT BY	INSPECT AT	ACCEPT AT	ACCEPT BY
0001	N/A	N/A	N/A	N/A
0002	N/A	N/A	N/A	N/A
0003	N/A	N/A	N/A	N/A
0004	N/A	N/A	N/A	N/A
0005	N/A	N/A	N/A	N/A
0006	N/A	N/A	N/A	N/A
0007	N/A	N/A	N/A	N/A
0008	N/A	N/A	N/A	N/A
0009	N/A	N/A	N/A	N/A
0010	N/A	N/A	N/A	N/A

FAR Clauses Incorporated by Reference

Number	Title	Effective Date	Alternate/ Deviation	Variation Effective Date
52.246-4	Inspection of Services-Fixed-Price.	Aug 1996		
52.246-16	Responsibility for Supplies.	Apr 1984		

Section F - Deliveries or Performance

Section F- 0200000

Management and Administration

DISTRIBUTION

Annex/ Spec Item	Form Attachment Number	Deliverable Title	Date (s) of Submission	Original	Copies (including original)	Frequency
0200000/ 2.2.1.2	N/A	Request to Work Outside Government's Regular Working Hours	At least seven calendar days prior to requested day.	KO and COR	1	As required
0200000/ 2.3.4	N/A	Permits and Licenses	Before work commences and as requested by the KO.	KO and COR	1	As specified
0200000 /2.3.5	N/A	Certificate of Insurance	At least 30 calendar days prior to start of contract performance	KO and COR	1	As specified
0200000 /2.6.7.1	N/A	Quality Management Plan	At least 30 calendar days prior to start of contract performance and within 15 calendar days prior to any changes.	KO and COR	1	As specified
0200000 /2.6.7.2	N/A	QC Inspection File	Within five calendar days of completion/ termination of the contract.	KO and COR	1	As specified
0200000/ 2.6.7.3	N/A	Contractor Quality Inspection and Surveillance Report	First workday of each month.	KO and COR	1	Monthly
0200000 /2.6.8	N/A	Property Management Plan	At least 30 calendar days prior to start of contract performance.	KO and COR	1	As specified
0200000 /2.7.1	N/A	List of Key Personnel and Qualifications	At least 30 calendar days prior to start of contract performance.	KO and COR	1	As specified
0200000/ 2.7.1	N/A	Organizational Chart	At least 15 calendar days prior to start of contract performance.	KO and COR	1	As specified
0200000/ 2.7.2.6	N/A	Proof of Legal Residency	Prior to be admitted to site of work.	KO and COR	1	As specified

0200000/ 2.7.3	N/A	Contractor Labor Hours (eCMRA) Report	No later than 31 October	KO and COR	1	Annually for labor executed during the period of performance during each Government fiscal year (FY)
0200000/ 2.8.1	N/A	Employee List	Within the First (1st) 30 days. Immediately if any changes	KO and COR	1	As required
0200000/ 2.8.8	N/A	Personnel Security Investigation (PSI), Fingerprint Card (FD87), and OF-306 Declaration for Federal Employment	Prior to employee access to sensitive unclassified information.	KO, COR, and Security Manager	1	As required
0200000/ 2.9.1	N/A	Accident Prevention Plan	At least 30 calendar days prior to start of contract performance and 15 calendar days prior to any changes.	KO and COR	1	As specified
0200000/ 2.9.2	N/A	Activity Hazard Analysis	Together with the Accident Prevention Plan and for changes	KO and COR	1	As specified
0200000/ 2.9.3	N/A	Compliance Plans, Programs, and Procedures	Together with the Accident Prevention Plan and for changes.	KO and COR	1	As required
0200000/ 2.9.5	J-0200000-05-1	NAVFAC Contractor Incident Reporting System (CIRS)	Within five calendar days of accident.	KO and COR	1	As required
0200000/ 2.9.5	J-0200000-05-2	Motor Vehicle Accident Report	Within 15 working days of accident.	KO and COR	1	As required
0200000/ 2.9.7	N/A	Monthly On-Site Labor Report	First workday of each month	KO and COR	1	Monthly
0200000/ 2.9.8	N/A	OSHA Citations and Violations Corrective Action Report	Within 48 hours after receiving a citation	KO and COR	1	As required
0200000/ 2.9.10	N/A	Safety Certifications	At least 15 calendar days prior to start of contract performance and prior to expiration of certifications	KO and COR	1	As specified
0200000/ 2.10.1.1	N/A	Water Conservation Plan	At least 30 calendar days prior to start of contract performance and 15 calendar days prior to any changes.	KO and COR	1	As specified
0200000/ 2.10.2.1	N/A	Written Sampling Plan		NA	NA	NA

0200000/ 2.10.2.7	J-1503010- 05-3	Spill Report	NA	NA	NA	NA
0200000/ 2.10.2.8	N/A	Emergency Planning and Community Right-To-Know Act (EPCRA) Report	At least 15 calendar days prior to start of contract performance and not less than 10 working days prior to planned use of hazardous material.	KO and COR	2	As specified
0200000/ 2.10.2.8	J-0200000- 05-4	Contractor Hazardous Material Inventory Log	Within 15 calendar days after the end of each calendar year and at termination of the contract.	KO and COR	2	Annually
0200000/ 2.10.2.12	N/A	Asbestos Containing Material (ACM)	Written notification within 24 hours of discovery	KO and COR	2	As specified
0200000/ 2.10.3	N/A	Sustainable Procurement and Practices Plan	At least 15 calendar days prior to start of contract performance and within 15 calendar days after exercised option periods	KO and COR	1	Annually
0200000/ 2.10.3	N/A	Sustainable Delivery of Services Report	Within five calendar days after each contract period.	KO and COR	1	Annually
0200000/ 2.10.3.2	N/A	Recovered Material Certification	As specified	KO and COR	1	When a product containing recovered materials is equal to or better than the original and could be used.
0200000/ 2.14.1	N/A	Detailed Scope of Work and Detailed Estimate	Within two workdays	KO and COR	2	As required
0200000/ 2.15.2.1	N/A	Non-Recurring Work Proposals	Within two working days following receipt of request	KO and COR	1	As required
0200000/ 2.15.1.1	N/A	Non-Recurring Work Quantities Ordered via FedMall	First workday of each month.	KO and COR	1	Monthly

Deliverables Form Preparation	
Instructions	
Deliverable Title: Emergency Planning and Community Right-To-Know Act (EPCRA) Report	
Form Attachment No.: J-0200000-XX	
Government Approval Required: ☒ Yes ☐ No	
Media: ☐ Hard Copy ☒ Electronic ☐ Direct System Input	

Instructions:

1. The report shall be prepared using Microsoft Office software.
2. Include the following:
 - a. EPCRA Plans and Procedures:
 - 1) Hazardous Materials Planned for Use: Include an inventory of hazardous materials planned for use, including estimated quantities, and a copy of the corresponding material safety data sheets (MSDS) for hazardous materials expected to be used for this contract during each calendar year. The inventory shall include all information required to complete the Contractor Hazardous Material Inventory Log shown in the Form Attachment. This report shall be submitted to the KO and Environmental Compliance Office via the KO.
 - 2) Plan for protecting personnel and property during the transport, storage, and use of the materials.
 - 3) Emergency procedures for spill response and disposal, including a site map with approximate quantities on site at any given time. The site map, showing where the hazardous substances are stored, shall be attached to the inventory.
 - 4) Approved labeling system to identify contents of all containers on-site.
 - b. Hazardous Materials Actually Used: Include an inventory of the actual hazardous materials used, including include quantities, to the KO and Environmental Compliance Office via the KO. The inventory shall include all information required to complete the Contractor Hazardous Material Inventory Log shown in the Form Attachment.
3. Submit additional information to the Government as requested to support EPCRA reporting requirements.

Overall Contract Delivery Period

Period of Performance

From 17 Jun 2026 to 16 Jun 2031

The ordering period above may include unexercised options

Contractor

Destination

FAR Clauses Incorporated by Reference

Number	Title	Effective Date	Alternate/ Deviation	Variation Effective Date
52.247-34	F.o.b. Destination.	Jan 1991		

Section G - Contract Administration Data

DFARS Clauses Incorporated by Reference

Number	Title	Effective Date	Alternate/ Deviation	Variation Effective Date
252.201-7000	Contracting Officer's Representative.	Dec 1991		
252.204-7006	Billing Instructions-Cost Vouchers	May 2023		
252.232-7003	Electronic Submission of Payment Requests and Receiving Reports.	Dec 2018		

DFARS Clauses Incorporated by Full Text

252.232-7006 Wide Area WorkFlow Payment Instructions. (Jan 2023)

WIDE AREA WORKFLOW PAYMENT INSTRUCTIONS (JAN 2023)

(a) *Definitions.* As used in this clause-

"Department of Defense Activity Address Code (DoDAAC)" is a six position code that uniquely identifies a unit, activity, or organization.

"Document type" means the type of payment request or receiving report available for creation in Wide Area WorkFlow (WAWF).

"Local processing office (LPO)" is the office responsible for payment certification when payment certification is done external to the entitlement system.

"Payment request" and "receiving report" are defined in the clause at 252.232-7003, Electronic Submission of Payment Requests and Receiving Reports.

(b) *Electronic invoicing.* The WAWF system provides the method to electronically process vendor payment requests and receiving reports, as authorized by Defense Federal Acquisition Regulation Supplement (DFARS) 252.232-7003, Electronic Submission of Payment Requests and Receiving Reports.

(c) *WAWF access.* To access WAWF, the Contractor shall-

- (1) Have a designated electronic business point of contact in the System for Award Management at <https://www.sam.gov>; and
- (2) Be registered to use WAWF at <https://wawf.eb.mil/> following the step-by-step procedures for self-registration available at this web site.

(d) *WAWF training.* The Contractor should follow the training instructions of the WAWF Web-Based Training Course and use the Practice Training Site before submitting payment requests through WAWF. Both can be accessed by selecting the "Web Based Training" link on the WAWF home page at <https://wawf.eb.mil/>

(e) *WAWF methods of document submission.* Document submissions may be via web entry, Electronic Data Interchange, or File Transfer Protocol.

(f) *WAWF payment instructions.* The Contractor shall use the following information when submitting payment requests and receiving reports in WAWF for this contract or task or delivery order:

(1) *Document type.* The Contractor shall submit payment requests using the following document type(s):

- (i) For cost-type line items, including labor-hour or time-and-materials, submit a cost voucher.
- (ii) For fixed price line items-

(A) That require shipment of a deliverable, submit the invoice and receiving report specified by the Contracting Officer.

Construction & Facilities Management Invoice Inspection/Acceptance Location: N44249

(B) For services that do not require shipment of a deliverable, submit either the Invoice 2in1, which meets the requirements for the invoice and receiving report, or the applicable invoice and receiving report, as specified by the Contracting Officer.

Construction & Facilities Management Invoice Inspection/Acceptance Location: N44249

- (iii) For customary progress payments based on costs incurred, submit a progress payment request.
- (iv) For performance based payments, submit a performance based payment request.

(v) For commercial financing, submit a commercial financing request.

(2) Fast Pay requests are only permitted when Federal Acquisition Regulation (FAR) 52.213-1 is included in the contract.

(3) *Document routing.* The Contractor shall use the information in the Routing Data Table below only to fill in applicable fields in WAWF when creating payment requests and receiving reports in the system.

Routing Data Table*

<i>Field Name in WAWF</i>	<i>Data to be entered in WAWF</i>
Pay Official DoDAAC	==
Issue By DoDAAC	==
Admin DoDAAC	==
Inspect By DoDAAC	==
Ship To Code	==
Ship From Code	==
Mark For Code	==
Service Approver (DoDAAC)	==
Service Acceptor (DoDAAC)	==
Accept at Other DoDAAC	==
LPO DoDAAC	==
DCAA Auditor DoDAAC	==

Other DoDAAC(s)	==
-----------------	----

(4) *Payment request.* The Contractor shall ensure a payment request includes documentation appropriate to the type of payment request in accordance with the payment clause, contract financing clause, or Federal Acquisition Regulation 52.216-7, Allowable Cost and Payment, as applicable.

(5) *Receiving report.* The Contractor shall ensure a receiving report meets the requirements of DFARS Appendix F.

(g) *WAWF point of contact.*

(1) The Contractor may obtain clarification regarding invoicing in WAWF from the following contracting activity's WAWF point of contact.

(2) Contact the WAWF helpdesk at 866-618-5988, if assistance is needed.

(End of clause)

DFARS PGI Section 204.7108, Payment Instructions have been updated and provides a standard set of payment Instructions, in table format, that define how payments should be made based on the payment request type and the supply or services being acquired.

Below is the link that provides the table

https://www.acq.osd.mil/dpap/dars/pgi/pgi_htm/current/PGI204_71.htm#payment_instructions

Section H - Special Contract Requirements

FEDMALL

Contractor Support of Electronic Contracting (FedMall)

The contractor is required to offer indefinite quantity (IQ) pre-priced line-item services to authorized Government personnel when they are ordering the work directly via the Governmentwide Commercial Purchase Card (GCPC) program. When receiving GCPC orders against Section B, the contractor shall provide the supplies and services at the offered price without additional markup or handling fee.

The contractor agrees to accept and process electronically submitted GCPC orders for IQ services, including those orders issued through the FedMall. The FedMall is a U.S. Government (USG) owned and operated web-based ordering system that enables any Department of Defense (DoD) or Federal activity to search for and order goods and services. Authorized GCPC users will receive approved accounts on FedMall to view and order IQ line items.

The contractor is required to receive electronic IQ orders from the FedMall using 128-bit encrypted email. The contractor agrees to purchase, install, and utilize the most recent version of PGP Personal software, or a comparable solution, for the purpose of decrypting order notification emails from the FedMall. In addition, the DoD has established the External Certification Authority (ECA) program to support the issuance of DoD-approved certificates to contractors. The ECA program is designed to provide the mechanism for contractors to securely communicate with the DoD and authenticate to DoD Information Systems. The contractor agrees to purchase, install, maintain and use a DoD-approved ECA certificate. Information on obtaining an ECA certificate can be found at <http://iase.disa.mil/pki/eca/Pages/certificate.aspx>.

The contractor shall post updates on order delivery schedule and performance to the FedMall in a timely manner.

The contractor shall track quantities and report total ordered quantity in FedMall and approved DD 1155's by line-item number each month and year-to-date. The report shall be due to the Contracting Officer by the fifth day of the following month. The contractor must track and report when total dollar value of all orders from both GCPC purchases and DD 1155s exceed 75% of the combined Section B Pre-Priced Line-Item quantities."

(c) Paragraphs (a) and (b) above apply to both new solicitations and to existing contracts awarded without the FedMall clause and provision.

(d) FedMall orders will not exceed the SAT for services. FedMall orders for construction work is not allowed.

(e) Unless an exception in paragraph (f) below applies, no IDIQ orders will be accepted for processing through a NAVFAC contract's office that can be ordered directly by the client through FedMall unless approved by a waiver. It is the intent that IDIQ contracts will be placed on FedMall. If a contract has been posted on FedMall and a client requests a task order be issued not using FedMall, a waiver by the Echelon III/IV CCO is required for each order. In no case shall the waiver process be utilized to provide a customer the flexibility to circumvent use of FedMall. Use of blanket delivery orders will only be utilized when a waiver has been granted by the Echelon III/IV CCO.

(f) An exception to paragraph (e) above may be made at the discretion of the contracting officer, in coordination with the appropriate technical authority, when:

(1) Service requirements warrant additional contractual and technical oversight due to complexity of the work involved (e.g., crane/technical/safety oversight or similar considerations);

or

(2) The client does not have GCPC authority to place FedMall orders valued above the micro-purchase threshold. Written justification by the contracting officer and appropriate technical authority shall be required prior to issuing an IDIQ order. The written justification shall be included in the contract file and a copy provided to the Echelon III/IV CCO to ensure this exception is applied prudently.

H.2 Non-Recurring Quantities

Once the estimated quantities for individual line items shown in the exhibit for the non-recurring portion have been ordered, additional quantities may be ordered as long as the overall Not-To-Exceed (NTE) amount of the contract per year is not exceeded, and the Contractor agrees by signing the task order.

H.4 Wildlife Preservation

Before commencing work, which may disturb wildlife, the Contractor shall obtain all necessary state, local and federal permits.

H.5
Consequences Of Contractor's Failure to Perform Required Services the Contractor shall perform all of the contract requirements. The Government will inspect and assess Contractor performance in accordance with FAR 52.246-4,

-INSPECTION OF SERVICES

-FIXED PRICE and the Section E provision entitled GOVERNMENT PERFORMANCE ASSESSMENT. The Government will require reperformance, withhold payment, or seek other suitable consideration for unsatisfactory or non-performed work. When defects can't be corrected by re-performance, the Government may reduce the price to reflect the reduced value of services performed.

(a) PROCEDURES.

In the case of unsatisfactory or non-performed work, the Government: (1) may give the Contractor written notice of observed deficiencies prior to withholding payment for unsatisfactory or non-performed work and/or assessing liquidated damages. Such written notice shall not be a prerequisite for withholding payment for non-performed work. The Government may specify, as provided for below, that liquidated damages can be assessed against the Contractor. Such liquidated damages are to compensate the Government for administrative costs and other expenses resulting from the unsatisfactory or non-performed work.

(2) may, at its option, allow the Contractor an opportunity to re-perform the unsatisfactory or non-performed work, at no additional cost to the Government. In the case of daily work, corrective action must be completed within two hours of notice to the Contractor. In the case of other work, corrective action must be completed within twenty-four hours of notice. In addition, the Government can assess liquidated damages, as referenced above, in the amount of 15 percent of the value of all observed defects. The original inspection results of the Contractor's work will not be modified upon re-inspection. However, the Contractor will be paid for satisfactorily re-performed work.

(3) shall withhold from the Contractor's invoice all amounts associated with the unsatisfactory or non-performed work at the prices set out in the Schedule or provided by other provisions of this contract, unless the Contractor is required to re-perform and satisfactorily complete the work. In addition, the Government can assess liquidated damages, as referenced above, in the amount of 15 percent of the value of all observed defects.

(4) may, at its option, perform the work by Government personnel or by other means. The Government will reduce the amount of payment to the Contractor, by the amount paid to any Government personnel (based on wages, retirement and fringe benefits) plus material, or by the actual costs incurred to accomplish the work by other means. If the actual costs cannot be readily determined, the prices set out in the Schedule will be used as the basis for the deduction.

In addition, the Government can assess liquidated damages, as referenced above, in the amount of 15 percent of the computed cost.

(b) The Contractor is responsible for maintaining an effective Quality Control Program during the course of the contract. Failure to maintain adequate quality control may result in Termination for Default.

(c) Re-performance by the Contractor does not waive the Government's right to terminate for nonperformance in accordance with FAR clause 52.249-8, "DEFAULT (FIXED-PRICE SUPPLY AND SERVICE)" of Section I and all other remedies for default as may be provided by law.

Section I - Contract Clauses

FAR Clauses Incorporated by Reference

Number	Title	Effective Date	Alternate/ Deviation	Variation Effective Date
52.202-1	Definitions.	Jun 2020		
52.203-3	Gratuities.	Apr 1984		
52.203-6	Restrictions on Subcontractor Sales to the Government. (Alternate I)	Jun 2020	Alternate I	Nov 2021
52.203-7	Anti-Kickback Procedures.	Jun 2020		
52.203-8	Cancellation, Rescission, and Recovery of Funds for Illegal or Improper Activity.	May 2014		
52.203-10	Price or Fee Adjustment for Illegal or Improper Activity.	May 2014		
52.203-12	Limitation on Payments to Influence Certain Federal Transactions.	Jun 2020		
52.203-19	Prohibition on Requiring Certain Internal Confidentiality Agreements or Statements.	Jan 2017		
52.204-9	Personal Identity Verification of Contractor Personnel.	Jan 2011		
52.204-10	Reporting Executive Compensation and First-Tier Subcontract Awards. (Deviation 2026-O0038)	Feb 2026		
52.204-13	System for Award Management-Maintenance. (Deviation 2026-O0038) (Alternate I)	Feb 2026	Alternate I	Feb 2026
52.204-19	Incorporation by Reference of Representations and Certifications.	Dec 2014		
52.209-6	Protecting the Government's Interest When Subcontracting With Contractors Debarred, Suspended, Proposed for Debarment, or Voluntarily Excluded. (Deviation 2026-O0038)	Feb 2026		
52.209-9	Updates of Publicly Available Information Regarding Responsibility Matters. (Deviation 2026-O0038)	Feb 2026		
52.209-10	Prohibition on Contracting With Inverted Domestic Corporations. (Deviation 2026-O0038)	Feb 2026		
52.210-1	Market Research. (Deviation 2026-O0038)	Feb 2026		
52.211-5	Material Requirements. (Deviation 2026-O0038)	Feb 2026		
52.215-2	Audit and Records-Negotiation. (Deviation 2026-O0038)	Feb 2026		
52.215-8	Order of Precedence-Uniform Contract Format. (Deviation 2026-O0038)	Feb 2026		
52.215-13	Subcontractor Certified Cost or Pricing Data-Modifications. (Deviation 2026-O0038) (Alternate I)	Feb 2026	Alternate I	Feb 2026
52.216-22	Indefinite Quantity. (Deviation 2026-O0038) (Alternate II)	Feb 2026	Alternate II	Feb 2026
52.219-6	Notice of Total Small Business Set-Aside. (Deviation 2026-O0038)	Feb 2026		
52.219-6	Notice of Total Small Business Set-Aside. (Alternate I)	Feb 2026	Alternate I	Mar 2020
52.219-8	Utilization of Small Business Concerns. (Deviation 2026-O0038)	Feb 2026		
52.222-3	Convict Labor. (Deviation 2026-O0038)	Feb 2026		
52.222-4	Contract Work Hours and Safety Standards-Overtime Compensation. (Deviation 2026-O0038)	Feb 2026		
52.222-35	Equal Opportunity for Veterans. (Deviation 2026-O0038)	Feb 2026		
52.222-37	Employment Reports on Veterans. (Deviation 2026-O0038)	Feb 2026		
52.222-41	Service Contract Labor Standards. (Deviation 2026-O0038)	Feb 2026		
52.222-50	Combating Trafficking in Persons. (Deviation 2026-O0038)	Feb 2026		
52.222-54	Employment Eligibility Verification. (Deviation 2026-O0038)	Feb 2026		
52.222-55	Minimum Wages for Contractor Workers Under Executive Order 14026. (Deviation 2026-O0038)	Feb 2026		
52.222-62	Paid Sick Leave Under Executive Order 13706. (Deviation 2026-O0038)	Feb 2026		
52.223-23	Sustainable Products. (Deviation 2026-O0038)	Feb 2026		
52.224-1	Privacy Act Notification.	Apr 1984		
52.224-2	Privacy Act.	Apr 1984		
52.226-8	Encouraging Contractor Policies to Ban Text Messaging While Driving.	May 2024		
52.228-5	Insurance-Work on a Government Installation.	Jan 1997		
52.229-3	Federal, State, and Local Taxes.	Feb 2013		
52.232-1	Payments.	Apr 1984		
52.232-2	Payments under Fixed-Price Research and Development Contracts.	Apr 1984		
52.232-8	Discounts for Prompt Payment.	Feb 2002		
52.232-11	Extras.	Apr 1984		
52.232-17	Interest.	May 2014		
52.232-18	Availability of Funds.	Apr 1984		
52.232-22	Limitation of Funds. (Deviation 2026-O0038)	Feb 2026		
52.232-25	Prompt Payment.	Jan 2017		
52.232-33	Payment by Electronic Funds Transfer-System for Award Management.	Oct 2018		
52.232-39	Unenforceability of Unauthorized Obligations.	Jun 2013		
52.232-40	Providing Accelerated Payments to Small Business Subcontractors.	Mar 2023		
52.233-1	Disputes. (Deviation 2026-O0038)	Feb 2026		
52.233-3	Protest after Award. (Deviation 2026-O0038)	Feb 2026		
52.233-3	Protest after Award. (Deviation 2026-O0038) (Alternate I)	Feb 2026	Alternate I	Feb 2026
52.233-4	Applicable Law for Breach of Contract Claim. (Deviation 2026-O0038)	Feb 2026		
52.240-91	Security Prohibitions and Exclusions. (Deviation 2026-O0038)	Feb 2026		
52.240-93	Basic Safeguarding of Covered Contractor Information Systems. (Deviation 2026-O0038)	Feb 2026		

52.242-5	Payments to Small Business Subcontractors.	Jan 2017		
52.242-13	Bankruptcy.	Jul 1995		
52.243-1	Changes-Fixed-Price. (Deviation 2026-O0038)	Feb 2026		
52.243-1	Changes-Fixed-Price. (Deviation 2026-O0038) (Alternate I)	Feb 2026	Alternate I	Feb 2026
52.243-1	Changes-Fixed-Price. (Deviation 2026-O0038) (Alternate II)	Feb 2026	Alternate II	Feb 2026
52.244-6	Subcontracts for Commercial Products and Commercial Services. (Deviation 2026-O0038)	Feb 2026		
52.246-25	Limitation of Liability-Services.	Feb 1997		
52.249-1	Termination for Convenience of the Government (Fixed-Price) (Short Form).	Apr 1984		
52.249-8	Default (Fixed-Price Supply and Service).	Apr 1984		
52.253-1	Computer Generated Forms. (Deviation 2026-O0038)	Feb 2026		

DFARS Clauses Incorporated by Reference

Number	Title	Effective Date	Alternate/ Deviation	Variation Effective Date
252.203-7000	Requirements Relating to Compensation of Former DoD Officials.	Sep 2011		
252.203-7001	Prohibition on Persons Convicted of Fraud or Other Defense-Contract-Related Felonies.	Jan 2023		
252.203-7002	Requirement to Inform Employees of Whistleblower Rights.	Dec 2022		
252.203-7003	Agency Office of the Inspector General.	Aug 2019		
252.203-7004	Display of Hotline Posters.	Jan 2023		
252.204-7000	Disclosure of Information.	Oct 2016		
252.204-7003	Control of Government Personnel Work Product.	Apr 1992		
252.204-7004	Antiterrorism Awareness Training for Contractors.	Jan 2023		
252.204-7012	Safeguarding Covered Defense Information and Cyber Incident Reporting.	May 2024		
252.204-7015	Notice of Authorized Disclosure of Information for Litigation Support.	Jan 2023		
252.204-7018	Prohibition on the Acquisition of Covered Defense Telecommunications Equipment or Services.	Jan 2023		
252.205-7000	Provision of Information to Cooperative Agreement Holders.	Oct 2024		
252.209-7004	Subcontracting with Firms that are Owned or Controlled by the Government of a Country that is a State Sponsor of Terrorism.	May 2019		
252.223-7006	Prohibition on Storage, Treatment, and Disposal of Toxic or Hazardous Materials.	Sep 2014		
252.225-7048	Export-Controlled Items.	Jun 2013		
252.225-7056	Prohibition Regarding Business Operations with the Maduro Regime.	Jan 2023		
252.232-7010	Levies on Contract Payments.	Dec 2006		
252.237-7010	Prohibition on Interrogation of Detainees by Contractor Personnel.	Jan 2023		
252.243-7001	Pricing of Contract Modifications.	Dec 1991		
252.243-7002	Requests for Equitable Adjustment.	Dec 2022		
252.244-7000	Subcontracts for Commercial Products or Commercial Services.	Nov 2023		
252.246-7004	Safety of Facilities, Infrastructure, and Equipment for Military Operations.	Oct 2010		
252.247-7023	Transportation of Supplies by Sea.	Oct 2024		

FAR Clauses Incorporated by Full Text

52.209-1 Qualification Requirements. (Deviation 2026-O0038) (Feb 2026)

QUALIFICATION REQUIREMENTS (FEB 2026) (DEVIATION 2026-O0038)

(a) *Definition.* As used in this clause-

Qualification requirement means a Government requirement for testing or other quality assurance demonstration that must be completed before award.

(b) One or more qualification requirements apply to the supplies or services covered by this contract. For those supplies or services requiring qualification, whether the covered product or service is an end item under this contract or simply a component of an end item, the product, manufacturer, or source must have demonstrated that it meets the standards prescribed for qualification before award of this contract. The product, manufacturer, or source must be qualified at the time of award whether or not the name of the product, manufacturer, or source is actually included on a qualified products list, qualified manufacturers list, or qualified bidders list. Offerors should contact the agency activity designated below to obtain all requirements that they or their products or services, or their subcontractors or their products or services, must satisfy to become qualified and to arrange for an opportunity to demonstrate their abilities to meet the standards specified for qualification.

(Name) _____

(Address) _____

(c) If an offeror, manufacturer, source, product or service covered by a qualification requirement has already met the standards specified, the relevant information noted below should be provided.

Offeror's Name _____

Manufacturer's Name_____

Source's Name

Item Name _____

Service Identification _____

Test Number (to the extent known)

(d) Even though a product or service subject to a qualification requirement is not itself an end item under this contract, the product, manufacturer, or source must nevertheless be qualified at the time of award of this contract. This is necessary whether the Contractor or a subcontractor will ultimately provide the product or service in question. If, after award, the Contracting Officer discovers that an applicable qualification requirement was not in fact met at the time of award, the Contracting Officer may either terminate this contract for default or allow performance to continue if adequate consideration is offered and the action is determined to be otherwise in the Government's best interests.

(e) If an offeror, manufacturer, source, product or service has met the qualification requirement but is not yet on a qualified products list, qualified manufacturers list, or qualified bidders list, the offeror must submit evidence of qualification prior to award of this contract. Unless determined to be in the Government's interest, award of this contract will not be delayed to permit an offeror to submit evidence of qualification.

(f) Any change in location or ownership of the plant where a previously qualified product or service was manufactured or performed requires reevaluation of the qualification. Similarly, any change in location or ownership of a previously qualified manufacturer or source requires reevaluation of the qualification. The reevaluation must be accomplished before the date of award.

(End of clause)

52.216-19 Order Limitations.

(Oct 1995)

Order Limitations (Oct 1995)

(a) *Minimum order.* When the Government requires supplies or services covered by this contract in an amount of less than \$3,000.00 the Government is not obligated to purchase, nor is the Contractor obligated to furnish, those supplies or services under the contract.

(b) *Maximum order.* The Contractor is not obligated to honor-

(1) Any order for a single item in excess of **\$100,000.00.**

(2) Any order for a combination of items in excess of \$100,000.00 or

(3) A series of orders from the same ordering office within 15 days that together call for quantities exceeding the limitation in paragraph (b)(1) or (2) of this section.

(c) If this is a requirements contract (*i.e.*, includes the Requirements clause at subsection 52.216-21 of the Federal Acquisition Regulation (FAR)), the Government is not required to order a part of any one requirement from the Contractor if that requirement exceeds the maximum-order limitations in paragraph (b) of this section.

(d) Notwithstanding paragraphs (b) and (c) of this section, the Contractor shall honor any order exceeding the maximum order limitations in paragraph (b), unless that order (or orders) is returned to the ordering office within ____ days after issuance, with written notice stating the Contractor's intent not to ship the item (or items) called for and the reasons. Upon receiving this notice, the Government may acquire the supplies or services from another source.

(End of clause)

52.217-8 Option to Extend Services.

(Nov 1999)

Option to Extend Services (Nov 1999)

The Government may require continued performance of any services within the limits and at the rates specified in the contract. These rates may be adjusted only as a result of revisions to prevailing labor rates provided by the Secretary of Labor. The option provision may be exercised more than once, but the total extension of performance hereunder shall not exceed 6 months. The Contracting Officer may exercise the option by written notice to the Contractor within 60 days.

(End of clause)

PRICING FOR FIRE SUPPRESSION SUPPORT (ANNEX 0200000) RECURRING IN ACCORDANCE WITH SECTION C, SPEC ITEM 3 OPTIONAL EXTENSION OF SERVICES, CLIN F011 AND ELINs F01101 - F011BP (NTE EXTENDED SERVICE PERIOD) ARE THE SAME LIN-ITEMS IN THE 4TH OPTION CLIN E009

--	--	--	--	--	--	--

ELIN	Description	Quantity	Unit of Issue	Freq	Unit Price	Total Price
F01101-F011BP 1 Month	Same Line Items as Fourth Option ELINS E00901-E009BP. Contractor shall provide one month (30 days) the cost of the 4th Option services for their pricing.	1	EA	A		
	Estimated Cost Includes: Labor, Materials, and Equipment					
F01101-F011BP 3 Months	Same Line Items as Fourth Option ELINS E00901-E009BP, Contractor shall provide a third (1/3) Cost of the 4th Option services for their pricing.	1	EA	A		
	Estimated Cost Includes: Labor, Materials, and Equipment					
F01101-F011BP 6 Months	Same Line Items as Fourth Option ELINS E00901-E009BP. Contractor shall provide a half (1/2) Cost of the 4th Option services for their pricing.	1	EA	A		
	Fourth Option ELINS Extension F01101 -F011BP					

PRICES TO PERFORM FIRE SUPPRESSION SUPPORT (SUB-ANNEX 0200000) - NON- RECURRING (IDIQ) - IN ACCORDANCE WITH SECTION C, SPEC ITEM 3, OPTIONAL EXTENSION OF SERVICES, CLIN F012 ELIN F012AA - F012AC (NTE Extended Service Period) are the same line items in the 4th Option CLIN E010 ELINS.

ELIN	Description	Quantity	Unit of Issue	Freq	Unit Price	Total Price
F012						
F01201 1-month	Same Line Items as Fourth Option ELINS E0010AA-E0010AN. Contractor shall provide one month (30 days) the cost of the 4th Option services for their pricing	1	LH			
	Estimated Cost Includes: Labor, Materials, and Equipment					

F01202 3-months	Same Line Items as Fourth Option ELINS E01001-E01002. Contractor shall provide a third (1/3) Cost of the 4th Option services for their pricing.	1	LS			
	Estimated Cost Includes: Labor, Materials, and Equipment					
F01201-F01202 6-months	Same Line Items as Fourth Option E0010AA-E0010AN. Contractor shall provide a half (1/2) Cost of the 4th Option services for their pricing.	1	LS			
	Estimated Cost Includes: Labor, Materials, and Equipment					
	Fourth Option ELINS Extension F01201-F01202					

52.217-9 Option to Extend the Term of the Contract.**(Mar 2000)**

Option to Extend the Term of the Contract (Mar 2000)

(a) The Government may extend the term of this contract by written notice to the Contractor within 90 days provided that the Government gives the Contractor a preliminary written notice of its intent to extend at least 60 days unless a different number of days is before the contract expires. The preliminary notice does not commit the Government to an extension.

(b) If the Government exercises this option, the extended contract shall be considered to include this option clause.

(c) The total duration of this contract, including the exercise of any options under this clause, shall not exceed 60 (months).

(End of clause)

52.219-14 Limitations on Subcontracting. (Deviation 2026-O0038)**(Feb 2026)****LIMITATIONS ON SUBCONTRACTING (FEB 2026) (DEVIATION 2026-O0038)**

(a) This clause does not apply to the unrestricted portion of a partial set-aside.

(b) *Definition. Similarly situated entity*, as used in this clause, means a first-tier subcontractor, including an independent contractor, that-

(1) Has the same small business program status as that which qualified the prime contractor for the award (*e.g.*, for a small business set-aside contract, any small business concern, without regard to its socioeconomic status); and

(2) Is considered small for the size standard under the North American Industry Classification System (NAICS) code the prime contractor assigned to the subcontract.

(c) *Applicability.* This clause applies only to-

(1) Contracts that have been set aside for any of the small business concerns identified in 19.000(a)(3);

(2) Part or parts of a multiple-award contract that have been set aside for any of the small business concerns identified in 19.000(a)(3);

(3) Contracts that have been awarded on a sole-source basis in accordance with sections 19.105, 19.106, 19.107, and 19.108;

(4) Orders expected to exceed the simplified acquisition threshold and that are set aside for small business concerns under multiple-award contracts, as described in 8.4 and 16.5;

(5) Orders, regardless of dollar value, that are set aside in accordance with sections 19.105, 19.106, 19.107, and 19.108 under multiple-award contracts, as described in 8.4 and 16.5; and

(6) Contracts using the HUBZone price evaluation preference to award to a HUBZone small business concern unless the concern waived the evaluation preference.

(d) *Independent contractors.* An independent contractor shall be considered a subcontractor.

(e) By submission of an offer and execution of a contract, the Contractor agrees that in performance of a contract assigned a North American Industry Classification System (NAICS) code for-

(1) Services (except construction), it will not pay more than 50 percent of the amount paid by the Government for contract performance to subcontractors that are not similarly situated entities. Any work that a similarly situated entity further subcontracts will count towards the prime contractor's 50 percent subcontract amount that cannot be exceeded. When a contract includes both services and supplies, the 50 percent limitation shall apply only to the service portion of the contract;

(2) Supplies (other than procurement from a nonmanufacturer of such supplies), it will not pay more than 50 percent of the amount paid by the Government for contract performance, excluding the cost of materials, to subcontractors that are not similarly situated entities. Any work that a similarly situated entity further subcontracts will count towards the prime contractor's 50 percent subcontract amount that cannot be exceeded. When a contract includes both supplies and services, the 50 percent limitation shall apply only to the supply portion of the contract;

(3) General construction, it will not pay more than 85 percent of the amount paid by the Government for contract performance, excluding the cost of materials, to subcontractors that are not similarly situated entities. Any work that a similarly situated entity further subcontracts will count towards the prime contractor's 85 percent subcontract amount that cannot be exceeded; or

(4) Construction by special trade contractors, it will not pay more than 75 percent of the amount paid by the Government for contract performance, excluding the cost of materials, to subcontractors that are not similarly situated entities. Any work that a similarly situated entity further subcontracts will count towards the prime contractor's 75 percent subcontract amount that cannot be exceeded.

(f) The Contractor shall comply with the limitations on subcontracting as follows:

(1) For contracts, in accordance with paragraphs (c)(1), (2), (3) and (6) of this clause-

[Contracting Officer check as appropriate.]

☐ By the end of the base term of the contract and then by the end of each subsequent option period; or

☐ By the end of the performance period for each order issued under the contract.

(2) For orders, in accordance with paragraphs (c)(4) and (5) of this clause, by the end of the performance period for the order.

(g) A joint venture agrees that, in the performance of the contract, the applicable percentage specified in paragraph (e) of this clause will be performed by the aggregate of the joint venture participants.

(1) In a joint venture comprised of a small business protégé and its mentor approved by the Small Business Administration, the small business protégé shall perform at least 40 percent of the work performed by the joint venture. Work performed by the small business protégé in the joint venture must be more than administrative functions.

(2) In an 8(a) joint venture, the 8(a) participant(s) shall perform at least 40 percent of the work performed by the joint venture. Work performed by the 8(a) participants in the joint venture must be more than administrative functions.

(End of clause)

52.252-2 **Clauses Incorporated by Reference.**

(Feb 1998)

CLAUSES INCORPORATED BY REFERENCE (FEB 1998)

This contract incorporates one or more clauses by reference, with the same force and effect as if they were given in full text. Upon request, the Contracting Officer will make their full text available. Also, the full text of a clause may be accessed electronically at this/these address(es):

====[Insert one or more Internet addresses]

(End of clause)

52.252-4 Alterations in Contract.

(Apr 1984)

ALTERATIONS IN CONTRACT (APR 1984)

Portions of this contract are altered as follows:

=====
(End of clause)

52.252-6 Authorized Deviations in Clauses.

(Nov 2020)

AUTHORIZED DEVIATIONS IN CLAUSES (NOV 2020)

(a) The use in this solicitation or contract of any Federal Acquisition Regulation (48 CFR Chapter 1) clause with an authorized deviation is indicated by the addition of "(DEVIATION)" after the date of the clause.

(b) The use in this solicitation or contract of any _____[insert regulation name] (48 CFR _____) clause with an authorized deviation is indicated by the addition of "(DEVIATION)" after the name of the regulation.

(End of clause)

DFARS Clauses Incorporated by Full Text

252.223-7001 Hazard Warning Labels.

(Dec 1991)

HAZARD WARNING LABELS (DEC 1991)

(a) "Hazardous material," as used in this clause, is defined in the Hazardous Material Identification and Material Safety Data clause of this contract.

(b) The Contractor shall label the item package (unit container) of any hazardous material to be delivered under this contract in accordance with the Hazard Communication Standard (29 CFR 1910.1200 et seq). The Standard requires that the hazard warning label conform to the requirements of the standard unless the material is otherwise subject to the labelling requirements of one of the following statutes:

- (1) Federal Insecticide, Fungicide and Rodenticide Act;
- (2) Federal Food, Drug and Cosmetics Act;
- (3) Consumer Product Safety Act;
- (4) Federal Hazardous Substances Act; or
- (5) Federal Alcohol Administration Act.

(c) The Offeror shall list which hazardous material listed in the Hazardous Material Identification and Material Safety Data clause of this contract will be labelled in accordance with one of the Acts in paragraphs (b)(1) through (5) of this clause instead of the Hazard Communication Standard. Any hazardous material not listed will be interpreted to mean that a label is required in accordance with the Hazard Communication Standard.

MATERIAL (If None, Insert "None.")	ACT
_____	_____
_____	_____
_____	_____

(d) The apparently successful Offeror agrees to submit, before award, a copy of the hazard warning label for all hazardous materials not listed in paragraph (c) of this clause. The Offeror shall submit the label with the Material Safety Data Sheet being furnished under the Hazardous Material Identification and Material Safety Data clause of this contract.

(e) The Contractor shall also comply with MIL-STD-129, Marking for Shipment and Storage (including revisions adopted during the term of this contract).

(End of clause)

252.232-7007 Limitation of Government's Obligation.

(Apr 2014)

LIMITATION OF GOVERNMENT'S OBLIGATION (APR 2014)

(a) Contract line item(s) 0001, 0003, 0005, 0007 and 0009 is/are incrementally funded. For this/these item(s), will be based upon the contract award amount of the total price is presently available for payment and allotted to this contract. An allotment schedule is set forth in paragraph (j) of this clause.

(b) For item(s) identified in paragraph (a) of this clause, the Contractor agrees to perform up to the point at which the total amount payable by the Government, including reimbursement in the event of termination of those item(s) for the Government's convenience, approximates the total amount currently allotted to the contract. The Contractor is not authorized to continue work on those item(s) beyond that point. The Government will not be obligated in any event to reimburse the Contractor in excess of the amount allotted to the contract for those item(s) regardless of anything to the contrary in the clause entitled "Termination for Convenience of the Government." As used in this clause, the total amount payable by the Government in the event of termination of applicable contract line item(s) for convenience includes costs, profit, and estimated termination settlement costs for those item(s).

(c) Notwithstanding the dates specified in the allotment schedule in paragraph (j) of this clause, the Contractor will notify the Contracting Officer in writing at least ninety days prior to the date when, in the Contractor's best judgment, the work will reach the point at which the total amount payable by the Government, including any cost for termination for convenience, will approximate 85 percent of the total amount then allotted to the contract for performance of the applicable item(s). The notification will state (1) the estimated date when that point will be reached and (2) an estimate of additional funding, if any, needed to continue performance of applicable line items up to the next scheduled date for allotment of funds identified in paragraph (j) of this clause, or to a mutually agreed upon substitute date. The notification will also advise the Contracting Officer of the estimated amount of additional funds that will be required for the timely performance of the item(s) funded pursuant to this clause, for a subsequent period as may be specified in the allotment schedule in paragraph (j) of this clause or otherwise agreed to by the parties. If after such notification additional funds are not allotted by the date identified in the Contractor's notification, or by an agreed substitute date, the Contracting Officer will terminate any item(s) for which additional funds have not been allotted, pursuant to the clause of this contract entitled "Termination for Convenience of the Government."

(d) When additional funds are allotted for continued performance of the contract line item(s) identified in paragraph (a) of this clause, the parties will agree as to the period of contract performance which will be covered by the funds. The provisions of paragraphs (b) through (d) of this clause will apply in like manner to the additional allotted funds and agreed substitute date, and the contract will be modified accordingly.

(e) If, solely by reason of failure of the Government to allot additional funds, by the dates indicated below, in amounts sufficient for timely performance of the contract line item(s) identified in paragraph (a) of this clause, the Contractor incurs additional costs or is delayed in the performance of the work under this contract and if additional funds are allotted, an equitable adjustment will be made in the price or prices (including appropriate target, billing, and ceiling prices where applicable) of the item(s), or in the time of delivery, or both. Failure to agree to any such equitable adjustment hereunder will be a dispute concerning a question of fact within the meaning of the clause entitled "Disputes."

(f) The Government may at any time prior to termination allot additional funds for the performance of the contract line item(s) identified in paragraph (a) of this clause.

(g) The termination provisions of this clause do not limit the rights of the Government under the clause entitled "Default." The provisions of this clause are limited to the work and allotment of funds for the contract line item(s) set forth in paragraph (a) of this clause. This clause no longer applies once the contract is fully funded except with regard to the rights or obligations of the parties concerning equitable adjustments negotiated under paragraphs (d) and (e) of this clause.

(h) Nothing in this clause affects the right of the Government to terminate this contract pursuant to the clause of this contract entitled "Termination for Convenience of the Government."

(i) Nothing in this clause shall be construed as authorization of voluntary services whose acceptance is otherwise prohibited under 31 U.S.C. 1342.

(j) The parties contemplate that the Government will allot funds to this contract in accordance with the following schedule:

On execution of contract	\$ _____
(month) (day), (year) _____	\$ _____

(month) (day), (year) ==	\$ ==
(month) (day), (year) ==	\$ ==

(End of clause)

Section J - List of Attachments

SECTION J-0200000 DOCUMENTS, EXHIBITS, AND OTHER ATTACHMENTS TABLE OF CONTENTS	
ATTACHMENT NUMBER	<u>ATTACHMENT TITLE</u>
J-0200000-01	DEFINITIONS AND ACRONYMS
J-0200000-02	WAGE DETERMINATIONS
J-0200000-03	DIRECTIVES, INSTRUCTIONS, AND REFERENCES
J-0200000-04	INVOICE FORM
J-0200000-05-1	CONTRACTOR SIGNIFICANT INCIDENT REPORT (CSIR)
J-0200000-05-2	MOTOR VEHICLE ACCIDENT REPORT
J-0200000-05-3	INSTALLATION SPILL CONTROL PLAN
J-0200000-05-4	CONTRACTOR HAZARDOUS MATERIAL INVENTORY LOG
J-0200000-06	EXHIBIT LINE-ITEM NUMBERS

SECTION J-1502000 DOCUMENTS, EXHIBITS, AND OTHER ATTACHMENTS TABLE OF CONTENTS	
ATTACHMENT NUMBER	<u>ATTACHMENT TITLE</u>
J-1502000-01	DEFINITIONS AND ACRONYMS
J-1502000-02	REFERENCES AND TECHNICAL DOCUMENTS

J-1502000-03	FACILITIES PROPERTY INVENTORY
--------------	-------------------------------

Attachments:

Number	Attachment Name	Attachment Description	Reference Identifier	Date
01	0100000 C General Information ver 2.1	Specification		02 Apr 2026
02	0200000 C Management and Administration v2. 9	Specification		02 Apr 2026
03	1502000 C Facility Management (Updated)	Specification		02 Apr 2026
04	J-0200000 01 thru 05-4	Performance Work Statement		21 Apr 2026
05	J-1502000-01 thru 03	Performance Work Statement		21 Apr 2026

Section K - Representations, Certification, & Other Statements

FAR Clauses Incorporated by Reference

Number	Title	Effective Date	Alternate/ Deviation	Variation Effective Date
52.203-11	Certification and Disclosure Regarding Payments to Influence Certain Federal Transactions.	Sep 2024		
52.223-4	Recovered Material Certification.	May 2008		
52.240-90	Security Prohibitions and Exclusions Representations and Certifications. (Deviation 2026-00038)	Feb 2026		
52.241-1	Electric Service Territory Compliance Representation.	May 1999		

DFARS Clauses Incorporated by Reference

Number	Title	Effective Date	Alternate/ Deviation	Variation Effective Date
252.203-7005	Representation Relating to Compensation of Former DoD Officials.	Sep 2022		
252.204-7008	Compliance with Safeguarding Covered Defense Information Controls.	Oct 2016		
252.225-7055	Representation Regarding Business Operations with the Maduro Regime.	May 2022		

FAR Clauses Incorporated by Full Text

52.203-2 **Certificate of Independent Price Determination.** **(Apr 1985)**

CERTIFICATE OF INDEPENDENT PRICE DETERMINATION (APR 1985)

(a) The offeror certifies that-

(1) The prices in this offer have been arrived at independently, without, for the purpose of restricting competition, any consultation, communication, or agreement with any other offeror or competitor relating to-

(i) Those prices;

(ii) The intention to submit an offer; or

(iii) The methods or factors used to calculate the prices offered.

(2) The prices in this offer have not been and will not be knowingly disclosed by the offeror, directly or indirectly, to any other offeror or competitor before bid opening (in the case of a sealed bid solicitation) or contract award (in the case of a negotiated solicitation) unless otherwise required by law; and

(3) No attempt has been made or will be made by the offeror to induce any other concern to submit or not to submit an offer for the purpose of restricting competition.

(b) Each signature on the offer is considered to be a certification by the signatory that the signatory-

(1) Is the person in the offeror's organization responsible for determining the prices being offered in this bid or proposal, and that the signatory has not participated and will not participate in any action contrary to paragraphs (a)(1) through (a)(3) of this provision; or

(2)

(i) Has been authorized, in writing, to act as agent for the following principals in certifying that those principals have not participated, and will not participate in any action contrary to paragraphs (a)(1) through (a)(3) of this provision ____ [insert full name of person(s) in the offeror's organization responsible for determining the prices offered in this bid or proposal, and the title of his or her position in the offeror's organization];

(ii) As an authorized agent, does certify that the principals named in subdivision (b)(2)(i) of this provision have not participated, and will not participate, in any action contrary to paragraphs (a)(1) through (a)(3) of this provision; and

(iii) As an agent, has not personally participated, and will not participate, in any action contrary to paragraphs (a)(1) through (a)(3) of this provision.

(c) If the offeror deletes or modifies subparagraph (a)(2) above, the offeror must furnish with its offer a signed statement setting forth in detail the circumstances of the disclosure.

(End of provision)

52.209-11 Representation by Corporations Regarding Delinquent Tax Liability or a Felony Conviction under any Federal Law. (Deviation 2026-O0038) (Feb 2026)

REPRESENTATION BY CORPORATIONS REGARDING DELINQUENT TAX LIABILITY OR A FELONY CONVICTION UNDER ANY FEDERAL LAW (FEB 2026) (DEVIATION 2026-O0038)

(a) The Government will not enter into a contract with any corporation that-

(1) Has any unpaid Federal tax liability that has been assessed, for which all judicial and administrative remedies have been exhausted or have lapsed, and that is not being paid in a timely manner pursuant to an agreement with the authority responsible for collecting the tax liability, where the awarding agency is aware of the unpaid tax liability, unless an agency has considered suspension or debarment of the corporation and made a determination that suspension or debarment is not necessary to protect the interests of the Government; or

(2) Was convicted of a felony criminal violation under any Federal law within the preceding 24 months, where the awarding agency is aware of the conviction, unless an agency has considered suspension or debarment of the corporation and made a determination that this action is not necessary to protect the interests of the Government.

(b) The Offeror represents that-

(1) It is ☐ is not ☐ a corporation that has any unpaid Federal tax liability that has been assessed, for which all judicial and administrative remedies have been exhausted or have lapsed, and that is not being paid in a timely manner pursuant to an agreement with the authority responsible for collecting the tax liability; and

(2) It is ☐ is not ☐ a corporation that was convicted of a felony criminal violation under a Federal law within the preceding 24 months.

(End of provision)

DFARS Clauses Incorporated by Full Text

252.204-7016 Covered Defense Telecommunications Equipment or Services-Representation. (Dec 2019)

COVERED DEFENSE TELECOMMUNICATIONS EQUIPMENT OR SERVICES-REPRESENTATION (DEC 2019)

(a) *Definitions.* As used in this provision, "covered defense telecommunications equipment or services" has the meaning provided in the clause 252.204-7018, Prohibition on the Acquisition of Covered Defense Telecommunications Equipment or Services.

(b) *Procedures.* The Offeror shall review the list of excluded parties in the System for Award Management (SAM) (<https://www.sam.gov>) for entities excluded from receiving federal awards for "covered defense telecommunications equipment or services".

(c) *Representation.* The Offeror represents that it ☐ does, ☐ does not provide covered defense telecommunications equipment or services as a part of its offered products or services to the Government in the performance of any contract, subcontract, or other contractual instrument.

(End of provision)

252.204-7017 Prohibition on the Acquisition of Covered Defense Telecommunications Equipment or Services-Representation. (May 2021)

PROHIBITION ON THE ACQUISITION OF COVERED DEFENSE TELECOMMUNICATIONS EQUIPMENT OR SERVICES-REPRESENTATION (MAY 2021)

The Offeror is not required to complete the representation in this provision if the Offeror has represented in the provision at 252.204-7016, Covered Defense Telecommunications Equipment or Services-Representation, that it "does not provide covered defense telecommunications equipment or services as a part of its offered products or services to the Government in the performance of any contract, subcontract, or other contractual instrument."

(a) *Definitions.* "Covered defense telecommunications equipment or services," "covered mission," "critical technology," and "substantial or essential component," as used in this provision, have the meanings given in the 252.204-7018 clause, Prohibition on the Acquisition of Covered Defense Telecommunications Equipment or Services, of this solicitation.

(b) *Prohibition.* Section 1656 of the National Defense Authorization Act for Fiscal Year 2018 (Pub. L. 115-91) prohibits agencies from procuring or obtaining, or extending or renewing a contract to procure or obtain, any equipment, system, or service to carry out covered missions that uses covered defense telecommunications equipment or services as a substantial or essential component of any system, or as critical technology as part of any system.

(c) *Procedures.* The Offeror shall review the list of excluded parties in the System for Award Management (SAM) at <https://www.sam.gov> for entities that are excluded when providing any equipment, system, or service to carry out covered missions that uses covered defense telecommunications equipment or services as a substantial or essential component of any system, or as critical technology as part of any system, unless a waiver is granted.

(d) *Representation.* If in its annual representations and certifications in SAM the Offeror has represented in paragraph (c) of the provision at 252.204-7016, Covered Defense Telecommunications Equipment or Services-Representation, that it "does" provide covered defense telecommunications equipment or services as a part of its offered products or services to the Government in the performance of any contract, subcontract, or other contractual instrument, then the Offeror shall complete the following additional representation:

The Offeror represents that it ☐ will ☐ will not provide covered defense telecommunications equipment or services as a part of its offered products or services to DoD in the performance of any award resulting from this solicitation.

(e) *Disclosures.* If the Offeror has represented in paragraph (d) of this provision that it "will provide covered defense telecommunications equipment or services," the Offeror shall provide the following information as part of the offer:

(1) A description of all covered defense telecommunications equipment and services offered (include brand or manufacturer; product, such as model number, original equipment manufacturer (OEM) number, manufacturer part number, or wholesaler number; and item description, as applicable).

(2) An explanation of the proposed use of covered defense telecommunications equipment and services and any factors relevant to determining if such use would be permissible under the prohibition referenced in paragraph (b) of this provision.

(3) For services, the entity providing the covered defense telecommunications services (include entity name, unique entity identifier, and Commercial and Government Entity (CAGE) code, if known).

(4) For equipment, the entity that produced or provided the covered defense telecommunications equipment (include entity name, unique entity identifier, CAGE code, and whether the entity was the OEM or a distributor, if known).

(End of provision)

252.204-7998 **Alternate A, Annual Representations and Certifications. (DEVIATION 2026-O0043)** (Feb 2026) **Alternate A Deviation 2026-O0043** (Feb 2026)

Alternate A, Annual Representations and Certifications (DEVIATION 2026-O0043)(FEB 2026)

Include the following paragraphs (e), (f), and (g) in the provision at FAR 52.204-7:

(e)(1) If the provision at FAR 52.204-7, System for Award Management - Registration, is included in this solicitation, paragraph (g) of this provision applies.

(2) If the provision at FAR 52.204-7, System for Award Management - Registration, is not included in this solicitation, and the Offeror has an active registration in the System for Award Management (SAM), the Offeror may choose to use paragraph (g) of this provision instead of completing the corresponding individual representations and certifications in the solicitation. The Offeror shall indicate which option applies by checking one of the following boxes:

☐ (i) Paragraph (g) applies.

☐ (ii) Paragraph (g) does not apply and the Offeror has completed the individual representations and certifications in the solicitation.

(f)(1) The following representations or certifications in the SAM database are applicable to this solicitation as indicated:

(i) 252.204-7016, Covered Defense Telecommunications Equipment or Services--Representation. Applies to all solicitations.

(ii) 252.216-7008, Economic Price Adjustment--Wage Rates or Material Prices Controlled by a Foreign Government. Applies to solicitations for fixed-price supply and service contracts when the contract is to be performed wholly or in part in a foreign country, and a foreign government controls wage rates or material prices and may during contract performance impose a mandatory change in wages or prices of materials.

(iii) 252.225-7042, Authorization to Perform. Applies to all solicitations when performance will be wholly or in part in a foreign country.

(iv) 252.225-7049, Prohibition on Acquisition of Certain Foreign Commercial Satellite Services--Representations. Applies to solicitations for the acquisition of commercial satellite services.

(v) 252.225-7050, Disclosure of Ownership or Control by the Government of a Country that is a State Sponsor of Terrorism. Applies to all solicitations expected to result in contracts of \$150,000 or more.

(vi) 252.229-7012, Tax Exemptions (Italy)--Representation. Applies to solicitations when contract performance will be in Italy.

(vii) 252.229-7013, Tax Exemptions (Spain)--Representation. Applies to solicitations when contract performance will be in Spain.

(2) The following representations or certifications in SAM are applicable to this solicitation as indicated by the Contracting Officer: [Contracting Officer check as appropriate.]

☐ (i) 252.209-7002, Disclosure of Ownership or Control by a Foreign Government.

☐ (ii) 252.225-7000, Buy American--Balance of Payments Program Certificate.

☐ (iii) 252.225-7020, Trade Agreements Certificate.

☐ Use with Alternate I.

☐ (iv) 252.225-7031, Secondary Arab Boycott of Israel.

☐ (v) 252.225-7035, Buy American--Free Trade Agreements--Balance of Payments Program Certificate.

☐ Use with Alternate I.

☐ Use with Alternate II.

☐ Use with Alternate III.

☐ Use with Alternate IV.

☐ Use with Alternate V.

☐ (vi) 252.226-7002, Representation for Demonstration Project for Contractors Employing Persons with Disabilities.

☐ (vii) 252.232-7015, Performance-Based Payments--Representation.

(g) The Offeror has completed the annual representations and certifications electronically via the SAM website at <https://www.sam.gov> After reviewing the SAM database information, the Offeror verifies by submission of the offer that the representations and certifications currently posted electronically that apply to this solicitation as indicated in FAR 52.204-7 and paragraph (f) of this provision have been entered or updated within the last 12 months, are current, accurate, complete, and applicable to this solicitation (including the business size standard applicable to the NAICS code referenced for this solicitation), as of the date of this offer, and are incorporated in this offer by reference (see FAR 4.203-1); except for the changes identified below [Offeror to insert changes, identifying change by provision number, title, date]. These amended representation(s) and/or certification(s) are also incorporated in this offer and are current, accurate, and complete as of the date of this offer.

FAR/DFARS provision No.	Title	Date	Change
==	==	==	==
==	==	==	==
==	==	==	==
==	==	==	==
==	==	==	==

Any changes provided by the Offeror are applicable to this solicitation only, and do not result in an update to the representations and certifications located in the SAM database.

(End of provision)

252.209-7002 Disclosure of Ownership or Control by a Foreign Government.

(Dec 2022)

DISCLOSURE OF OWNERSHIP OR CONTROL BY A FOREIGN GOVERNMENT

(DEC 2022)

(a) *Definitions.* As used in this provision-

(1) "Effectively owned or controlled" means that a foreign government or any entity controlled by a foreign government has the power, either directly or indirectly, whether exercised or exercisable, to control the election, appointment, or tenure of the Offeror's officers or a majority of the Offeror's board of directors by any means, e.g., ownership, contract, or operation of law (or equivalent power for unincorporated organizations).

(2) "Entity controlled by a foreign government"-

(i) Means-

(A) Any domestic or foreign organization or corporation that is effectively owned or controlled by a foreign government; or

(B) Any individual acting on behalf of a foreign government.

(ii) Does not include an organization or corporation that is owned, but is not controlled, either directly or indirectly, by a foreign government if the ownership of that organization or corporation by that foreign government was effective before October 23, 1992.

(3) "Foreign government" includes the state and the government of any country (other than the United States and its outlying areas) as well as any political subdivision, agency, or instrumentality thereof.

(4) "Proscribed information" means-

(i) Top Secret information;

(ii) Communications security (COMSEC) material, excluding controlled cryptographic items when unkeyed or utilized with unclassified keys;

(iii) Restricted Data as defined in the U.S. Atomic Energy Act of 1954, as amended;

(iv) Special Access Program (SAP) information; or

(v) Sensitive Compartmented Information (SCI).

(b) *Prohibition on award.* No contract under a national security program may be awarded to an entity controlled by a foreign government if that entity requires access to proscribed information to perform the contract, unless the Secretary of Defense or a designee has waived application of 10 U.S.C. 4874.

(c) *Disclosure.* The Offeror shall disclose any interest a foreign government has in the Offeror when that interest constitutes control by a foreign government as defined in this provision. If the Offeror is a subsidiary, it shall also disclose any reportable interest a foreign government has in any entity that owns or controls the subsidiary, including reportable interest concerning the Offeror's immediate parent, intermediate parents, and the ultimate parent. Use separate paper as needed, and provide the information in the following format:

Offeror's Point of Contact for Questions about Disclosure (Name and Phone Number with Country Code, City Code and Area Code, as applicable)	

Name and Address of Offeror	
=====	

Name and Address of Entity Controlled by a Foreign Government	Description of Interest, Ownership Percentage, and Identification of Foreign Government
==	==
(End of provision)	

Section L - Instructions, Conditions, & Notices to Offerors or Quoters

FAR Clauses Incorporated by Reference

Number	Title	Effective Date	Alternate/ Deviation	Variation Effective Date
52.203-18	Prohibition on Contracting with Entities that Require Certain Internal Confidentiality Agreements or Statements-Representation.	Jan 2017		
52.204-7	System for Award Management-Registration. (Deviation 2026-O0038)	Feb 2026		

DFARS Clauses Incorporated by Reference

Number	Title	Effective Date	Alternate/ Deviation	Variation Effective Date
252.204-7019	Notice of NIST SP 800-171 DoD Assessment Requirements.	Nov 2023		
252.204-7024	Notice on the Use of the Supplier Performance Risk System.	Mar 2023		
252.215-7013	Supplies and Services Provided by Nontraditional Defense Contractors.	Jan 2023		

FAR Clauses Incorporated by Full Text

52.216-1 **Type of Contract. (Deviation 2026-O0038)** **(Feb 2026)**

Type of Contract (Feb 2026) (Deviation 2026-O0038)

The Government contemplates award of a **Firm Fixed Price** contract resulting from this solicitation.

(End of provision)

52.252-1 **Solicitation Provisions Incorporated by Reference.** **(Feb 1998)**

Solicitation Provisions Incorporated by Reference (Feb 1998)

This solicitation incorporates one or more solicitation provisions by reference, with the same force and effect as if they were given in full text. Upon request, the Contracting Officer will make their full text available. The offeror is cautioned that the listed provisions may include blocks that must be completed by the offeror and submitted with its quotation or offer. In lieu of submitting the full text of those provisions, the offeror may identify the provision by paragraph identifier and provide the appropriate information with its quotation or offer. Also, the full text of a solicitation provision may be accessed electronically at this/these address(es):

FAR: <https://www.acquisition.gov/browse/index/far>

DFARS: <https://www.acq.osd.mil/dpap/dars/dfarspgi/current/index.html>

NMCARS: <http://www.secnave.navy.mil/rda/DASN-P/Pages/NMCARS.aspx>

(End of provision)

52.252-3 **Alterations in Solicitation.** **(Apr 1984)**

ALTERATIONS IN SOLICITATION (APR 1984)

Portions of this solicitation are altered as follows:

=====

(End of clause)

52.252-5 **Authorized Deviations in Provisions.** **(Nov 2020)**

AUTHORIZED DEVIATIONS IN PROVISIONS (NOV 2020)

(a) The use in this solicitation of any Federal Acquisition Regulation (48 CFR Chapter 1) provision with an authorized deviation is indicated by the addition of "(DEVIATION)" after the date of the provision.

(b) The use in this solicitation of any ____ [insert regulation name] (48 CFR Chapter ____) provision with an authorized deviation is indicated by the addition of "(DEVIATION)" after the name of the regulation.

(End of provision)

DFARS Clauses Incorporated by Full Text

252.215-7008 Only One Offer.

(Dec 2022)

ONLY ONE OFFER (DEC 2022)

(a) *Cost or pricing data requirements.* After initial submission of offers, if the Contracting Officer notifies the Offeror that only one offer was received, the Offeror agrees to-

(1) Submit any additional cost or pricing data that is required in order to determine whether the price is fair and reasonable (10 U.S.C. 3705) or to comply with the statutory requirement for certified cost or pricing data (10 U.S.C. 3702 and FAR 15.403-3); and

(2) Except as provided in paragraph (b) of this provision, if the acquisition exceeds the certified cost or pricing data threshold and an exception to the requirement for certified cost or pricing data at FAR 15.403-1(b)(2) through (5) does not apply, certify all cost or pricing data in accordance with paragraph (c) of DFARS provision 252.215-7010, Requirements for Certified Cost or Pricing Data and Data Other Than Certified Cost or Pricing Data, of this solicitation.

(b) *Canadian Commercial Corporation.* If the Offeror is the Canadian Commercial Corporation, certified cost or pricing data are not required. If the Contracting Officer notifies the Canadian Commercial Corporation that additional data other than certified cost or pricing data are required in accordance with DFARS 225.870-4(c), the Canadian Commercial Corporation shall obtain and provide the following:

(1) Profit rate or fee (as applicable).

(2) Analysis provided by Public Works and Government Services Canada to the Canadian Commercial Corporation to determine a fair and reasonable price (comparable to the analysis required at FAR 15.404-1).

(3) Data other than certified cost or pricing data necessary to permit a determination by the U.S. Contracting Officer that the proposed price is fair and reasonable ____ [U.S. Contracting Officer to provide description of the data required in accordance with FAR 15.403-3(a)(1) with the notification].

(4) As specified in FAR 15.403-3(a)(4), an offeror who does not comply with a requirement to submit data that the U.S. Contracting Officer has deemed necessary to determine price reasonableness or cost realism is ineligible for award unless the head of the contracting activity determines that it is in the best interest of the Government to make the award to that offeror.

(c) *Subcontracts.* Unless the Offeror is the Canadian Commercial Corporation, the Offeror shall insert the substance of this provision, including this paragraph (c), in all subcontracts exceeding the simplified acquisition threshold defined in FAR part 2.

(End of provision)

Section M - Evaluation Factors for Award

Evaluation Factors for Award

A. BASIS FOR AWARD

1. The Government reserves the right to eliminate from consideration for award any or all offers at any time prior to award of the contract to negotiate with offerors in the competitive range; and to award the contract to the offeror submitting the lowest priced, technically acceptable offer.
2. As stated in the solicitation, the Government intends to evaluate proposals and award a contract without discussions with offerors (except clarifications as described in FAR 15.306(a)). The Government reserves the right to conduct discussions if the Contracting Officer later determines them to be necessary. In addition, if the Contracting Officer determines that the number of proposals that would otherwise be in the competitive range exceeds the number at which an efficient competition can be conducted, the Contracting Officer may limit the number of proposals in the competitive range to the greatest number that will permit an efficient competition among the most highly rated proposals.
3. The LPTA process is selected as appropriate for this acquisition because the best value is expected to result from selection of the technically acceptable proposal with the lowest evaluated price.
4. In order to permit efficient competition, the Navy will utilize the following methodology. Proposals will initially be screened for price and placed in order: (lowest price to highest price). The Navy will then evaluate the technical factors of the lowest priced proposal. In the event the proposal is deemed Unacceptable, the process described will be conducted again as many times as necessary, until such time, as the Government identifies a technically acceptable proposal. The Navy will make award to the lowest priced technically acceptable proposal from among the lowest priced proposals. However, the Navy, at its sole discretion, reserves the right to increase the number of proposals it will review under this methodology. Accordingly, under this methodology, the technical factors of some proposals may not be evaluated by the Navy. If discussions are deemed necessary by the Contracting Officer, all proposals will be evaluated (both technical and price) for the purpose of establishing a competitive range.
5. An overall non-price factors rating must be at least **"ACCEPTABLE"** in order to be eligible for award. An **"UNACCEPTABLE"** rating in any factor results in the overall non-price factors proposal being rated **"UNACCEPTABLE"** unless corrected through discussions. An overall non-price factors rating of **"UNACCEPTABLE"** makes a proposal ineligible for award.

B. EVALUATION FACTORS FOR AWARD

NOTE: For any elements to be included in the solicitation that are included in the SSP (e.g., evaluation factors, significant subfactors, and relative order of importance, etc.), the solicitation language must be verbatim from the language in the SSP. The evaluation factors for award, basis of evaluation and submittal requirements specified in Sections L and M (or a non-UCF solicitation) of the RFP should be consistent with what is stated in the SSP.

1. The solicitation requires the evaluation of price and the following non-price factors:

Factor 1- Corporate Experience

Factor 2-Safety

Factor 3- Past Performance

The distinction between corporate experience and past performance is corporate experience pertains to the types of work and volume of work completed by a contractor that are comparable to the types of work covered by this requirement, in terms of size, scope, and complexity. Past performance pertains to both the relevance of recent efforts and how well a contractor has performed on the contracts."

2. Basis of Evaluation and Submittal Requirements for Each Factor.

(a) Price:

(1) Solicitation Submittal Requirements: Provide one (1) marked original, two (2) marked copies of the solicitation submittal requirements identified below. In case of variation, the original hard copy proposal takes precedence over copies. Additionally, technical information contained in the price proposal will not be considered. Likewise, price information contained in the technical proposal will not be considered.

(i) Executed SF33. Offeror shall insert its company name and address in Block #15, telephone number in Block #15B, acknowledge all amendments in Block #14 (if applicable), name and title of person authorized to sign in Block #16 (if not the President or Vice President of the company, and authorization letter is required for the contract file upon award); signature in Block #17, and offer date in Block #18 of the SF33. In addition, Offeror shall provide its UEI Number, CAGE code, and Federal Tax ID number with its proposal.

(ii) Completed proposed CLIN pricing and ELIN pricing.

(iii) Offeror will follow instruction in Section M of the RFP for pricing submittals.

(iv) SAM registration. Offeror shall ensure current registration on the SAM Website, www.SAM.gov, including Annual Representations and Certifications are complete and updated for this procurement. If a Representation or Certification required by Section K of the RFP is not provided in SAM, include the representation or certification in your price proposal.

(v) FAPIIS Certification. Offeror shall ensure Federal Awardee Performance and Integrity Information System (FAPIIS) Certification as required by FAR 52.209-7, Information Regarding Responsibility Matters.

(vi) VETS-4212 registration. Offeror shall ensure a current VETS-4212 report has been submitted to the Department of Labor (DOL), at <http://www.beta.SAM.gov>, if the Offeror is required to submit. An email confirmation of submission can be requested for submission with priced proposal. If the Offeror is not required to submit a report to VETS-4212, include a brief statement and justification explaining why the Offeror is not required to submit a report. Visit the beta.SAM.gov website for details concerning if your company is required to submit a VETS-4212 report and to request an email confirmation of submission.

(2) Basis of Evaluation:

The Government will evaluate price based on the total price. Total price consists of the basic requirements and all option items (see Section B of the solicitation). The Government intends to evaluate all options and has included the provision FAR 52.217-5, Evaluation of Options (JUL 1990) in Section M of the solicitation. In accordance with FAR 52.217-5, Evaluation of Options will not obligate the Government to exercise the option(s). Analysis will be performed by one or more of the following techniques to ensure a fair and reasonable price:

- (i) Comparison of proposed prices received in response to the RFP.
- (ii) Comparison of proposed prices with the IGCE.
- (iii) Comparison of proposed prices with available historical information.
- (iv) Comparison of market survey results.

Proposals will be evaluated for completeness and reasonableness as follows:

Completeness. All pricing information required by the solicitation has been provided, all mathematic computations are correct, and the pricing application understood, prices are on an "all or none" basis, and failure to submit a price on an item or a number of items may cause this factor and the entire offer to be determined unacceptable.

Reasonableness. Price analysis comparisons indicate the offered price to be fair and reasonable, balanced across option years, and balanced between fixed-price and IDIQ items.

Unreasonable, unbalanced or incomplete pricing may cause a proposal to be determined unacceptable.

(b) Technical Factors:

(1) Factor 1, Corporate Experience:

(i) Solicitation Submittal Requirements:

The offeror shall provide no more than a three (3) page narrative that clearly demonstrates its understanding of and approach to accomplishing the complexity and magnitude of services required, and minimum controls that will be used to ensure full compliance with all performance objectives and standards as described in Section 0200000 - Management and Administration.

Narrative should discuss what percentage of work requirements will be accomplished in-house or by subcontractor, and what methods will be used in order to comply with FAR 52.219-14, Limitations on Subcontracting (FEB 2024) (DEVIATION 2024-O0008), as set forth in the RFP.

Narrative shall discuss the equipment to be used and experience of the company in performing the proposed requirements. Offeror shall provide copies of certifications with the proposal for both in-house and/or subcontracted personnel that have all the following certifications:

NICET Level III certification in Fire Alarm Systems
NICET Level IV certification in Special Hazards Suppression Systems
NICET Level III certification in Water-Based Fire Protection System Layout
NICET Level III certification in Inspection and Testing of Water- Based Systems
Registered Fire Protection Engineer as defined in UFC 3-600-01

The offeror shall provide information for three (3) relevant projects that best demonstrate experience with projects that are similar to the size and scope of the solicitation. The projects submitted must demonstrate performance within the past five (5) years, with a minimum of at least one (1) year of performance on the project from the date of receipt of proposals. Acceptable projects for this factor include those that demonstrate the ability to perform preventative maintenance, inspection, testing and repair for the following building system

3) Fire Alarm and Detection System

Conventional Systems
Addressable Systems

4) Fire Suppression Systems

Wet Pipe Automatic Sprinkler Systems
Dry Pipe Automatic Sprinkler Systems
Pre-Action Automatic Sprinkler Systems
Clean Agent Fire Suppression Systems
Carbon Dioxide (CO2) Fire Suppression Systems
Fire and Smoke Barrier Opening Protection

Each submitted project shall range at least from \$50,000 to \$1M annually.

The attached Corporate Experience Form (Attachment C) is MANDATORY and SHALL be used to submit the three relevant projects information. Except as specifically requested, the Government will not consider information submitted in addition to this form. Individual blocks on this form may be expanded; however, total length for each project data sheet shall not exceed two (2) single-sided pages.

For all submitted projects, the description of the project shall clearly describe the scope of work performed and the relevancy to the project requirements of this RFP as described above.

The Government will not evaluate projects performed by parent, affiliate, subsidiary, sister or any other company with a similar relationship to the offeror. Teaming arrangements and joint ventures are excluded from this competition.

The assessment of the Offeror's relevant experience will be used as a means of evaluating the capability of the Offeror to successfully meet the requirements of the RFP.

(ii) Basis of Evaluation

An offeror will be rated "**Acceptable**" if the narrative demonstrates that the offeror clearly understands and has the technical capability to accomplish the proposed requirements with the required certifications.

(2) Factor 2, Safety

(i) Solicitation Submittal Requirements:

The Offeror shall submit the following information: The Days Away from Work, Restricted Duty, or Job Transfer (DART) Rate; and Total Case Rate (TCR) for (CY2025, CY2024, CY2023, CY2022, and CY2021), Calendar Years (CY), as well as a safety narrative, as described below. For a partnership or joint venture, the Offeror shall submit separate DART and TCR rates for the specified five (5) CY for each contractor who is part of the partnership/joint venture; however, only one safety narrative is required. Any fatalities experienced within this 5-year timeframe must be explained in detail, to include root cause and corrective actions.

NOTE: DART and TCR shall not be submitted for subcontractors

1. DART Rate: Submit five (5) previous complete calendar years' (CY2025, CY2024, CY2023, CY2022, and CY2021) worth of data (not an overall average). If the Offeror has no DART rate for any year, the offeror must affirmatively state so and explain why.

a. DART cases include injuries or illnesses resulting in death, days away from work, and/or restricted work or transfer to another job days beyond the day of injury/illness.

b. Calculation of DART rate: Multiply the total number of DART cases by 200,000 and then divide by the number of employee labor hours worked.

DART RATE = $\frac{\text{Number of DART Incidents} \times 200,000}{\text{Total Number of Employee Labor Hours Worked}}$

2. TCR Rate: Submit five (5) previous complete calendar (CY2025, CY2024, CY2023, CY2022, and CY2021) worth of data (not an overall average). If the Offeror has no TCR rate for any year, the offeror must affirmatively state so and explain why.

a. TCR cases include injuries or illnesses resulting in death, days away from work, and/or restricted work or transfer to another job days beyond the day of injury/illness.

b. Calculation of TCR rate: Multiply the total number of TCR cases by 200,000 and then divide by the number of employee labor hours worked.

TCR RATE = $\frac{\text{Number of TCR Incidents} \times 200,000}{\text{Total Number of Employee Labor Hours Worked}}$

3. Technical Approach to Safety: Submit a narrative that addresses the following:

a. Describe the Offeror's approach to implementing and executing a Safety Management System (SMS) including Management/Leadership involvement, Employee involvement, Hazard prevention, Hazard control, Worksite analysis, and Safety and health training, to include the standard(s) used to benchmark the SMS.

b. Describe the evaluation process used to select potential subcontractors.

c. Describe the processes of how the Offeror will oversee safety compliance of subcontractors at all levels throughout performance of the contract (to include the Offeror's own in-house workforce).

d. The Technical Approach to Safety narrative shall be limited to two (2) single-sided pages or one (1) double-sided page.

(ii) Basis of Evaluation: The evaluation will collectively consider the following:

The Government is seeking to determine that the Offeror has consistently demonstrated a commitment to safety and that the Offeror plans to properly manage and implement safety procedures for itself and its subcontractors. To meet the minimum requirements, the Offeror must demonstrate the following:

1. DART rates at or below 2.99

2. TCR Rates at or below 4.49

NOTE: If the Offeror's rates exceed the established levels above for any of the five years, it will result in a Deficiency, and the offeror will be ineligible for award.

2. Technical Approach to Safety

- a. Offeror describes a viable approach to implementing and executing a Safety Management System (SMS) including Management/Leadership involvement, Employee involvement, Hazard prevention, Hazard control, Worksite analysis, and Safety and health training, to include the standard(s) used to benchmark the SMS.
 - b. Offeror describes a methodical process of evaluating subcontractor's safety performance in their selection process.
 - c. Offeror describes a logical management plan to hold both themselves and their subcontractors accountable for adhering to the safety requirements of the contract.
4. The Government reserves the right to review other available sources (public/Government internal) of information. These may include but are not limited to OSHA data, NAVFAC's Contractor Incident Reporting System (CIRS), Contractor Performance Assessment Reporting System (CPARS), Electronic Subcontract Reporting System (eSRS), etc.

(c) Past Performance

(1) Factor 3, Past Performance:

(i) Solicitation Submittal Requirements:

Offerors shall submit past performance information for the three (3) relevant projects submitted for Factor 1, Corporate Experience.

(ii) Basis of Evaluation:

IF A COMPLETED CPARS EVALUATION IS AVAILABLE, IT SHALL BE SUBMITTED WITH THE PROPOSAL. IF THERE IS NOT A COMPLETED CPARS EVALUATION, the Past Performance Questionnaire (PPQ) included in the solicitation is provided for the offeror or its team members to submit to the client for each project the offeror includes in its proposal for Factor (insert applicable factor number, usually Factor 1, and insert factor title, usually Corporate Experience). AN OFFEROR SHALL NOT SUBMIT A PPQ WHEN A COMPLETED CPARS IS AVAILABLE.

IF A CPARS EVALUATION IS NOT AVAILABLE, ensure correct phone numbers and email addresses are provided for the client point of contact. Completed PPQs should be submitted with your proposal. If the offeror is unable to obtain a completed PPQ from a client for a project(s) before proposal closing date, the offeror should complete and submit with the proposal the first page of the PPQ (**Attachment C_**), which will provide contract and client information for the respective project(s). Offerors should follow-up with clients/references to ensure timely submittal of questionnaires. If the client requests, questionnaires may be submitted directly to the Government's point of contact, Sharon E. Humphrey, via email at **sharon.e.humphrey.civ@us.navy.mil** and Regenia D. Guest **regenia.d.guest.civ@us.navy.mil** prior to proposal closing date. Offerors shall not incorporate by reference into their proposal PPQs or CPARS previously submitted for other RFPs. However, this does not preclude the Government from utilizing previously submitted PPQ information in the past performance evaluation.

Also include performance recognition documents received within the last (5) years other forms of performance recognition.

Sources of Past Performance Information for evaluation are as follows:

- Past performance information provided by the offeror, as solicited;
- Past performance information obtained from questionnaires tailored to the circumstances of the acquisition; and
- Past performance information obtained from any other sources available to the Government, to include, but not limited to, Contractor Performance Assessment Reporting System (CPARS), Federal Awardee Performance and Integrity Information System (FAPIIS), Electronic Subcontract Reporting System (eSRS), or other databases; the Defense Contract Management Agency; and interviews with Program Managers, Contracting Officers, and Fee Determining Officials.

While the Government may elect to consider data from other sources, the burden of providing detailed, current, accurate and complete past performance information rests with the Offeror.

A copy of the blank Past Performance Questionnaire to be used for requesting client references is included as Attachment C.

(ii) Basis of Evaluation: The degree to which past performance evaluations and all other past performance information reviewed by the Government (e.g., CPARS, Federal Awardee Performance and Integrity Information System (FAPIS), Electronic Subcontract.

Reporting System (eSRS), performance recognition documents, and information obtained for any other source) reflect a trend of satisfactory performance considering:

- A pattern of successful completion of tasks;
- A pattern of deliverables that are timely and of good quality;
- A pattern of cooperativeness and teamwork with the Government at all levels

(task managers, contracting officers, auditors, etc.);

- Tasks that are identical to, similar to, or related to the task at hand"

The Government will consider the currency and relevance of the information, the source of the information, context of the data, and general trends in the Contractor's performance. This evaluation is separate and distinct from the Contracting Officer's responsibility determination.

Basic of Evaluation

A. With the approval of the SSA, the Contracting Officer may establish a competitive range and conduct discussions with all the most highly rated proposals, unless the range is further reduced for purposes of efficiency pursuant to FAR 15.306 (c)(2). At the conclusion of discussions, each offeror still in the competitive range shall be given an opportunity to submit a final proposal revision.

B. The SSA shall ensure the proposals are evaluated for acceptability but not ranked using the non-price/price factors.

C. The SSA shall select the source whose proposal offers the lowest evaluated price and for which all non-price factors are rated as Acceptable in accordance with established criteria in the solicitation. Both the solicitation and the Source Selection Plan must clearly describe the minimum requirements that will be used to determine the acceptability of the proposal. The characteristics will be expressed in terms of performance objectives, measures, and standards that map to the Statement of Work or other requirements documents.

D. The SSA shall document the supporting rationale in the SSDD. The SSDD shall be the single summary document supporting selection of the best-value proposal consistent with the stated evaluation criteria.

V. ATTACHMENTS

Attachment A - N/A

Attachment B - N/A

Attachment C - Past Performance Questionnaire

Attachment D - CPARS Statement

FAR Clauses Incorporated by Reference

Number	Title	Effective Date	Alternate/ Deviation	Variation Effective Date
52.217-4	Evaluation of Options Exercised at Time of Contract Award. (Deviation 2026-O0038)	Feb 2026		

0100000 –General Information	
Table of Contents	
Spec Item	Title
1	General Information
1.1	Outline of Services
1.2	Project Location
1.3	Acquisition of Additional Work
1.4	Background Information
1.5	Verification of Workload and Conditions
1.6	Climate Patterns
1.7	Related Information
1.8	Navy Approach to Service Contracting
1.8.1	Partnering Philosophy
1.8.2	Contractor’s Knowledge
1.8.3	Industry Best Practices
1.9	Standard Template
1.10	Navy PBSA Approach
1.11	Technical Proposal Certification

0100000 – General Information		
Spec Item	Title	Description
1	General Information	The Contractor shall furnish all labor, supervision, management, tools, materials, equipment, facilities, transportation, incidental engineering, and other items necessary to provide water analysis monitoring services at Marine Corps Base Camp Lejeune, North Carolina.
1.1	Outline of Services	Except where otherwise stated, the Contractor shall furnish all labor, supervision, management, tools, materials, equipment, facilities, transportation, incidental engineering, and other items necessary to provide the services outlined below and described in this Performance Work Statement (PWS) at combination recurring and non-recurring. The PWS is organized into annexes. Annex 1 is "General Information". Annex 2 contains the on-site project management and administration requirements. Annexes 3 through 18 contain the technical requirements. The annex numbers are identified as 1 through 18 in the description column, but the full expanded annex numbers include seven digits (e.g., Annex 1 expanded number is 0100000 as shown in the header row at the top of this page Annex 1 General Information Annex 010000 General Information Annex 2 Management and Administration Annex 020000 Management and Administration Annex 3 Command and Staff N/A Annex 4 Public Safety N/A Annex 5 Air Operations N/A Annex 6 Port Operations N/A Annex 7 Ordnance N/A Annex 8 Range Operations N/A Annex 9 Health Care Support N/A Annex 10 Supply N/A Annex 11 Personnel Support N/A Annex 12 Morale, Welfare and Recreation Support N/A Annex 13 Galley N/A Annex 14 Housing N/A Annex 15 Facilities Support Annex 1502000 Facility Investment - Fire Suppression Annex 16 Utilities N/A Annex 17 Base Support Vehicles and Equipment N/A Annex 18 Environmental
1.2	Project Location	The work shall be performed at various locations and could vary from location to location. The following is an example of the dispersion of work at the various locations. 1. Building AS256 2. Building AS320 3. Building TC755 4. Building 895 5. Building BB248 6. Building FC307 7. Building H1 8. Building HP5 9. Building M165 10. Building PP5 11. Building RR134 12. Building WC99

0100000 – General Information		
Spec Item	Title	Description
		13. Building WC507 14. Building 24 15. Building 835 16. Building 855 17. Building 883 18. Building 2027 19. Building 2028 20. Building PP201 21. Building TT84 22. Building AS990
1.3	Acquisition of Additional Work	The Government reserves the right to acquire additional inspection and maintenance services at additional locations in addition to the services and locations identified in the Firm-Fixed Price requirements of this contract. Additional services will be incorporated into the contract in accordance with the CHANGES clause, SECTION I or ordered under the non-recurring provisions of the contract. Items of work not covered by this contract but within the general intent are considered in the scope of this contract.
1.4	Background Information	Water analysis monitoring is conducted at MCB, Camp Lejeune's Environmental Laboratory Section (ELS) is responsible for collecting all samples for analysis. All testing laboratories must be certified by the state of North Carolina (NC) for analysis of compliance sample.
1.5	Verification of Workload and Conditions	N/A to this contract.
1.6	Climate Patterns	Climate information for the area can be found online at the State Climate Office of North Carolina (http://nc-climate.ncsu.edu/cronos/normal.php). The station number for the local area is 893727.
1.7	Related Information	There are four types of Related Information that can be found in the Description and Related Information columns of the specification as follows: Informational Notes as used throughout this PWS provides additional information to offerors to be used in developing a thorough understanding of the work to be performed in this contract. Any block of text marked "Informational Notes" throughout Annexes 1 through 18 is subject to this disclaimer. Offerors may not rely upon the "Informational Notes" as material representations of the Government. Information provided in "Informational Notes" does not create a contractual requirement on either party to this contract. Clarifying Information describes client expectations in a more detailed manner than the Performance Objective and Performance standard alone. Constraining Information describes limitations to the work performed to meet the Performance Objective and Performance Standard. Requirement Information further describes client requirements associated with each Performance Objective.

0100000 – General Information		
Spec Item	Title	Description
1.8	Navy Approach to Service Contracting	The Department of Navy (DoN) spends over \$1 billion in annual obligations to meet global requirements for facility operations and maintenance provided through Facility Support Contracts (FSC) and additional billions to provide other base operations support services (OBOS). The Head of the Contracting Activity (HCA) of the Naval Facilities Engineering Command (NAVFAC) has focused increased attention on re-engineering FSC contracts in response to customer and industry feedback, budget constraints, and the impact of a variety of contracting, program management and financial management regulations. The Navy also supports the following principles:
1.8.1	Partnering Philosophy	The first principle is that the Navy views its contractors as partners and not just abstract service providers. The Navy wants its contractors to succeed because partners' success drives the Navy's successful mission completion. Within the bounds of acquisition policy the Navy intends to work to find solutions that will be beneficial to both the Government and its partners.
1.8.2	Contractor's Knowledge	The second principle is that the Navy will receive insightful management from its contractors. This management will include the knowledge, skills, authority and willingness to use contractor resources to find better ways of serving Navy clients' strategic and operational goals and objectives. The Navy's use of performance-based objectives evidences this principle. Although performance work statements will typically contain several levels of performance assessment, the Navy wants its contractors to exercise maximum discretion within bounds of prudent risk management to adjust processes and resources needed to reach specified objectives at the highest performance level.
1.8.3	Industry Best Practices	The third principle is that the Navy will adopt industry best commercial practices and maintain state-of-the-art service delivery. It is the Navy's and contractor's responsibility as partners to reach this goal. To that end, the Navy's emphasis will be in evaluating performance objectives (end results).
1.9	Standard Template	Key to implementing a programmatic approach is using a standard template that ensures Navy-wide consistency yet affords appropriate tailoring to meet local needs. This contract conforms to the standard template and has been tailored for this solicitation. NAVFAC intends to use this template-based approach for future service contracts. Offerors should develop an understanding of the template as part of performing due diligence in reaching an understanding of the Navy's requirements and expectations. The standard template contains 18 standard annexes. Annex 1 will always contain information that is relevant to the entire scope of the contract. Annex 2 contains on-site project management and administration requirements that are relevant to the entire scope of the contract. Annexes 3 through 18 contain the technical information and requirements peculiar to that technical annex. Within each technical annex, the organization of information and requirements are also standardized. Specification item 1 will always contain General Information. Specification item 2 will always contain the management and administrative requirements. Specification item 3 will always contain the recurring requirements. Specification item 4 will always contain the non-recurring requirements. Requirements and standards for higher level specification items apply to all subordinate specification items, e.g., Specification Item 3 standards apply to all firm fixed priced specification items. Specification Item 3.1 is applicable to all

0100000 – General Information		
Spec Item	Title	Description
		3.1 subordinate specification items. Specification Items 3.2 and 3.3 are not considered subordinate to 3.1. All costs associated with Annexes 1 and 2 and Specification items 1 and 2 must be priced and distributed within Specification Item 3 of Annexes 3 through 18.
1.10	Navy PBSA Approach	The Navy’s approach to performance-based service acquisition (PBSA) includes four component parts which are 1) performance outcomes, 2) measurable standards, 3) consideration of incentives, and 4) performance assessment plan.
1.11	Technical Proposal Certification	The Contractor warrants that its proposal incorporated herein by reference will meet or exceed the performance objectives set forth in this contract.

0200000 – Management and Administration	
Spec Item	Title
2	Management and Administration
2.1	Definitions and Acronyms
2.2	General Information
2.2.1	Government Regular Working Hours
2.2.1.1	Observed Federal Holidays
2.2.1.2	Restriction to Contractor Working Hours
2.2.2	Wage Determinations
2.2.3	Requirements Hierarchy
2.3	General Administrative Requirements
2.3.1	Required Conferences and Meetings
2.3.2	Training for Maintenance and Operation of New and Replacement Systems and Equipment
2.3.3	Partnering
2.3.3.1	Informal Partnering
2.3.3.2	Contract Partnering Administration
2.3.3.3	Contract Partnering Session Attendees
2.3.4	Permits and Licenses
2.3.5	Insurance
2.3.5.1	Certificate of Insurance
2.3.5.2	Minimum Insurance Amounts
2.3.6	Protection of Government Property
2.3.7	Government Information Technology (IT) System
2.3.8	Directives, Instructions, and References
2.3.9	Invoicing Procedures
2.3.10	Forms
2.4	Government-Furnished Property, Materials and Services
2.4.1	Government-Furnished Facilities (GFF)
2.4.2	Government-Furnished Utilities
2.4.3	Government-Furnished Materials (GFM)
2.4.4	Government-Furnished Equipment (GFE)
2.4.5	Government-Furnished Services (GFS)
2.5	Contractor-Furnished Items
2.6	Management
2.6.1	Work Reception
2.6.2	Work Control
2.6.3	Work Schedule
2.6.4	Deliverables
2.6.5	Service Interruptions
2.6.6	NAVFAC MAXIMO
2.6.6.1	MAXIMO Data
2.6.6.2	MAXIMO Method of Data Entry
2.6.6.3	MAXIMO Access
2.6.6.4	MAXIMO Training
2.6.7	Quality Management System (QMS)
2.6.7.1	Quality Management (QM) Plan
2.6.7.2	Quality Inspection and Surveillance
2.6.7.3	Quality Inspection and Surveillance Report
2.6.8	Property Management Plan
2.6.9	System and Equipment Replacement
2.7	Personnel Requirements
2.7.1	Key Personnel
2.7.1.1	Project Manager (PM)

0200000 – Management and Administration	
Spec Item	Title
2.7.1.2	Quality Manager
2.7.1.3	Site Safety and Health Officer (SSHO)
2.7.1.4	Environmental/Energy Manager
2.7.2	Employee Requirements
2.7.2.1	Employee Certification and Training
2.7.2.2	Employee Appearance
2.7.2.3	Employee Conduct
2.7.2.4	Identification as Contractor Employee
2.7.2.5	Removal of Employees
2.7.2.6	Proof of Legal Residency
2.7.3	Enterprise-wide Contractor Manpower Reporting Application (eCMRA)
2.8	Security Requirements
2.8.1	Employee Listing
2.8.2	Vehicles
2.8.3	Passes and Badges
2.8.4	Access to Installation
2.8.4.1	DBIDS Program
2.8.4.2	DBIDS Credentials
2.8.5	Access to Buildings
2.8.6	Access Arrangements
2.8.6.1	Escort Arrangement for Secured Areas
2.8.7	Security Clearances
2.8.8	Access to Sensitive Unclassified Information
2.8.9	Access to Navy Marine Corps Intranet (NMCI)
2.8.10	Employee Status
2.9	Contractor Safety Program
2.9.1	Accident Prevention Plan (APP)
2.9.2	Activity Hazard Analysis (AHA)
2.9.3	Safety and Occupational Health (SOH) Risks and Compliance Plans
2.9.3.1	Alcohol and Drug Abuse Prevention Plan
2.9.3.2	Chemical Hazard Communication Program
2.9.3.3	Confined Space Program
2.9.3.4	Critical Lift Plan
2.9.3.5	Fall Prevention and Protection Plan
2.9.4	Crane Operations
2.9.4.1	Crane Inspections
2.9.4.2	Rigging Gear
2.9.4.3	Crane Operators
2.9.5	Accident and Damage Reporting
2.9.5.1	Accident Reporting and Notification Criteria
2.9.6	Fire Protection
2.9.7	Monthly On-Site Labor Report
2.9.8	OSHA Citations and Violations
2.9.9	Safety Inspections and Monitoring
2.9.10	Safety Certification
2.9.11	Safety Apparel on Jobsites
2.9.12	Emergency Medical Treatment
2.9.13	Excavations
2.10	Environmental Management and Sustainability
2.10.1	Energy Management Program
2.10.1.1	Water Conservation Plan

0200000 – Management and Administration	
Spec Item	Title
2.10.1.2	Energy Efficient Products
2.10.2	Environmental Protection
2.10.2.1	Sampling, Testing and Laboratory Services
2.10.2.2	ODS Requirements for Refrigerant Recycling
2.10.2.3	Solid Waste Management and Recycling
2.10.2.4	Non-Regulated Waste Disposal
2.10.2.5	Regulated Waste Disposal
2.10.2.6	Universal Waste
2.10.2.7	Spill Prevention, Containment, and Clean-up
2.10.2.8	Hazardous Material Management
2.10.2.9	Protection of Endangered and Threatened Species (Flora and Fauna)
2.10.2.10	Noise Control
2.10.2.11	Salvage
2.10.2.12	Asbestos Containing Material (ACM)
2.10.2.13	Clean Air Act (CAA)
2.10.3	Sustainable Procurement and Practices
2.10.3.1	Environmentally Preferable Products
2.10.3.2	Use of Recovered Materials
2.10.3.3	Use of Biobased Products
2.11	Disaster Preparedness
2.12	Technical Library
2.13	Warranty Management
2.14	Recurring Work Procedures
2.14.1	Notification to the Government for Work Above the Recurring Work Limitations
2.14.2	Recurring Work Exhibit Line Item Numbers (ELINS)
2.15	Non-Recurring Work
2.15.1	Unit Priced Task (UPT) Work (Non-Negotiated)
2.15.1.1	Acceptance and Performance
2.15.1.2	Invoicing and Receiving Payment
2.15.2	Unit Priced Labor (UPL) Work (Negotiated)
2.15.2.1	Non-recurring Preparation of Proposals
2.15.2.1.1	Labor Requirements
2.15.2.1.2	Material and Equipment Requirements
2.15.2.2	Issuance of Final Task Order
2.15.3	Non-Recurring Work ELINS

0200000 - Management and Administration		
Spec Item	Title	Description
2	Management and Administration	
2.1	Definitions and Acronyms	Definitions and Acronyms are listed in (J-0200000-01) .
2.2	General Information	
2.2.1	Government Regular Working Hours	The Government's regular working hours are 0700-1600, five days per week, Monday through Friday, except observed Federal holidays. Exceptions to the regular hours of operation are detailed in subsequent sections of this PWS. Work in certain annexes or sub-annexes require Contractor continuous operations, 24 hours a day, every day of the year including holidays. The performance of other work requirements shall be accomplished within the Government's regular working hours unless the specific work requirement specified herein necessitates otherwise. Any other work outside Government regular working hours requires prior KO approval.
2.2.1.1	Observed Federal Holidays	The Government observes the following holidays: New Year's Day, Martin Luther King Jr.'s Birthday, President's Day, Memorial Day, Independence Day, Labor Day, Columbus Day, Veterans' Day, Thanksgiving Day, and Christmas Day.
2.2.1.2	Restriction to Contractor Working Hours	If the Contractor wishes to work outside of the Government's regular working hours for the Contractor's convenience, the Contractor shall submit a written Request to Work Outside Government's Regular Working Hours per Section F. Excludes work to be performed during specified hours.
2.2.2	Wage Determinations	Wage Determinations are included in (J-0200000-02) .
2.2.3	Requirements Hierarchy	Requirements or definitions specified in each spec item of this contract apply to subordinate paragraphs. For example, requirements shown in spec item 3.1 would apply to spec items 3.1.1, 3.1.2, 3.1.2.1 and so on. Likewise, Performance Standards specified at a lower digit level (i.e. spec item 3.1.1, 3.1.2, 3.1.2.1) apply when performance is assessed at a higher tier (i.e., spec item 3.1) based on the composite work requirements.
2.3	General Administrative Requirements	
2.3.1	Required Conferences and Meetings	The Contractor may be required to attend administrative and coordination meetings.
2.3.2	Training for Maintenance and Operation of New and Replacement Systems and Equipment	When construction, renovation, or repair work is performed by means other than this contract, the Contractor shall attend Government provided training, as applicable, for maintenance and operation of new and replacement systems and equipment at no additional cost to the Government.
2.3.3	Partnering	To increase the likelihood of successful performance of this contract, the Government requires cohesive partnerships with its Contractors and subcontractors. Key stakeholders, including the supported commands who will receive services, principal individuals from NAVFAC, the performance assessment team, and representative(s) of the installation(s) will be invited to participate in the partnering process. Key members of the prime and sub-contractor teams, including senior management personnel must participate. The partnership will draw on the strength of each organization in an effort to

0200000 - Management and Administration		
Spec Item	Title	Description
		achieve quality contract services done right the first time, within the contract price, as scheduled, and without any safety mishaps. Partnering should accomplish three goals: - The first goal is to develop a cohesive team with common purpose, commitment and established communication processes. - The second goal of partnering is contract specific, identifying risks and opportunities for the team to address. - The third goal is to sustain the Partnership throughout the contract by identifying and addressing issues that affect the Partnership.
2.3.3.1	Informal Partnering	The Contracting Officer shall organize the initial Partnering Meeting with key personnel of the project team, including Contractor's personnel and Government personnel. The initial session will be scheduled concurrent with the Pre-Performance Conference and held no later than 30 days after award and will be held at a Government provided facility as designated by the KO. The Initial Informal Partnering Session will be conducted and facilitated using electronic media (a video and accompanying forms) provided by Contracting Officer. The senior Government stakeholder present will lead the meeting, however, the Contractor's PM or senior representative is encouraged to participate as co-lead. The Partners will determine the frequency of the follow-on sessions.
2.3.3.2	Contract Partnering Administration	Upon award, the ACO will contact the Contractor, supported command(s), Region, and Installation(s) stakeholders, and the performance assessment team to discuss implementation of partnering A partnership agreement, The Charter, should be in place as early as possible so issues arising, even before work begins, can be resolved using the issues resolution process. Replacement of Core Management Team members (stakeholders who attended the initial session and manage the contract work day-to-day) is discouraged since it will disrupt the synergy that has been developed. If replacement of a team member proves to be unavoidable, a follow-on partnering session must be held to officially turn the responsibilities of the position over to the new member. The Core Management Team consisting of the attendees below must be present during the initial and all follow-on partnering sessions. These are the core mandatory attendees. Other stakeholders may attend if they desire or as recommended by the partners.
2.3.3.3	Contract Partnering Session Attendees	The Contractor shall bring the necessary personnel to successfully partner on this contract. Asterisk indicates mandatory personnel. President/Vice President * Project Manager * Quality Manager Site Safety and Health Officer
2.3.4	Permits and Licenses	The Contractor shall obtain all required permits, licenses, and authorizations to perform work under this contract and comply with all the applicable Federal, state and local laws and regulations. The Contractor shall submit copies of Permits and Licenses per Section F.
2.3.5	Insurance	The Contractor shall submit a Certificate of Insurance per Section F as evidence of the existence of the following insurance coverage in amounts not less than the amounts specified below in accordance with the FAR Clause 52.228-5, INSURANCE – WORK ON A GOVERNMENT

0200000 - Management and Administration		
Spec Item	Title	Description
		INSTALLATION. This insurance must be maintained during the performance period.
2.3.5.1	Certificate of Insurance	The Certificate of Insurance shall provide for at least 30 calendar days written notice to the KO by the insurance company prior to cancellation or material change in policy coverage. Other requirements and information are contained in the aforementioned insurance clause.
2.3.5.2	Minimum Insurance Amounts	The Contractor shall procure and maintain, during the entire period of performance under this contract, the following minimum insurance coverage: Comprehensive General Liability: \$500,000 per occurrence Automobile Liability: \$200,000 per person, \$500,000 per occurrence, \$20,000 per occurrence for property damage Workmen's Compensation: As required by Federal and state worker's compensation and occupational disease statutes Employer's Liability coverage: \$100,000, except in states where worker's compensation may not be written by private carriers Other as required by state law
2.3.6	Protection of Government Property	During execution of the work, the Contractor shall protect Government property. The Contractor shall return areas damaged as a result of negligence under this contract to their original condition at no cost to the Government.
2.3.7	Government Information Technology (IT) System	Additional information about NMCI may be obtained at http://www.eds.com/nmci .
2.3.8	Directives, Instructions, and References	Department of Defense (DoD), Secretary of the Navy (SECNAV), Chief of Naval Operations (OPNAV), and other applicable Directives, Instructions, and References are listed in (J-0200000-03) . The Contractor shall comply with the most current version of directives, instructions, and references including versions published during the term of the contract.
2.3.9	Invoicing Procedures	Refer to Invoice Form in (J-0200000-04) for sample.
2.3.10	Forms	Forms referenced in this Annex, e.g. accident reporting, and damage reporting are included among the Forms in (J-0200000-05-1 through J-0200000-05-4) .
2.4	Government-Furnished Property, Materials and Services	N/A to this contract.
2.4.1	Government-Furnished Facilities (GFF)	N/A to this contract.
2.4.2	Government-Furnished Utilities	The Government will furnish water and electricity at existing outlets required for the work to be performed under the contract at no cost to the Contractor. Information concerning the location of existing outlets may be secured from the KO. The Contractor shall provide and maintain, at its expense, the necessary service lines from the existing Government outlets to the work site. Provide and maintain backflow prevention devices on connections to domestic water lines and electrical transformer provisions on connections to electric lines. Meet all Federal, State, local, and installation codes and regulations for backflow prevention devices and electrical transformer

0200000 - Management and Administration		
Spec Item	Title	Description
		provisions. Services required by the Contractor, for which there are no available Government outlets, shall be provided by the Contractor at no cost to the Government.
2.4.3	Government-Furnished Materials (GFM)	N/A to this contract.
2.4.4	Government-Furnished Equipment (GFE)	N/A to this contract.
2.4.5	Government-Furnished Services (GFS)	N/A to this contract.
2.5	Contractor-Furnished Items	Except for items identified as Government Furnished, the Contractor shall provide all equipment, materials, parts, supplies, components, and facilities to perform the requirements of this contract. The KO may inspect Contractor-furnished items for adequacy and compliance with contract requirements. Inadequate or unsafe items shall be removed and replaced by the Contractor at no cost to the Government. Materials containing asbestos, lead, and polychlorinated biphenyls (PCBs) shall not be brought onsite. Energy efficient tools and equipment shall be used when available. The KO may at any time require Samples, Safety Data Sheets (SDS) or Manufacturer's Data Cut Sheets of Materials used in this contract.
2.6	Management	The Contractor shall manage the total work effort associated with the services required herein to meet the performance objectives and standards. Such management includes but is not limited to planning, scheduling, cost accounting, report preparation, establishing and maintaining records, and quality assurance. The Contractor shall provide a staff with the necessary management expertise to ensure performance objectives and standards are met.
2.6.1	Work Reception	The Contractor shall provide the capability to receive, prioritize, correspond, and respond to trouble/service calls and task orders during Government regular working hours and provide a point of contact at a local or toll free number who can perform the above function during other than Government regular working hours.
2.6.2	Work Control	The Contractor shall implement all necessary work control procedures to ensure timely accomplishment of work requirements, as well as to permit tracking and reporting of work in progress. The Contractor shall plan and schedule work to assure material, labor, and equipment are available to complete work requirements within the specified time limits and in conformance with the quality standards established herein. Verbal scheduling and work status updates shall be provided when requested by the KO. A status update of any item of work must be provided within two hours of the inquiry during regular working hours, and by 0800 the following work day for inquiries after regular working hours.
2.6.3	Work Schedule	The Contractor's work shall not interfere with normal Government business. In those cases where some interference is unavoidable, the Contractor shall minimize the impact and effects of the interference. The Contractor shall provide advance access of all of its work schedules to the Government. The Contractor shall notify the KO of any difficulty in scheduling work due to Government controls.

0200000 - Management and Administration		
Spec Item	Title	Description
2.6.4	Deliverables	Records and reports are specified in Sections C, F, H, I, J, and within the Directives, Instructions, and References. The Contractor shall submit accurate and complete documents within the specified timeframes. The Contractor shall revise/modify records and reports, as directed by the KO, at no additional cost to the Government. Government acceptance of deliverables shall not relieve the Contractor of the responsibility for any error or omission which may exist in the deliverable, as the Contractor is responsible for all requirements of this contract.
2.6.5	Service Interruptions	If any utilities or other services must be discontinued (even temporarily) due to scheduled contract work, the Contractor shall notify the KO, affected tenants, and customers in accordance with local procedures. If the discontinued service is due to an emergency breakdown the Contractor shall notify the KO, affected tenants and customers as soon as practicable.
2.6.6	NAVFAC MAXIMO	N/A to this contract.
2.6.6.1	MAXIMO Data	N/A to this contract.
2.6.6.2	MAXIMO Method of Data Entry	N/A to this contract.
2.6.6.3	MAXIMO Access	N/A to this contract.
2.6.6.4	MAXIMO Training	N/A to this contract.
2.6.7	Quality Management System (QMS)	The Contractor shall establish and maintain a complete QMS program in accordance with the provisions specified herein. The Contractor's QMS program shall provide an effective and efficient means of identifying and correcting problems throughout the entire scope of operations. The Contractor's QMS program shall address: • Accurate documentation of work processes, procedures, and output measures. • A systematic procedure for assessing compliance with performance objectives and standards. • Accurate documentation of quality inspections and surveillance conducted throughout the execution of work. • Assessment-driven corrective actions and process adjustments as appropriate in a timely manner.
2.6.7.1	Quality Management (QM) Plan	The Contractor shall develop and submit a QM Plan per Section F. The QM Plan shall describe the QMS methodology and approaches used under this contract. If any changes are made during the period of performance, submit to the KO a revised QM Plan for acceptance. The Contractor's QM Plan shall include, at a minimum, the following: • Policy and objectives of Quality Management System (QMS) • Quality organization • List of personnel • Responsibilities & lines of authority • Training and qualifications • Approach to assuring quality of services provided and conformance with performance objectives and standards

0200000 - Management and Administration		
Spec Item	Title	Description
		• Methods and procedures for effective planning, operation and control of processes and performance of work • Procedures for inspection and surveillance of services • Scheduling and performance of inspection and surveillance • Measurement, data collection and analysis • Corrective action, preventive action, and continuous improvement • Oversight of subcontracted work Documentation and records management • Communication with government (customers)
2.6.7.2	Quality Inspection and Surveillance	The Contractor shall establish and maintain an inspection and surveillance system in accordance with the FAR Clause 52.246-4, INSPECTION OF SERVICES – FIXED PRICE, to ensure that the work performed conforms to the contract requirements. The Contractor shall document and maintain a file of all scheduled and performed inspections and surveillances, inspection and surveillance results, and dates and details of corrective and preventive actions. The quality inspection and surveillance file shall be the property of the Government and made available during the Government's regular working hours. The file shall be submitted to the KO after termination of the contract per Section F.
2.6.7.3	Quality Inspection and Surveillance Report	The Contractor shall submit a copy of the Contractor Quality Inspection and Surveillance Report per Section F. The Contractor Quality Inspection and Surveillance Report shall include a summary and results of the quality inspection and surveillance events performed and assessment-driven corrective actions and process adjustments during the previous month. The Government may adjust the frequency of the submittal based on the Contractor's quality of performance.
2.6.8	Property Management Plan	The Contractor shall establish and maintain a plan that meets the contract clause requirements of Specification Item 2.4, Government-Furnished Property, Materials and Services, of this Annex. This plan shall identify the Contractor's policies, procedures, and practices in receiving and performing physical inventories, repairing and maintaining, preserving and protecting, and reporting the disposition of accepted government property in its possession. The Property Management Plan shall be submitted per Section F.
2.6.9	System and Equipment Replacement	The Contractor shall maintain the integrity and performance of existing energy saving, water conservation or other sustainability design features of systems and equipment in the performance of repair and replacement work. Except where otherwise specified, replacement components shall be of the same model/style or equivalent as the component being replaced. Substitutes for replacement components must be accepted by the KO prior to use. The KO will furnish available information for the existing systems and equipment.
2.7	Personnel Requirements	The Contractor shall comply with the personnel requirements stated below.
2.7.1	Key Personnel	The Contractor shall submit a List of Key Personnel and Qualifications per Section F. The Contractor shall provide any additional information requested by the KO necessary to certify their qualifications. The Contractor shall submit an Organizational Chart per Section F showing lines of authority of the key personnel and on-site supervisor(s) for this contract. The chart shall include names of personnel and their position title in this contract. As a minimum, include the PM, Quality

0200000 - Management and Administration		
Spec Item	Title	Description
		Manager, SSHO, and on-site supervisor(s) and who they will report directly to for this contract. The key personnel shall be revised as applicable for the contract.
2.7.1.1	Project Manager (PM)	The Contractor shall provide a PM and designated alternate, as applicable, who has the have full authority to act for the Contractor on all contract matters relating to this contract. The PM or alternate shall be on-site during the Government's regular working hours and shall be available onsite within one hour after the Government's regular working hours. The PM shall have satisfactory relevant experience at a comparable level of responsibility on contracts of similar size, scope and complexity.
2.7.1.2	Quality Manager	The Contractor shall provide a Quality Manager or designated alternate shall be on-site within during the Government's regular working hours and shall be available on-site within two hours after the Government's regular working hours. The Quality Manager must report directly to a senior corporate official and shall not report directly to the Project Manager. The Quality Manager shall have fulfilled the following pre-requisite training and experiences before being hired as the Quality Manager under this contract: The Quality Manager shall have satisfactory experience in preparing and enforcing QMS programs on contracts of similar size, scope and complexity. The Quality Manager may be the same person as the SSHO.
2.7.1.3	Site Safety and Health Officer (SSHO)	The SSHO must meet the requirements of EM 385-1-1 Section 1 and ensure that the requirements of 29 CFR 1926.16 are met for the project. Provide a Safety oversight team that includes a minimum of one Competent Person at each project site to function as the Site Safety and Health Officer (SSHO). The SSHO or an equally-qualified Designated Representative/alternate shall be on-site at all times when work is being performed to implement and administer the Contractor's safety program and government-accepted Accident Prevention Plan. The SSHO's training, experience, and qualifications shall be as required by EM 385-1-1 paragraph 01.A.17, entitled SITE SAFETY AND HEALTH OFFICER (SSHO), and all associated sub-paragraphs. The Contractor is responsible for all of the cost incurred for the mandated safety training. A Competent Person shall be provided for all of the hazards identified in the Contractor's Safety and Health Program in accordance with the accepted Accident Prevention Plan, and shall be on-site at all times when the work that presents the hazards associated with their professional expertise is being performed. Provide the credentials of the Competent Persons(s) to the Contracting Officer for acceptance in consultation with the Safety Office. The Contractor shall provide a SSHO whose primary duty and responsibility is to prepare and enforce the Contractor's safety program on this contract. The SSHO shall have fulfilled the following pre-requisite training and experiences before being hired as the SSHO under this contract: The SSHO shall have satisfactory experience in preparing and enforcing safety programs on contracts of similar size and complexity in the past, and have completed the OSHA 30-hour construction safety class or equivalent. The SSHO shall maintain competency through 24 hours of formal safety and health related coursework every four years. The SSHO may be the same person as the project manager but shall have fulfilled the pre-requisite

0200000 - Management and Administration		
Spec Item	Title	Description
		qualification and experience. The Contractor is responsible for all of the cost incurred for the mandated safety training.
2.7.1.4	Environmental/ Energy Manager	The Contractor shall provide an Environmental/Energy Manager whose primary duty and responsibility is to ensure Contractor operations adhere to the goals and policies of the Environmental Management System, the Installation Energy Plan, and other specified Sustainability requirements affecting this contract. The Environmental/Energy Manager shall develop, implement and monitor environmental strategies, policies and programs that promote sustainable development and examine the contract activities to establish where improvements can be made and ensure compliance with environmental legislation and energy policy. The Environmental/Energy Manager shall have a minimum two years' experience with environmental procedures similar to those of this contract; familiarity with Environmental Management Systems (EMSs); and knowledge of environmental regulations and federal energy laws and policy (including energy and water reduction requirements and renewable energy requirements) that are applicable to operations similar to those of this contract.
2.7.2	Employee Requirements	The Contractor shall provide experienced, qualified, and capable personnel to perform the work in this contract. Personnel shall be fully knowledgeable of all safety, environmental, and energy requirements associated with the work they perform. Personnel shall speak, read, and comprehend English to the extent that they can perform the contract requirements and comply with installation emergency procedures.
2.7.2.1	Employee Certification and Training	The Contractor shall maintain personnel certification, training, and licensing records for employee requirements specified herein and within all technical annexes/sub-annexes. Certification, training, and licensing records shall be kept current and on file for the duration of the contract including all option periods. Records shall be made available for Government review within 4 hours of request.
2.7.2.2	Employee Appearance	The Contractor shall ensure that all employees present a professional appearance that is appropriate for their position. The KO reserves the right to determine the acceptability of any clothing worn. All Contractor/subcontractor employees working under this contract shall be identified by a distinctive nameplate, emblem, or patch attached in a prominent place on an outer garment. Employee identification shall not be substituted for station required passes or badges.
2.7.2.3	Employee Conduct	Contractor employees shall conduct themselves in a proper, efficient, courteous and businesslike manner.
2.7.2.4	Identification as Contractor Employee	Contractor employees shall identify themselves as Contractor personnel by introducing themselves or being introduced as Contractor personnel and displaying distinguishing badges or other visible identification for meetings with Government personnel. All Contractor employees shall appropriately identify themselves as contractor employees in telephone conversations and in formal and informal written correspondence.
2.7.2.5	Removal of Employees	The Contractor shall remove from the site any individual whose continued employment is deemed by the KO to be contrary to the public interest or inconsistent with the best interests of National Security.
2.7.2.6	Proof of Legal Residency	No employee or representative of the Contractor will be admitted to the site of work unless satisfactory Proof of Legal Residency is furnished per Section F.
2.7.3	Enterprise-wide Contractor	The following manpower reporting is required by NMCARS 5237.102.

0200000 - Management and Administration		
Spec Item	Title	Description
	Manpower Reporting Application (eCMRA)	The Contractor shall report all contractor labor hours (including subcontractor labor hours) required for performance of services provided under this contract via a secure data collection site. The contractor is required to completely fill in all required data fields using the following web address: https://doncmra.nmci.navy.mil. Per Section F, reporting inputs will be for the labor executed during the period of performance during each Government fiscal year (FY), which runs October 1 through September 30. While inputs may be reported any time during the FY, all data shall be reported no later than October 31 of each calendar year. Contractors may direct questions to the help desk, linked at https://doncmra.nmci.navy.mil.
2.8	Security Requirements	The Contractor shall comply with all Federal, state, and local security statutes, regulations, and requirements. The Contractor shall become acquainted with and comply with all Government regulations as posted, or as requested by the KO when required to enter a Government site. The Contractor shall ensure that all security/entrance clearances are obtained.
2.8.1	Employee Listing	The Contractor shall maintain a current Employee List and submit per Section F. The list shall include employee's name, supervisor, company, and level of security clearance.
2.8.2	Vehicles	The company name shall be displayed on each of the Contractor's vehicles in a manner and size that is clearly visible. All vehicles shall display a valid state license plate that complies with State Vehicle Code. Vehicles shall meet all other requirement of the State Vehicle Code, such as safety standards, and shall carry proof of insurance and state registration, if applicable.
2.8.3	Passes and Badges	All Contractor employees shall obtain the required employee and vehicle passes. The Contractor employees must be able to obtain Common Access Cards (CAC) in accordance with security requirements. Each employee shall wear the Government issued badge over the front of the outer clothing. When an employee leaves the Contractor's service, the employee's Passes and Badges shall be returned within 10 calendar days.
2.8.4	Access to Installation	All Contractor personnel shall obtain access to the installation through enrollment and registration into the Defense Biometric Identification System (DBIDS). The Contractor shall provide the KO with the name of their designated Service Contractor Administrator (SCA) for enrollment in DBIDS. Once enrolled, the Contractor must provide the DBIDS Registrar with an approved employee list and then direct their employees to register into DBIDS.
2.8.4.1	DBIDS Program	DBIDS is an enterprise identity management and perimeter installation access control solution in which Contractor personnel who enroll, and are approved, are subsequently granted access to the installation for a period up to three years, or the length of the contract, whichever is less, and are not required to obtain a new pass from the Base Pass and Identification Office for each visit. There are no fees associated with obtaining a DBIDS credential. The Government performs background screening and credentialing. Throughout the year the Contractor employee must continue to meet background screening standards. Periodic background screenings are conducted to verify continued DBIDS participation and installation access privileges. DBIDS access privileges will be immediately suspended or revoked if at any time a Contractor employee becomes ineligible.
2.8.4.2	DBIDS Credentials	Contractor employees shall furnish a completed copy of the SECNAV 5512/1

0200000 - Management and Administration		
Spec Item	Title	Description
		form to obtain the required background check and visit the local Navy Installation Visitor Control Center to obtain a DBIDS credential once approved. The SECNAV 5512/1 form and additional information about DBIDS can be found at: https://www.cnmc.navy.mil/om/dbids.html. The Contractor may initiate the adjudication process when a background screen failure results in disqualification from participation in DBIDS and the Contractor employees do not agree with the reason for disqualification. The Contractor may also apply for a waiver when a background screening failure results in disqualification from participation in DBIDS. The Commanding Officer will be the final waiver determination authority. The Contractor shall immediately collect employee DBIDS credentials and notify the KO in writing: (1) That an employee has departed the company without having properly returned or surrendered their DBIDS credentials. (2) That there is a reasonable basis to conclude that an employee, or former employee, might pose a risk, compromise, or threat to the safety or security of the installation or anyone therein.
2.8.5	Access to Buildings	The Contractor shall monitor and control access into restricted areas under their responsibility, allowing only those individuals who have been properly cleared into restricted areas or other controlled access areas. The Contractor shall comply with security requirements, plus those imposed by the installation Commander at all times. Personnel with access to special areas will have the appropriate screening and/or security clearance, and personnel requiring routine access to restricted areas will wear special badges authorizing access for those areas. Contractor personnel shall not enter restricted or controlled areas or installation facilities unless specifically authorized in performance of their duties. The Contractor shall secure all buildings and facilities entered during non-duty hours and will secure all building and facilities under the Contractor's cognizance at the end of each work day or shift period.
2.8.6	Access Arrangements	The Contractor shall make all arrangements through the appropriate office necessary to obtain access to buildings, facilities and other work areas, and when necessary, arrange for them to be opened and closed by the controlling authority. The Government may issue keys to the Contractor. The Contractor shall use due diligence and be responsible for compromised security systems to include replacement costs that result from its action or inaction.
2.8.6.1	Escort Arrangement for Secured Areas	The Contractor shall make arrangements for Government escort into secured areas requiring escort. The KO will provide information on applicable buildings, spaces and the appropriate point of contact. The Contractor may experience delays while waiting for escorts. The Government estimates the wait period can be up to 15 minutes. The Contractor shall notify the Government Performance Assessment Representative (PAR) and appropriate point of contact if an escort is not available after 15 minutes and access to accomplish the work is denied. Unscheduled requirements, e.g., trouble calls, may require a longer wait for an escort.
2.8.7	Security Clearances	The Contractor shall obtain all required corporate and personnel Security Clearances prior to commencement of work. The Contractor shall ensure that a list of all personnel with Security Clearances is maintained current, including clearances that are pending.

0200000 - Management and Administration		
Spec Item	Title	Description
2.8.8	Access to Sensitive Unclassified Information	The Contractor personnel whose work involves access to sensitive unclassified information shall undergo a National Agency Check Investigation (NACI) to verify their suitability. If the Contractor personnel currently have a favorably adjudicated NACI the Contractor shall notify the Government Command Security Manager who will validate this in the Joint Personnel Adjudication System (JPAS). The Contractor shall request from the Government for access to the E-QIP Direct program for the Contractor employees to complete the SF-85 form on line for an NACI. The Security Manager will determine suitability. Upon a favorable NACI, the Contractor personnel shall provide the completed Personnel Security Investigation (PSI) to the Security Manager along with the original signed release statements, applicant fingerprint card (FD87), and an OF-306 Declaration for Federal Employment per Section F. The Contractor shall be responsible for providing the fingerprint card. The request shall be renewed annually or for the duration of the contract if less than one year.
2.8.9	Access to Navy Marine Corps Intranet (NMCI)	The Contractor may be required to access Navy Marine Corps Intranet (NMCI). Prior to being granted access to NMCI, Contractor employees shall obtain a CAC in accordance with security requirements, successfully complete required training, submit a Systems Authorization Access Request (SAAR) Form, and meet all eligibility requirements.
2.8.10	Employee Status	The Contractor shall notify the KO of any changes to any employee's status to include, but not limited to, termination, convictions/arrests, adverse actions taken on the job for any reason or any other documented misbehavior that may affect, or have the potential to affect, security standing in terms of access to federal facilities or IT systems.
2.9	Contractor Safety Program	The Contractor shall develop and implement a Safety Program detailing how the Contractor plans, staffs, performs, and controls all safety practices while delivering best value services to the Government without any accidents or mishaps. The Contractor's safety program shall comply with all safety standards identified in the U.S. Army Corps of Engineers Safety and Health Requirements Manual, EM 385-1-1 and Public Law 91-596, Occupational Safety and Health Act. Any reference to "USACE" facilities, property, or equipment specified in EM 385-1-1 should be interpreted as Government facilities, property, and equipment.
2.9.1	Accident Prevention Plan (APP)	The Contractor shall develop and implement a site Accident Prevention Plan (APP). The APP shall be prepared by the Contractor's SSO and shall be followed by all Contractor employees, subcontractors, and vendors at each service site. The APP shall follow the abbreviated format and include as a minimum, elements addressed in paragraph 11 of Appendix A of EM 385-1-1." The Contractor shall submit an APP for acceptance per Section F. The Contractor shall review, update, and submit revisions to the APP whenever a change in work conditions, hazards, or activities occur. Submittal of the APP shall include Activity Hazard Analyses (AHAs) and applicable compliance plans, programs, and procedures as specified below.

0200000 - Management and Administration		
Spec Item	Title	Description
		The Contractor shall not commence work until the APP has been accepted and no activity shall be started on site until the applicable AHAs and compliance plans have been accepted. Once accepted by the Contracting Officer, the APP and attachments will be enforced as part of the contract. Disregarding the provisions of this contract or the accepted APP will be cause for stopping of work, at the discretion of the Contracting Officer, until the matter has been rectified.
2.9.2	Activity Hazard Analysis (AHA)	The Contractor shall prepare Activity Hazard Analyses (AHAs) for all applicable common recurring work activities performed under this contract. AHAs for recurring work shall be submitted with the APP and shall be updated as work activities or conditions change and additional AHAs prepared as new work activities are required. AHAs for nonrecurring and one-time (e.g., Non-recurring task orders) work occurrences shall be submitted at least two working days prior to start of work. Specifically: • For Recurring contract modifications where changes are germane to the original contract, the Contractor shall revise applicable AHAs within 15 calendar days after modification is signed. • For combination Recurring/Non-recurring contracts, the Contractor shall submit an AHA on task orders, with the associated proposal, whenever the service environment or required task is different from the recurring services. AHAs shall follow format of Figure 1-2 of EM 385-1-1 and shall explain the following as detailed in the EM 385-1-1: • The steps of the service process; Identify potential hazards that exist as a result of the Contractor's service process within the environment; • Measures or plans of actions to safely remove potential hazards away from people in and around the service process and environment; • Specific materials and equipment necessary to safely remove potential hazards away from people in and around the service process and environment; • Inspection requirements to assure service activity is safe; and • Training of service personnel to be aware of potential hazards and measures or plans of actions to be used to remove hazards from service environment. During performance of services, the SSHO shall periodically review the AHA at each service site and for each sub-annex to assess the effectiveness of the Contractor's overall APP. If changes to the AHAs are required, such changes shall be submitted to the KO for review and acceptance.
2.9.3	Safety and Occupational Health (SOH) Risks and Compliance Plans	Based on a risk assessment of recurring and non-recurring work requirements and on mandatory OSHA compliance programs, the Contractor shall develop, provide and implement all applicable compliance plans, as necessary for the situation or types of work to be performed under this contract. Compliance plans, programs, and procedures along with their respective references are detailed in Appendix A, paragraph 3.i of EM 385-1-1. These plans shall be submitted with the APP and shall be updated as situations change. Additional compliance plans, programs, and procedures

0200000 - Management and Administration		
Spec Item	Title	Description
		shall be developed as applicable when new types of work are required under this contract.
2.9.3.1	Alcohol and Drug Abuse Prevention Plan	The Contractor shall develop an alcohol and drug abuse prevention plan to explain how it will satisfy the drug-free work force requirement as stated in DFARS Clause 252.223-7004 and include elements addressed in paragraph 01.C.02 of EM 385-1-1.
2.9.3.2	Chemical Hazard Communication Program	N/A to this contract.
2.9.3.3	Confined Space Program	N/A to this contract.
2.9.3.4	Critical Lift Plan	N/A to this contract.
2.9.3.5	Fall Prevention and Protection Plan	N/A to this contract.
2.9.4	Crane Operations	All operations of Cranes, Multi-Purpose Machines and Material Handling Equipment shall comply with EM 385-1-1, NAVFAC P-307, 29 CFR Part 1910, and 29 CFR Part 1926. The Contractor shall comply with paragraph 1.7.2 of NAVFAC P-307 and notify the Contracting Officer at least 24 hours prior to bringing any crane (including delivery vehicles with crane boom attachments), multi-purpose machines, material handling equipment, or construction equipment that may be used in a crane-like application to lift suspended loads on board a Navy Installation. Written documentation of the last weight test of the crane and all related weight handling equipment (e.g. attachments, rigging gear, etc.) shall be maintained on site. A joint verification with the Government representative must be performed to ensure that a legible and indelible completed copy of Appendix P, Figure P-1 of NAVFAC P-307 is maintained on the crane, multi-purpose machine, and material handling equipment or construction equipment used in a crane-like application to lift suspended loads. The following certification and testing documentation shall be on site prior to entry and use on any Navy Installation: 1) Crane, multi-purpose machine, material handling equipment or construction equipment used in a crane-like application to lift suspended load certification 2) Load testing 3) Yearly, monthly and daily inspection logs 4) Rope/sling certifications 5) Operator certifications/designations 6) Designation of person performing log inspections 7) Cranes that are permanently located on a Navy Installation shall have a quarterly joint verification.
2.9.4.1	Crane Inspections	The Contractor shall ensure all inspections are performed in accordance with EM 385-1-1, NAVFAC P-307, 29 CFR Part 1910, and 29 CFR Part 1926 (daily, monthly, quarterly, yearly), and retain the current documentation of inspections. Documents shall be kept on site. Daily pre-use inspections and testing shall be performed on all load hoisting and lowering mechanisms, boom hoisting and lowering mechanisms, swinging mechanisms, travel mechanisms (if to be used that day), and safety devices. Cranes that have to be re-rated shall be in accordance with SAE

0200000 - Management and Administration		
Spec Item	Title	Description
		Recommended Practices, Crane Load Stability Test Code J765 and documentation maintained on site. The Contractor shall have an operational anti-two block device or a two-block damage prevention feature for all points of two blocking and a boom hoist disconnect, shutoff, or hydraulic relief to automatically stop the boom hoist when the boom reaches a predetermined high angle.
2.9.4.2	Rigging Gear	The Contractor shall ensure rigging gear and below the hook lifting devices and personnel comply with the following requirements: 1) Personnel performing rigging shall have an understanding of all signs, notices, and operating instructions, and be familiar with the applicable hand signals prescribed by the ASME B30 standard for the type of crane in use. 2) Personnel performing rigging shall be familiar with the rigging requirements in EM 385-1-1, NAVFAC P-307, 29 CFR Part 1910, and 29 CFR Part 1926. 3) The Contractor shall inspect rigging gear in accordance with EM 385-1-1, NAVFAC P-307, 29 CFR Part 1910, and 29 CFR Part 1926 and paragraph 1.7.2 of NAVFAC P-307. Certification records shall be made available for review upon request.
2.9.4.3	Crane Operators	Crane operators shall meet the personnel qualifications requirements in paragraph 16.B of EM 385-1-1 and paragraph 1.7.2 of NAVFAC P-307. For mobile cranes with Original Equipment Manufacturer (OEM) rated capacities of 2,000 pounds or greater, designate crane operators as qualified by a source that qualifies crane operators (i.e., union, a government agency, or an organization that tests and qualifies crane operators).
2.9.5	Accident and Damage Reporting	The Contractor shall notify the Contracting Officer as soon as practical, but no more than four hours after any accident meeting the definition of Recordable Injuries or Illnesses or High Visibility Accidents, property damage equal to or greater than \$2,000, or any Weight Handling Equipment (WHE) accident. Notification shall also be provided for any mishap occurring in any of the following high hazard areas: electrical (to include Arc Flash, electrical shock, etc.); uncontrolled release of hazardous energy (includes electrical and non-electrical); weight or load handling equipment (LHE) or rigging; fall-from-height (any level other than same surface); and underwater diving. These mishaps shall be investigated in depth to identify all causes and to recommend hazard control measures. Within notification include Contractor name; contract title; type of contract; name of activity, installation or location where accident occurred; date and time of accident; names of personnel injured; extent of property damage, if any; extent of injury, if known, and brief description of accident (to include type of equipment used, PPE used, etc.). Preserve the conditions and evidence on the accident site until the Government investigation team arrives on-site and Government investigation is conducted. The Contractor shall conduct an accident investigation for recordable injuries and illnesses, for accidents requiring Medical Treatment, property damage accidents resulting in at least \$20,000 in damages, and near misses as defined in EM 385-1-1, to establish the root cause(s) of the accident. The Contractor shall complete the applicable NAVFAC Contractor Incident Reporting System (CIRS), and electronically submit via the NAVFAC Enterprise Safety Applications Management System (ESAMS) per Section F. Required or special forms are provided within the Forms in (J-0200000-05-1). For any weight handling equipment accident (including rigging gear accidents) the Contractor shall conduct an accident investigation to establish

0200000 - Management and Administration		
Spec Item	Title	Description
		the root cause(s) of the accident and comply with additional requirements and procedures for accidents in accordance with NAVFAC P-307, Section 12. The Contractor shall submit a WHE Accident Report (Crane and Rigging Gear) per Section F. No crane operations are allowed to proceed until cause is determined and corrective actions have been implemented to the satisfaction of the Contracting Officer. For a near miss, the Contractor shall complete the applicable documentation in NAVFAC Contractor Incident Reporting System (CIRS), and electronically submit via the NAVFAC Enterprise Safety Applications Management System (ESAMS) per Section F. For a near miss involving crane or rigging operations, the Contractor shall report verbally to the Contracting Officer as soon as management becomes aware but not later than 4 hours of such event and comply with additional requirements and procedures for near-misses in accordance with NAVFAC P-307, Section 12. A near miss occurs when an accident was avoided by mere chance or when intervention prevented an ongoing sequence of events that would have resulted in an accident (e.g. unplanned encroachment, improper crane set-up, improperly rigged load, etc.). The Contractor shall submit a Crane and Rigging Gear Near Miss Report per Section F.
2.9.5.1	Accident Reporting and Notification Criteria	The following criteria and definitions apply to the accident reporting requirements specified above: Recordable Injuries or Illnesses. Any work-related injury or illness that results in: 1) Death, regardless of the time between the injury and death, or the length of the illness; 2) Days away from work (any time lost after day of injury/illness onset); 3) Restricted work; 4) Transfer to another job; 5) Medical treatment beyond first aid; 6) Loss of consciousness; or 7) A significant injury or illness diagnosed by a physician or other licensed health care professional, even if it did not result in (1) through (6) above. High Visibility Accident. Any mishap which may generate publicity or high visibility. Medical Treatment. Treatment administered by a physician or by registered professional personnel under the standing orders of a physician. Medical treatment does not include first aid treatment even through provided by a physician or registered personnel. WHE Accident. A WHE accident occurs when any one or more of the eight elements in the operating envelope fails to perform correctly during operation, including operation during maintenance or testing resulting in personnel injury or death; material or equipment damage; dropped load; derailment; two-blocking; overload; or collision, including unplanned contact between the load, crane, or other objects. A dropped load, derailment, two-blocking, overload and collision are considered accidents even though no material damage or injury occurs. A component failure (e.g., motor burnout,

0200000 - Management and Administration		
Spec Item	Title	Description
		gear tooth failure, bearing failure) is not considered an accident solely due to material or equipment damage unless the component failure results in damage to other components (e.g., dropped boom, dropped load, roll over, etc.) The Motor Vehicle Accident Report form is provided within the Forms in (J-0200000-05-2) .
2.9.6	Fire Protection	The Contractor shall know where fire alarms are located and how to activate them. The Contractor shall handle and store all combustible supplies, materials, waste and trash in a manner that prevents fire or hazards to persons, facilities, and materials.
2.9.7	Monthly On-Site Labor Report	The Contractor shall submit a Monthly On-Site Labor Report per Section F. This report is a compilation of employee-hours worked each month for all site workers, both prime and subcontractor.
2.9.8	OSHA Citations and Violations	The Contractor shall correct violations and citations promptly and submit a copy of each OSHA citation and OSHA report with written OSHA Citations and Violations Corrective Action Report per Section F.
2.9.9	Safety Inspections and Monitoring	The Contractor shall conduct inspections of its work areas, job sites, and work crews every day work is being performed to ensure that all Contractor operations are being conducted safely. These inspections shall ensure: The site is safe and free of job-site hazards • Proper PPE is being utilized and worn. • Safe work practices and processes are being followed. • Workers are familiar with the hazards covered in the respective AHA for that work activity. • All equipment and tools are in good condition and being used safely. The Government reserves the right to inspect and monitor Contractor operations for safety compliance. In general, the Government approach will be to conduct Performance Assessment on the quality and effectiveness of the Contractor's safety program. The Government reserves the right to stop any work activity when it deems danger is imminent. Contractor personnel shall work in a safe manner and comply with all applicable safety regulations. The Contractor shall be subject to safety inspections of its work sites by the Government. Contractor safety records shall be available to the KO upon request. Whenever the KO becomes aware of any safety noncompliance or any condition which poses a serious or imminent danger or hazard to the health or safety of the public or Government Personnel, the KO will notify the Contractor orally, with written confirmation, and request immediate corrective action. This notice, when delivered to the Contractor's representative or SSHO, shall be deemed sufficient notice of noncompliance and that corrective action is required. After receiving this notice, the Contractor shall immediately take corrective action. If the Contractor fails, delays, or refuses to promptly take corrective action, the KO may issue a stop work order for all or part of the services or work until satisfactory corrective action has been taken. Whenever such a stop work order has been issued, the Contractor shall waive all equitable adjustments to the contract related to the stop work ordered issued. The Contractor shall include this requirement in all of its subcontracts and vendor contracts in support of contract safety.
2.9.10	Safety Certification	The Contractor shall submit copies of all the required Federal, state, county, city and industry Safety Certifications for work performed under this contract per Section F. These certifications shall be kept up to date by the Contractor. The Contractor shall submit new versions of certifications as the old

0200000 - Management and Administration		
Spec Item	Title	Description
		certifications expire. No work, that requires a certification, shall start without a valid and approved certification.
2.9.11	Safety Apparel on Jobsites	The Contractor personnel shall wear appropriate high-visibility safety apparel (garment, vest, or harness of retro-reflective and fluorescent material) meeting ANSI/ISEA 107-2010 requirements. Appropriate garment shall be based on the worker hazards and tasks, complexity of the work environment or background, and vehicular traffic and speed. As a minimum, the Contractor personnel shall wear ANSI/ISEA 107-2010 Class I compliant apparel.
2.9.12	Emergency Medical Treatment	Contractor will arrange for their own emergency medical treatment. The Government has no responsibility to provide emergency medical treatment.
2.9.13	Excavations	Soil classification must be performed by a competent person in accordance with 29 CFR 1926 and EM 385-1-1. The Contractor shall provide a third party, independent, private utility locating company to positively identify underground utilities in the work area in addition to any station locating service and coordinated with the station utility department. The Contractor shall physically verify underground utility locations, including utility depth, by hand digging using wood or fiberglass handled tools when any adjacent work is expected to come within 3 feet of the underground system. Utilities located within and under concrete slabs or pier structures, bridges, parking areas, and the like, are extremely difficult to identify. Whenever contract work involves chipping, saw cutting, or core drilling through concrete, bituminous asphalt or other impervious surfaces, the existing utility location shall be coordinated with station utility departments in addition to location and depth verification by a third party, independent, private locating company. The third party, independent, private locating company must locate utility depth by use of Ground Penetrating Radar (GPR), X-ray, bore scope, or ultrasound prior to the start of work. Outages to isolate utility systems must be used in circumstances where utilities are unable to be positively identified. The use of historical drawings does not alleviate the Contractor from meeting this requirement.
2.10	Environmental Management and Sustainability	The Contractor shall perform work under this contract consistent with the following Environmental Management System (EMS) goals and policy. Goals: • Reduce purchase and use of toxic and hazardous materials; • Expand purchase of green products and services; increase recycling; • Reduce energy and water use; • Increase use of alternative fuels and renewable energy; • Integrate green building concepts in major renovations and new construction; • Prevent pollution at the source; and • Continual improvement. Policy: • Protect public health and the environment by being an environmentally responsible member of the community; • Preserve our natural, historic and cultural resources;

0200000 - Management and Administration		
Spec Item	Title	Description
		• Conserve natural resources by reducing what we discard, reusing items, and recycling materials, which includes purchasing products made from recycled materials; • Integrate sound environmental practices into all our operations and business decisions; Integrate environmental protection requirements and pollution prevention initiatives into the early planning, design and procurement of facilities, equipment and material, as well as the planning and implementation of military training activities; • Prevent or minimize pollution at its source as we seek out ways to eliminate or further minimize use of hazardous materials and generation of hazardous waste; • Maintain a sound partnership with regulatory agencies to sustain our compliance with existing and new environmental laws and regulations; • Enhance our program as we develop and implement an Environmental Management System; and • Adhere to this policy, remind one another to do so, and ensure that our entire community knows this is our policy by our actions as well as our words. The Contractor shall maintain monitoring and measurement information to address the EMS goals and policy and provide the EMS Goals and Policy Measurement Information to the KO when requested. In the event an EMS nonconformance or environmental noncompliance associated with the contracted services, tasks, or actions occurs, the Contractor shall take corrective and/or preventative actions, assume legal and financial liability for the noncompliance and take corrective action immediately to remedy the noncompliance. The Contractor shall ensure that its employees are aware of their roles and responsibilities under the EMS and how these EMS roles and responsibilities affect work performed under the contract.
2.10.1	Energy Management Program	The Contractor PM, or designee, shall represent the Contractor's interest at all meetings of the activity's Energy Management Board. The Contractor shall attend periodic meetings with the Installation Energy Manager, where energy and water efficiency goals and project status will be discussed to ensure that any Contractor work complements and optimizes efficiency efforts.
2.10.1.1	Water Conservation Plan	The Contractor shall develop, submit and implement a Water Conservation Plan per Section F.
2.10.1.2	Energy Efficient Products	The Contractor shall use life-cycle cost analysis in making decisions about investments in products, services, construction and other projects to lower Federal Government's costs and reduce energy consumption. The Contractor shall elect lifecycle cost effective Energy Star and other energy-efficient products when acquiring energy-using products. For product groups where Energy Star labels are not yet available, select products that are in upper 25 percent of energy efficiency as designated by the Federal Energy Management Program. Use of high energy consuming tools or equipment is subject to approval by the KO prior to use.
2.10.2	Environmental Protection	The Contractor shall comply with all applicable Federal, state, and local laws, regulations, and executive orders, and with base-wide instructions, standards, and permit requirements. All environmental protection matters shall be coordinated with the KO. Inspection of any of the facilities operated by the Contractor may be accomplished by the Installation Environmental Protection

0200000 - Management and Administration		
Spec Item	Title	Description
		Coordinator, or authorized officials on a no-notice basis during Government regular working hours. The Contractor shall comply with the instructions of the cognizant Navy Medical Department with respect to avoidance of conditions which create a nuisance or which may be hazardous to the health of military or civilian personnel. The Contractor is responsible for ensuring that its employees receive applicable environmental and occupational health and safety training, and are kept up to date on regulatory required specific training for the type of work to be conducted onsite. All on-site Contractor personnel, and their subcontractor personnel, performing tasks that have the potential to cause a significant environmental impact shall be competent on the basis of appropriate education, training or experience.
2.10.2.1	Sampling, Testing and Laboratory Services	N/A to this contract.
2.10.2.2	ODS Requirements for Refrigerant Recycling	N/A to this contract.
2.10.2.3	Solid Waste Management and Recycling	N/A to this contract.
2.10.2.4	Non-Regulated Waste Disposal	N/A to this contract.
2.10.2.5	Regulated Waste Disposal	N/A to this contract.
2.10.2.6	Universal Waste	N/A to this contract.
2.10.2.7	Spill Prevention, Containment, and Clean-up	The Contractor shall prevent, contain, clean up, and report all spills on Government property caused by the Contractor, in a manner that complies with applicable Federal, state, and local laws and regulations and with the Installation Spill Control Plan provided in (J-0200000-05-3) at no additional cost to the Government.
2.10.2.8	Hazardous Material Management	The Contractor shall support the Consolidated Hazardous Material Reutilization and Inventory Management Program (CHRIMP). The Contractor shall submit an Emergency Planning and Community Right to Know Act (EPCRA) Report and Contractor Hazardous Material Inventory Log per Section F following the format provided in (J-0200000-05-4). The Contractor shall receive approval from the KO prior to bringing hazardous material on Government Property or prior to any other use in conjunction with this contract. For approval to use any hazardous material, allow a minimum of 10 working days for processing the request. The Contractor shall post Safety Data Sheets (SDS) at the worksite where the products are being used. Should the Government determine that a chemical the Contractor will use needs to be tracked, the Government may direct the Contractor to submit additional information in order to fulfill reporting requirements. The Contractor shall ensure that procedures are in place to deal with hazardous materials, pursuant to the FAR Clause 52.223-3, HAZARDOUS MATERIAL IDENTIFICATION AND MATERIAL SAFETY DATA. Notwithstanding any other hazardous material used in this contract, radioactive materials or instruments capable of producing ionizing/non-

0200000 - Management and Administration		
Spec Item	Title	Description
		ionizing radiation (with the exception of radioactive material and devices used in accordance with EM 385-1-1 such as nuclear density meters for compaction testing and laboratory equipment with radioactive sources) as well as materials which contain asbestos, mercury or polychlorinated biphenyls, di-isocyanates, lead-based paint are prohibited. The Contracting Officer, upon written request by the Contractor, may consider exceptions to the use of any of the above excluded materials. Low mercury lamps used within fluorescent lighting fixtures are allowed as an exception without further Contracting Officer approval. Notify the Radiation Safety Officer (RSO) prior to excepted items of radioactive material and devices being brought on base.
2.10.2.9	Protection of Endangered and Threatened Species (Flora and Fauna)	The Contractor shall not disturb endangered and threatened species and their habitat. The Contractor shall carefully protect in-place and report immediately to the KO endangered and threatened species discovered in the course of work. The Contractor shall stop work in the immediate area of the discovery until directed by the KO to resume work.
2.10.2.10	Noise Control	The Contractor shall comply with all applicable Federal, state and local laws, ordinances, and regulations relative to noise control.
2.10.2.11	Salvage	N/A to this contract.
2.10.2.12	Asbestos Containing Material (ACM)	Asbestos containing insulation, flooring, and other building materials may be encountered by the Contractor during the performance of work under this contract, and the Contractor shall remain alert to this possibility. If ACM is encountered or suspected in the performance of work, the Contractor shall avoid removing, sanding, abrading, or disturbing the material. The Contractor shall verbally notify the KO within one hour and submit a written ACM Notification within 24 hours per Section F.
2.10.2.13	Clean Air Act (CAA)	N/A to this contract.
2.10.3	Sustainable Procurement and Practices	The Contractor shall develop, submit, and implement a Sustainable Procurement and Practices Plan per Section F. This plan shall identify how the Contractor will comply with all applicable Federal, state and local laws and regulation, including E.O. 13423, E.O. 13514, Installation Energy Management Program and Water Conservation Programs and energy reduction requirements. The plan shall specifically address the following components: • Recycled Contents Products • Energy/Water efficiency • Energy Efficient Tools and Equipment • Alternate Fuels and Alternate Fuel Vehicles • Biobased Products • Non-Ozone Depleting Products • Environmental Preferred Products and Services • Low/Non-Toxic and Hazardous Materials The Contractor shall submit an annual Sustainable Delivery of Services Report per Section F.
2.10.3.1	Environmentally Preferable Products	The Contractor shall procure and use products that are energy-efficient (Energy Star or Federal Energy Management Program (FEMP)-designated), water efficient, bio-based, environmentally preferable (e.g., Electronic Product Environmental Assessment Tool (EPEAT)-registered), non-ozone depleting, contain recycled content, or are non-toxic or less toxic alternatives, where such products and services meet performance requirements.

0200000 - Management and Administration		
Spec Item	Title	Description
2.10.3.2	Use of Recovered Materials	The Government has an affirmative procurement program to promote the purchase of products containing recovered materials. The intent is to reduce the solid waste stream and conserve natural resources by establishing markets for recycled content products and encouraging manufacturers to produce quality products containing recovered materials. Participate in this program by using, for Environmental Protection Agency (EPA) designated items, recovered materials to the maximum extent practicable without jeopardizing the intended end use of the item. The percentage of recovered materials content levels for use in the performance of this contract will be, at a minimum, the amount recommended in the EPA Comprehensive Procurement Guideline (CPG) Product Index website (http://www.epa.gov/epawaste/conserve/tools/cpg/index.htm). Use of EPA designated products is not required for products that are either not available within a reasonable period of time, are not available at a reasonable price, are not available from a sufficient number of sources to maintain a satisfactory level of competition, or fail to meet performance standards based on technical verification. EPA designation of products is an on-going process. Listings of EPA designated products containing recovered materials are found in 40 CFR 247. Make recommendation and submit Recovered Material Certification, per Section F, when a product containing recovered materials is equal to or better than the original and could be used for this contract. All changes of products must be accepted by the KO before it is used.
2.10.3.3	Use of Biobased Products	The Contractor shall make maximum use of biobased products in accordance with the FAR Clause 52.223-2 -- Affirmative Procurement of BIOBASED Products Under Service And Construction Contracts. Information about these products is available at http://www.usda.gov/biopreferred .
2.11	Disaster Preparedness	The Contractor shall comply with the installation's Contingency Instruction contingency response plan. The Contractor shall support the installation contingency response plan as directed by the KO.
2.12	Technical Library	N/A to this contract.
2.13	Warranty Management	Prior to performing repair work, the Contractor shall report to the KO any defect in workmanship, material, or parts, and any improper installation of equipment and components that are covered by a warranty. The Contractor is responsible for knowing which equipment and components are covered by the original warranty and the warranty duration. The KO will provide available warranty documents.
2.14	Recurring Work Procedures	
2.14.1	Notification to the Government for Work Above the Recurring Work Limitations	The Contractor is fully responsible for work up to the recurring work limits. Recurring work limits are specified in subsequent annexes or sub-annexes. When work is expected to exceed the recurring work limits, the Contractor shall notify the KO within two hours of identification for further direction. The Government may issue a task order in accordance with the non-recurring work portion of the contract detailed below or accomplish the work by means other than this contract.
2.14.2	Recurring Work Exhibit Line Item Numbers (ELINS)	Recurring work ELINS are provided in (J-0200000-06) .
2.15	Non-recurring Work	Non-recurring work is identified in each applicable annex or sub-annex. Non-recurring work may consist of Unit Priced Task (UPT) Work (non-negotiated) and Unit Priced Labor (UPL) Work (negotiated). The Contractor

0200000 - Management and Administration		
Spec Item	Title	Description
		shall perform all non-recurring task work as ordered by the KO per Section G and DoD FedMall requirements in Section H. Non-recurring work will consist of Unit Priced Tasks and Unit Priced Labor Work which may be ordered by the Government as separate items or in combinations of items from the Non-recurring Work Exhibit Line Items (ELINs) provided in Section J on an as needed basis.
2.15.1	Unit Priced Task (UPT) Work (Non-Negotiated)	A UPT is defined as a non-recurring work item that includes all direct and indirect costs plus profit associated with the particular unit of work. All materials and equipment (rented, leased or Contractor-owned) required for the accomplishment of a UPT shall be included within the respective exhibit line item prices. The fixed price for the task order is determined by multiplying the exhibit line item unit prices by the quantities ordered. The Contractor is not required to submit cost estimates for UPTs.
2.15.1.1	Acceptance and Performance	The Contractor shall possess the capability to accept and perform non-recurring work via an electronic medium with supported commands utilizing their Government Purchase Card (GPC). DoD FedMall is the electronic medium for authorized Government personnel to place orders for service to the Contractor. DoD FedMall is located at: http://www.dla.mil/Info/FedMall/ under NAVFAC contract. The Contractor shall submit a report of all non-recurring work quantities ordered via FedMall monthly per Section F.
2.15.1.2	Invoicing and Receiving Payment	Payment for completed FedMall orders will be made using the GPC. Reference "payment by third party" clause FAR 52.232-36. The Contractor shall possess the capability to invoice and receive payment for non-recurring work via an electronic medium with supported command representatives utilizing their GPC. No partial or advance payments will be provided.
2.15.2	Unit Priced Labor (UPL) Work (Negotiated)	The Contractor shall perform all UPL work in accordance with the scope and delivery schedule negotiated per each task order. UPL work is defined as non-recurring work that utilizes negotiated labor hours and materials to accomplish a task not required by the recurring work portion of the contract. UPL includes separately priced labor, material, and equipment exhibit line items. The Contractor shall prepare and furnish a detailed cost estimate identifying proposed labor, material, and equipment costs, which upon approval by the KO, becomes the fixed price for the task order.
2.15.2.1	Non-recurring Work Preparation of Proposals	In response to the Government's Request for Proposal (RFP), the Contractor shall submit a non-recurring work proposal to the KO, per Section F, within two working days following receipt for each potential task order which includes: 1) a complete list of all tasks necessary to perform the required scope of work, 2) the number of direct labor hours to perform each task and 3) the projected quantity and costs of materials and equipment to perform the required scope of work.
2.15.2.1.1	Labor Requirements	Accepted industry time standards published in R. S. Means cost data, industry organizations, and similar estimating sources shall be used for determining the number of direct labor hours required to complete the scope of work. The total labor cost will be determined by totaling the number of direct labor hours and then multiplying by the UPL amount in the Non-recurring Work Exhibit Line Items (ELINs) provided in Section J.
2.15.2.1.2	Material and Equipment Requirements	Accepted industry and Government material and equipment costs published in R. S. Means cost data, national material supplier catalogues, U.S. Army Corps of Engineers Construction Equipment Ownership and Operating Expense Schedule (EP 1110-1-8), equipment rental catalogues, and similar estimating sources shall be used for determining customary and reasonable costs for the material and equipment estimate. Projected material requirements shall include a list of materials establishing the size, quality,

0200000 - Management and Administration		
Spec Item	Title	Description
		number of units, and unit prices. Pre-expended bin supplies and materials shall not be included in the list of materials since the cost for these items are to be included in the labor hour unit price. Material prices shall be the lowest price available considering the availability of materials and the time constraints of the job. The direct material price shall include all discounts and rebates for core value and salvage value that accrue to the Contractor and Contractor-furnished warehousing cost. Equipment costs shall include rental and lease costs, ownership costs where Contractor-owned, equipment mobilization, and tools, not priced under the recurring work portion of the contract. The direct material price will be multiplied by the Contractor's non-recurring work material fixed burden rate.
2.15.2.2	Issuance of Final Task Order	The KO will order unit priced labor by issuing to the Contractor a copy of the approved scope of work and a task order for the work described, in accordance with Section G. Task order completion times will be specified on each task order.
2.15.3	Non-recurring work ELINS	Non-recurring Work ELINs are provided in (J-0200000-08) .

1502000 – Facility Investment Table of Content	
Spec Item	Title
1	General Information
1.1	Concept of Operations
2	Management and Administration
2.1	Definitions and Acronyms
2.2	Personnel
2.2.1	Certification, Training and Licensing.
2.3	Special Requirements
2.3.1	Workmanship and Material Standards
2.3.2	Historical Preservation
2.3.3	Contractor Qualifications
2.3.4	Management Requirements
2.3.5	Inspection Testing and Maintenance Requirements
2.3.6	Repair Work
2.3.6.1	Fire Alarm Systems
2.3.6.2	Water Based Suppression Systems
2.3.6.3	Special Hazard Systems
2.4	References and Technical Documents
3	FFP Work
3.1	Routine Integrated Maintenance Program (IMP)
3.1.1	Fire Protection Systems Annual Inspections
3.1.1.1	Provide Complete Inventory
3.1.1.2	Update Inventory as needed
3.1.2	Fire Protection Systems Periodic Inspection and Service.
4	IDIQ Work

1502000-Facility Investment																										
Spec Item	Title	Description																								
1	General Information	The Contractor shall provide all labor, management, supervision, tools, material, and equipment required to perform Facility Investment services for Facilities at MCB Camp Lejeune and MCAS New River, Jacksonville NC.																								
1.1	Concept of Operations	The intent of 1502000 Facility Investment is to specify the requirements for Sustainment, Restoration, and Modernization (SRM) sub-functions only. The Facility Investment requirements within this sub-annex primarily consist of infrastructure sustainment and minimal restoration and modernization work. Sustainment is the maintenance and repair necessary to keep an inventory of facilities and other assets in good working order. Restoration and modernization normally consists of major rehabilitation and capital improvements that is accomplished through other Navy programs. Some major repair, minor construction and stand-alone demolition may be accomplished as part of Facility Investment. The Contractor shall perform Preventative Maintenance (PM), Inspection, Testing, and Repair for the following: Building Systems: • Fire Protection ◆ Fire Alarm and Detection System • Conventional Systems • Addressable Systems ◆ Fire Suppression Systems • Wet Pipe Automatic Sprinkler Systems • Dry Pipe Automatic Sprinkler Systems • Pre-Action Automatic Sprinkler Systems • Clean Agent Fire Suppression Systems • Carbon Dioxide (CO2) Fire Suppression Systems • Fire and Smoke Barrier Opening Protection The above Preventative Maintenance, Inspection, Testing, and Repair shall be done on the following buildings: <table><tr><td>AS256</td><td>AS320</td></tr><tr><td>TC755</td><td>895</td></tr><tr><td>BB248</td><td>FC307</td></tr><tr><td>H1</td><td>HP5</td></tr><tr><td>M165</td><td>PP5</td></tr><tr><td>RR134</td><td>1043</td></tr><tr><td>WC99</td><td>WC507</td></tr><tr><td>24</td><td>835</td></tr><tr><td>855</td><td>883</td></tr><tr><td>2027</td><td>2028</td></tr><tr><td>PP201</td><td>TT84</td></tr><tr><td>AS990</td><td></td></tr></table>	AS256	AS320	TC755	895	BB248	FC307	H1	HP5	M165	PP5	RR134	1043	WC99	WC507	24	835	855	883	2027	2028	PP201	TT84	AS990	
AS256	AS320																									
TC755	895																									
BB248	FC307																									
H1	HP5																									
M165	PP5																									
RR134	1043																									
WC99	WC507																									
24	835																									
855	883																									
2027	2028																									
PP201	TT84																									
AS990																										
2	Management and Administration																									
2.1	Definitions and Acronyms	Definitions and Acronyms are listed in J-1502000-01																								
2.2	Personnel	The Contractor shall provide personnel with qualifications, technical knowledge, experience and skills required for efficient operations within the Fire Protection System Field.																								

1502000-Facility Investment		
Spec Item	Title	Description
2.2.1	Certification, Training, and Licensing	Specific certification and training requirements are addressed in Spec Item 2.3.3-2.3.5.
2.3	Special Requirements	
2.3.1	Workmanship and Material Standards	The Contractor shall be responsible for maintaining all facilities, systems, and equipment, identified in this technical sub-annex, to a standard that prevents deterioration beyond that which results from normal wear and tear and corrects deficiencies in a timely manner to assure full life expectancy of the facilities, systems, and equipment. Best commercial practices shall be applied in the performance of work. All work shall be completed per approved and accepted industry and equipment manufacturers' standards and shall comply with building and safety codes, applicable activity, local, state, and federal regulations, and other technical requirements identified within this technical sub-annex. Workmanship for maintenance and repair shall include all work necessary to complete facility and system restoration, including touch-up painting and operational checks. Upon completion of work, the Contractor shall ensure all facilities, systems, and equipment are free of missing components or defects which would affect the safety, appearance, or habitability of the facilities and structures or would prevent any electrical, mechanical, plumbing or structural system from functioning in accordance with design intent. Repairs shall be made in accordance with the manufacturers' specifications and guidelines, and standard building codes. The quality of repairs shall meet the applicable standards and shall prevent any malfunction reoccurrences caused by poor workmanship or other Contractor inadequacies. The quality of the repaired areas shall be fully compatible with adjacent surfaces or equipment. Except where otherwise specified, replacements shall match existing in dimensions, finish, color, design, and functionality and shall have an appearance similar to the original finished appearance with only minor unobjectionable deterioration resulting from normal use. The Contractor shall not allow debris to spread unnecessarily into adjacent areas nor accumulate in the work area. All such debris, excess material, and parts shall be cleaned up and removed at the completion of the job and at the end of each day work is in progress. Upon completion of work, any stains and other unsightly marks shall be removed.
2.3.2	Historical Preservation	Buildings and Facilities designated as historical sites shall be maintained in accordance with Federal, State, and Local Historical Policies and regulations.
2.3.3	Contractor Qualification	The Contractor shall, at a minimum, provide either in house or contracted staff that has the following: • NICET Level III certification in Fire Alarm Systems • NICET Level IV certification in Special Hazards Suppression Systems • NICET Level III certification in Water-Based Fire Protection System Layout • NICET Level III certification in Inspection and Testing of Water- Based Systems • Registered Fire Protection Engineer as defined in UFC 3-600-01
2.3.4	Management Requirements	The maintenance contract shall be managed by a qualified individual who is NICET Level III in Fire Alarm or Special Hazard Systems. The manager shall provide daily supervision over all contracted inspection, testing, and maintenance operations.

1502000-Facility Investment		
Spec Item	Title	Description
2.3.5	Inspection Testing and Maintenance Requirements	Inspection testing and maintenance (ITM) shall be performed by qualified individuals. The following certifications are required by at least one member of the crew performing the ITM tasks. <u>Fire Alarm Systems</u> Fire Alarm: NICET Level II certification in Fire Alarm Systems. Detection and releasing systems for Special Hazard Systems such as those found in computer server rooms: NICET Level II certification in Special Hazard Systems. <u>Water Based Suppression Systems</u> Wet Pipe and Dry Pipe Sprinklers: NICET Level II certification in Inspection and Testing of Water Based Systems. Pre-Action, Deluge, Foam and Antifreeze Systems: NICET Level III certification in Inspection and Testing of Water Based Systems. <u>Special Hazard Systems</u> Clean Agent, CO₂ and Combination Detection/Releasing Systems: NICET Level II certification in Special Hazard Systems.
2.3.6	Repair Work	All repair work that involves a direct component replacement may be accomplished by the ITM personnel meeting the requirements stated above for ITM tasks. Any repair work that is not a direct replacement and requires modification, design, engineering work, or that requires changes to system programming must follow the requirements outlined below for the type of work being performed. This repair work must be approved by a REGISTERED Fire Protection Engineer prior to beginning the work. The REGISTERED Fire Protection Engineer may require additional design or manufacturer documentation prior to approving repair work. Once completed, repairs shall be successfully tested in the presence of a REGISTERED Fire Protection Engineer or a representative designated by a REGISTERED Fire Protection Engineer. Acceptance testing of repair work shall follow the requirements of applicable NFPA criteria.
2.3.6.1	Fire Alarm Systems	Repair work on fire alarm systems that is not a direct replacement or that requires modifying the fire alarm panel software shall be approved by a REGISTERED Fire Protection Engineer and the KO prior to beginning the work. The work will then be performed by an individual with a NICET Level II certification in fire alarm systems and who is factory certified by the equipment manufacturer of the fire alarm control panel. All repair work shall be coordinated and reviewed by a person who is NICET Level III certified in fire alarm systems or a Registered Fire Protection Engineer.
2.3.6.2	Water Based Suppression Systems	Repair work shall be performed by a licensed plumber or licensed pipe fitter with NICET Level II certification in water based suppression systems layout or NICET Level III in Inspection and Testing of Water Based Systems. All repair work shall be coordinated and reviewed by a person who is NICET Level III certified in water based suppression systems layout or a Registered Fire Protection Engineer.
2.3.6.3	Special Hazard Systems	Repair work shall be performed by an individual with a NICET Level II certification in Special Hazards Suppression Systems and who is factory certified by the equipment manufacturer of the piece of equipment needing repair. All repair work shall be coordinated and reviewed by a person who is NICET level IV certified in special hazard systems or a Registered Fire Protection Engineer.

1502000 – Facility Investment		
Spec Item	Title	Description
2.4	References and Technical Documents	References and Technical Documents are listed in J-1502000-02.

1502000-Facility Investment				
Spec Item	Title	Performance Objective	Related Information	Performance Standard
3	FFP Work	The Contractor shall maintain, repair, test and inspect installed Fire Protection Equipment and systems to ensure its fully functional and in the normal Original Equipment Manufactory (OEM) working condition.	The Contractor shall develop, implement, and execute a routine Integrated Maintenance Program, (IMP) to maintain and repair installed Fire protection equipment and systems listed in the inventory attachment J-1502000-03. The Contractor shall provide Facility Support Contract (FSC) with a copy of all the maintenance, repair, and inspection data and warranty records and maintain all in a technical library.	Installed Fire protection equipment and systems are in normal working condition and function properly in accordance with OEM specified standards.
3.1	Routine Integrated Maintenance Program (IMP)	The Contractor shall develop and implement a routine IMP program that falls 6 months after the annual inspection for installed Fire Protection Equipment and systems to ensure its are safe, fully functional, and operational. This routine IMP shall be based on all requirements in the most current version of UFC 3-601-02 and the OEM requirements of each brand named system and on the inventory located in attachment J-1502000-03.	The Contractor shall develop and submit a routine IMP per Section F based on the inventory in attachment J-1502000-03. The routine IMP shall include the Contractor's approach for integrated maintenance, including maintenance and inspection tasks, schedules for planned work accomplishment, plan for minimizing occurrence of repair and downtime, process for the identification of the need for repairs, and the process for scheduling and completing repair work. As a part of the routine IMP the Contractor has full responsibility for any individual occurrence of repairs up to \$250 per part and \$2,500 per system in direct material and labor cost for repairs and or replacement. Repairs or replacements which are caused by the improper action(s) or inactions(s) of the base personnel, other Contractors, Acts of God, Lightning strikes or vandalism which could result in incidents such as a CO2, or any other special gas dumps or Fire alarm System failures will not be the responsibility of the Contractor	Routine Maintenance is performed in accordance with Contractor's IMP and work schedule. When a problem or a need for repair is identified, the Contractor shall respond within 3-5 calendar days and complete the repair within 21 calendar days. Systems and equipment are maintained and repaired to sustain a fully functional and operable condition in accordance with OEM specifications. When repair is complete the facility, system, or equipment does not present any hazard or danger to personnel.

1502000-Facility Investment				
Spec Item	Title	Performance Objective	Related Information	Performance Standard
			or be part of the IMP. The Contractor shall notify the KO upon identification that the repair will exceed the limit of liability listed above. If the estimated cost of the repair exceeds the FFP Liability Limit, the Government may order the work under the IDIQ section of this contract; however, the Government will only be liable for the amount of the cost that exceeding the FFP Liability limit. The Contractor shall perform all the repairs, whether identified as part of their routine IMP accomplishment, QC inspections, or notification from the Government that a breakdown or malfunction has occurred. If the Government identifies a problem or a need for a repair, the Government will contact the Contractors work reception desk. Service orders will not be issued for accomplishment of repairs on systems and equipment under routine IMP. The Contractor shall submit a monthly IMP schedule and IMP maintenance and repair status report per Section F.	
3.1.1	Fire Protection Systems Annual Inspections	The Contractor shall within 4 months of award of the contract (or as soon as possible thereafter) complete an Annual inspection of all fire protection systems, fire alarm systems and components covered under this contract supplied in Attachment J-1502000-03. The Contractor shall accept into the Routine	All systems found to meet OEM standards for operation will become the responsibility of the Contractor and shall be maintained for the duration of the contract in accordance with the routine IMP, the routine IMP repair limit, and the terms of this contract. All systems found to be in operational condition but needing minor repairs shall be accepted into the routine IMP by the Contractor exclusive of those	Contractor provides inspection and acceptance report in a timely manner. Contractor provides repair and modification list including cost estimate for each system need repair.

1502000-Facility Investment				
Spec Item	Title	Performance Objective	Related Information	Performance Standard
		IMP all systems found to be operable and that meet OEM specifications. The Contractor shall provide a complete list of repairs / modifications required before the system can be accepted into the Contractors routine IMP program. Each report shall be complete with cost estimate for repairs suggested by the Contractor. Submit Per section F.	minor repairs reported to the Contracting officer. When the minor repairs have been completed they will also be part of the routine IMP. Fire protection systems that are operable but otherwise do not meet current fire protection standards (because of change of building use or because of the system age) shall be accepted into the routine IMP. In these cases the Contractor will bear no responsibility for up-grade of the systems, and will only be required to maintain the systems in its current condition of operation. As noted in the inspection report to the Contracting Officer. Systems that are non-operable due to needed repairs / modifications shall be accepted into the routine IMP as soon as repairs / modifications have been completed. The Government at its sole discretion will have the option to have all repairs / modification completed through this contract, through other government contracts, or through Government forces. The Government may also choose to not have repairs / modifications completed and to withdraw any effected system from this contract. The Contractor shall place inspection tags on all systems identifying when the inspection was completed and when the next one is due.	

1502000-Facility Investment				
Spec Item	Title	Performance Objective	Related Information	Performance Standard
3.1.1.1	Provide Complete Inventory Base Year Only	As each system is tested the Contractor shall record a complete inventory of each system by building and providing a copy of that information to the Contracting Officer, and FSC.	The inventory shall provide all available information on each system inspected to include but not be limited to: Building number, System location, System type, System manufacturer, number of sprinkler heads, number of pull stations, number of detectors, number of alarm bells or type of notification, chemical used, cylinder size and number of cylinders.	System inventory is recorded and provided to Contracting officer. Per section F
3.1.1.2	Update Inventory as needed	The Contractor shall maintain a complete inventory of all systems on contract and update that inventory as individual units are repaired, replaced, updated, or deleted / removed. Provide to Contracting officer as needed.	The inventory format is to be approved and/or provided by the Contracting Officer prior to final submission.	Inventory is maintained current and updated as changes are made. Per Section F
3.1.2	Fire Protection Systems periodic inspection and service	Within the IMP the Contractor shall be responsible for: Tracking and executing all periodic service tasks as called for in UFC 3-601-02 up to required 5 year service tasks. Fire Protection Systems periodic inspection and service frequency as specified in UFC 3-601-02. If the Contractor becomes aware that a long term inspection or test is due they shall inform the Contracting Officer in a timely manner so those events can be ordered and completed in a timely manner to maintain system certification.	It shall be the Contractors responsibility to work with Government property managers to help identify when 5 year and beyond service events are due to be performed based on field records, Contractor records, and equipment age. When 5 year inspection / service and beyond is required the Government will order that work to be performed under the IDIQ portion of this contract.	All inspections, tests and services are completed within a timely manner and are done in accordance with the guiding documents. The Contracting Officer is informed of long term events that are due to be performed.

1502000-Facility Investment				
Spec Item	Title	Performance Objective	Related Information	Performance Standard
		Provide a list of required 5 year and beyond, inspections that need to be performed per section F.		

1502000-Facility Investment				
Spec Item	Title	Performance Objective	Related Information	Performance Standard
4	IDIQ Work	IDIQ work maybe ordered utilizing a Task order in accordance with the PROCEDURES FOR ISSUING ORDERS clause in section G. The order will specify the exact locations and types of work to be accomplished. The period of performance will be specified in each order.	Refer to IDIQ ELINs for task listings, descriptions and related requirements. All periods of performance are measured from issue date of order to acceptance of the work. Performance Standards for IDIQ work will be the same as those in Spec Item 3 where applicable.	

**ATTACHMENT J-0200000-01
DEFINITIONS AND ACRONYMS**

Definition	Description
Assessment	A general term referring to either a survey or inspection of a facility to determine condition.
Asset	A general term used to refer to an item, such as a component, system, building or facility, which is managed by an automated data management program.
Business Management System (BMS)	A web-based tool that provides a systematic method for the management of business processes, common practices, and process quality improvements that produce and support the most efficient and effective delivery of NAVFAC's products and services.
Competent Person	A person who has the professional experience and training necessary to identify existing and predictable hazards at a work or service environment, and who has the authority to take prompt and corrective action to eliminate or remove dangers from the environment.
Component Inventory Management Unit (CIMU)	An organization of like-kind real property into manageable maintenance units. CIMU is a building component, group of components or component assemblies, serving a specific purpose in a facility that can be expected to follow a common and predictable lifecycle behavior. This class of non-equipment will include items such as exterior walls, exterior windows, interior finish, and roofs. This class of equipment will include items such as fan coil units, air handling units, lighting, and water closets. CIMUs can include one or more items of installed equipment typically subject to routine scheduled maintenance.
Confined Work Space	A space that is large enough and so configured that a person may bodily enter a space (such as in tanks, vessels, silos, storage bins, hoppers, vaults, pits, and like spaces where there is limited means of entry) and is hindered or restricted from escaping during an emergency.
Contracting Officer (KO)	That individual with the authority to enter into, administer, and/or terminate contracts and make related determinations and findings. The term includes certain authorized representatives of the Contracting Officer acting within the limits of their authority as delegated by the Contracting Officer.
Contractor	That entity or its representative responsible for the delivery of the services or materials specified in this contract, as designated by contract award. The term Contractor as used herein refers to both the prime Contractor and any subcontractors. The prime Contractor shall insure that subcontractors comply with the provision of this contract.
Contractor Representative	That individual appointed by the Contractor, either orally or in writing, who has been assigned responsibility for executing the requirements of this contract.
Direct Material Costs	The actual vendor invoice charges for materials used for performance of work under this contract. Direct material costs shall include transportation charges when such charges are included on the invoice by the vendor, as well as any discounts allowed for prompt payment and discounts or rebates for core value or salvage value that accrue to the Contractor. When questions arise concerning the cost of materials, material costs will be based on the lowest of quotes provided by the Contractor from at least three different commercial vendors for the direct material cost. The Government retains the right to obtain additional quotes in questionable situations. The lowest price will be used.
Electronic Operation And Maintenance And Support Information (eOMSI)	A set of consultant-prepared data and document files that contain detailed, as-built technical information that describes the efficient, economical and safe operation, maintenance and repair of a facility, plant, equipment or system throughout its life cycle. Generally it is prepared during construction and submitted upon completion of a new facility or major facility upgrade. eOMSI's typically include asset information, staffing and budgeting information, supply support including critical spare parts, operating procedures, troubleshooting and diagnostic guides, extended warranty data, maintenance task frequencies and documentation, technical data, repair procedures and manufacturer's product data. eOMSI data and document files are provided in electronic formats.
Equipment	Tangible asset that is functionally complete for its intended purpose, durable, and non-expendable.
Facility	A building or structure designed and created to serve a particular function.

ATTACHMENT J-0200000-01
DEFINITIONS AND ACRONYMS

Definition	Description
Fixed Burden Rate (FBR)	The additional costs (expressed in percent of direct material cost) for ordering, handling, and stockpiling materials and repair parts. For example, if the offeror's Fixed Burden Rate for materials in the Base Period is 10% then: $\$100,000.00 + (\$100,000.00 \times 10\%) = \$110,000.00$ The Government will compensate the Contractor for the required parts and materials and not the total amount shown in Schedule of Indefinite Delivery Indefinite Quantity Work.
Frequency Of Service	Annual (A). Services performed once during each 12-month period of the contract at intervals of 335 to 395 days. Semiannual (SA). Services performed twice during each 12-month period of the contract at intervals of 160 to 200 calendar days. Monthly (M). Services performed once during each month period of the contract at intervals of 30 days.
Government Furnished Property (GFP)	Property in the possession of, or directly acquired by, the Government and subsequently furnished to the contractor for performance of a contract. Government furnished property includes, but is not limited to, spares and property furnished for repairs, maintenance, overhaul, or modification. Government furnished property also includes contractor acquired property if the contractor acquired property is a deliverable under a cost contract when accepted by the Government for continued use under the contract.
Infrastructure Condition Assessment Program (ICAP)	A Navy automated data management program that utilizes historical asset lifecycle data and a structured assessment process to evaluate the condition facilities and their components.
Inspection	A rigorous, detailed assessment of the condition of a facility performed to generate a fundable scope and cost estimate for prioritization and funding of maintenance and repair.
Job or Work Order	An authorization for work that requires planning and estimating and has an individual line of accounting for financial and performance evaluation.
Maintenance And Repair	The preservation or restoration of a piece of equipment, system, or facility to such condition that it may be effectively used for its designated purposes. Maintenance/repair may be adjustment, overhaul, reprocessing, or replacement of constituent parts or materials that are missing or have deteriorated by action of the elements or usage, or replacement of the entire unit or system if beyond economical repair.
USMC MAXIMO	A specially configured software version of MAXIMO®, a commercially available computerized maintenance management system (CMMS), adopted by NAVFAC for enterprise facility asset data management. The terms “MAXIMO”, “NAVFAC MAXIMO” or “Government’s MAXIMO” shall be used interchangeably in the document.
Performance Assessment	A method used by the Government to provide some measure of control over the quality of purchased goods and services received.
Performance Assessment Representative (PAR)	That individual designated by the KO to be responsible for the monitoring of Contractor performance.
Pre-Expended Bin Materials And Supplies	The minor materials and supplies that are incidental to the job, for which the total direct cost of any one material line item shown on the material estimate is \$10.00 or less. Examples of pre-expended bin materials and supplies include, but are not limited to, solder, lead, flux, electrical connectors, electrical tape, fuses, nails, screws, bolts, nuts, washers, spacers, masking tape, sand paper, solvent, cleaners, lubricants, grease, oil, rags, mops, glue, epoxy, spackling compound, joint tape, plumbers tape and compound, clips, welding rods, and touch up paint.
Property Administrator	An authorized representative of the Contracting Officer who is responsible for administering contract property requirements, terms and conditions of the contract

ATTACHMENT J-0200000-01
DEFINITIONS AND ACRONYMS

Definition	Description
Property Management Program	A Government program established for the purpose of reviewing and approving the Contractor's Property Management Plan and System through performance of a system analysis whenever government property is in the possession of the Contractor.
Quality Assurance (QA)	The planned and systematic activities implemented in a quality system so that quality requirements for a product or service will be fulfilled.
Quality Control (QC)	The observation techniques and activities used to fulfill requirements for quality.
R. S. Means	A data collection and organization system developed by R. S. Means Company which can be used to prepare accurate, dependable construction estimates and budgets in a variety of ways. The Contractor shall use the latest edition. Material prices are based on a national average and computed labor costs are based on a 30-city national average. An estimate prepared using this data is called a "Means estimate"; data may simply be referred to as "Means".
Real Property Inventory Equipment (RPIE)	A Government owned or leased individual pieces of equipment, apparatus, or fixture that are essential to the function of the real property (i.e. plumbing, electrical, heating, cooling and elevators). It is physically attached to, integrated into, and built in or on the property. Individual RPIE's can be combined to make a CIMU to facilitate facilities management. An individual RPIE can also be a CIMU if the equipment is complex enough to require its own management planning.
Response Time	The time allowed the Contractor after initial notification of a work requirement to be physically on the premises at the work site with appropriate personnel, tools, equipment, and materials, ready to perform the work required.
Unit Priced Labor (UPL) Hour	The unit price bid by the Contractor to perform one hour of work-in-place. With the exception of direct material and construction equipment costs, the unit price includes all indirect and direct costs associated with performing work. The price includes the Contractor's hourly composite trade wage, adjusted to allow for workforce productivity; costs for pre-expended bin materials, union agreements, crew sizes, hand tools, payroll burdens and fringes, overtime, job (field) overhead (including clerical support, supervision, inspection, fees, taxes, licenses, permits, and insurance), general and administrative (home office) overhead, and profit. Additionally, time for job preparation, safety standby personnel, and similar indirect labor elements are included.

Attachment J-0200000-02
WAGE DETERMINATION

"REGISTER OF WAGE DETERMINATIONS UNDER		U.S. DEPARTMENT OF LABOR
THE SERVICE CONTRACT ACT		EMPLOYMENT STANDARDS ADMINISTRATION
By direction of the Secretary of Labor		WAGE AND HOUR DIVISION
		WASHINGTON D.C. 20210
		Wage Determination No.: 2015-4389
Daniel W. Simms		Revision No.: 32
Director		Date Of Last Revision: 12/03/2025

State: North Carolina

Area: North Carolina County of Onslow

Fringe Benefits Required Follow the Occupational Listing

OCCUPATION CODE - TITLE	FOOTNOTE	RATE
01000 - Administrative Support And Clerical Occupations		
01011 - Accounting Clerk I		16.44
01012 - Accounting Clerk II		18.45
01013 - Accounting Clerk III		20.64
01020 - Administrative Assistant		28.91
01035 - Court Reporter		19.99
01041 - Customer Service Representative I		15.00
01042 - Customer Service Representative II		16.37
01043 - Customer Service Representative III		18.37

01051 - Data Entry Operator I	15.76
01052 - Data Entry Operator II	17.20
01060 - Dispatcher, Motor Vehicle	18.91
01070 - Document Preparation Clerk	15.92
01090 - Duplicating Machine Operator	15.92
01111 - General Clerk I	14.91
01112 - General Clerk II	16.27
01113 - General Clerk III	18.26
01120 - Housing Referral Assistant	22.28
01141 - Messenger Courier	12.97
01191 - Order Clerk I	14.59
01192 - Order Clerk II	15.92
01261 - Personnel Assistant (Employment) I	18.85
01262 - Personnel Assistant (Employment) II	21.09
01263 - Personnel Assistant (Employment) III	23.52
01270 - Production Control Clerk	22.78
01290 - Rental Clerk	16.36
01300 - Scheduler, Maintenance	17.87
01311 - Secretary I	17.87
01312 - Secretary II	19.99
01313 - Secretary III	22.28
01320 - Service Order Dispatcher	16.81
01410 - Supply Technician	28.91
01420 - Survey Worker	17.37
01460 - Switchboard Operator/Receptionist	14.23
01531 - Travel Clerk I	15.92
01532 - Travel Clerk II	17.87
01533 - Travel Clerk III	19.59
01611 - Word Processor I	15.92
01612 - Word Processor II	17.87
01613 - Word Processor III	19.99
05000 - Automotive Service Occupations	
05005 - Automobile Body Repairer, Fiberglass	22.41

05010 - Automotive Electrician	20.68
05040 - Automotive Glass Installer	19.35
05070 - Automotive Worker	19.35
05110 - Mobile Equipment Servicer	16.80
05130 - Motor Equipment Metal Mechanic	21.86
05160 - Motor Equipment Metal Worker	19.35
05190 - Motor Vehicle Mechanic	21.86
05220 - Motor Vehicle Mechanic Helper	15.25
05250 - Motor Vehicle Upholstery Worker	18.11
05280 - Motor Vehicle Wrecker	19.35
05310 - Painter, Automotive	20.68
05340 - Radiator Repair Specialist	19.35
05370 - Tire Repairer	16.54
05400 - Transmission Repair Specialist	21.86
07000 - Food Preparation And Service Occupations	
07010 - Baker	14.43
07041 - Cook I	16.09
07042 - Cook II	18.53
07070 - Dishwasher	11.89
07130 - Food Service Worker	13.30
07210 - Meat Cutter	19.02
07260 - Waiter/Waitress	10.25
09000 - Furniture Maintenance And Repair Occupations	
09010 - Electrostatic Spray Painter	23.90
09040 - Furniture Handler	14.34
09080 - Furniture Refinisher	23.90
09090 - Furniture Refinisher Helper	17.62
09110 - Furniture Repairer, Minor	20.92
09130 - Upholsterer	23.90
11000 - General Services And Support Occupations	
11030 - Cleaner, Vehicles	13.46
11060 - Elevator Operator	13.96
11090 - Gardener	22.90

11122 - Housekeeping Aide	13.96
11150 - Janitor	13.96
11210 - Laborer, Grounds Maintenance	16.92
11240 - Maid or Houseman	13.04
11260 - Pruner	15.04
11270 - Tractor Operator	20.79
11330 - Trail Maintenance Worker	16.92
11360 - Window Cleaner	15.71
12000 - Health Occupations	
12010 - Ambulance Driver	23.69
12011 - Breath Alcohol Technician	23.69
12012 - Certified Occupational Therapist Assistant	32.50
12015 - Certified Physical Therapist Assistant	28.05
12020 - Dental Assistant	22.11
12025 - Dental Hygienist	37.13
12030 - EKG Technician	35.88
12035 - Electroneurodiagnostic Technologist	35.88
12040 - Emergency Medical Technician	23.69
12071 - Licensed Practical Nurse I	21.18
12072 - Licensed Practical Nurse II	23.69
12073 - Licensed Practical Nurse III	26.40
12100 - Medical Assistant	17.34
12130 - Medical Laboratory Technician	23.06
12160 - Medical Record Clerk	21.22
12190 - Medical Record Technician	23.74
12195 - Medical Transcriptionist	21.18
12210 - Nuclear Medicine Technologist	52.05
12221 - Nursing Assistant I	13.17
12222 - Nursing Assistant II	14.81
12223 - Nursing Assistant III	16.16
12224 - Nursing Assistant IV	18.14
12235 - Optical Dispenser	25.37
12236 - Optical Technician	21.18

12250 - Pharmacy Technician	18.50
12280 - Phlebotomist	17.53
12305 - Radiologic Technologist	29.69
12311 - Registered Nurse I	25.30
12312 - Registered Nurse II	30.94
12313 - Registered Nurse II, Specialist	30.94
12314 - Registered Nurse III	37.43
12315 - Registered Nurse III, Anesthetist	37.43
12316 - Registered Nurse IV	44.88
12317 - Scheduler (Drug and Alcohol Testing)	29.34
12320 - Substance Abuse Treatment Counselor	24.20
13000 - Information And Arts Occupations	
13011 - Exhibits Specialist I	20.93
13012 - Exhibits Specialist II	25.93
13013 - Exhibits Specialist III	31.72
13041 - Illustrator I	20.93
13042 - Illustrator II	25.93
13043 - Illustrator III	31.72
13047 - Librarian	28.72
13050 - Library Aide/Clerk	16.67
13054 - Library Information Technology Systems Administrator	25.93
13058 - Library Technician	20.93
13061 - Media Specialist I	18.71
13062 - Media Specialist II	20.93
13063 - Media Specialist III	23.34
13071 - Photographer I	18.71
13072 - Photographer II	20.93
13073 - Photographer III	25.93
13074 - Photographer IV	31.72
13075 - Photographer V	38.38
13090 - Technical Order Library Clerk	20.93
13110 - Video Teleconference Technician	18.71

14000 - Information Technology Occupations		
14041 - Computer Operator I		17.07
14042 - Computer Operator II		19.09
14043 - Computer Operator III		21.28
14044 - Computer Operator IV		23.65
14045 - Computer Operator V		26.19
14071 - Computer Programmer I	(see 1)	22.75
14072 - Computer Programmer II	(see 1)	
14073 - Computer Programmer III	(see 1)	
14074 - Computer Programmer IV	(see 1)	
14101 - Computer Systems Analyst I	(see 1)	
14102 - Computer Systems Analyst II	(see 1)	
14103 - Computer Systems Analyst III	(see 1)	
14150 - Peripheral Equipment Operator		17.07
14160 - Personal Computer Support Technician		23.65
14170 - System Support Specialist		26.81
15000 - Instructional Occupations		
15010 - Aircrew Training Devices Instructor (Non-Rated)		34.32
15020 - Aircrew Training Devices Instructor (Rated)		41.53
15030 - Air Crew Training Devices Instructor (Pilot)		49.78
15050 - Computer Based Training Specialist / Instructor		34.32
15060 - Educational Technologist		32.76
15070 - Flight Instructor (Pilot)		49.78
15080 - Graphic Artist		28.64
15085 - Maintenance Test Pilot, Fixed, Jet/Prop		49.78
15086 - Maintenance Test Pilot, Rotary Wing		49.78
15088 - Non-Maintenance Test/Co-Pilot		49.78
15090 - Technical Instructor		24.56
15095 - Technical Instructor/Course Developer		30.04
15110 - Test Proctor		19.82
15120 - Tutor		19.82
16000 - Laundry, Dry-Cleaning, Pressing And Related Occupations		
16010 - Assembler		10.75

16030 - Counter Attendant	10.75
16040 - Dry Cleaner	13.39
16070 - Finisher, Flatwork, Machine	10.75
16090 - Presser, Hand	10.75
16110 - Presser, Machine, Drycleaning	10.75
16130 - Presser, Machine, Shirts	10.75
16160 - Presser, Machine, Wearing Apparel, Laundry	10.75
16190 - Sewing Machine Operator	14.29
16220 - Tailor	15.21
16250 - Washer, Machine	11.61
19000 - Machine Tool Operation And Repair Occupations	
19010 - Machine-Tool Operator (Tool Room)	25.99
19040 - Tool And Die Maker	31.90
21000 - Materials Handling And Packing Occupations	
21020 - Forklift Operator	17.05
21030 - Material Coordinator	23.63
21040 - Material Expediter	23.63
21050 - Material Handling Laborer	15.43
21071 - Order Filler	14.94
21080 - Production Line Worker (Food Processing)	17.05
21110 - Shipping Packer	17.54
21130 - Shipping/Receiving Clerk	17.54
21140 - Store Worker I	14.66
21150 - Stock Clerk	20.85
21210 - Tools And Parts Attendant	17.05
21410 - Warehouse Specialist	17.05
23000 - Mechanics And Maintenance And Repair Occupations	
23010 - Aerospace Structural Welder	32.10
23019 - Aircraft Logs and Records Technician	25.21
23021 - Aircraft Mechanic I	30.43
23022 - Aircraft Mechanic II	32.10
23023 - Aircraft Mechanic III	33.73
23040 - Aircraft Mechanic Helper	21.23

23050 - Aircraft, Painter	28.79
23060 - Aircraft Servicer	25.21
23070 - Aircraft Survival Flight Equipment Technician	28.79
23080 - Aircraft Worker	26.94
23091 - Aircrew Life Support Equipment (ALSE) Mechanic I	26.94
23092 - Aircrew Life Support Equipment (ALSE) Mechanic II	30.43
23110 - Appliance Mechanic	25.99
23120 - Bicycle Repairer	21.11
23125 - Cable Splicer	27.83
23130 - Carpenter, Maintenance	22.04
23140 - Carpet Layer	24.31
23160 - Electrician, Maintenance	25.20
23181 - Electronics Technician Maintenance I	27.85
23182 - Electronics Technician Maintenance II	29.77
23183 - Electronics Technician Maintenance III	31.47
23260 - Fabric Worker	22.75
23290 - Fire Alarm System Mechanic	27.47
23310 - Fire Extinguisher Repairer	21.11
23311 - Fuel Distribution System Mechanic	27.47
23312 - Fuel Distribution System Operator	21.11
23370 - General Maintenance Worker	19.43
23380 - Ground Support Equipment Mechanic	30.43
23381 - Ground Support Equipment Servicer	25.21
23382 - Ground Support Equipment Worker	26.94
23391 - Gunsmith I	21.11
23392 - Gunsmith II	24.31
23393 - Gunsmith III	27.47
23410 - Heating, Ventilation And Air-Conditioning Mechanic	23.12
23411 - Heating, Ventilation And Air Contidioning Mechanic (Research Facility)	24.39

23430 - Heavy Equipment Mechanic	30.15
23440 - Heavy Equipment Operator	23.29
23460 - Instrument Mechanic	27.47
23465 - Laboratory/Shelter Mechanic	25.99
23470 - Laborer	15.43
23510 - Locksmith	25.99
23530 - Machinery Maintenance Mechanic	28.98
23550 - Machinist, Maintenance	24.98
23580 - Maintenance Trades Helper	16.71
23591 - Metrology Technician I	27.47
23592 - Metrology Technician II	28.98
23593 - Metrology Technician III	30.44
23640 - Millwright	27.47
23710 - Office Appliance Repairer	25.99
23760 - Painter, Maintenance	20.57
23790 - Pipefitter, Maintenance	26.34
23810 - Plumber, Maintenance	24.92
23820 - Pneudraulic Systems Mechanic	27.47
23850 - Rigger	27.47
23870 - Scale Mechanic	24.31
23890 - Sheet-Metal Worker, Maintenance	25.48
23910 - Small Engine Mechanic	24.31
23931 - Telecommunications Mechanic I	30.42
23932 - Telecommunications Mechanic II	32.09
23950 - Telephone Lineman	29.06
23960 - Welder, Combination, Maintenance	24.93
23965 - Well Driller	27.47
23970 - Woodcraft Worker	27.47
23980 - Woodworker	21.11
24000 - Personal Needs Occupations	
24550 - Case Manager	18.96
24570 - Child Care Attendant	13.34
24580 - Child Care Center Clerk	16.63

24610 - Chore Aide	13.19
24620 - Family Readiness And Support Services Coordinator	18.22
24630 - Homemaker	18.22
25000 - Plant And System Operations Occupations	
25010 - Boiler Tender	30.69
25040 - Sewage Plant Operator	29.02
25070 - Stationary Engineer	30.69
25190 - Ventilation Equipment Tender	21.41
25210 - Water Treatment Plant Operator	29.02
27000 - Protective Service Occupations	
27004 - Alarm Monitor	18.43
27007 - Baggage Inspector	17.55
27008 - Corrections Officer	20.04
27010 - Court Security Officer	20.04
27030 - Detection Dog Handler	19.63
27040 - Detention Officer	20.04
27070 - Firefighter	21.66
27101 - Guard I	17.55
27102 - Guard II	19.63
27131 - Police Officer I	22.57
27132 - Police Officer II	25.08
28000 - Recreation Occupations	
28041 - Carnival Equipment Operator	16.53
28042 - Carnival Equipment Repairer	18.20
28043 - Carnival Worker	11.95
28210 - Gate Attendant/Gate Tender	17.72
28310 - Lifeguard	15.79
28350 - Park Attendant (Aide)	19.83
28510 - Recreation Aide/Health Facility Attendant	14.47
28515 - Recreation Specialist	24.56
28630 - Sports Official	15.79
28690 - Swimming Pool Operator	20.96

29000	- Stevedoring/Longshoremen Occupational Services	
29010	- Blocker And Bracer	24.31
29020	- Hatch Tender	24.31
29030	- Line Handler	24.31
29041	- Stevedore I	22.75
29042	- Stevedore II	25.99
30000	- Technical Occupations	
30010	- Air Traffic Control Specialist, Center (HF0) (see 2)	46.07
30011	- Air Traffic Control Specialist, Station (HF0) (see 2)	31.77
30012	- Air Traffic Control Specialist, Terminal (HF0) (see 2)	34.99
30021	- Archeological Technician I	18.48
30022	- Archeological Technician II	20.67
30023	- Archeological Technician III	25.61
30030	- Cartographic Technician	25.61
30040	- Civil Engineering Technician	25.43
30051	- Cryogenic Technician I	28.36
30052	- Cryogenic Technician II	31.32
30061	- Drafter/CAD Operator I	18.48
30062	- Drafter/CAD Operator II	20.67
30063	- Drafter/CAD Operator III	23.04
30064	- Drafter/CAD Operator IV	28.36
30081	- Engineering Technician I	16.47
30082	- Engineering Technician II	18.48
30083	- Engineering Technician III	20.67
30084	- Engineering Technician IV	25.61
30085	- Engineering Technician V	31.32
30086	- Engineering Technician VI	37.89
30090	- Environmental Technician	25.61
30095	- Evidence Control Specialist	25.25
30210	- Laboratory Technician	23.04
30221	- Latent Fingerprint Technician I	28.36
30222	- Latent Fingerprint Technician II	31.32
30240	- Mathematical Technician	25.61

30361 - Paralegal/Legal Assistant I	22.48
30362 - Paralegal/Legal Assistant II	27.85
30363 - Paralegal/Legal Assistant III	34.07
30364 - Paralegal/Legal Assistant IV	41.22
30375 - Petroleum Supply Specialist	30.87
30390 - Photo-Optics Technician	25.61
30395 - Radiation Control Technician	30.87
30461 - Technical Writer I	25.61
30462 - Technical Writer II	31.32
30463 - Technical Writer III	37.89
30491 - Unexploded Ordnance (UXO) Technician I	29.28
30492 - Unexploded Ordnance (UXO) Technician II	35.43
30493 - Unexploded Ordnance (UXO) Technician III	42.46
30494 - Unexploded (UXO) Safety Escort	29.28
30495 - Unexploded (UXO) Sweep Personnel	29.28
30501 - Weather Forecaster I	28.36
30502 - Weather Forecaster II	34.50
30620 - Weather Observer, Combined Upper Air Or	(see 2) 23.04
Surface Programs	
30621 - Weather Observer, Senior	(see 2) 25.61
31000 - Transportation/Mobile Equipment Operation Occupations	
31010 - Airplane Pilot	35.43
31020 - Bus Aide	12.31
31030 - Bus Driver	17.97
31043 - Driver Courier	15.11
31260 - Parking and Lot Attendant	10.94
31290 - Shuttle Bus Driver	14.86
31310 - Taxi Driver	11.92
31361 - Truckdriver, Light	16.65
31362 - Truckdriver, Medium	17.94
31363 - Truckdriver, Heavy	21.12
31364 - Truckdriver, Tractor-Trailer	21.12
99000 - Miscellaneous Occupations	

99020 - Cabin Safety Specialist	17.27
99030 - Cashier	12.46
99050 - Desk Clerk	13.06
99095 - Embalmer	29.28
99130 - Flight Follower	29.28
99251 - Laboratory Animal Caretaker I	16.87
99252 - Laboratory Animal Caretaker II	18.58
99260 - Marketing Analyst	27.95
99310 - Mortician	29.28
99410 - Pest Controller	19.47
99510 - Photofinishing Worker	15.39
99710 - Recycling Laborer	20.72
99711 - Recycling Specialist	25.46
99730 - Refuse Collector	18.41
99810 - Sales Clerk	13.62
99820 - School Crossing Guard	16.61
99830 - Survey Party Chief	26.71
99831 - Surveying Aide	15.80
99832 - Surveying Technician	21.66
99840 - Vending Machine Attendant	22.97
99841 - Vending Machine Repairer	29.14
99842 - Vending Machine Repairer Helper	22.97

Note: Executive Order (EO) 13706, Establishing Paid Sick Leave for Federal Contractors, applies to all contracts subject to the Service Contract Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2017. If this contract is covered by the EO, the contractor must provide employees with 1 hour of paid sick leave for every 30 hours they work, up to 56 hours of paid

sick leave each year. Employees must be permitted to use paid sick leave for their own illness, injury or other health-related needs, including preventive care; to assist a family member (or person who is like family to the employee) who is ill, injured, or has other health-related needs, including preventive care; or for reasons resulting from, or to assist a family member (or person who is like family to the employee) who is the victim of, domestic violence, sexual assault, or stalking. Additional information on contractor requirements and worker protections under the EO is available at www.dol.gov/whd/govcontracts.

Note: Executive Order 13658 generally applies to contracts subject to the Service Contract Act that were awarded on or between January 1, 2015 and January 29, 2022, and that have not been renewed or extended on or after January 30, 2022. If a contract is subject to Executive Order 13658, the contractor must pay all covered workers at least \$13.30 per hour (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on the contract in 2025. The applicable Executive Order minimum wage rate will be adjusted annually. Additional information on contractor requirements and worker protections under Executive Order 13658 is available at www.dol.gov/whd/govcontracts.

ALL OCCUPATIONS LISTED ABOVE RECEIVE THE FOLLOWING BENEFITS:

HEALTH & WELFARE: \$5.55 per hour, up to 40 hours per week, or \$222.00 per week or \$962.00 per month

HEALTH & WELFARE EO 13706: \$5.09 per hour, up to 40 hours per week, or \$203.60 per week, or \$882.27 per month*

*This rate is to be used only when compensating employees for performance on an SCA-covered contract also covered by EO 13706, Establishing Paid Sick Leave for Federal Contractors. A contractor may not receive credit toward its SCA obligations for any paid sick leave provided pursuant to EO 13706.

VACATION: 2 weeks paid vacation after 1 year of service with a contractor or

successor; 3 weeks after 8 years, and 4 weeks after 20 years. Length of service includes the whole span of continuous service with the present contractor or successor, wherever employed, and with the predecessor contractors in the performance of similar work at the same Federal facility. (Reg. 29 CFR 4.173)

HOLIDAYS: A minimum of eleven paid holidays per year: New Year's Day, Martin Luther King Jr.'s Birthday, Washington's Birthday, Memorial Day, Juneteenth National Independence Day, Independence Day, Labor Day, Columbus Day, Veterans' Day, Thanksgiving Day, and Christmas Day. (A contractor may substitute for any of the named holidays another day off with pay in accordance with a plan communicated to the employees involved.) (See 29 CFR 4.174)

THE OCCUPATIONS WHICH HAVE NUMBERED FOOTNOTES IN PARENTHESES RECEIVE THE FOLLOWING:

1) COMPUTER EMPLOYEES: This wage determination does not apply to any individual employed in a bona fide executive, administrative, or professional capacity, as defined in 29 C.F.R. Part 541. (See 41 C.F.R. 6701(3)). Because most Computer Systems Analysts and Computer Programmers who are paid at least \$27.63 per hour (or at least \$684 per week if paid on a salary or fee basis) likely qualify as exempt computer professionals under 29 U.S.C. 213(a)(1) and 29 U.S.C. 213(a)(17), this wage determination may not include wage rates for all occupations within those job families. In such instances, a conformance will be necessary if there are nonexempt employees in these job families working on the contract.

Job titles vary widely and change quickly in the computer industry, and are not determinative of whether an employee is an exempt computer professional. To be exempt, computer employees who satisfy the compensation requirements must also have a primary duty that consists of:

(1) The application of systems analysis techniques and procedures, including consulting with users, to determine hardware, software or system functional

specifications;

(2) The design, development, documentation, analysis, creation, testing or modification of computer systems or programs, including prototypes, based on and related to user or system design specifications;

(3) The design, documentation, testing, creation or modification of computer programs related to machine operating systems; or

(4) A combination of the aforementioned duties, the performance of which requires the same level of skills. (29 C.F.R. 541.400).

Any computer employee who meets the applicable compensation requirements and the above duties test qualifies as an exempt computer professional under both section 13(a)(1) and section 13(a)(17) of the Fair Labor Standards Act. (Field Assistance Bulletin No. 2006-3 (Dec. 14, 2006)). Accordingly, this wage determination will not apply to any exempt computer employee regardless of which of these two exemptions is utilized.

2) AIR TRAFFIC CONTROLLERS AND WEATHER OBSERVERS - NIGHT PAY & SUNDAY PAY: If you work at night as part of a regular tour of duty, you will earn a night differential and receive an additional 10% of basic pay for any hours worked between 6pm and 6am.

If you are a full-time employed (40 hours a week) and Sunday is part of your regularly scheduled workweek, you are paid at your rate of basic pay plus a Sunday premium of 25% of your basic rate for each hour of Sunday work which is not overtime (i.e. occasional work on Sunday outside the normal tour of duty is considered overtime work).

**** HAZARDOUS PAY DIFFERENTIAL ****

An 8 percent differential is applicable to employees employed in a position that represents a high degree of hazard when working with or in close proximity to

ordnance, explosives, and incendiary materials. This includes work such as screening, blending, dying, mixing, and pressing of sensitive ordnance, explosives, and pyrotechnic compositions such as lead azide, black powder and photoflash powder.

All dry-house activities involving propellants or explosives. Demilitarization, modification, renovation, demolition, and maintenance operations on sensitive ordnance, explosives and incendiary materials. All operations involving re-grading and cleaning of artillery ranges.

A 4 percent differential is applicable to employees employed in a position that represents a low degree of hazard when working with, or in close proximity to ordnance, (or employees possibly adjacent to) explosives and incendiary materials which involves potential injury such as laceration of hands, face, or arms of the employee engaged in the operation, irritation of the skin, minor burns and the like; minimal damage to immediate or adjacent work area or equipment being used. All operations involving, unloading, storage, and hauling of ordnance, explosive, and incendiary ordnance material other than small arms ammunition. These differentials are only applicable to work that has been specifically designated by the agency for ordnance, explosives, and incendiary material differential pay.

**** UNIFORM ALLOWANCE ****

If employees are required to wear uniforms in the performance of this contract (either by the terms of the Government contract, by the employer, by the state or local law, etc.), the cost of furnishing such uniforms and maintaining (by laundering or dry cleaning) such uniforms is an expense that may not be borne by an employee where such cost reduces the hourly rate below that required by the wage determination. The Department of Labor will accept payment in accordance with the following standards as compliance:

The contractor or subcontractor is required to furnish all employees with an adequate number of uniforms without cost or to reimburse employees for the actual cost of the uniforms. In addition, where uniform cleaning and maintenance is made the responsibility of the employee, all contractors and subcontractors subject to

this wage determination shall (in the absence of a bona fide collective bargaining agreement providing for a different amount, or the furnishing of contrary affirmative proof as to the actual cost), reimburse all employees for such cleaning and maintenance at a rate of \$3.35 per week (or \$.67 cents per day). However, in those instances where the uniforms furnished are made of "wash and wear" materials, may be routinely washed and dried with other personal garments, and do not require any special treatment such as dry cleaning, daily washing, or commercial laundering in order to meet the cleanliness or appearance standards set by the terms of the Government contract, by the contractor, by law, or by the nature of the work, there is no requirement that employees be reimbursed for uniform maintenance costs.

**** SERVICE CONTRACT ACT DIRECTORY OF OCCUPATIONS ****

The duties of employees under job titles listed are those described in the "Service Contract Act Directory of Occupations", Fifth Edition (Revision 1), dated September 2015, unless otherwise indicated.

**** REQUEST FOR AUTHORIZATION OF ADDITIONAL CLASSIFICATION AND WAGE RATE, Standard Form 1444 (SF-1444) ****

Conformance Process:

The contracting officer shall require that any class of service employee which is not listed herein and which is to be employed under the contract (i.e., the work to be performed is not performed by any classification listed in the wage determination), be classified by the contractor so as to provide a reasonable relationship (i.e., appropriate level of skill comparison) between such unlisted classifications and the classifications listed in the wage determination (See 29 CFR 4.6(b)(2)(i)). Such conforming procedures shall be initiated by the contractor prior to the performance of contract work by such unlisted class(es) of employees (See 29 CFR 4.6(b)(2)(ii)). The Wage and Hour Division shall make a final determination of conformed classification, wage rate, and/or fringe benefits which shall be paid to all employees performing in the classification from the first day

of work on which contract work is performed by them in the classification. Failure to pay such unlisted employees the compensation agreed upon by the interested parties and/or fully determined by the Wage and Hour Division retroactive to the date such class of employees commenced contract work shall be a violation of the Act and this contract. (See 29 CFR 4.6(b)(2)(v)). When multiple wage determinations are included in a contract, a separate SF-1444 should be prepared for each wage determination to which a class(es) is to be conformed.

The process for preparing a conformance request is as follows:

- 1) When preparing the bid, the contractor identifies the need for a conformed occupation(s) and computes a proposed rate(s).
- 2) After contract award, the contractor prepares a written report listing in order the proposed classification title(s), a Federal grade equivalency (FGE) for each proposed classification(s), job description(s), and rationale for proposed wage rate(s), including information regarding the agreement or disagreement of the authorized representative of the employees involved, or where there is no authorized representative, the employees themselves. This report should be submitted to the contracting officer no later than 30 days after such unlisted class(es) of employees performs any contract work.
- 3) The contracting officer reviews the proposed action and promptly submits a report of the action, together with the agency's recommendations and pertinent information including the position of the contractor and the employees, to the U.S. Department of Labor, Wage and Hour Division, for review (See 29 CFR 4.6(b)(2)(ii)).
- 4) Within 30 days of receipt, the Wage and Hour Division approves, modifies, or disapproves the action via transmittal to the agency contracting officer, or notifies the contracting officer that additional time will be required to process the request.
- 5) The contracting officer transmits the Wage and Hour Division's decision to the

contractor.

6) Each affected employee shall be furnished by the contractor with a written copy of such determination or it shall be posted as a part of the wage determination (See 29 CFR 4.6(b)(2)(iii)).

Information required by the Regulations must be submitted on SF-1444 or bond paper.

When preparing a conformance request, the "Service Contract Act Directory of Occupations" should be used to compare job definitions to ensure that duties requested are not performed by a classification already listed in the wage determination. Remember, it is not the job title, but the required tasks that determine whether a class is included in an established wage determination. Conformances may not be used to artificially split, combine, or subdivide classifications listed in the wage determination (See 29 CFR 4.152(c)(1))."

ATTACHMENT J-0200000-03
DIRECTIVES, INSTRUCTIONS, AND REFERENCES

<u>Reference</u>	<u>Title</u>
ANSI/ISEA 107-2010	High Visibility Garment Standard
29 CFR 1910.120	Hazardous Materials - Hazardous waste operations and emergency response
29 CFR 1910.134	Personal Protective Equipment-Respiratory protection.
29 CFR 1926.16	Safety and Health Regulations for Construction
29 CFR 1926.59	Occupational Health and Environmental Controls - Hazard communication
40 CFR 247	Comprehensive Procurement Guideline for Products Containing Recovered Materials
DFARS 252.223-7004	Drug Free Work Force
EM 385-1-1	U.S. Army Corps of Engineers Safety and Health Requirements
E.O. 13423	Executive Order Strengthening Federal Environmental, Energy, and Transportation Management
FAR 52.223-2	Affirmative Procurement of Biobased Products under Service and Construction Contracts
FAR 52.223-3	Hazardous Material Identification and Material Safety Data Sheet
FAR 52.228-5	Insurance – Work On A Government Installation
FAR 52.246-4	Inspection of Services Fixed-Price
NFPA 10	Standard for Portable Fire Extinguishers
NFPA 241	Standard for Safeguarding Construction, Alteration, and Demolition Operations
NFPA 51B	Standard for Fire Prevention During Welding, Cutting and other Hot Work
NFPA 70	National Electric Code
NFPA 70E	Standard for Electrical Safety in the Workplace
P.L. 91-596	Occupational Safety and Health Act

ATTACHMENT J-0200000-04
INVOICE FORM

NAVFAC 7300/30
(Rev 2/01)

NAVAL FACILITIES ENGINEERING SYSTEMS COMMAND

1. **CONTRACTOR'S INVOICE**

From: _____

DUNS NO: _____
CAGE CODE NO: _____
Invoice Date: _____
Invoice Number: _____

POC/Telephone/email for this invoice: _____

To: Contract Specialist: _____

Below is a Statement of Performance under Contract N40085-_____ Task Order: _____

For _____ at _____

The enclosure provides breakdown of this statement of performance.

- | | | |
|--|-------|-------|
| A. Total value of contract/task order through change | _____ | _____ |
| B. Percentage of performance complete | _____ | _____ |
| C. Value of completed performance | _____ | _____ |
| D. Less total of prior payments | _____ | _____ |
| E. Amount of this invoice | _____ | _____ |

Signature and Title: _____

Date: _____ Signature of Authorized Representative

2. **FIRST ENDORSEMENT**

Receipt and Acceptance Certification

From: _____

To: _____

1. Payment is recommended as follows:

- | | | |
|---|-------|--------------------|
| A. Amount of work completed to (date) | _____ | _____ |
| B. Less: | | |
| Retention | _____ | |
| Other Deductions: | _____ | _____ |
| C. Subtotal | | _____ |
| D. Less previous payments | | _____ |
| E. Certified amount for payment # | _____ | Final on TO# _____ |
| F. Elapsed contract time (if applicable) | _____ | |
| G. Responsible Certifying UIC | _____ | |
| H. Invoice Receipt Date | _____ | |
| I. Material/Services Receipt Date | _____ | |
| J. Material/Services Acceptance Date | _____ | |
| K. Date forwarded to paying office | _____ | |
| L. I certify this amount is correct and payment is recommended. | | |

Signature: _____ Date: _____

Signature of Authorized Representative

Name and Title (Typed): _____

Phone and address: _____

3. **PROMPT PAYMENT CERTIFICATION**

I certify that the accounting data provided is accurate, funds have been obligated in appropriate accounting system and changes have been applied to the appropriate accounting classification reference number (ACRN), available funds have been decremented for the amount approved for disbursement and will not be de-obligated and the above invoice is correct and proper for payment.

Signature: _____ Date: _____

Signature of Authorized Representative

Name and Title (typed): _____

Phone and address: _____

Line(s) of accounting to be used for this invoice (include appropriate Line Item # (CLIN, SLIN, OR ACRN, etc)

- ☐ Initial Report
- ☐ Follow-up Report
- ☐ Final Report

Contractor Significant Incident Report (CSIR)

1. General Information			
Contracting Activity/ROICC Office: [REDACTED]			
Accident Classification:			
☐ Injury	☐ Fatality	☐ Environment	☐ Procedural Issues
☐ Illness	☐ Property Damage	☐ Lessons Learned	
Other: [REDACTED]			
Involving:			
☐ Confined Space	☐ Equip/Mrt Ver/Mat Handling (Heavy Construction Equip.)	☐ Hazardous Material	
☐ Crane and Rigging	☐ Equip/Mrt Ver/Mat Handling (Material Handling)	☐ Trenching/Excavation	
☐ Diving	☐ Equip/Mrt Ver/Mat Handling (Man-Lift/Elevated Platform)	☐ Waterfront/Marine	
☐ Demolition/Renovation	☐ Fall from Ladder	☐ Fall from Scaffold	☐ Other_
☐ Electrical	☐ Fall from Roof	☐ Fire	☐ [REDACTED]
2. Personal Information			
Name (Last, First, MI): [REDACTED]		Age: [REDACTED]	Sex: [REDACTED]
Job Title/Description: [REDACTED]		Employed By: [REDACTED]	
Supervisor Name (Last, First, MI) & Title: [REDACTED]		Was the person trained to perform this activity/task? Yes ☐ No ☐	
What type of training was received (OJT, classroom, etc)? [REDACTED]		Date of the most recent formal training and topics discussed? [REDACTED]	
3. Witness Information			
Witness #1: Name (Last, First, MI): [REDACTED]		Job Title/Description: [REDACTED]	
Employed By: [REDACTED]		Supervisor Name (Last, First, MI): [REDACTED]	
Witness #2: Name (Last, First, MI): [REDACTED]		Job Title/Description: [REDACTED]	
Employed By: [REDACTED]		Supervisor Name (Last, First, MI): [REDACTED]	

ATTACHMENT J-0200000-05-1

Additional Witnesses:
(List any additional witnesses on a separate sheet and attach.)

Yes

No

Indirect Cause(s) of Accident:

Action(s) taken to prevent re-occurrence or provide on-going corrective actions:

Corrective Action Beginning Date:

Anticipated Completion Date:

Personal Protective Equipment:

☐

Available and used

☐

Available and not used

☐

Not Required

☐

Not related to Mishap

☐

Wrong PPE for job

List PPE Used:

Type of Construction Equipment (Make, Model, Serial #, VIN#) Involved:

Was Hazardous Material Spilled/Released?

☐

Yes

☐

No

Please List Hazardous Material(s) Involved:

Who provided first aid or cleanup of mishap site?

Any blood-borne pathogen exposure, other than EMTs?

☐

Yes

☐

No

Who?

List OSHA and WM-385-1-1 standards that were violated:

Was site secured and witness statements taken immediately?

Yes

No

By Whom?

6. Injury Illness/Fatality Information

Severity of Injury/Illness: ☐ Fatality ☐ Temporary Disability ☐ Permanent Total Disability ☐ Permanent Partial Disability ☐ Lost Workday Case Involving Days Away From Work ☐ Recordable Workday Case Involving Restricted Duty ☐ Other Recordable Case ☐ Non-Recordable Case ☐ Recordable First Aid Case ☐ No Injury		
Estimated Days Lost:	Estimated Days Hospitalized:	Estimated Days Restricted Duty:
List Primary Body Part Affected:	List Other Body Part(s) Affected:	
Nature of Injury/Illness for Primary Body Part (Examples: Amputation, Burn, Hernia):		
Type of Accident (Examples: Fall same level, Lifting, Bitten, Exerted):		
Source of Accident (Examples: Crane, Carbon Monoxide, Ladder, Welding Equipment):		

7. Casual Factors (Explain answers on supplementary sheet)

• Design – Design of facility, workplace, or equipment was a factor?	☐ Yes	☐ No
• Inspection/Maintenance – Inspection & Maintenance procedures were a factor?	☐ Yes	☐ No
• Persons Physical Condition – In your opinion, the physical condition of the person was a factor?	☐ Yes	☐ No
• Operation Procedures – Operating procedures were a factor?	☐ Yes	☐ No
• Job Practices – One or more job safety/health practices not being followed when the accident occurred contributed to the accident?	☐ Yes	☐ No
• Human Factors – One or more human factors, such as a person's size or strength contributed to the accident?	☐ Yes	☐ No
• Environmental Factors – Heat, cold, dust, sun, glare, etc., contributed to the accident?	☐ Yes	☐ No
• Chemical and Physical Agent Factors – Exposure to chemical agents, such as dust, fumes, mist, vapors, or physical agents such as noise, radiation, etc., contributed to the accident?	☐ Yes	☐ No
• Office Factors – Office setting such as lifting office furniture, carrying, stooping, contributed to the accident?	☐ Yes	☐ No
• Support Factors – Inappropriate tools/resources were provided to perform the task?	☐ Yes	☐ No
• PPE – Improper selection, use or maintenance of PPE contributed to the accident?	☐ Yes	☐ No
• Drugs/Alcohol – In your opinion, were drugs or alcohol a factor?	☐ Yes	☐ No
• Job Hazard Analysis – The lack of an adequate (IAW-EM-385-1-1 Sec 01.A) activity hazard analysis was a contributing factor.	☐ Yes	☐ No
• Job Hazard Analysis – JHA was not site specific and/or did not address the type of work/operations performed when the mishap occurred.	☐ Yes	☐ No
• Management – A lack of adequate supervision contributed to the accident.	☐ Yes	☐ No
• Management – Inadequate information was provided at pre con meeting.	☐ Yes	☐ No

8. OSHA Information			
Date OSHA was Notified:	Date(s) of Investigation:	Date of citation: (Attach Copy)	Dollar amount of Penalties:
9. Report Preparer			
Name (Last, First, MI):		Date of Report:	
Title:		Signature:	
Employer:			
Phone #:			

CONTRACTOR SIGNIFICANT INCIDENT REPORT (CSIR) INSTRUCTIONS

Complete Sections Appropriate to Incident (Rev. 06/02).

NOTE: THE ATTACHED CSIR FORM IS TO BE USED BY CONTRACTORS TO RECORD THE RESULTS OF THEIR ACCIDENT/INCIDENTS INVESTIGATIONS AND SHALL BE PROVIDED TO THE CONTRACTING OFFICER WITHIN THE REQUIRED TIMEFRAMES.

GENERAL. Complete a separate report for each person who was injured in the accident. A report needs to be completed for all OSHA recordable accidents, property damage in excess of \$2000.00 (This amount is for record purposes only. GOV is not required to enter property damage reports into FAIR database if it is less than \$10,000.00.), WHE accidents, or near miss/high visibility mishaps. Please type or print legibly. Appropriate items shall be marked with an "X" in box(es), non-applicable sections shall be marked "N/A". If additional space is needed, provide the information on a separate sheet of paper and attach to the completed form.

Mark the report:

INITIAL – If this form is being used as initial notification of a Fatality or High Visibility Mishap. The initial form is due within 4 hours of a serious accident. A form marked 'Follow-up' or 'Final' is required within 5 days.

FOLLOW-UP – If you are providing additional information on a report previously submitted.

FINAL – If you are providing a completed report and expect no changes.

SECTION 1 – GENERAL INFORMATION

CONTRACTING ACTIVITY/ROICC OFFICE - Enter the name and address of the Contracting Office administering the contract under which the mishap took place (e.g. ROICC MCBH, ROICC NORFOLK, PWC GUAM, etc.).

ACCIDENT CLASSIFICATION - INJURY/ILLNESS/FATALITY/PROPERTY DAMAGE/-PROCEDURAL ISSUES/-ENVIRONMENTAL/LESSONS LEARNED/OTHER – Mark the appropriate block(s) if the incident resulted in any of these conditions.

INVOLVING - If the mishap involved any of the conditions listed under "Involving" mark the appropriate box(es). Specific questions associated with each of these conditions are available from the Contracting Officer to assist you in your investigation. When these questions are used they shall be attached as part of this report.

SECTION 2 - PERSONAL INFORMATION

NAME - Enter last name, first name, middle initial of person involved.

AGE - Enter age.

SEX - Enter M for Male and F for Female.

JOB TITLE/DESCRIPTION - Enter the job title/description assigned to the injured person (e.g. carpenter, laborer, surveyor, etc.).

EMPLOYED BY - Enter employment company name of the person involved.

SUPERVISOR'S NAME & TITLE - Enter name and title of the immediate supervisor.

WAS PERSON TRAINED TO PERFORM ACTIVITY/TASK? - For the purpose of this section "trained" means the person has been provided the necessary information (either formal and/or on-the-job (OJT) training) to competently perform the activity/task in a safe and healthful manner.

TYPE OF TRAINING - Indicate the specific type of training (classroom or on-the-job) that the injured person received before the accident happened.

DATE OF MOST RECENT FORMAL TRAINING/TOPICS DISCUSSED - Enter the month, day, and year of the last *formal* training completed that covered the activity/task being performed at the time of the accident. List topics that were discussed at the training identified above.

SECTION 3 - WITNESS INFORMATION

The following applies to Witness #1 and Witness #2:

WITNESS NAME - Enter last name, first name, middle initial of the witness.

JOB DESCRIPTION/TITLE - Enter the job title/description assigned to the witness (e.g. carpenter, laborer, surveyor, etc.).

EMPLOYED BY - Enter the name of the employment company of the witness.

SUPERVISORS NAME - Enter name of immediate supervisor of the witness.

ADDITIONAL WITNESSES - Provide same information, as above, for each witnesses. Use additional pages if necessary.

SECTION 4 - CONTRACTOR INFORMATION

TYPE OF CONTRACT - Mark appropriate box. A/E means architect/engineer. If "OTHER" is marked, specify type of contract on line provided.

CONTRACT NUMBER/TITLE - Enter complete contract number and title of prime contract (e.g. N62477-85-C-0100, 184 Pearl City Hsg. Revitalization).

CONSTRUCTION INDUSTRIAL GROUP AND INDUSTRIAL TYPE – This is the type of construction that will be done at this project.

1. First, you must choose the Industrial Group. You have 4 choices to choose from: (**NOTE!** Review of the Industrial Types below and knowing what the projects scope of work is will assist you in deciding what the Industrial Group should be.)

- a. Buildings
- b. Heavy Industrial
- c. Infrastructure
- d. Light Industrial

2. Once you have chosen the Industrial Group, you now select the Industrial Type. You have multiple choices under each Group, chose the one you feel fits the project most closely because on most projects there won't be an exact match:

- a. Buildings:
 - (1) Communications Ctr.
 - (2) Dormitory/Hotel
 - (3) High-rise Office
 - (4) Hospital
 - (5) Housing
 - (6) Laboratory
 - (7) Low-rise Office
 - (8) Maintenance Facility
 - (9) Parking Garage
 - (10) Physical Fitness Ctr.
 - (11) Restaurant/Nightclub
 - (12) School
 - (13) Warehouse
- b. Heavy Industrial:
 - (1) Chemical Mfg.
 - (2) Electrical (Generating)
 - (3) Environmental
 - (4) Metals Refining/Processing
 - (5) Mining
 - (6) Natural Gas Processing
 - (7) Oil Exploration/Production
 - (8) Oil Refining
 - (9) Pulp and Paper
- c. Infrastructure:
 - (1) Airport
 - (2) Electrical Distribution
 - (3) Flood Control
 - (4) Highway
 - (5) Marine Facilities
 - (6) Navigation
 - (7) Rail
 - (8) Tunneling
 - (9) Water/Wastewater
- d. Light Industrial:
 - (1) Automotive Assembly/Mfg.
 - (2) Consumer Products Mfg.
 - (3) Foods
 - (4) Microelectronics Mfg.
 - (5) Office Products Mfg.
 - (6) Pharmaceuticals Mfg.

CONTRACTOR'S NAME/ADDRESS/PHONE NUMBER

- (1) PRIME - Enter the exact name (title of firm), address, phone and fax numbers of the prime contractor.
- (2) SUBCONTRACTOR - Enter the exact name, address, phone and fax numbers of any subcontractor involved in the accident.

SAFETY MANAGER'S NAME

- (1) PRIME - Enter the name of the prime contractor safety manager.
- (2) SUBCONTRACTOR - Enter the name of the subcontractors safety manager.

INSURANCE CARRIER

- (1) PRIME - Enter the exact name/title of the prime's insurance company. Policy number not required.
- (2) SUBCONTRACTOR - Enter the exact name of the subcontractor's insurance company. Policy number not required.

SECTION 5 - ACCIDENT DESCRIPTION

DATE OF ACCIDENT - Enter the month, day, and year of accident.

TIME OF ACCIDENT - Enter the local time of accident in military time. Example: 14:30 hrs (not 2:30 p.m.).

EXACT LOCATION OF ACCIDENT - Enter facts needed to locate the accident scene (installation/project name, building/room number, street, direction and distance from closest landmark, etc.).

DESCRIBE THE ACCIDENT IN DETAIL. Fully describe the accident in the space provided. If property damage involved, give estimated dollar amount of damage and/or repair costs involved. If additional space is needed continue on a separate sheet and attach to this report. Give the sequence of events that describe what happened leading up to and including the accident. Fully identify personnel and equipment involved and their role(s) in the accident. Ensure that relationships between personnel and

equipment are clearly specified. Ensure questions below regarding direct cause(s), indirect cause(s), and actions taken are answered. **NOTE!** Review questions in Section 7 below before completing.

DIRECT CAUSE(S) - The direct cause is that single factor which most directly lead to the accident. See examples below.

INDIRECT CAUSE(S) - Indirect cause are those factors, which contributed to, but did not directly initiate the occurrence of the accident.

Examples for Direct and Indirect Cause:

1. Employee was dismantling scaffold and fell 12 feet from unguarded opening.

Direct cause: Failure to provide fall protection at elevation

Indirect causes: Failure to enforce safety requirements: improper training/motivation of employee (possibility that employee was not knowledgeable of fall protection requirements or was lax in his attitude toward safety); failure to ensure provision of positive fall protection whenever elevated; failure to address fall protection during scaffold dismantling in phase hazard analysis.

2. Private citizen had stopped his vehicle at intersection for red light when vehicle was struck in rear by contractor vehicle. (note contractor vehicles was in proper safe working condition.)

Direct cause: Failure of contractor driver to maintain control of and stop contractor vehicle within safe distance.

Indirect cause: Failure of employee to pay attention to driving (defensive driving).

ACTION(S) TAKEN TO PREVENT RE-OCCURRENCE OR PROVIDE ON-GOING CORRECTIVE ACTIONS. Fully describe all the actions taken, anticipated, and recommended to eliminate the cause(s) and prevent reoccurrence of similar accidents/illnesses. Continue on back or additional sheets of paper if necessary to fully explain and attach to the complete report form.

CORRECTIVE ACTION DATES -

(1) Beginning - Enter the date when the corrective action(s) identified above will begin.

(2) Anticipated Completion - Enter the date when the corrective action(s) identified above will be completed.

PERSONAL PROTECTIVE EQUIPMENT (PPE) - Mark appropriate box(es) and list PPE which was being used by the injured person at the time of the accident (e.g. protective clothing, shoes, glasses, goggles, respirator, safety belt, harness, etc.)

TYPE OF CONTRACTOR EQUIPMENT - Enter the Serial Number, Model Number and specific type of equipment involved in the mishap (e.g. dump truck (off highway), crane (rubber tire), pump truck (concrete), etc.).

WAS HAZARDOUS MATERIAL SPILLED/RELEASED? - Mark appropriate block and list name(s) of any reportable quantities of hazardous materials spilled/released during the mishap.

WHO PROVIDED FIRST AID OR CLEAN-UP OF MISHAP SITE? - List name(s) of individual(s) and employer, if known.

ANY BLOOD-BORNE PATHOGEN EXPOSURE, OTHER THAN EMT? - Mark appropriate block and list name(s) of individual(s) and employer, if known.

LIST OSHA AND/OR EM 385-1-1 STANDARDS THAT WERE VIOLATED. - Self explanatory.

WAS SITE SECURED AND WITNESS STATEMENT TAKEN IMMEDIATELY? - Mark appropriate block and list by whom.

SECTION 6 - INJURY/ILLNESS/FATALITY INFORMATION

SEVERITY OF INJURY/ILLNESS - Mark appropriate box.

ESTIMATED DAYS LOST - Enter the estimated number of workdays the person will lose from work. Update when final data is known.

ESTIMATED DAYS HOSPITALIZED - Enter the estimated number of workdays the person will be hospitalized. Update when final data is known.

ESTIMATED DAYS RESTRICTED DUTY - Enter the estimated number of workdays the person, as a result of the accident, will not be able to perform all of their regular duties. Update when final data is known.

BODY PART(S) AFFECTED - Enter the most appropriate primary and when applicable, secondary, etc. body part(s) affected (e.g. arm: wrist: abdomen: single eye: jaw : both elbows: second finger: great toe: collar bone: kidney, etc.).

NATURE OF INJURY/ILLNESS FOR PRIMARY BODY PART - Enter the most appropriate nature of injury/illness (e.g. amputation, back strain, dislocation, laceration, strain, asbestosis, food poisoning, heart conditions, etc.).

TYPE AND SOURCE OF INJURY/ILLNESS - Type and Source Codes are used to describe what caused the incident.

(1) TYPE Code stands for an "Action" (Example: Worker, installing conduit, lost his balance and fell five feet from a ladder.

Type Code: Fell different levels".) Select the most appropriate Type of injury from the list below:

TYPE OF INJURY/ILLNESS

STRUCK BY/AGAINST	CONTACTED CONTACTED WITH (INJURED PERSON MOVING) CONTACTED BY (OBJECT WAS MOVING)
FELL, SLIPPED, TRIPPED SAME LEVEL/DIFFERENT LEVEL/NO FALL	EXERTED LIFTED, STRAINED BY (SINGLE ACTION) STRESSED BY (REPEATED ACTION)
CAUGHT ON/IN/BETWEEN	EXPOSED INHALED/INGESTED/ABSORBED/EXPOSED TO
PUNCTURED, LACERATED PUNCTURED BY/CUT BY/STUNG BY/BITTEN BY	TRAVELING IN

(2) SOURCE Code stands for an "object or substance." (Example: Worker, installing conduit, lost his balance and fell five feet from a ladder. Source Code: "Ladder".) Select the most appropriate Source of injury from the list below:

SOURCE OF INJURY/ILLNESS

BUILDING OR WORKING AREA WALKING/WORKING AREA STAIRS/STEPS LADDER FURNITURE BOILER/PRESSURE VESSEL EQUIPMENT LAYOUT WINDOWS/DOORS ELECTRICITY	DUST, VAPOR, ETC. DUST (SILICA, COAT, ETC.) FIBERS ASBESTOS GASES CARBON MONOXIDE MIST, STEAM, VAPOR, FUME WELDING FUMES PARTICLES (UNIDENTIFIED)
ENVIRONMENT CONDITION TEMPERATURE EXTREME (INDOOR) WEATHER (ICE, RAIN, HEAT, ETC.) FIRE, FLAME, SMOTE (NOT TABACCO) NOISE RADIATION LIGHT VENTILATION TOBACCO SMOKE STRESS (EMOTIONAL) CONFINED SPACE	CHEMICAL, PLASTIC, ETC. DRY CHEMICAL - CORROSIVE DRY CHEMICAL - TOXIC DRY CHEMICAL - EXPLOSIVE DRY CHEMICAL - FLAMMABLE LIQUID CHEMICAL - CORROSIVE LIQUID CHEMICAL - TOXIC LIQUID CHEMICAL - EXPLOSIVE LIQUID CHEMICAL - FLAMMABLE PLASTIC WATER MEDICINE
MACHINE OR TOOL HAND TOOL (POWERED: SAW, GRINDER, ETC.) HAND TOOL (NON POWERED) MECHANICAL POWER TRANSMISSION APPARATUS GUARD, SHIELD (FIXED, MOVEABLE, INTERLOCK) VIDEO DISPLAY TERMINAL PUMP, COMPRESSOR, AIR PRESSURE TOOL HEATING EQUIPMENT WELDING EQUIPMENT	INANIMATE OBJECT BOX, BARREL, ETC. PAPER METAL ITEM, MINERAL NEEDLE GLASS SCRAP, TRASH, WOOD FOOD CLOTHING, APPAREL, SHOES
MACHINE OR TOOL HAND TOOL (POWERED: SAW, GRINDER, ETC.) HAND TOOL (NON POWERED) MECHANICAL POWER TRANSMISSION APPARATUS GUARD, SHIELD (FIXED, MOVEABLE, INTERLOCK) VIDEO DISPLAY TERMINAL PUMP, COMPRESSOR, AIR PRESSURE TOOL HEATING EQUIPMENT WELDING EQUIPMENT	INANIMATE OBJECT BOX, BARREL, ETC. PAPER METAL ITEM, MINERAL NEEDLE GLASS SCRAP, TRASH, WOOD FOOD CLOTHING, APPAREL, SHOES
VEHICLE AS DRIVER OF PRIVATELY OWNED, RENTAL VEH. AS PASSENGER OF PRIVATELY OWNED, RENTAL VEH. DRIVER OF GOVERNMENT VEHICLE PASSENGER OF GOVERNMENT VEHICLE COMMON CARRIER (AIRLINE, BUS, ETC.) AIRCRAFT (NOT COMMERCIAL) BOAT, SHIP, BARGE	ANIMATE OBJECT DOG OTHER ANIMAL PLANT INSECT HUMAN (VIOLENCE) HUMAN (COMMUNICABLE DISEASE) BACTERIA, VIRUS (NOT HUMAN CONTACT)
MATERIAL HANDLING EQUIPMENT EARTHMOVER (TRACTOR, BACKHOE, ETC.) CONVEYOR (FOR MATERIAL AND EQUIPMENT) ELEVATOR, ESCALATOR, PERSONNEL HOIST HOIST, SLING CHAIN, JACK CRANE FORKLIFT HANDTRUCK, DOLLY	PERSONAL PROTECTIVE EQUIPMENT PROTECTIVE CLOTHING, SHOES, GLASSES, GOGGLES RESPIRATOR, MASK DIVING EQUIPMENT SAFETY BELT, HARNESS PARACHUTE

SECTION 7 - CAUSAL FACTORS

Review thoroughly. Answer each question by marking the appropriate block. **NOTE!** If any answer is yes, explain in section 5 above.

- (1) **DESIGN** - Did inadequacies associated with the building or work site play a role? Would an improved design or layout of the equipment or facilities reduce the likelihood of similar accidents? Were the tools or other equipment designed and intended for the task at hand?

- (2) **INSPECTION/MAINTENANCE** - Did inadequately or improperly maintained equipment, tools, workplace, etc., create or worsen any hazards that contributed to the accident? Would better equipment, facility, work site or work activity inspections have helped avoid the accident?
- (3) **PERSONS PHYSICAL CONDITION** - Do you feel that the accident would probably not have occurred if the employee was in "good" physical condition? If the person involved in the accident had been in better physical condition, would the accident have been less severe or avoided altogether? Was overexertion a factor?
- (4) **OPERATION PROCEDURES** - Did lack of or inadequacy within established operating procedures contribute to the accident? Did any aspect of the procedures introduce any hazard to, or increase the risk associated with the work process? Would establishment or improvement of operating procedures reduce the likelihood of similar accidents?
- (5) **JOB PRACTICES** - Were any of the provision of the Safety and Health Requirements Manual (EM 385-1-1) violated? Was the task being accomplished in a manner which was not in compliance with an established job hazard analysis or activity hazard analysis? Did any established job practice (including EM 385-1-1) fail to adequately address the task or work process? Would better job practices improve the safety of the task?
- (6) **HUMAN FACTORS** - Was the person under undue stress (either internal or external to the job)? Did the task tend toward overloading the capabilities of the person: i.e., did the job require tracking and reacting to many external inputs such as displays, alarms, or signals? Did the arrangement of the workplace tend to interfere with efficient task performance? Did the task require reach strengths, endurance, agility, etc., at or beyond the capabilities of the employee? Was the work environment ill-adapted to the person? Did the person need more training, experience, or practice in doing the task? Was the person inadequately rested to perform safely?
- (7) **ENVIRONMENTAL FACTORS** - Did any factors such as moisture, humidity, rain, snow, sleet, hail, ice, fog, cold, heat, sun temperature changes, wind, tides, floods, currents, terrain; dust, mud, glare, pressure changes, lighting, etc., play a part in the accident?
- (8) **CHEMICAL AND PHYSICAL AGENT FACTORS** - Did exposure to chemical agents (either single shift exposure or long-term exposure such as dusts, fibers, (asbestos, etc.), silica, gases (carbon, monoxide, chlorine, etc.), mists, steam, vapors, fumes, smoke, other particulates, liquid or dry chemicals that are corrosive, toxic, explosive or flammable, by-products of combustion or physical agents such as noise, ionizing radiation, non-ionizing radiation (UV radiation created during welding, etc.) contribute to the accident/incident?
- (9) **OFFICE FACTORS** - Did the fact that the accident occurred in an office setting or to an office worker have a bearing on its cause? For example, office workers tend to have less experience and training in performing tasks such as lifting office furniture. Did physical hazards within the office environment contribute to the hazard?
- (10) **SUPPORT FACTORS** - Was the person using an improper tool for the job? Was inadequate time available or utilized to safely accomplish the task? Were less than adequate personnel resources (in terms of employee skills, number of workers, and adequate supervision) available to get the job done properly? Was funding available, utilized and adequate to provide proper tools, equipment, personnel, site preparation, etc.
- (11) **PERSONAL PROTECTIVE EQUIPMENT** - Did the person fail to use appropriate personal protective equipment (gloves, eye protection, hard-toed shoes, respirator, etc) for the task or environment? Did protective equipment provided or worn fail to provide adequate protection from the hazard(s)? Did lack of or inadequate maintenance of protective gear contribute to the accident?
- (12) **DRUGS/ALCOHOL** - Is there any reason to believe the person's mental or physical capabilities, judgment, etc., were impaired or altered by the use of drugs or alcohol? Consider the effects of prescription medicine and over the counter medications as well as illicit drug use. Consider the effect of drug or alcohol induced "hangovers".
- (13) **JOB/ACTIVITY HAZARD ANALYSIS** - Was a written Job/Activity Analysis completed for the task being performed at the time of the accident? If one was made, did it address the hazard adequately or does it need to be updated? If none made, will one be made? These may also need to be addressed in the Corrective Actions Taken section. Mark the appropriate box. If one was made, attach a copy of the analysis to the report.
- (14) **MANAGEMENT** - Did the lack of supervisor or management support play a part in the mishap? Mark the appropriate box.

SECTION - 8 OSHA INFORMATION - Complete this section if applicable

SECTION 9 - REPORT PREPARER

Providing a completed CSIR to the Contracting Officer is the PRIME CONTRACTOR'S RESPONSIBILITY. Enter the name, date of report, title, employer, phone number and signature of person completing the accident report and provide it to the Contracting Officer, or his representative, responsible for oversight of that contractor activity. **NOTE!** If prepared by other than the Prime Contractor, a person employed by the Prime Contractor must sign that they have reviewed and concur with the report and it's findings (e.g. company owner, project supervisor/foreman, Safety Officer, etc.).

Attachment J-0200000-05-2
MOTOR VEHICLE ACCIDENT REPORT

DATE: _____ **YEAR/MAKE** _____

Time: _____ **MODEL:** _____

DRIVER: _____

HOME ADDRESS: _____

TELEPHONE: _____

REGISTRATION NUMBER OR NAME: _____

DESCRIPTION OF ACCIDENT _____

This image shows a blank sheet of white paper with horizontal ruling lines. The lines are evenly spaced and run across the width of the page. There are no margins, text, or other markings on the paper.

ATTACHMENT J-0200000-05-3

SPILL RESPONSE FORM

MCBCL/MCASNR SPCC State Notification of Discharge Report (POL's)		
Subj:		
Installation POC/Phone Number:		John Hamilton RCRS Supervisor 910-451-1482
1. Date and Time When Release Occurred/Discovered		
2. Activity/Responsible Party Originating Release		
2a. Address of Responsible Party		
3. Source of Release (Storage Area, Shop, Vehicle, etc)		
4. Location of Spill (Bldg, Highway, Range, etc)		
5. Quantity Released (Gallons/Liters, Pounds/Kilograms) - If Unknown, Indicate Size of Contaminated Area		
6. Type of Substance Released		
7. Container Involved (Drum, Bag, Storage Tank, etc)		
8. Samples Taken (Yes/No; Specify Analyses Requested/Performed)		
9. Cause of Release		
10. Release Scene Description (Contaminated Area, Path of Release, etc)		
11. Document the Action Taken/Planned to Mitigate the Release		
12. On-Scene Weather/Wind (Temp, Humidity, Wind Velocity, Visibility, etc)		
13. Areas Threatened/Damaged (Beach, Wetlands, Water Intake, Aquifer, etc)		
14. Potential Dangers (Fire, Explosion, Toxic Vapor, etc)		
15. Notifications Made (NRC, Coast Guard MSO, EPA, State, Local Agency, etc)		
16. Telephonic Report to NRC was/was not made (NRC POC/Report Number)		
17. POC for Report (Person, Activity, Phone Number)		
18. Document Any Other Relevant Information Pertaining to the Release		
Document the Presence of Free Product (If Known)		
State how the Release Was Discovered		
Are There Any Water Supply Wells Within 1,500 Feet of the Release?		
If Yes, How Many Water Supply Wells are within 1,500 feet of the Release		
Was any surface water impacted or the spill within 100 feet or less of any surface water?		
Latitude and Longitude of Release	Latitude (Decimal Degrees)	Longitude (Decimal Degrees)
Directions to the spill site	Map Attached	

ATTACHMENT J-0200000-05-4
CONTRACTOR HAZARDOUS MATERIAL INVENTORY LOG

CONTRACTOR HAZARDOUS MATERIAL INVENTORY LOG
(EPCRA 312&313 WORKSHEET)

Company Name:_____ CONTRACT NO:_____

Product Name or Trade	Manufacturer	Max Amount of Product Stored on Site	Amount of Product Used (e.g Gallons, Pounds)	Specific Gravity (or weight/volume	Toxic Chemical Ingredient in Product Refer to MSDS & List individually)	Toxic Chemical CAS# (Refer to MSDS)	% Toxic Chemical by Weight	Days on Site

() Contractors certify that no hazardous materials will be brought onto the installation and/or used at the project site.

() Contractors certify that no hazardous waste will be generated from this project.

Submitted By:_____ Phone:_____ Date:_____

Contract Administrator:_____ Phone_____ Date:_____

ATTACHMENT J-1502000-01
DEFINITIONS AND ACRONYMS

DEFINITION	DESCRIPTION
CRANE, CATEGORY 1	Portal cranes, Hammerhead cranes, Locomotive cranes, Derricks, Floating cranes (YD), Tower cranes, Container cranes, Mobile cranes (except those indicated as category 4), including truck, cruiser, crawler, warehouse/industrial cranes, and cranes used for dragline, pile driving, clamshell, magnet, bucket work, and Aircraft crash cranes.
CRANE, CATEGORY 2 & 3	Cranes with rated capacities of 20,000 pounds or greater are category 2. Examples are Over head traveling cranes, Gantry cranes (rail mounted), Wall cranes, Jib cranes, Pillar cranes, Pillar jib cranes, Monorails and associated hoists, Fixed hoists, including chain falls. Pedestal mounted commercial boom assemblies (fixed length, telescoping, and articulating types) attached to stake trucks, trailers, flatbeds, or railcars, or stationary mounted to piers, etc., with OEM rated capacities less than 2,000 pounds.
CRANE, CATEGORY 4	Commercial truck mounted cranes, Truck mounted articulating boom cranes, Pedestal mounted commercial boom assemblies (fixed length, telescoping, and articulating types) attached to stake trucks, trailers, flatbeds, or railcars, or stationary mounted to piers, etc., with OEM rated capacities of 2,000 pounds and greater. Commercial truck mounted cranes and truck mounted articulating boom cranes with OEM capacities of 2,000 pounds and greater require a licensed operator even if the cranes are down rated below 2,000 pounds capacity for administrative purposes.
EQUIPMENT, COLLATERAL	Encompasses built-in and large substantially affixed equipment/property that is normally acquired and installed as part of a facility project.
EQUIPMENT, INSTALLED	Encompasses building-type equipment, built-in equipment, and large, substantially affixed equipment/property, and is normally acquired and installed as part of a facility project. Installed equipment is normally required to make a facility useful and operable. Removing such equipment would impair the usefulness, safety, or environment of the facility or the facility restoration work required after its removal, is substantial.
EQUIPMENT, PERSONAL PROPERTY	Personal property equipment includes all equipment other than collateral equipment. Such equipment, when acquired and used in a facility or a test apparatus, can be severed and removed after erection or installation without substantial loss of value or damage thereto or to the premises where installed.
FACILITIES LIFE CYCLE	A facilities life cycle is divided into four stages, requirements (planning and design), acquisition (construction and acceptance), stewardship (operations, maintenance and repair), and disposal.
FACILITIES MAINTENANCE MANAGEMENT	The planning, prioritizing, organizing, controlling, reporting, evaluating, and adjusting of facilities maintenance operations to support the CNO/NAVFAC facilities policy and objectives and satisfy customers' facility needs. Defined by the International Facility Management Association as "the practice of coordinating the physical workplace with the people and work of the organization."

ATTACHMENT J-1502000-01
DEFINITIONS AND ACRONYMS

DEFINITION	DESCRIPTION
Integrated Maintenance Program (IMP)	IMP is a recurring state-of-the-art, reliability-centered inspection, testing, maintenance and repair program that determines best practices for managing the functions and consequences of failures of facilities equipment and system components. IMP encompasses accepted commercial practices, including reactive, preventive, predictive and proactive maintenance, into one optimal program. The IMP approach gives the Contractor full responsibility to maintain systems and equipment and perform repairs whenever necessary to ensure equipment and systems are operational and remain in a constant state of readiness. Service calls will not be issued for accomplishment of repairs on systems and equipment maintained under IMP.
LIFE-CYCLE COSTS	A form of economic analysis that considers the total cost of owning, operating, and maintaining a building or system over its useful life.
MAINTENANCE, PREVENTIVE	Maintenance designed to increase the availability of the facilities/equipment by reducing the number of unexpected breakdowns or service interruptions. It is any planned maintenance activity that improves equipment life and avoid any unplanned maintenance requirements.
MANAGEMENT INFORMATION SYSTEMS- MAINTENANCE	A computerized system that will provide sufficient information for management to evaluate differences between budgets and actual costs and evaluate performance.
REPAIR	Repair is the restoration of facilities or equipment to such a condition that it may be effectively utilized for its designated purposes by overhaul, reconstruction, or replacement of constituent parts or materials which have deteriorated by action of the elements or usage, and which have not been corrected through maintenance. This term also applies to replacement of the entire unit or system if beyond economical repair. The intent of repair is to have the equipment at normal working condition.
REPLACEMENT	Replacement, as a distinct work element, is confined to a program of planned replacement of a facility or its components. It may be further limited to major components such as air conditioning compressors, furnaces or hot water heaters. Replacement is performed when the equipment has reached the end of its useful life; when it no longer can perform due to degradation of its internal components and repair is no longer cost effective. Included under the replacement would be the major rebuilding of any component, since rebuilding also restores performance.
RESTORATION	Restoration of real property to such a condition that it can be used for its intended purpose. Includes repair or replacement work to restore facilities damaged by inadequate sustainment, excessive age, natural disaster, fire, accident or other causes.
SUSTAINMENT	Maintenance and repair activities necessary to keep a typical inventory of facilities in "normal working condition". Sustainment includes regularly scheduled maintenance as well as cyclical major repairs or replacement of components that occur periodically over the expected service life of the facilities.

ATTACHMENT J-1502000-01
DEFINITIONS AND ACRONYMS

DEFINITION	DESCRIPTION
SERVICE ORDER	Any work required to return a facility, system, equipment or component to normal working condition. Service orders are minor facility problem requests or requests for other non-recurring work that is too small to be planned and estimated. The purpose of a service order is to provide the Government with a means of issuing work up to a defined liability limit for requirements occurring outside of the specified recurring work. The Government may utilize service orders to accomplish any work up to the respective liability limit based on the service order classification.
SERVICE ORDER CYCLE	Count down starts when the customer is notified that the work has been accepted to be accomplished to the time when the work chit is turned in by the craftsmen as complete is one complete cycle period for a service order.
SERVICE ORDER, EMERGENCY	Emergency is defined as any facility deficiency that immediately compromises the mission or life, health and safety. Always includes, but is not limited to, failure of any utility, fire protection, environmental control, or security alarm systems.
SERVICE ORDER, URGENT	Urgent is defined as any deficiency that does not immediately endanger personnel or property, but extended delays of repairs could result in damage to Government property, or soon affect the security, health, or well-being of personnel or the continued operation of a service or system.
SERVICE ORDER, ROUTINE	Routine is defined as any work requirement within the defined LOL that does not qualify as emergency or urgent.
WEIGHT HANDLING EQUIPMENT (WHE)	Weight handling equipment consists of cranes (e.g., portal cranes, jib cranes), rigging gear (e.g., slings, shackles), and associated equipment (e.g., portable hoists, dynamometers). For purposes of this technical sub-annex, WHE does not include mobile or transportable truck, crawler, and railway mounted locomotive cranes covered in 1700000 BSVE.

ATTACHMENT J-1502000-01
DEFINITIONS AND ACRONYMS

Acronym	Title
BPVC	Boiler and Pressure Vessel Code
HVAC	Heating, Ventilation, and Air Conditioning
RPIE	Real Property Inventory Equipment
SCADA	Supervisory Control And Data Acquisition
SRM	Sustainment, Restoration and Modernization
UFC	Unified Facilities Criteria
UPV	Unfired Pressure Vessel
VTE	Vertical Transportation Equipment

ATTACHMENT J-1502000-02
REFERENCES AND TECHNICAL DOCUMENTS

Reference	Title
UCF 3-601-02 8 September 2010	Operation and Maintenance: Inspection, Testing, and Maintenance of Fire Protection Systems
Appendix A of UCF 3-601-02 8 September 2010	All Code and Building standards listed in this Appendix shall apply to the work under this contract as well as the standards in (UCF 3-601-02)

J-1502000-03

Facilities Property Inventory

AS256 Telephone Exchange

Devices	Quantity	Freq
Simplex 4100ES FACP	1	A
Simplex Digital Alarm Communicator Transmitter	1	A
12 Volt 110 Amp Hour Battery (For FACP)	2	A
Simplex Annunciator	1	A
Simplex Local Operating Console	1	A
Simplex Pull Station	8	A,2
Simplex Smoke Detector	4	2,5
Simplex Door Holder	3	2,5
Speaker/Strobe	56	A
Speaker	10	A
Strobe	1	A
Simplex Monitor Module	12	A
Simplex Relay Module	3	A
Electric Bell - System Sensor SSM 24-8	1	A
Waterflow Switch - Potter	1	A
Pressure Switch - Potter	1	
Xtralis VESDA VLP-002	3	A
Simplex Releasing Panel	1	A
12 Volt 110 Amp Hour Battery (For Releasing)	2	A
Simplex Pull Station (FM200 Release)	5	A,2
Simplex Abort Switch	4	A,2
Simplex Disconnect/Disable Switches	5	A
Simplex Horn/Strobe	3	A
FM200 Cylinder	8	5
FM200 Nozzel	13	A
Simplex Monitor Module	17	A
Simplex Relay Module	9	A
Xtralis Vesda VLP-002	3	A
Wet System	1	A
Pre-Action System	1	A
Nitrogen Generator - Potter	1	A
Tamper, OS&Y - Potter	2	A
Tamper, Butterfly - Anvil Gruvlok	3	A
Tamper, Butterfly - Victaulic Firelock Series	2	A
Sprinkler Head	164	20,50
Gauge Water	4	A,10
Gauge Air/Water	1	A,10
Fire Department Connection	1	A

Telephone Exchange is 19,414 Square Feet

AS320 Simulator

Devices	Quantity	Freq
Simplex 4100ES Fire Alarm Control Panel	1	A
12 Volt 110 Amp Hour Battery	2	A
IDNet Double Action Pull Station	16	A
IDNet Supervised IAM	18	A
IDNet Isolator Module	1	A
True Alarm Photo Smoke Detector	26	2,5
True Alarm Duct Smoke Detector w/Relay Output	6	2,5
Remote Test Station w/LED and Key Switch	6	A
Encapsulated Relay PAM-SD	6	A
Speaker/Strobe	39	A
Speaker	10	A
Strobe	7	A
Releasing Panel CO ₂ - Fike Cheetah Xi	1	A
Power Supply - Fire-Lite FCPS-24FS8	1	A
Power Supply - Fire-Lite FCPS-24FS6	1	A
12 Volt 55 Amp Hour Battery	2	A
12 Volt 18 Amp Hour Battery	4	A
CO ₂ Cylinders	9	A,10
CO ₂ Hose Reel	2	A
CO ₂ Nozzles	1	A
Potter - Manual Release Pull Station	7	A
Fike - Smoke Detector	14	2,5
Fike - Heat Detector	72	2
Fike - Release Module	3	A
Horn/Strobe (Red Lens)	4	A
Sprinkler System - Wet	1	A
Sprinkler System - Pre-Action	2	A
Air Compressor	2	A
Sprinkler Head	225	20,50
Water Gong	2	A

Simulator Trainer is 21,201 Square Feet

TC755
Telephone Exchange

Devices	Quantity	Freq
AutoPulse Z-10 Agent Release Control Panel	1	A
12 Volt 7 Amp Hour Battery	2	A
Inergen Cylinder	8	5
Inergen Nozzel	1	A
Inergen Release Pull Station	1	A
Abort Push and Hold Switch	1	A
Smoke Detector (Zone)	8	2,5
Horn/Strobe	3	A
Magnetic Door Holder	1	A

Telephone Exchange is 1,504 Square Feet

Building 895
MCCS Central Administrative Offices

Devices	Quantity	Freq
Simplex 4010 Fire Alarm Control Panel	1	A
12 Volt 33 Amp Hour Battery	2	A
Wheelock SafePath Model SP40S	1	A
12 Volt 7 Amp Hour Battery	2	A
Simplex Smoke Detector (Addressable)	1	2,5
Garnwell Flex Alarm Extension Relay	1	A
Anti-freeze Loop	1	5
Sprinkler System - Wet	1	A
Pressure Switch - System Sensor EPS10-1	1	A
Guage - Water 0 - 300 PSI	1	A,10
Releasing Panel - Fenwall Model 2320	1	A
FM200 Shotgun System	1	5
FM200 Nozzel	1	A
Push Switch (Push to Start / Push to Stop)	1	A
Smoke Detector	4	2,5
Horn	1	A
Sprinkler Head	112	20,50

MCCS Administrative Offices is 16,782 Square Feet

BB248
Telephone Exchange

Devices	Quantity	Freq
Gamewell/FCI 7100-1D Fire Alarm Control Panel	1	A
12 Volt 7 Amp Hour Battery	2	A
FM200 Cylinder	6	5
FM200 Nozzel	8	A
FM200 Release Pull Station	2	A
Abort Push and Hold Switch	2	A
Fire Alarm Pull Station	2	A,2
Horn/Strobe	12	A
Suppression Disconnect Switch	2	A
Container Main and Reserve Switch	1	A
Fike Xi Suppression Releasing Panel	1	A
12 Volt 18 Amp Hour Battery	2	A
Fike VESDA High Level Interface (HLI)	1	A
12 Volt 12 Amp Hour	2	A
Xtralis VESDA Power Supply Model VPS-100US	1	A
Xtralis VESDA LASER Compact Detector	3	A
Sprinkler System - Pre-Action	1	A
Air Compressor - Riser Mount	1	2
Tamper Switch - System Sensor OSY2	2	A
Tamper Butterfly - NIBCO	2	A
Guage - Water 0 - 300 PSI	2	A,10
Guage - Air 0 - 80 PSI with 80 - 250 PSI Retard	1	A,10
Pressure Switch - Low/Hi Air	1	A
Pressure Switch - Water	1	A
Sprinkler Heads	35	20,50

Telephone Exchange is 2,827 Square Feet

FC307
Telephone Exchange

Devices	Quantity	Freq
Fike Cheetah Xi Fire Alarm Control Panel	1	A
BOSCH FPT-DACT-LC D9068	1	A
12 Volt 75 Amp Hour Battery	2	A
FM200 Cylinder	6	5
FM200 Nozzel	8	A
FM200 Release Pull Station	2	A
Abort Push and Hold Switch	1	A
Fire Alarm Pull Station	2	A,2
Horn/Strobe	11	A
Suppression Disconnect Switch	1	A
Container Main and Reserve Switch	2	A
Fike Vesda LASER Plus Detector	1	A
Annunciator - Fike 14 Button Remote Display	1	A

Telephone Exchange is 3,944 Square Feet

H1

Telephone Exchange

Devices	Quantity	Freq
Simplex 4100U Fire Alarm Control Panel	5	A
Simplex Transponder	4	A
12 Volt 110 Amp Hour Battery	4	A
12 Volt 6.2 Amp Hour Battery	26	A
12 Volt 7 Amp Hour Battery	2	A
12 Volt 7.2 Amp Hour Battery	2	A
12 Volt 18 Amp Hour Battery	2	A
12 Volt 50 Amp Hour Battery	4	A
Simplex Audible Annunciator	1	A
Simplex Graphic Annunciator	1	A
Simplex 4009 IDNet NAC Extender	13	A
Simplex Fire Alarm Terminal Cabinet	9	A
Simplex Manual Pull Station (Addressable)	110	A,2
Simplex Smoke Detector (Addressable)	506	2,5
Simplex Heat Detector (Addressable)	18	2
Simplex Duct Detector (Addressable)	72	A,2
Simplex Remote LED Indicator	72	A
Simplex Relay - Encapsulated	83	A
Simplex IAM - Monitor	30	A
Simplex IAM - Control Relay	8	A
Simplex IAM Signal	4	A
Remote Firefighter Telephone Cabinet	12	A
Firefighter Phone	37	A
Firefighter Phone Jack	28	A
Speaker/Strobe	569	A
Speaker	199	A
Strobe	28	A
Tamper Switch	13	A
Water Flow Switch	3	A
Pressure Switch	8	A
Guage - Water 0 - 300 PSI	14	A,10
Guage - Air/Water 0 - 300 PSI	1	A,10
Guage - Air 0 - 80 & 80 - 250 PSI with retard	2	A,10
Guage 0 - 100 PSI	1	A,10
Guage 0 - 200 PSI	2	A,10
Water Gong	4	A
Sprinkler System - Wet	5	A
Sprinkler System - Dry	4	A
Sprinkler System - Pre-Action	1	A
Sprinkler Heads	1500	20,50
AutoPulse Z-10 Agent Release Control Panel	1	A
Inergen Cylinder	6	5
Inergen Nozzel	9	A

H1

Telephone Exchange

Simplex Smoke Detectors (Zone)	5	2,5
Simplex Heat Detector (Zone)	2	2
Inergen Pull Station	1	A
Pre-Action Pull Station	1	A
Abort Push and Hold Switch	1	A
Horn/Strobe	2	A
Bell - Wheelock 4-inch	1	A

Headquarters is 395,500 Square Feet

HP5 Telephone Exchange

Devices	Quantity	Freq
EST Quick Start Fire Alarm Control Panel	1	A
EST Dual Line Dialer (DLD)	1	A
12 Volt 7 Amp Hour Battery	4	A
AutoPulse Z-10 Agent Release Control Panel	1	A
Inergen Cylinder	26	5
Inergen Nozzel	5	A
Inergen Pull Station	2	A
Abort Push and Hold Switch	2	A
Fire Alarm Pull Station	2	A,2
Horn/Strobe	7	A
Simplex Smoke Detectors (Zone)	16	2,5
EST Smoke Detectors (Addressable)	8	2,5
Sprinkler System - Pre-Action	1	A
Grinnell Supervisory Air Panel (Model F112)	1	A
Barksdale, Inc. Pressure Actuated Switch	1	A
Tamper Switch - System Sensor OSY2 Tamper Switch	2	A
Waterflow Switch - Potter PS10-1A	1	A
Gauge - Water 0 - 300	3	A,10
Gauge - Air / Water 0 - 300 PSI	1	A,10
Sprinkler Heads	35	20,50
Water Gong	1	A

Telephone Exchange is 4,292 Square Feet

M165 **Telephone Exchange**

Devices	Quantity	Freq
Fike Cheetah Xi Fire Alarm Control Panel	1	A
BOSCH FPT-DACT-LC D9068	1	A
12 Volt 75 Amp Hour Battery	2	A
FM200 Cylinder	4	5
FM200 Nozzel	7	A
FM200 Release Pull Station	2	A
Abort Push and Hold Switch	2	A
Fire Alarm Pull Station	2	A,2
Horn/Strobe	11	A
Suppression Disconnect Switch	1	A
Container Main and Reserve Switch	1	A
Fike Vesda LASER Plus Detector	1	A
Annunciator - Fike 14 Button Remote Display	1	A

Telephone Exchange is 2,756 Square Feet

PP5
Telephone Exchange

Devices	Quantity	Freq
Simplex 4006 Fire Alarm Control Panel	1	A
12 Volt 10 Amp Hour Battery	2	A
Fenwalnet 6000 Suppression Releasing Panel	1	A
12 Volt 18 Amp Hour Battery	2	A
Altronix Power Supply Charger	1	A
12 Volt 12 Amp Hour Battery	2	A
FM200 Cylinder	4	5
FM200 Nozzel	10	A
FM200 Release Pull Station	2	A
Abort Push and Hold Switch	2	A
Fire Alarm Pull Station (Addressable)	3	A,2
Horn/Strobe	5	A
Strobe	1	A
IDNet Supervised IAM	11	A
Suppression Disconnect Switch	1	A
Simplex Smoke Detector (Addressable)	2	2,5
Fenwalnet Smoke Detector	1	2,5
Air Intelligence ASD-320	1	A
Air Intelligence ASD-640 Basic Detector	2	A
Sprinkler System - Pre-Action	1	A
Air Compressor - Tank Mounted	1	2
Gauge - Water 0 - 300 PSI	2	A,10
Gauge - Air/Water 0 - 300 PSI	1	A,10
Tamper Switch Butterfly - Vitaulic	2	A
Tamper Switch - Potter OYSU-2	2	A
Tamper Switch - Potter PCVS-2	1	A
Pressure Switch - System Sensor EPS10-2V	1	A
Pressure Switch - System Sensor EPS10-2	1	A
Electric Bell - Potter PBA-6-120	1	A
Sprinkler Head	33	20,50

Telephone Exchange is 3,000 Square Feet

RR134 **Telephone Exchange**

Devices	Quantity	Freq
Johnson Control IFC-320 Fire Alarm Control Panel	1	A
Notifier UDACT-2	1	A
12 Volt 55 Amp Hour Battery	2	A
Pull Station (Addressable)	1	A,2
Horn/Strobe	6	A
Strobe	2	A
Smoke Detector (Addressable)	8	2,5
Module - Relay	1	A
Module - Single Inpute	7	A
Relay - Shunt Trip (120VAC Coil)	1	A
Sprinkler System - Pre-Action	1	A
Air Compressor - Tank Mounted	1	2
Pressure Switch - System Sensor EPS10-2	1	A
Pressure Switch - System Sensor EPS40-2	1	A
Guage - Air/Water 0 - 300 PSI	2	A,10
Guage - Air/Water 0 - 250 PSI	1	A,10
Guage - Water 0 - 300 PSI	2	A,10
Sprinkler Head	31	20,50

Telephone Exchange is 4,015 Square Feet

Building 1043 Range Control

Devices	Quantity	Freq
Notifier NFS2-640 FACP	1	A
Notifier Universal Digital Alarm Communicator Transmitter	1	A
Notifier Power Supply FCPS-24S8	3	A
Notifier Power Supply CPS-24	4	A
12 Volt 100 Amp Hour Battery (For FACP)	4	A
12 Volt 7 Amp Hour Battery (For FCPS-24S8)	6	A
12 Volt 100 Amp Hour Battery (For CPS-24)	6	A
12 Volt 35 Amp Hour Battery (For CPS-24)	2	A
Notifier Annunciator	1	A
Notifier Pull Station	9	A,2
Notifier Smoke Detector	3	2,5
Notifier Duct Detector	1	2,5
Speaker/Strobe	75	A
Speaker	50	A
Strobe	6	A
Electric Bell - Potter MBA-6-24	1	A
Waterflow Switch - Potter	2	A
Xtralis VESDA VLF	1	A
Kidde Aries Releasing Panel	1	A
12 Volt 26 Amp Hour Battery	2	A
Kidde Pull Station (FM200 Release)	5	A,2
Kidde Smoke Detector	15	2,5
Kidde Abort Station	5	A,2
Kidde Horn/Strobe	2	A
Kidde Strobe	6	A
FM200 Cylinder	2	5
FM200 Nozzel	7	A
Kidde Monitor Module	9	A
Kidde Relay Module	1	A
Xtralis Vesda VLP-012	1	A
Xtralis Vesda VLF-500	2	A
Altronix Supervised Power Supply/Charger VLPPS	3	A
12 Volt 12 Amp Hour Battery (For VLPPS)	6	A
Tamper, OS&Y - Potter	2	A
Tamper, Butterfly - Victaulic Firelock Series 705	2	A
Sprinkler Head	300	20,50
Gauge Water	2	A,10
Fire Department Connection	1	A

Range Control is 21,694 Square Feet

WC99
Telephone Exchange

Devices	Quantity	Freq
Simplex 4100U Fire Alarm Control Panel	1	A
12 Volt 110 Amp Hour Battery (For FACP)	2	A
12 Volt 12 Amp Hour Battery (For Power Supply)	2	A
Power Supply - Simplex 4009 IDNet NAC Panel	1	A
Simplex True Alert LASER Compact VESDA	2	A
Simplex Pull Station (Addressable)	2	A,2
Supervisory Release Periph & Enclosure	1	A
2 Amp Coil Supervisory Module	1	A
IDNet Class A Monitor ZAM	1	A
Horn/Strobe	3	A
Strobe	5	A
Abort Push and Hold Switch	1	A
Sprinkler System - Pre-Action	1	A
Air Compressor - Riser Mounted	1	2
Tamper Switch - System Sensor OSY2	2	A
Tamper Butterfly - NIBCO	1	A
Guage - Water 0 - 300 PSI	1	A,10
Guage - Air 0 - 80 PSI with 80 - 250 PSI Retard	1	A,10
Guage - 0 - 60 oz/in ²	1	A,10
Supervisory Pressure Switch	1	A
Sprinkler Head	35	20,50

Telephone Exchange is 4,310 Square Feet

WC507
2nd Radio Battalion Complex

Devices	Quantity	Freq
Notifier NFS2-640 FMCP	1	A
Notifier Universal Digital Alarm Communicator Transmitter	1	A
Notifier NFS2-640 (Node 4)	1	A
Notifier (PSTC)	1	A
Honeywell Power Supply Model: HPFF8-CM	1	A
12 Volt 100 Amp Hour Battery (For FMCP)	2	A
12 Volt 100 Amp Hour Battery (For Node 4)	2	A
12 Volt 40 Amp Hour Battery (For FMCP)	2	A
12 Volt 40 Amp Hour Battery (For PSTC)	2	A
12 Volt 7 Amp Hour Battery (For HPFF8-CM)	2	A
Notifier Annunciator	1	A
Notifier Pull Station	13	A,2
Notifier Smoke Detector	2	2,5
Notifier Smoke /CO Detector	2	A,2,5
Notifier Duct Detector	6	2,5
Speaker/Strobe	128	A
Speaker	14	A
Electric Bell - Potter MBA-6-24	1	A
Waterflow Switch - Potter	2	A
Xtralis VESDA VLF	1	A
Fike Cheetah Xi Releasing Panel	1	A
BOSCH FPT-DACT-LC D9068	1	A
12 Volt 75 Amp Hour Battery	2	A
FM200 Cylinder	2	5
FM200 Nozzel	2	A
FM200 Release Pull Station	1	A
Abort Push and Hold Switch	1	A
Fire Alarm Pull Station	2	A,2
Gentex Strobe	3	A
Suppression Disconnect Switch	1	A
Container Main Switch	2	A
Fike Vesda LASER Plus Detector	1	A
Fike Monitoring Module	5	A
Fike Control Module	3	A
Fike Relay Module	8	A
Fike Releasing Module	1	A
Tamper, OS&Y	2	A
Tamper, Butterfly - NIBCO	2	A
Sprinkler Head	600	20,50
Gauge Water	3	A,10
Gauge Air/Water	1	A,10
Fire Department Connection	1	A

2nd Radio Battalion Complex is 55,628 Square Feet

BUILDING 24

DEVICES	QUANTITY	FREQ
Simplex 4100 Fire Control Panel	1	A
Smoke Detector	2	2.5
Manual Pull Stations	12	A
Waterflow Switch	2	A
Supervisory Swith	9	A
Alarm Pressure Switch	2	A
Potter Preaction Panel PFC-4410RC	1	A
Releasing Solinoid	3	A
EST Clean Agent Panel Minimax MX-2002	2	A
Clean Agent Pull Stations	4	A

Building 835
Lejeune High School

Devices	Quantity	Freq
Simplex 4009 N.A.C Power Extender (non-peripheral)	1	A
Smoke Detector (2 located at Baseball/Softball Field Concession Stand/Bathroom Facility)	9	A, 2, 5
Simplex 4002 (Fire Alarm Panel)	1	A
Duct Smoke Detector-Analog (Sensitivity Not Required)	20	A
Pull Station	23	A, 2
Audible Visual Devices (Horns, Strobes, Speakers, etc.)	48	A
Heat Detector	12	A, 2
1AM (Addressable Monitor Module)	28	A
Sprinkler System - Wet	1	A
Sprinkler Head	151	2, 5
Water F2low Switch – System Sensor WFD40	1	A
Tamper Switch – System Sensor OS&Y	2	A
Gauge – Water (0-300 PSI)	2	A, 10
Domestic Water Sprinkler System	7	A
Water Flow Switch	7	A
Tamper Switch	7	A
Fire Department Connection (FDC)	1	A

Lejeune High School is 122,601 Square Feet

Building 855

District Superintendent's Office

Devices	Quantity	Freq
Simplex 4100ES (Fire Alarm Panel)	1	A
Smoke Detector (2 located at Baseball/Softball Field Concession Stand/Bathroom Facility)	5	A, 2, 5
Duct Smoke Detector	1	A
Pull Stations	12	A, 2
Remote Test Stations	1	A
Audible Visual Devices (Horns, Strobes, Speakers, etc.)	50	A
Heat Detector	1	A, 2
Domestic Water Sprinkler System	2	A
Sprinkler Head	902	2, 5
Fire Department Connection (FDC)	1	A

District Superintendent's Office 17,067 Square Feet

Building 883**Brewster Middle School**

Devices	Quantity	Freq
Simplex 4009 N.A.C Power Extender (non-peripheral)	4	A
Smoke Detector (2 located at Baseball/Softball Field Concession Stand/Bathroom Facility)	7	A, 2, 5
Simplex 4002 (Fire Alarm Panel)	1	A
Duct Smoke Detector-Analog (Sensitivity Not Required)	16	A
Pull Station	27	A, 2
Audible Visual Devices (Horns, Strobes, Speakers, etc.)	124	A
Graphic Annunciator L.E.D. Model W-2	10	A
Sprinkler System - Wet	3	A
Sprinkler Head	1,143	2, 5
Water Flow Switch - Potter VSR-F	3	A
Tamper Switch - Potter OSYSU-2	5	A
Tamper Butterfly - Victaulic Series 705W	1	A
Tamper - System Sensor PIBV2	1	A
Gauge - Water (0-300 PSI)	6	A, 10
Bell - Potter 115VIC	1	A
Fire Department Connection (FDC)	1	A
Clocks-Simplex 6351 Time Control System I Digital: 13, Analog: 102 (hardwired, controlled by master clock) Bell system is integrated with master clock	1	A

Brewster Middle School 126,852 Square Feet

Building 2027
Johnson Primary School

Devices	Quantity	Freq
Siemens MXL Fire Alarm Control Panel	1	A
12 Volt 75 Amp Hour Battery	2	A
Power Supply - Notification Appliance Circuit	5	A
12 Volt 7 Amp Hour Battery	10	A
Siemens MDACT DCT-1	1	A
Fire Alarm Pull Station (Addressable)	35	A,2
Smoke Detector (Addressable)	13	2,5
Duct Detector (Addressable)	18	2,5
Horn/Strobe	72	A
Strobe	109	A
Monitor Module - TRI-S	7	A
Monitor Module - TRI-R	5	A
Relay - TRI-R	18	A
Magnetic Door Holder	3	A
Sprinkler System - Wet	1	A
Sprinkler Heads	1050	20,50
Gauge - Water 0 - 300 PSI	2	A,10
Waterflow Switch - System Sensor WFD60	2	A
Tamper - System Sensor OSY2	4	A
Bell - System Sensor SSV120-8	1	A
Fire Department Connection (FDC)	1	A

Johnson Primary School is 103,254 Square Feet

Building 2028
Bitz Intermediate School

Devices	Quantity	Freq
Siemens MXL Fire Alarm Control Panel	1	A
12 Volt 75 Amp Hour Battery	2	A
Power Supply - Notification Appliance Circuit	4	A
12 Volt 7 Amp Hour Battery	8	A
Fire Alarm Pull Station (Addressable)	24	A,2
Smoke Detector (Addressable)	10	2,5
Duct Detector (Addressable)	22	2,5
Horn/Strobe	65	A
Strobe	75	A
Monitor Module - TRI-S	8	A
Monitor Module - TRI-R	6	A
Relay - TRI-R	22	A
Magnetic Door Holder	3	A
Sprinkler System - Wet	1	A
Sprinkler Head	850	20,50
Gauge - Water 0 - 300 PSI	2	A,10
Waterflow Switch - System Sensor WFD60	2	A
Tamper - System Sensor OSY2	4	A
Bell - System Sensor SSV120-8	1	A
Fire Department Connection (FDC)	1	A

Bitz Intermediate School is 84,894 Square Feet

Building PP201
Heroes Elementary School

Devices	Quantity	Freq
Simplex 4009 N.A.C Power Extender (non-peripheral)	2	A
Smoke Detector (2 located at Baseball/Softball Field Concession Stand/Bathroom Facility)	12	A, 2, 5
Simplex 4100U (Fire Alarm Panel)	1	A
Simplex Fire Alarm Transponder	1	A
Duct Smoke Detector-Analog (Sensitivity Not Required)	14	A
Door Holder	4	A
Audible Visual Devices (Horns, Strobes, Speakers, etc.)	207	A
IAM (Addressable Monitor Module)	11	A
Heat Detector	31	A, 2
Remote Test Stations	6	A
Local Operating Console	5	A
Sprinkler System - Wet	1	A
Sprinkler Head	902	2, 5
Gauge - Water (0-300 PSI)	6	A, 10
Water Flow Switch - System Sensor WFD40	2	A
Water Flow Switch - System Sensor WFD60	1	A
Tamper - System Sensor OSY2	5	A
Fire Department Connection (FDC)	1	A

Heroes Elementary School 115,763 Square Feet

Building TT84

Tarawa Terrace Elementary School

Devices	Quantity	Freq
EST 3 Fire Alarm Control Panel	1	A
12 Volt 55 Amp Hour Battery	4	A
Power Supply - Notification Appliance Circuit	20	A
12 Volt 7 Amp Hour Battery	24	A
12 Volt 10.5 Amp Hour Battery	2	A
12 Volt 12 Amp Hour Battery	10	A
12 Volt 18 Amp Hour Battery	4	A
Annunciator - Audible	2	A
Annunciator - Graphic	2	A
Fire Alarm Pull Station (Addressable)	54	A, 2
Smoke Detector (Addressable)	18	2, 5
Duct Detector (Addressable)	11	2, 5
Duct Test Station w/Key	11	2, 5
Magnetic Door Holder	16	A
Module - Single Input	6	A
Module - Control Relay	16	A
Module - Synchronized Input Signal	11	A
Speaker/Strobe	201	A
Speaker/Strobe	85	A
Strobe	24	A
Sprinkler System - Wet	2	A
Sprinkler Head	716	2, 5
Gauge - Water O - 300 PSI	2	A, 10
Gauge - Air/Water O - 300 PSI	3	A, 10
Water Flow Switch - Potter VSR	1	A
Pressure Switch - Water Potter WFSR-F	2	A
Tamper - Potter OSYU-2	6	A
Tamper Butterfly - Victaulic	1	A
Tamper Butterfly - Fivalco	1	A
Tamper Ball Valve - Potter BVS	2	A
Tamper PIV - Potter PCVS-2	1	A
Bell - Electric HC-120	1	A
Water Gong - Victaulic 168-205	1	A
Fire Department Connection (FDC)	1	A
Clocks-Simplex Master Clock 6400 Annual	1	A
Digital: 20 (10 Dual Face) corridor clocks, Analog: 25- 12" classroom clocks (hardwired, controlled by master clock)		

Tarawa Terrace Elementary School 126,908 Square Feet

AS990
Delalio Elementary School

Devices	Quantity	Freq
Simplex 4100ES FACP	1	A
Simplex Digital Alarm Communicator Transmitter	1	A
12 Volt 110 Amp Hour Battery (For FACP)	2	A
Simplex IDNet NAC Extender Power Supply	2	A
12 Volt 7 Amp Hour Battery (For Power Supply)	4	A
Simplex Annunciator	1	A
Simplex Local Operating Console	1	A
Simplex Pull Station	31	A,2
Simplex Smoke Detector	31	2,5
Simplex Duct Detectors	7	2,5
Simplex Door Holder	6	2,5
Speaker/Strobe	56	A
Speaker	10	A
Strobe	8	A
Simplex Monitor Module	12	A
Simplex Relay Module	3	A
Electric Bell - System Sensor SSM 24-8	1	A
Waterflow Switch - Potter	1	A
Wet System	1	A
Tamper, OS&Y - System Sensor	2	A
Tamper, Butterfly - Kennedy	2	A
Sprinkler Head	650	20,50
Gauge Water	1	A,10
Gauge Air/Water	1	A,10
Fire Department Connection	1	A

Delalio Elementary School is 66,880 Square Feet