

Inspection and Testing Certificate

Presented To

WASHITA BATTLEFIELD CTR

For

WASHITA BATTLEFIELD CTR

18555 HIGHWAY 47
STE A
CHEYENNE, Oklahoma 73628
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Wednesday, June 25, 2025

Test Session :ANNUAL FIRE ALARM INSPECTION, OJ4658

Test Plans : FIRE ALARM - ANNUAL

ACCEPTED BY

Doug

WASHITA BATTLEFIELD CTR

18555 HIGHWAY 47

STE A

CHEYENNE, Oklahoma 73628

United States


TESTED BY



INSPECTION STATUS

Acceptable

SYSTEM APPEARS TO BE OPERATIONAL AT THIS TIME



Inspection Summary

Building Information

PROPERTY	WASHITA BATTLEFIELD CTR	CONTACT
ADDRESS	18555 HIGHWAY 47\nSTE A	PHONE
CITY/STATE/ZIP	CHEYENNE, Oklahoma 73628	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY		CONTACT	
ADDRESS		LICENSE NUMBER	
COUNTRY	United States	PHONE	
		EMAIL	

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	22	22(100%)	22(100%)	0(0%)
Batteries & Equipment	2	2(100%)	2(100%)	0(0%)
Emergency Control Equipment	2	2(100%)	2(100%)	0(0%)
Fire Control	1	1(100%)	1(100%)	0(0%)
Initiating Device	52	52(100%)	52(100%)	0(0%)

General Information

Test Session Comment: ANNUAL FIRE ALARM INSPECTION
SYSTEM TAGGED GREEN
ALL CONDITIONS APPEAR TO BE SATISFACTORY.

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, June 25, 2025

ACCEPTED BY	06/25/2025	TESTED BY	06/25/2025
	Doug		
	Building Representative		

System Details

Control Units

ADDRESS / SCAN ADDRESS	MAIN BUILDING	DESCRIPTION	MAIN FACP (TOP OF THE STAIRS)
MANUFACTURER	NOTIFIER	S/W VERSION	
MODEL	NFW2-100	LAST UPDATE	
SERIAL NUMBER		S/W LOCATION	
INSTALL DATE	08/12/2012		

Secondary Power

TYPE	Battery - Sealed Lead-acid	DESCRIPTION	MAIN FACP BATTERY (LEFT)
ADDRESS / SCAN ADDRESS	MAIN BUILDING	NOMINAL VOLTAGE	12
LOAD VOLTAGE	13.2	AMP HOURS	12
STANDBY HOURS	24	ALARM MINUTES	15
BATTERY LOCATION	FACP (LEFT)	CHARGER VOLTAGE	27.9
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	FACP BATTERY (RIGHT)
ADDRESS / SCAN ADDRESS	MAIN BUILDING	NOMINAL VOLTAGE	24
LOAD VOLTAGE	12.98	AMP HOURS	12
STANDBY HOURS	24	ALARM MINUTES	15
BATTERY LOCATION	FACP (RIGHT)	CHARGER VOLTAGE	27.6

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Audible And Visible	MAIN BUILDING	HORN STROBE 1ST FLR BOTTOM OF THE STAIRS	Manual	6/25/2025 3:32:38 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	MAIN BUILDING	HORN STROBE 1ST FLR CONFERENCE ROOM	Manual	6/25/2025 3:32:45 PM
		Manufacturer	SYSTEM SENSOR	
		Model	SRL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE 1ST FLR MAIN ENTRANCE	Manual	6/25/2025 3:32:40 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	MAIN BUILDING	HORN STROBE 1ST FLR NPS BY COPIER	Manual	6/25/2025 3:32:49 PM
		Manufacturer	SYSTEM SENSOR	
		Model	SRL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE 1ST FLR NPS ENTRANCE	Manual	6/25/2025 3:32:48 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE 1ST FLR NPS EXIT	Manual	6/25/2025 3:26:47 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE 1ST FLR NPS OFFICE	Manual	6/25/2025 3:32:43 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE 1ST FLR RISER ROOM HALL	Manual	6/25/2025 3:32:47 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE 2ND FLR OUTSIDE RESTROOM	Manual	6/25/2025 3:32:13 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE 2ND FLR OUTSIDE RESTROOM	Manual	6/25/2025 3:32:36 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE AT MAIN ENTRANCE	Manual	6/25/2025 3:32:27 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE ENTURP. OFFICE	Manual	6/25/2025 3:32:20 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE EXHIBIT	Manual	6/25/2025 3:32:29 PM
		Manufacturer	SYSTEM SENSOR	
		Model	PC2WL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE IN THE BOOKSTORE	Manual	6/25/2025 3:32:33 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Audible And Visible	MAIN BUILDING	HORN STROBE OUTSIDE OF BOOKSTORE	Manual	6/25/2025 3:32:31 PM
		Manufacturer	SYSTEM SENSOR	
		Model	P2RL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	MAIN BUILDING	STROBE ONLY	Manual	6/25/2025 3:32:12 PM
		Manufacturer	SYSTEM SENSOR	
		Model	SRL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	MAIN BUILDING	STROBE ONLY 1ST FLR MENS RESTROOM	Manual	6/25/2025 3:32:41 PM
		Manufacturer	SYSTEM SENSOR	
		Model	SRL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	MAIN BUILDING	STROBE ONLY 1ST FLR WOMENS RESTROOM	Manual	6/25/2025 3:32:35 PM
		Manufacturer	SYSTEM SENSOR	
		Model	SRL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	MAIN BUILDING	STROBE ONLY 2ND FLR MENS RESTROOM	Manual	6/25/2025 3:32:22 PM
		Manufacturer	SYSTEM SENSOR	
		Model	SRL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	MAIN BUILDING	STROBE ONLY 2ND FLR RESTROOM	Manual	6/25/2025 3:32:24 PM
		Manufacturer	SYSTEM SENSOR	
		Model	SRL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Visible	MAIN BUILDING	STROBE ONLY 2ND FLR WOMENS RESTROOM	Manual	6/25/2025 3:32:25 PM
		Manufacturer	SYSTEM SENSOR	
		Model	SRL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible	MAIN BUILDING	STROBE ONLY ENTURP. OFFICE	Manual	6/25/2025 3:32:10 PM
		Manufacturer	SYSTEM SENSOR	
		Model	SRL	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Batteries & Equipment

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid	MAIN BUILDING	FACP BATTERY (RIGHT)	Manual	6/25/2025 3:26:21 PM
		Manufacturer	YUASA	
		Model	NP12-12S, 2022	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Ah Capacity Available	10.8	
		Alarm Minutes	15	
		Amp Hours	12	
		Battery Location	FACP (RIGHT)	
		Charger Voltage	27.6	
		Load Voltage	12.98	
		Nominal Voltage	24	
		Stand By Hours	24	

Battery - Sealed Lead-acid	MAIN BUILDING	MAIN FACP BATTERY (LEFT)	Manual	6/25/2025 3:35:03 PM
		Manufacturer	YUASA	
		Model	NP12-12S	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Ah Capacity Available	11	
		Alarm Minutes	15	
		Amp Hours	12	
		Battery Location	FACP (LEFT)	
		Charger Voltage	27.9	
		Load Voltage	13.2	
		Nominal Voltage	12	
		Stand By Hours	24	

Emergency Control Equipment

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Elevator Recall - Alternate	MAIN BUILDING	ALTERNATE RECALL	Manual	6/25/2025 3:34:55 PM
		Manufacturer	NOTIFIER	
		Model	NFW2-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Elevator Recall - Primary	MAIN BUILDING	PRIMARY RECALL	Manual	6/25/2025 3:34:58 PM
		Manufacturer	NOTIFIER	
		Model	NFW2-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Fire Control

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Control Panel	MAIN BUILDING	MAIN FACP (TOP OF THE STAIRS)	Manual	6/25/2025 3:34:59 PM
		Manufacturer	NOTIFIER	
		Model	NFW2-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

Passed				
EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector - Restorable Spot	MAIN BUILDING 1D:018	HEAT DETECTOR, EVIDENCE LOWER STORAGE	Manual	6/25/2025 3:29:27 PM
		Manufacturer	NOTIFIER	
		Model	NH-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Heat Detector - Restorable Spot	MAIN BUILDING 1D:027	Alarm Verification Participation	True	
		HEAT ELEVATOR EQUIPMENT ROOM	Manual	6/25/2025 3:29:11 PM
		Manufacturer	NOTIFIER	
		Model	NH-100	
		Visual Inspection	Passed (Manual)	
Heat Detector - Restorable Spot	MAIN BUILDING 1D:025	Functional Inspection	Passed	
		Alarm Verification Participation	True	
		HEAT ELEVATOR PIT	Manual	6/25/2025 3:29:13 PM
		Manufacturer	NOTIFIER	
		Model	NH-100	
Heat Detector - Restorable Spot	MAIN BUILDING 1D:014	Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
		HEAT ELEVATOR SHAFT	Manual	6/25/2025 3:29:14 PM
		Manufacturer	NOTIFIER	
Heat Detector - Restorable Spot	MAIN BUILDING 1D:019	Model	NH-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
		HEAT JANITOR CLOSET	Manual	6/25/2025 3:29:16 PM
Manual Pull Station	MAIN BUILDING 1M:002 14145005	Manufacturer	NOTIFIER	
		Model	NBG-12LX	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Manual Pull Station	MAIN BUILDING 1M:006 14145034	PULL BOOKSTORE	Manual	6/25/2025 3:34:50 PM
		Manufacturer	NOTIFIER	
		Model	NBG-12LX	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	MAIN BUILDING 1M:001 14145015	Alarm Verification Participation	True	
		PULL MAIN ENTRANCE	Manual	6/25/2025 3:30:01 PM
		Manufacturer	NOTIFIER	
		Model	NBG-12LX	
		Visual Inspection	Passed (Manual)	
Manual Pull Station	MAIN BUILDING 1M:001 14145015	Functional Inspection	Passed	
		Alarm Verification Participation	True	
		PULL MAIN LOBBY	Manual	6/25/2025 3:26:55 PM
		Manufacturer	NOTIFIER	
		Model	NBG-12LX	
Manual Pull Station	MAIN BUILDING 1M:005 14145051	Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
		PULL NPS LOBBY	Manual	6/25/2025 3:30:39 PM
		Manufacturer	NOTIFIER	
		Model	NBG-12LX	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	MAIN BUILDING 1D:020	SMOKE MAP AND FILE STORAGE	Manual	6/25/2025 3:31:38 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:016	SMOKE ABOVE THE FACP	Manual	6/25/2025 3:31:58 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:031	SMOKE BREAK ROOM	Manual	6/25/2025 3:30:04 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:023	SMOKE COMMUNICATIONS ROOM	Manual	6/25/2025 3:31:35 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:030	SMOKE CONFERENCE ROOM	Manual	6/25/2025 3:30:03 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:029	SMOKE CONFERENCE STORAGE	Manual	6/25/2025 3:31:47 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:028	SMOKE ELEVATOR EQUIPMENT ROOM	Manual	6/25/2025 3:31:45 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:026	SMOKE ELEVATOR PIT	Manual	6/25/2025 3:31:48 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:024	SMOKE LOWER ELEVATOR LOBBY	Manual	6/25/2025 3:31:51 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:001	SMOKE LOWER ENTRANCE	Manual	6/25/2025 3:27:34 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:037	SMOKE LOWER NORTH EAST HALL	Manual	6/25/2025 3:30:42 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:036	SMOKE LOWER NORTH EAST HALL	Manual	6/25/2025 3:30:52 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:017	SMOKE LOWER STAIRWELL	Manual	6/25/2025 3:31:37 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General above 12 Feet	MAIN BUILDING 1D:044	SMOKE MAIN LOBBY	Manual	6/25/2025 3:31:32 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General above 12 Feet	MAIN BUILDING 1D:045	SMOKE MAIN LOBBY	Manual	6/25/2025 3:31:34 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	MAIN BUILDING 1D:021	SMOKE MECHANICAL ROOM	Manual	6/25/2025 3:31:40 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:022	SMOKE MECHANICAL ROOM	Manual	6/25/2025 3:31:44 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:010	SMOKE NORTH EXHIBIT	Manual	6/25/2025 3:34:45 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:032	SMOKE NPS LOBBY	Manual	6/25/2025 3:30:20 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:034	SMOKE NPS OFFICE #1	Manual	6/25/2025 3:30:16 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:035	SMOKE NPS OFFICE #2	Manual	6/25/2025 3:30:17 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:043	SMOKE NPS RECEPTIONIST	Manual	6/25/2025 3:30:22 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:033	SMOKE NPS SUPERVISOR OFFICE	Manual	6/25/2025 3:30:06 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:009	SMOKE SOUTH EXHIBIT	Manual	6/25/2025 3:34:47 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:013	SMOKE TOP OF ELEVATOR SHAFT	Manual	6/25/2025 3:34:52 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:011	SMOKE UPPER AUDITORIUM	Manual	6/25/2025 3:34:48 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:007	SMOKE UPPER BOOKSTORE	Manual	6/25/2025 3:27:29 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:005	SMOKE UPPER COUNTER	Manual	6/25/2025 3:27:05 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:002	SMOKE UPPER EAST OFFICE	Manual	6/25/2025 3:27:02 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:012	SMOKE UPPER ELEVATOR LOBBY	Manual	6/25/2025 3:31:55 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	MAIN BUILDING 1D:006	Functional Inspection	Passed	6/25/2025 3:27:32 PM
		Alarm Verification Participation	True	
		SMOKE UPPER GALLERY	Manual	
		Manufacturer	NOTIFIER	
		Model	NP-100	
Smoke Detector - General	MAIN BUILDING 1D:004	Visual Inspection	Passed (Manual)	6/25/2025 3:26:59 PM
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
		SMOKE UPPER STORAGE	Manual	
		Manufacturer	NOTIFIER	
Smoke Detector - General	MAIN BUILDING 1D:008	Model	NP-100	6/25/2025 3:27:31 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		SMOKE UPPER VIEWING	Manual	
		Manufacturer	NOTIFIER	
Smoke Detector - General	MAIN BUILDING 1D:015	Model	NP-100	6/25/2025 3:31:57 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
		SMOKE UPPER WAITING HALL	Manual	
Smoke Detector - General	MAIN BUILDING 1D:003	Manufacturer	NOTIFIER	6/25/2025 3:27:03 PM
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
Smoke Detector - General	MAIN BUILDING 1D:040	SMOKE USFS OFFICE	Manual	6/25/2025 3:30:36 PM
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector - General	MAIN BUILDING 1D:039	Alarm Verification Participation	True	6/25/2025 3:30:38 PM
		SMOKE USFS OFFICE	Manual	
		Manufacturer	NOTIFIER	
		Model	NP-100	
		Visual Inspection	Passed (Manual)	
Smoke Detector - General	MAIN BUILDING 1D:038	Functional Inspection	Passed	6/25/2025 3:30:41 PM
		Alarm Verification Participation	True	
		SMOKE USFS OFFICE	Manual	
		Manufacturer	NOTIFIER	
		Model	NP-100	
Smoke Detector - General	MAIN BUILDING 1D:041	Visual Inspection	Passed (Manual)	6/25/2025 3:30:45 PM
		Functional Inspection	Passed	
		Alarm Verification Participation	True	
		SMOKE USFS OFFICE	Manual	
		Manufacturer	NOTIFIER	
Smoke Detector - General	MAIN BUILDING 1D:042	Model	NP-100	6/25/2025 3:30:47 PM
		Visual Inspection	Passed (Manual)	
		SMOKE USFS OFFICE	Manual	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Monitor Module	MAIN BUILDING 1M:041	Functional Inspection	Passed	6/25/2025 3:31:52 PM
		Alarm Verification Participation	True	
		TAMPER RISER RM #1	Manual	
		Manufacturer	NOTIFIER	
		Model	MMF-300	
Monitor Module	MAIN BUILDING 1M:045	Visual Inspection	Passed (Manual)	6/25/2025 3:29:59 PM
		Functional Inspection	Passed	
		TAMPER RISER RM #2	Manual	
		Manufacturer	NOTIFIER	
		Model	MMF-300	
Monitor Module	MAIN BUILDING 1M:040	Visual Inspection	Passed (Manual)	6/25/2025 3:31:42 PM
		Functional Inspection	Passed	
		WATERFLOW RISER RM	Manual	
		Manufacturer	NOTIFIER	
		Model	MMF-300	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Device/Equipment Details

Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Audible And Visible					QTY 13
MAIN BUILDING	HORN STROBE 2ND FLR OUTSIDE RESTROOM	SYSTEM SENSOR	P2RL		08/13/2012
MAIN BUILDING	HORN STROBE ENTURP. OFFICE	SYSTEM SENSOR	P2RL		08/13/2012
MAIN BUILDING	HORN STROBE AT MAIN ENTRANCE	SYSTEM SENSOR	P2RL		08/13/2012
MAIN BUILDING	HORN STROBE OUTSIDE OF BOOKSTORE	SYSTEM SENSOR	P2RL		08/13/2012
MAIN BUILDING	HORN STROBE EXHIBIT	SYSTEM SENSOR	PC2WL		08/13/2012
MAIN BUILDING	HORN STROBE IN THE BOOKSTORE	SYSTEM SENSOR	P2RL		08/13/2012
MAIN BUILDING	HORN STROBE 2ND FLR OUTSIDE RESTROOM	SYSTEM SENSOR	P2RL		08/13/2012
MAIN BUILDING	HORN STROBE 1ST FLR BOTTOM OF THE STAIRS	SYSTEM SENSOR	P2RL		08/13/2012
MAIN BUILDING	HORN STROBE 1ST FLR MAIN ENTRANCE	SYSTEM SENSOR	P2RL		08/13/2012
MAIN BUILDING	HORN STROBE 1ST FLR RISER ROOM HALL	SYSTEM SENSOR	P2RL		08/13/2012
MAIN BUILDING	HORN STROBE 1ST FLR NPS ENTRANCE	SYSTEM SENSOR	P2RL		08/13/2012
MAIN BUILDING	HORN STROBE 1ST FLR NPS OFFICE	SYSTEM SENSOR	P2RL		08/13/2012
MAIN BUILDING	HORN STROBE 1ST FLR NPS EXIT	SYSTEM SENSOR	P2RL		08/13/2012
Visible					QTY 9
MAIN BUILDING	STROBE ONLY	SYSTEM SENSOR	SRL		08/13/2012
MAIN BUILDING	STROBE ONLY 2ND FLR RESTROOM	SYSTEM SENSOR	SRL		08/13/2012
MAIN BUILDING	STROBE ONLY 2ND FLR MENS RESTROOM	SYSTEM SENSOR	SRL		08/13/2012
MAIN BUILDING	STROBE ONLY 2ND FLR WOMENS RESTROOM	SYSTEM SENSOR	SRL		08/13/2012
MAIN BUILDING	STROBE ONLY ENTURP. OFFICE	SYSTEM SENSOR	SRL		08/13/2012
MAIN BUILDING	STROBE ONLY 1ST FLR WOMENS RESTROOM	SYSTEM SENSOR	SRL		08/13/2012
MAIN BUILDING	STROBE ONLY 1ST FLR MENS RESTROOM	SYSTEM SENSOR	SRL		08/13/2012
MAIN BUILDING	HORN STROBE 1ST FLR CONFERENCE ROOM	SYSTEM SENSOR	SRL		08/13/2012
MAIN BUILDING	HORN STROBE 1ST FLR NPS BY COPIER	SYSTEM SENSOR	SRL		08/13/2012

Batteries & Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Battery - Sealed Lead-acid					QTY 2
MAIN BUILDING	FACP BATTERY (RIGHT)	YUASA	NP12-12S, 2022		08/26/2022
MAIN BUILDING	MAIN FACP BATTERY (LEFT)	YUASA	NP12-12S		08/26/2022

Emergency Control Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Elevator Recall - Primary					QTY 1
MAIN BUILDING	PRIMARY RECALL	NOTIFIER	NFW2-100		08/13/2012
Elevator Recall - Alternate					QTY 1
MAIN BUILDING	ALTERNATE RECALL	NOTIFIER	NFW2-100		08/13/2012

Fire Control

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fire Alarm Control Panel					QTY 1
MAIN BUILDING	MAIN FACP (TOP OF THE STAIRS)	NOTIFIER	NFW2-100		08/13/2012

Initiating Device					
ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Manual Pull Station					QTY 4
MAIN BUILDING 1M:001 14145015	PULL MAIN LOBBY	NOTIFIER	NBG-12LX		08/13/2012
MAIN BUILDING 1M:002 14145005	PULL BOOKSTORE	NOTIFIER	NBG-12LX		08/13/2012
MAIN BUILDING 1M:005 14145051	PULL NPS LOBBY	NOTIFIER	NBG-12LX		08/13/2012
MAIN BUILDING 1M:006 14145034	PULL MAIN ENTRANCE	NOTIFIER	NBG-12LX		08/13/2012
Monitor Module					QTY 3
MAIN BUILDING 1M:041	TAMPER RISER RM #1	NOTIFIER	MMF-300		08/13/2012
MAIN BUILDING 1M:045	TAMPER RISER RM #2	NOTIFIER	MMF-300		08/13/2012
MAIN BUILDING 1M:040	WATERFLOW RISER RM	NOTIFIER	MMF-300		08/13/2012
Smoke Detector - General					QTY 37
MAIN BUILDING 1D:001	SMOKE LOWER ENTRANCE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:002	SMOKE UPPER EAST OFFICE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:003	SMOKE UPPER WEST OFFICE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:004	SMOKE UPPER STORAGE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:005	SMOKE UPPER COUNTER	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:006	SMOKE UPPER GALLERY	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:007	SMOKE UPPER BOOKSTORE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:009	SMOKE SOUTH EXHIBIT	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:010	SMOKE NORTH EXHIBIT	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:011	SMOKE UPPER AUDITORIUM	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:012	SMOKE UPPER ELEVATOR LOBBY	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:013	SMOKE TOP OF ELEVATOR SHAFT	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:015	SMOKE UPPER WAITING HALL	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:016	SMOKE ABOVE THE FACP	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:017	SMOKE LOWER STAIRWELL	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:020	SMOKE MAP AND FILE STORAGE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:021	SMOKE MECHANICAL ROOM	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:022	SMOKE MECHANICAL ROOM	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:023	SMOKE COMMUNICATIONS ROOM	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:024	SMOKE LOWER ELEVATOR LOBBY	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:026	SMOKE ELEVATOR PIT	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:028	SMOKE ELEVATOR EQUIPMENT ROOM	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:029	SMOKE CONFERENCE STORAGE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:030	SMOKE CONFERENCE ROOM	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:031	SMOKE BREAK ROOM	NOTIFIER	NP-100		08/13/2012

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
MAIN BUILDING 1D:032	SMOKE NPS LOBBY	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:033	SMOKE NPS SUPERVISOR OFFICE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:034	SMOKE NPS OFFICE #1	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:035	SMOKE NPS OFFICE #2	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:036	SMOKE LOWER NORTH EAST HALL	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:037	SMOKE LOWER NORTH EAST HALL	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:038	SMOKE USFS OFFICE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:039	SMOKE USFS OFFICE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:040	SMOKE USFS OFFICE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:041	SMOKE USFS OFFICE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:042	SMOKE USFS OFFICE	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:043	SMOKE NPS RECEPTIONIST	NOTIFIER	NP-100		08/13/2012
Smoke Detector - General above 12 Feet					QTY 3
MAIN BUILDING 1D:008	SMOKE UPPER VIEWING	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:044	SMOKE MAIN LOBBY	NOTIFIER	NP-100		08/13/2012
MAIN BUILDING 1D:045	SMOKE MAIN LOBBY	NOTIFIER	NP-100		08/13/2012
Heat Detector - Restorable Spot					QTY 5
MAIN BUILDING 1D:014	HEAT ELEVATOR SHAFT	NOTIFIER	NH-100		08/13/2012
MAIN BUILDING 1D:018	HEAT DETECTOR, EVIDENCE LOWER STORAGE	NOTIFIER	NH-100		08/13/2012
MAIN BUILDING 1D:019	HEAT JANITOR CLOSET	NOTIFIER	NH-100		08/13/2012
MAIN BUILDING 1D:025	HEAT ELEVATOR PIT	NOTIFIER	NH-100		08/13/2012
MAIN BUILDING 1D:027	HEAT ELEVATOR EQUIPMENT ROOM	NOTIFIER	NH-100		08/13/2012