

Semi Annual Inspection Report

Completed on: 12-16-2025

for

VA Grand Junction Building 22
2121 North Ave
Grand Junction, CO

Conducted By:

James Trudeau
Platinum Fire Protection
PO Box 607
Mead, CO 80542

This Joint Commission inspection was performed in accordance with the following codes and regulations:

- NFPA 25 2011 - Standard for the Inspection, Testing, and Maintenance of Water Based Fire Protection Systems

Report of Inspection / Test

Semi-Annual NFPA 25

12-16-2025

Property

VA Grand Junction Building 22
2121 North Ave
Grand Junction CO

Print Date: 12-22-2025

Conducted by: James Trudeau

Platinum Fire Protection
PO Box 607
Mead CO 80542
3036880177
rachel@platfire.com



Deficiencies - General Questions

None

Deficiencies - General Wet System Questions

None

Deficiencies - Wet

Deficiency #1

Sprinkler Type: Wet

Is flow observed? - 13.2.5: No

Notes: Water fed from bldg 7. See that report for results.

Deficiencies - Inspectors Test Connection

Deficiency #2

Location: Secure pharmacy storage

Description: Bldg 22 inspectors test

Pass?: No

Notes: No delay. Flow switch Needs to be replaced

Report of Inspection / Test

Semi-Annual NFPA 25

12-16-2025

Property

VA Grand Junction Building 22

2121 North Ave

Grand Junction CO

Print Date: 12-22-2025

Conducted by: James Trudeau

Platinum Fire Protection

PO Box 607

Mead CO 80542

3036880177

rachel@platfire.com



Inspector Signature

I state that the information on this form is correct at the time and place of my inspection, and all equipment tested at this time was left in operational condition upon completion of this inspection except as noted.

Inspector Name	Signature	Date Completed
James Trudeau		2025-12-16