

# 10 CFR 50 Appendix B — EKONERG

## Conformance Dashboard

Audit reference framework: 10 CFR 50 Appendix B, interpreted through ASME NQA-1 Part 1. This dashboard presents Ekonerg vendor-document evidence from the approved intake and active evaluation run.

● Ekonerg evidence snapshot

Overall: 77.8% — Substantially Matched

Vendor crumbs: 475

18 / 18 criteria evaluated

**77.8%**

OVERALL CONFORMANCE

1400 / 1800 evidence points

**18**

APPENDIX B CRITERIA

All criteria evaluated

**475**

VENDOR CRUMBS

Active Ekonerg evidence

**3**

■ FULLY MATCHED

5 / 5 level

**14**

■ SUBSTANTIALLY MATCHED

4 / 5 level

**0**

■ UNMET

No direct vendor evidence

## | Executive Summary

Ekonerg documents were evaluated against all 18 Appendix B criteria. The evidence-based result is **77.8% — Substantially Matched**, using the approved five-level Enconet scale. This closes the owner-operated pre-flight tool run.

The score is the average of the criterion ratings: fully = 5/5 (100), substantially = 4/5 (75), partially = 3/5 (50), minimally = 2/5 (25), and unmet = 1/5 (0).

**What full means:** the written controls cover the applicable duties. Work records still need a real-audit check. Missing work samples alone do not lower a documentation rating; real written gaps still do. The score is an ordinal summary, not a measured share of every regulatory clause.

**Part 21 remains applicable:** it is not included in Criterion XVI or the overall Appendix B score. The reporting path remains unresolved: PQ10.2-1 section 3.11 describes customer notification, not proof of the complete applicable reporting route. Verify that route in the real audit; full XVI does not mean full Part 21 compliance.

**Review priorities:** IX. Read the specific gaps below. A high crumb count does not itself raise a score.

**Source boundary:** Ekonerg is the only supplier shown. Regulatory documents are the comparison baseline; no other supplier data is used.

## | Classification Distribution



■ Fully: 3 ■ Substantially: 14 ■ Partially: 1 ■ Minimally: 0 ■ Unmet: 0

**Interpretation:** each criterion has a recorded five-level rating. Follow-up verification should target the lowest-rated criteria first; later real-audit work does not keep this tool run open.

**| Criterion Cards — Evidence Review**

## I Organization

**SUBSTANTIALLY MATCHED**

Manual 5.3 and Prilog 2 give QA staff authority, freedom and direct reporting to management. The written rules do not clearly state how nuclear safety wins a cost or schedule conflict. This is a substantial match; test that safeguard in the real audit.

75% · 4/5

52 linked controls; content-based judgment: substantially (4/5, 75 points)

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0008-APP\_B\_I-0001, CRUMB-DOC-0008-APP\_B\_I-0002, CRUMB-DOC-0009-APP\_B\_I-0001, CRUMB-DOC-0010-APP\_B\_I-0001, CRUMB-DOC-0011-APP\_B\_I-0009, CRUMB-DOC-0011-APP\_B\_I-0010, CRUMB-DOC-0011-APP\_B\_I-0011, CRUMB-DOC-0011-APP\_B\_I-0012, CRUMB-DOC-0015-APP\_B\_I-0001, CRUMB-DOC-0016-APP\_B\_I-0013, CRUMB-DOC-0016-APP\_B\_I-0014, CRUMB-DOC-0017-APP\_B\_I-0001, CRUMB-DOC-0017-APP\_B\_I-0002, CRUMB-DOC-0018-APP\_B\_I-0001, CRUMB-DOC-0019-APP\_B\_I-0001, CRUMB-DOC-0020-APP\_B\_I-0001, CRUMB-DOC-0020-APP\_B\_I-0002, CRUMB-DOC-0020-APP\_B\_I-0003, CRUMB-DOC-0021-APP\_B\_I-0007, CRUMB-DOC-0021-APP\_B\_I-0008, CRUMB-DOC-0022-APP\_B\_I-0001, CRUMB-DOC-0022-APP\_B\_I-0002, CRUMB-DOC-0023-APP\_B\_I-0001, CRUMB-DOC-0024-APP\_B\_I-0001, CRUMB-DOC-0025-APP\_B\_I-0001, CRUMB-DOC-0026-APP\_B\_I-0001, CRUMB-DOC-0028-APP\_B\_I-0001, CRUMB-DOC-0030-APP\_B\_I-0002, CRUMB-DOC-0032-APP\_B\_I-0001, CRUMB-DOC-0032-APP\_B\_I-0003, CRUMB-DOC-0032-APP\_B\_I-0004, CRUMB-DOC-0032-APP\_B\_I-0005, CRUMB-DOC-0032-APP\_B\_I-0007, CRUMB-DOC-0032-APP\_B\_I-0008, CRUMB-DOC-0032-APP\_B\_I-0009, CRUMB-DOC-0032-APP\_B\_I-0010, CRUMB-DOC-0032-APP\_B\_I-0011, CRUMB-DOC-0032-APP\_B\_I-0012, CRUMB-DOC-0032-APP\_B\_I-0013, CRUMB-DOC-0032-APP\_B\_I-0014, CRUMB-DOC-0032-APP\_B\_I-0015, CRUMB-DOC-0032-APP\_B\_I-0016, CRUMB-DOC-0032-APP\_B\_I-0017, CRUMB-DOC-0032-APP\_B\_I-0018, CRUMB-DOC-0032-APP\_B\_I-0019, CRUMB-DOC-0032-APP\_B\_I-0020, CRUMB-DOC-0032-APP\_B\_I-0021, CRUMB-DOC-0032-APP\_B\_I-0022, CRUMB-DOC-0032-APP\_B\_I-0023, CRUMB-DOC-0032-APP\_B\_I-0024, CRUMB-DOC-0032-APP\_B\_I-0025, CRUMB-DOC-0032-APP\_B\_I-0029; source documents: PQ06.1\_Upravljanje\_rizicima.md, PQ07.1-1\_r8\_Kontrola\_školoovanja\_i\_treninga\_osoblja.md, PQ07.1-2\_r5\_Kontrola\_opreme\_za\_mjerenje\_inspekcij.md, PQ07.5-2\_r8\_Postupci\_sustava\_kvalitete\_sustava\_za.md, PQ07.5-6\_r5\_Kontrola\_dokumentacije\_koju\_prima\_Ekon.md, PQ07.5-7\_r10\_Kontrola\_zapisa.md, PQ08.1-1\_r5\_Svrstavanja\_aktivnosti\_u\_nivo\_e\_složeno.md, PQ08.1-2\_r4\_Plan\_kvalitete.md, PQ08.1-3\_r2\_Plan\_vođenja\_projekta.md, PQ08.2-1\_r6\_Odnosi\_s\_Naručiteljima.md, PQ08.2-2\_r5\_Priprema\_i\_postupanje\_s\_ugovornom\_doku.md, PQ08.3-1\_r4\_Kontrola\_studijskih\_projektnih\_radova\_.md, PQ08.4-1\_r3\_Kontrola\_studijskih\_projektnih\_radova\_.md, PQ08.4-2\_r9\_Kontrola\_nabave.md, PQ08.4-3\_r11\_Evaluacija\_i\_izbor\_dobavljača.md, PQ08.6\_r3\_Kontrola\_i\_verifikacija\_aktivnosti.md, PQ09.3\_r6\_Pregled\_i\_ocjena\_sustava\_kvalitete\_zašt.md, PQ10.2-2\_r10\_Kontrola\_korektivnih\_akcija.md, Priručnik\_sustava\_upravljanja\_rev.5\_9492b447c386.md

### ► CRITERION SUMMARY

Manual 5.3 and Prilog 2 give QA staff authority, freedom and direct reporting to management. The written rules do not clearly state how nuclear safety wins a cost or schedule conflict. This is a substantial match; test that safeguard in the real audit.

### ► AFFIRMATIVE ARGUMENT

Manual 5.3 and Prilog 2 §§1.2-1.3 assign duties, preserve responsibility after delegation, give QA personnel organizational freedom, and provide direct management access. PQ10.2-1 §2.9 gives management a stop-work duty on significant nonconformances.

► **CONTRARY ARGUMENT**

The written organization rules do not clearly protect QA decisions when cost or schedule conflicts with nuclear safety. Management access and a stop-work route support independence, but do not fully settle that conflict.

 **JUDGE RULING**

Substantially matched, 4/5. The organization has defined authority and reporting routes; the safety-over-cost/schedule safeguard needs clarification under Appendix B I and NQA-1 Requirement 1 §201(d).

► **Crumbs linked to this score (52)**

✓ **AUDITOR VERIFICATION ACTION**

Resolve or verify these specific points: The written organization rules do not clearly protect QA decisions when cost or schedule conflicts with nuclear safety. Management access and a stop-work route support independence, but do not fully settle that conflict.

**Anchor evidence:** Ovaj postupak se primjenjuje se na sve razine organizacije unutar EKONERG-a, kao i na aktivnosti dobavljača i podizvođača koji obavljaju aktivnosti od utjecaja na okoliš te na kvalitetu proizvoda i usluga EKONERG-a. (source locator: 1. UVOD > 1.1. Opseg)

## II Quality Assurance Program

**SUBSTANTIALLY MATCHED**

Manual 8.1 requires quality plans with staff, methods, equipment, checks, acceptance criteria and records; Dodatak 1 §2 sets nuclear grading. Training and annual review are defined. Nuclear inspection/test qualification maintenance is less clear than NQA-1 Requirement 2 §203, so the program is a substantial match.

**75% • 4/5**

**47 linked controls; content-based judgment: substantially (4/5, 75 points)**

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0008-APP\_B\_II-0001, CRUMB-DOC-0009-APP\_B\_II-0001, CRUMB-DOC-0009-APP\_B\_II-0002, CRUMB-DOC-0011-APP\_B\_II-0003, CRUMB-DOC-0017-APP\_B\_II-0001, CRUMB-DOC-0018-APP\_B\_II-0001, CRUMB-DOC-0018-APP\_B\_II-0002, CRUMB-DOC-0020-APP\_B\_II-0001, CRUMB-DOC-0021-APP\_B\_II-0004, CRUMB-DOC-0022-APP\_B\_II-0001, CRUMB-DOC-0028-APP\_B\_II-0001, CRUMB-DOC-0032-APP\_B\_II-0002, CRUMB-DOC-0032-APP\_B\_II-0004, CRUMB-DOC-0032-APP\_B\_II-0005, CRUMB-DOC-0032-APP\_B\_II-0006, CRUMB-DOC-0032-APP\_B\_II-0007, CRUMB-DOC-0032-APP\_B\_II-0008, CRUMB-DOC-0032-APP\_B\_II-0009, CRUMB-DOC-0032-APP\_B\_II-0010, CRUMB-DOC-0032-APP\_B\_II-0011, CRUMB-DOC-0032-APP\_B\_II-0012, CRUMB-DOC-0032-APP\_B\_II-0013, CRUMB-DOC-0032-APP\_B\_II-0014, CRUMB-DOC-0032-APP\_B\_II-0015, CRUMB-DOC-0032-APP\_B\_II-0016, CRUMB-DOC-0032-APP\_B\_II-0017, CRUMB-DOC-0032-APP\_B\_II-0018, CRUMB-DOC-0032-APP\_B\_II-0020, CRUMB-DOC-0032-APP\_B\_II-0021, CRUMB-DOC-0032-APP\_B\_II-0022, CRUMB-DOC-0032-APP\_B\_II-0023, CRUMB-DOC-0032-APP\_B\_II-0024, CRUMB-DOC-0032-APP\_B\_II-0025, CRUMB-DOC-0032-APP\_B\_II-0026, CRUMB-DOC-0032-APP\_B\_II-0027, CRUMB-DOC-0032-APP\_B\_II-0028, CRUMB-DOC-0032-APP\_B\_II-0030, CRUMB-DOC-0032-APP\_B\_II-0031, CRUMB-DOC-0032-APP\_B\_II-0032, CRUMB-DOC-0032-APP\_B\_II-0033, CRUMB-DOC-0032-APP\_B\_II-0034, CRUMB-DOC-0032-APP\_B\_II-0035, CRUMB-DOC-0032-APP\_B\_II-0037, CRUMB-DOC-0032-APP\_B\_II-0038, CRUMB-DOC-0032-APP\_B\_II-0040, CRUMB-DOC-0032-APP\_B\_II-0041, CRUMB-DOC-0032-APP\_B\_II-0042; source documents: PQ06.1\_Upravljanje\_rizicima.md, PQ07.1-1\_r8\_Kontrola\_školenja\_i\_treninga\_osoblja.md, PQ07.5-2\_r8\_Postupci\_sustava\_kvalitete\_sustava\_za.md, PQ08.1-1\_r5\_Svrstavanja\_aktivnosti\_u\_nivo\_e\_slozeno.md, PQ08.1-2\_r4\_Plan\_kvalitete.md, PQ08.2-1\_r6\_Odnosi\_s\_Naručiteljima.md, PQ08.2-2\_r5\_Priprema\_i\_postupanje\_s\_ugovornom\_doku.md, PQ08.3-1\_r4\_Kontrola\_studijskih\_projektnih\_radova\_.md, PQ09.3\_r6\_Pregled\_i\_ocjena\_sustava\_kvalitete\_zašt.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 8.1 requires quality plans with staff, methods, equipment, checks, acceptance criteria and records; Dodatak 1 §2 sets nuclear grading. Training and annual review are defined. Nuclear inspection/test qualification maintenance is less clear than NQA-1 Requirement 2 §203, so the program is a substantial match.

#### ► AFFIRMATIVE ARGUMENT

Manual 7.1-7.3, 8.1 and 9.3 define resources, competence, work conditions, project quality plans and annual management review. Dodatak 1 §2 places NS/AQ work at level I. PQ7.1-1 §§2-3 requires planned training and competence records; PQ9.2 §3.8 defines nuclear auditor qualifications.

#### ► CONTRARY ARGUMENT

The program has a meaningful graded planning process. Its written nuclear inspection/test personnel qualification rules do not clearly set the periodic re-evaluation and inactivity checks in

NQA-1 Requirement 2 §203. General training and certificate renewal do not fully define those checks.

#### JUDGE RULING

Substantially matched, 4/5. The written program meets the main planning, resource, training and review duties. Nuclear inspection/test qualification maintenance needs clearer rules. An absent completed project plan is not treated as a missing generic planning process.

► **Crumbs linked to this score (47)**

#### ✓ **AUDITOR VERIFICATION ACTION**

Resolve or verify these specific points: The program has a meaningful graded planning process. Its written nuclear inspection/test personnel qualification rules do not clearly set the periodic re-evaluation and inactivity checks in NQA-1 Requirement 2 §203. General training and certificate renewal do not fully define those checks.

**Anchor evidence:** Svrha ovog postupka je opisati prepoznavanje opasnosti u procesima, utvrđivanje metode za procjenu i procjena veličine rizika, izradu podloga za aktivnosti uklanjanja ili smanjenja rizika, kontrolu učinkovitosti poduzetih mjera te prepoznavanje novih mogućnosti/prilika. (source locator: 1. UVOD > 1.2. Svrha)

### III Design Control

**SUBSTANTIALLY MATCHED**

Manual 8.3 and PQ8.3-1 define checked inputs, independent verification, controlled interfaces and changes. Conflicting RSP/ROS references leave the design-software verification route unclear. The written design process is a substantial match; verify the correct procedure and a calculation in the real audit.

75% • 4/5

34 linked controls; content-based judgment: substantially (4/5, 75 points)

#### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0017-APP\_B\_III-0001, CRUMB-DOC-0017-APP\_B\_III-0002, CRUMB-DOC-0019-APP\_B\_III-0001, CRUMB-DOC-0019-APP\_B\_III-0002, CRUMB-DOC-0019-APP\_B\_III-0003, CRUMB-DOC-0022-APP\_B\_III-0001, CRUMB-DOC-0022-APP\_B\_III-0002, CRUMB-DOC-0022-APP\_B\_III-0003, CRUMB-DOC-0022-APP\_B\_III-0004, CRUMB-DOC-0022-APP\_B\_III-0005, CRUMB-DOC-0023-APP\_B\_III-0001, CRUMB-DOC-0023-APP\_B\_III-0002, CRUMB-DOC-0032-APP\_B\_III-0001, CRUMB-DOC-0032-APP\_B\_III-0003, CRUMB-DOC-0032-APP\_B\_III-0004, CRUMB-DOC-0032-APP\_B\_III-0005, CRUMB-DOC-0032-APP\_B\_III-0006, CRUMB-DOC-0032-APP\_B\_III-0007, CRUMB-DOC-0032-APP\_B\_III-0009, CRUMB-DOC-0032-APP\_B\_III-0010, CRUMB-DOC-0032-APP\_B\_III-0011, CRUMB-DOC-0032-APP\_B\_III-0012, CRUMB-DOC-0032-APP\_B\_III-0013, CRUMB-DOC-0032-APP\_B\_III-0014, CRUMB-DOC-0032-APP\_B\_III-0015, CRUMB-DOC-0032-APP\_B\_III-0016, CRUMB-DOC-0032-APP\_B\_III-0017, CRUMB-DOC-0032-APP\_B\_III-0018, CRUMB-DOC-0032-APP\_B\_III-0019, CRUMB-DOC-0032-APP\_B\_III-0020, CRUMB-DOC-0032-APP\_B\_III-0025, CRUMB-DOC-0032-APP\_B\_III-0026, CRUMB-DOC-0032-APP\_B\_III-0027, CRUMB-DOC-0032-APP\_B\_III-0029; source documents: PQ07.5-7\_r10\_Kontrola\_zapisa.md, PQ08.1-1\_r5\_Svrstavanja\_aktivnosti\_u\_nivou\_slozeno.md, PQ08.1-3\_r2\_Plan\_vodenja\_projekta.md, PQ08.3-1\_r4\_Kontrola\_studijskih\_projektnih\_radova\_.md, PQ08.4-1\_r3\_Kontrola\_studijskih\_projektnih\_radova\_.md, Prirucnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 8.3 and PQ8.3-1 define checked inputs, independent verification, controlled interfaces and changes. Conflicting RSP/ROS references leave the design-software verification route unclear. The written design process is a substantial match; verify the correct procedure and a calculation in the real audit.

#### ► AFFIRMATIVE ARGUMENT

Manual 8.3 and PQ8.3-1 §§3.1-3.5 control design inputs, interfaces, independent checks, release, records and changes. Software verification is triggered by configuration and use changes in Dodatak 1's flow notes.

#### ► CONTRARY ARGUMENT

The nuclear addendum and Prilog 5 use inconsistent RSP and ROS identifiers. The actual design-software verification method is not supplied, so the written chain to a proven calculation tool or independently verified result is incomplete.

#### 🔨 JUDGE RULING

Substantially matched, 4/5. The main design-control process is substantive. The software verification/reference chain needs clarification for NQA-1 Requirement 3 §§401 and 500. No blanket Part II compliance is assumed.

► **Crumbs linked to this score (34)**

✓ **AUDITOR VERIFICATION ACTION**

Resolve or verify these specific points: The nuclear addendum and Prilog 5 use inconsistent RSP and ROS identifiers. The actual design-software verification method is not supplied, so the written chain to a proven calculation tool or independently verified result is incomplete.

**Anchor evidence:** Original studije/elaborata (source locator: KONTROLA ZAPISA > PRILOG B)

## IV Procurement Document Control

FULLY MATCHED

PQ8.4-2 §3.2 expressly requires lower-tier flow-down, record controls, access rights and document delivery times, alongside technical, QA and acceptance requirements. Manual 8.4 governs review and changes. The written procurement-document process is fully matched; inspect issued orders in the real audit.

100% · 5/5

11 linked controls; content-based judgment: fully (5/5, 100 points)

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0021-APP\_B\_IV-0010, CRUMB-DOC-0021-APP\_B\_IV-0011, CRUMB-DOC-0021-APP\_B\_IV-0012, CRUMB-DOC-0024-APP\_B\_IV-0001, CRUMB-DOC-0032-APP\_B\_IV-0001, CRUMB-DOC-0032-APP\_B\_IV-0003, CRUMB-DOC-0032-APP\_B\_IV-0004, CRUMB-DOC-0032-APP\_B\_IV-0005, CRUMB-DOC-0032-APP\_B\_IV-0006, CRUMB-DOC-0032-APP\_B\_IV-0008, CRUMB-DOC-0032-APP\_B\_IV-0010; source documents: PQ08.2-2\_r5\_Priprema\_i\_postupanje\_s\_ugovornom\_doku.md, PQ08.4-2\_r9\_Kontrola\_nabave.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

PQ8.4-2 §3.2 expressly requires lower-tier flow-down, record controls, access rights and document delivery times, alongside technical, QA and acceptance requirements. Manual 8.4 governs review and changes. The written procurement-document process is fully matched; inspect issued orders in the real audit.

#### ► AFFIRMATIVE ARGUMENT

Manual 8.4 and PQ8.4-2 §3.2 require technical and QA requirements, acceptance methods, access rights, record controls, nonconformance reporting, lower-tier flow-down and document delivery times. Named staff prepare, review and approve the purchase documents; Manual 8.4.4 applies contract-document change controls.

#### ► CONTRARY ARGUMENT

No specific missing written procurement-document duty is identified in the reviewed scope. Real-audit sampling must confirm that nuclear purchase documents use the required clauses, including lower-tier flow-down and record/submittal terms.

### ⚖ JUDGE RULING

Fully matched for documentation, 5/5. PQ8.4-2 §3.2 and Manual 8.4 cover the procurement-document intent of Appendix B IV and NQA-1 Requirement 4 §§200-400. This is not a finding that every issued order has been checked.

► Crumbs linked to this score (11)

### ✓ AUDITOR VERIFICATION ACTION

Resolve or verify these specific points: No specific missing written procurement-document duty is identified in the reviewed scope. Real-audit sampling must confirm that nuclear purchase documents use the required clauses, including lower-tier flow-down and record/submittal terms.

**Anchor evidence:** Svrha ovog postupka je definiranje načina izrade ponuda, prijedloga ugovora, ugovora, njihov pregled i odobrenje, te distribucija ugovora potpisanih od ugovornih strana. (source locator: PRIPREMA I POSTUPANJE S UGOVORNOM DOKUMENTACIJOM > 1. UVOD)

## V Instructions, Procedures, and Drawings

FULLY MATCHED

Manual 7.5.1 and PQ7.5-4 §3.1 require clear work steps, qualified staff and equipment, acceptance criteria and required records. Review, approval and distribution are assigned. The written instruction framework is fully matched; technical method qualification remains a separate check under the relevant criterion.

100% · 5/5

22 linked controls; content-based judgment: fully (5/5, 100 points)

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0008-APP\_B\_V-0001, CRUMB-DOC-0011-APP\_B\_V-0007, CRUMB-DOC-0011-APP\_B\_V-0008, CRUMB-DOC-0011-APP\_B\_V-0009, CRUMB-DOC-0012-APP\_B\_V-0001, CRUMB-DOC-0012-APP\_B\_V-0002, CRUMB-DOC-0013-APP\_B\_V-0001, CRUMB-DOC-0013-APP\_B\_V-0002, CRUMB-DOC-0017-APP\_B\_V-0001, CRUMB-DOC-0018-APP\_B\_V-0001, CRUMB-DOC-0020-APP\_B\_V-0001, CRUMB-DOC-0020-APP\_B\_V-0002, CRUMB-DOC-0026-APP\_B\_V-0001, CRUMB-DOC-0032-APP\_B\_V-0001, CRUMB-DOC-0032-APP\_B\_V-0002, CRUMB-DOC-0032-APP\_B\_V-0003, CRUMB-DOC-0032-APP\_B\_V-0004, CRUMB-DOC-0032-APP\_B\_V-0005, CRUMB-DOC-0032-APP\_B\_V-0006, CRUMB-DOC-0032-APP\_B\_V-0007, CRUMB-DOC-0032-APP\_B\_V-0008, CRUMB-DOC-0032-APP\_B\_V-0010; source documents: PQ06.1\_Upravljanje\_rizicima.md, PQ07.5-2\_r8\_Postupci\_sustava\_kvalitete\_sustava\_za.md, PQ07.5-3\_r3\_Kontrolni\_postupci.md, PQ07.5-4\_r6\_Radni\_postupci.md, PQ08.1-1\_r5\_Svrstavanja\_aktivnosti\_u\_nivo\_e\_slozeno.md, PQ08.1-2\_r4\_Plan\_kvalitete.md, PQ08.2-1\_r6\_Odnosi\_s\_Naruciteljima.md, PQ08.6\_r3\_Kontrola\_i\_verifikacija\_aktivnosti.md, Prirucnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 7.5.1 and PQ7.5-4 §3.1 require clear work steps, qualified staff and equipment, acceptance criteria and required records. Review, approval and distribution are assigned. The written instruction framework is fully matched; technical method qualification remains a separate check under the relevant criterion.

#### ► AFFIRMATIVE ARGUMENT

Manual 7.5.1 and 8.5.1 require detailed work instructions with prerequisites, people, equipment, responsibilities, acceptance criteria and reporting. PQ7.5-4 §3.1 specifies those contents and §3.3 requires competent preparation, independent review and approval.

#### ► CONTRARY ARGUMENT

No specific missing general instruction-content duty is identified. Task-specific RVT/RPT/RMT/RUT and RSP/ROS methods still need real-audit checks in their own technical areas; a title alone is not proof that a special method is qualified.

### 🔍 JUDGE RULING

Fully matched for documentation, 5/5. The written instruction framework covers Appendix B V and NQA-1 Requirement 5 §100, including acceptance criteria and detail suited to the task. This does not approve every listed technical method.

► Crumbs linked to this score (22)

### ✓ AUDITOR VERIFICATION ACTION

Resolve or verify these specific points: No specific missing general instruction-content duty is identified. Task-specific RVT/RPT/RMT/RUT and RSP/ROS methods still need real-audit checks in their own technical areas; a title alone is not proof that a special method is qualified.

**Anchor evidence:** Mjere za uklanjanje, smanjenje ili prenošenje srednjih rizika poduzimaju se kroz planove kvalitete ili srodne dokumente. Mjere za uklanjanje, smanjenje ili prenošenje velikih rizika provode se kroz ugradnju u ciljeve i programe kvalitete, ili izradu novih, odnosno korekciju postojećih, postupaka/uputa. (source locator: 3.3 Aktivnosti tretmana rizika)

## VI Document Control

**SUBSTANTIALLY MATCHED**

Manual 7.5.3 and PQ7.5-5 define approval, revision, distribution and current copies at use. The manual's ROS-02/ROS-03 and RSP-03/ROS-04 references conflict with its procedure register. The process is a substantial match; resolve which controlled methods staff must use.

75% · 4/5

40 linked controls; content-based judgment: substantially (4/5, 75 points)

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0011-APP\_B\_VI-0007, CRUMB-DOC-0011-APP\_B\_VI-0008, CRUMB-DOC-0011-APP\_B\_VI-0009, CRUMB-DOC-0012-APP\_B\_VI-0001, CRUMB-DOC-0012-APP\_B\_VI-0002, CRUMB-DOC-0012-APP\_B\_VI-0003, CRUMB-DOC-0013-APP\_B\_VI-0001, CRUMB-DOC-0013-APP\_B\_VI-0002, CRUMB-DOC-0014-APP\_B\_VI-0001, CRUMB-DOC-0014-APP\_B\_VI-0002, CRUMB-DOC-0014-APP\_B\_VI-0003, CRUMB-DOC-0014-APP\_B\_VI-0004, CRUMB-DOC-0015-APP\_B\_VI-0001, CRUMB-DOC-0015-APP\_B\_VI-0002, CRUMB-DOC-0015-APP\_B\_VI-0003, CRUMB-DOC-0016-APP\_B\_VI-0007, CRUMB-DOC-0018-APP\_B\_VI-0001, CRUMB-DOC-0021-APP\_B\_VI-0004, CRUMB-DOC-0022-APP\_B\_VI-0001, CRUMB-DOC-0022-APP\_B\_VI-0002, CRUMB-DOC-0023-APP\_B\_VI-0001, CRUMB-DOC-0032-APP\_B\_VI-0001, CRUMB-DOC-0032-APP\_B\_VI-0002, CRUMB-DOC-0032-APP\_B\_VI-0003, CRUMB-DOC-0032-APP\_B\_VI-0004, CRUMB-DOC-0032-APP\_B\_VI-0005, CRUMB-DOC-0032-APP\_B\_VI-0006, CRUMB-DOC-0032-APP\_B\_VI-0008, CRUMB-DOC-0032-APP\_B\_VI-0010, CRUMB-DOC-0032-APP\_B\_VI-0011, CRUMB-DOC-0032-APP\_B\_VI-0012, CRUMB-DOC-0032-APP\_B\_VI-0013, CRUMB-DOC-0032-APP\_B\_VI-0014, CRUMB-DOC-0032-APP\_B\_VI-0018, CRUMB-DOC-0032-APP\_B\_VI-0019, CRUMB-DOC-0032-APP\_B\_VI-0023, CRUMB-DOC-0032-APP\_B\_VI-0024, CRUMB-DOC-0032-APP\_B\_VI-0025, CRUMB-DOC-0032-APP\_B\_VI-0026, CRUMB-DOC-0032-APP\_B\_VI-0027; source documents: PQ07.5-2\_r8\_Postupci\_sustava\_kvalitete\_sustava\_za.md, PQ07.5-3\_r3\_Kontrolni\_postupci.md, PQ07.5-4\_r6\_Radni\_postupci.md, PQ07.5-5\_r10\_Kontrola\_dokumenata\_koji\_nastaju\_u\_Ek.md, PQ07.5-6\_r5\_Kontrola\_dokumentacije\_koju\_prima\_Ekon.md, PQ07.5-7\_r10\_Kontrola\_zapisa.md, PQ08.1-2\_r4\_Plan\_kvalitete.md, PQ08.2-2\_r5\_Priprema\_i\_postupanje\_s\_ugovornom\_doku.md, PQ08.3-1\_r4\_Kontrola\_studijskih\_projektnih\_radova\_.md, PQ08.4-1\_r3\_Kontrola\_studijskih\_projektnih\_radova\_.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 7.5.3 and PQ7.5-5 define approval, revision, distribution and current copies at use. The manual's ROS-02/ROS-03 and RSP-03/ROS-04 references conflict with its procedure register. The process is a substantial match; resolve which controlled methods staff must use.

#### ► AFFIRMATIVE ARGUMENT

Manual 7.5.3 and PQ7.5-5 §3-4 assign preparation, review, approval, changes and controlled distribution. They require current copies at use, revision status, controlled external documents and withdrawal or marking of obsolete copies.

#### ► CONTRARY ARGUMENT

The supplied manual has conflicting references: Dodatak 1 §11 cites ROS-02 for software control while Prilog 5 lists ROS-03; §17 cites RSP-03 for backup while the register lists ROS-04. These are live navigation ambiguities, not merely absent work samples.

### JUDGE RULING

Substantially matched, 4/5. Document-control duties are written and assigned. Conflicting controlled references prevent an unqualified full match under NQA-1 Requirement 6 §§100-300.

► **Crumbs linked to this score (40)**

✓ **AUDITOR VERIFICATION ACTION**

Resolve or verify these specific points: The supplied manual has conflicting references: Dodatak 1 §11 cites ROS-02 for software control while Prilog 5 lists ROS-03; §17 cites RSP-03 for backup while the register lists ROS-04. These are live navigation ambiguities, not merely absent work samples.

**Anchor evidence:** Svrha ovog postupka je da uspostavi zahtjeve u odnosu na sadržaj, format, pregled, odobrenje, reviziju i promjenu navedenih dokumenata. (source locator: POSTUPAK SUSTAVA KVALITETE > 1. UVOD > 1.2. Svrha)

## VII Control of Purchased Material, Equipment, and Services

**SUBSTANTIALLY MATCHED**

Manual 8.4 and PQ8.4-2/PQ8.4-3 require supplier evaluation, nuclear qualification, checks and acceptance records. Safety-related hardware evidence timing and the detailed commercial-product acceptance route are less clear. The supplier-control process is a substantial match, not a review of other companies as separate audit targets.

**75% · 4/5**

**24 linked controls; content-based judgment: substantially (4/5, 75 points)**

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0021-APP\_B\_VII-0010, CRUMB-DOC-0021-APP\_B\_VII-0011, CRUMB-DOC-0021-APP\_B\_VII-0012, CRUMB-DOC-0024-APP\_B\_VII-0001, CRUMB-DOC-0024-APP\_B\_VII-0002, CRUMB-DOC-0024-APP\_B\_VII-0003, CRUMB-DOC-0025-APP\_B\_VII-0001, CRUMB-DOC-0025-APP\_B\_VII-0002, CRUMB-DOC-0025-APP\_B\_VII-0003, CRUMB-DOC-0025-APP\_B\_VII-0004, CRUMB-DOC-0030-APP\_B\_VII-0002, CRUMB-DOC-0032-APP\_B\_VII-0001, CRUMB-DOC-0032-APP\_B\_VII-0002, CRUMB-DOC-0032-APP\_B\_VII-0003, CRUMB-DOC-0032-APP\_B\_VII-0004, CRUMB-DOC-0032-APP\_B\_VII-0005, CRUMB-DOC-0032-APP\_B\_VII-0006, CRUMB-DOC-0032-APP\_B\_VII-0007, CRUMB-DOC-0032-APP\_B\_VII-0008, CRUMB-DOC-0032-APP\_B\_VII-0009, CRUMB-DOC-0032-APP\_B\_VII-0011, CRUMB-DOC-0032-APP\_B\_VII-0013, CRUMB-DOC-0032-APP\_B\_VII-0014, CRUMB-DOC-0032-APP\_B\_VII-0015; source documents: PQ08.2-2\_r5\_Priprema\_i\_postupanje\_s\_ugovornom\_doku.md, PQ08.4-2\_r9\_Kontrola\_nabave.md, PQ08.4-3\_r11\_Evaluacija\_i\_izbor\_dobavljača.md, PQ10.2-2\_r10\_Kontrola\_korektivnih\_akcija.md, Priručnik\_sustava\_upravljanja\_rev.5\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 8.4 and PQ8.4-2/PQ8.4-3 require supplier evaluation, nuclear qualification, checks and acceptance records. Safety-related hardware evidence timing and the detailed commercial-product acceptance route are less clear. The supplier-control process is a substantial match, not a review of other companies as separate audit targets.

#### ► AFFIRMATIVE ARGUMENT

Manual 8.4, PQ8.4-2 §§3.1-3.4 and PQ8.4-3 §§3.2-3.9 define supplier selection, nuclear qualification, graded surveillance, acceptance and performance review. Supplier evidence is checked against requirements and retained; Dodatak 1 §7 defines safety significance, critical characteristics and verification selection for commercial products.

#### ► CONTRARY ARGUMENT

Commercial-product dedication is described at a high level, without the detailed acceptance route. Manual 8.4.3 describes conformity evidence before/after installation, which does not clearly secure required evidence before installation or use for safety-related hardware.

### JUDGE RULING

Substantially matched, 4/5. The service procurement and supplier-control process is substantive. The safety-related hardware acceptance timing and detailed commercial-product route need confirmation under Appendix B VII and NQA-1 Requirement 7 §501. No blanket Part II obligation is added.

► **Crumbs linked to this score (24)**

✓ **AUDITOR VERIFICATION ACTION**

Resolve or verify these specific points: Commercial-product dedication is described at a high level, without the detailed acceptance route. Manual 8.4.3 describes conformity evidence before/after installation, which does not clearly secure required evidence before installation or use for safety-related hardware.

**Anchor evidence:** Kod ugovaranja isporuke ili usluge s dobavljačima Direktor odjela nositelja posla odgovoran je za analizu ponude i/ili prijedloga ugovora dobavljača po sadržaju, opsegu, cijeni i rokovima. (source locator: PRIPREMA I POSTUPANJE S UGOVORNOM DOKUMENTACIJOM > 2.2.)

## VIII Identification and Control of Materials, Parts, and Components

**SUBSTANTIALLY MATCHED**

Manual 8.5.3 links engineering work to work-order and document identifiers; Dodatak 1 §8 requires nuclear marking and traceability planning. The service process is a substantial match. Written hardware safeguards for split items, damaged marks and shelf-life expiry need clarification where that work is undertaken.

**75% · 4/5**

**5 linked controls; content-based judgment: substantially (4/5, 75 points)**

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0032-APP\_B\_VIII-0001, CRUMB-DOC-0032-APP\_B\_VIII-0002, CRUMB-DOC-0032-APP\_B\_VIII-0003, CRUMB-DOC-0032-APP\_B\_VIII-0004, CRUMB-DOC-0032-APP\_B\_VIII-0006; source documents: PQ07.5-7\_r10\_Kontrola\_zapisa.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 8.5.3 links engineering work to work-order and document identifiers; Dodatak 1 §8 requires nuclear marking and traceability planning. The service process is a substantial match. Written hardware safeguards for split items, damaged marks and shelf-life expiry need clarification where that work is undertaken.

#### ► AFFIRMATIVE ARGUMENT

Manual 8.5.3 maintains project and study identity through work-order and document identifiers. Sections 8.5.4-8.5.5 control customer property and preservation. Dodatak 1 §8 requires a nuclear document defining traceability methods, special requirements and marking authority.

#### ► CONTRARY ARGUMENT

The process is clear for engineering deliverables. The generic nuclear hardware rules do not clearly cover identity transfer on subdivision, replacement of damaged storage marks, or limited-life item expiry under NQA-1 Requirement 8 §§202 and 302-303.

### ⚖️ JUDGE RULING

Substantially matched, 4/5. The stated engineering-service scope has a meaningful identity and traceability process. The remaining gap concerns the generic hardware safeguards, not the absence of a completed job-specific marking record.

#### ► Crumbs linked to this score (5)

### ✓ AUDITOR VERIFICATION ACTION

Resolve or verify these specific points: The process is clear for engineering deliverables. The generic nuclear hardware rules do not clearly cover identity transfer on subdivision, replacement of damaged storage marks, or limited-life item expiry under NQA-1 Requirement 8 §§202 and 302-303.

**Anchor evidence:** 1. \*\*3.1.1.\*\* Izveštaji i ostala dokumentacija s provjere označavaju se brojem provjere i brojem zapisa, te godinom. (source locator: 3. POSTUPAK > 3.1. Identifikacija zapisa)

## IX Control of Special Processes

PARTIALLY MATCHED

Manual 8.5.2 requires special-process validation and supervision, and Prilog 5 identifies NDT methods. The reviewed documents do not show a complete method-specific qualification and current-qualification control route. This is a partial match; request the relevant RVT/RPT/RMT/RUT methods and qualification rules in the real audit.

50% • 3/5

3 linked controls; content-based judgment: partially (3/5, 50 points)

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0032-APP\_B\_IX-0001, CRUMB-DOC-0032-APP\_B\_IX-0002, CRUMB-DOC-0032-APP\_B\_IX-0003; source documents: Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 8.5.2 requires special-process validation and supervision, and Prilog 5 identifies NDT methods. The reviewed documents do not show a complete method-specific qualification and current-qualification control route. This is a partial match; request the relevant RVT/RPT/RMT/RUT methods and qualification rules in the real audit.

#### ► AFFIRMATIVE ARGUMENT

Manual 3 defines qualified procedures and special processes; 8.5.2 commits to validation and supervision of such work. PQ7.5-4 §3.1 requires personnel/equipment qualifications and technical criteria in work procedures. Prilog 5 lists RVT, RPT, RMT and RUT methods.

#### ► CONTRARY ARGUMENT

The generic template and procedure titles do not establish the actual special-process qualification method. The supplied set does not show how a specific NDT method is demonstrated fit for purpose, how its parameters/acceptance limits are approved, and how current process, equipment and personnel qualifications are maintained.

### 🔨 JUDGE RULING

Partially matched, 3/5. The policy and procedural framework are present, but method-specific qualification controls remain weakly evidenced against NQA-1 Requirement 9 §§201-203 and 400. Coatings, concrete, epoxy and non-metal testing are scope questions, not assumed Ekonergr activities.

#### ► Crumbs linked to this score (3)

### ✓ AUDITOR VERIFICATION ACTION

Resolve or verify these specific points: The generic template and procedure titles do not establish the actual special-process qualification method. The supplied set does not show how a specific NDT method is demonstrated fit for purpose, how its parameters/acceptance limits are approved, and how current process, equipment and personnel qualifications are maintained.

**Anchor evidence:** Postupci koji su dokazano provjereni za odgovarajuću namjenu uz poštivanje svih primjenjivih propisa, standarda i tehničkih specifikacija. (source locator: Main 3 — Definitions and abbreviations / Kvalificirani postupci [lines 264-264; source 9492b447c386])

## X Inspection

**SUBSTANTIALLY MATCHED**

Manual 9.1.4 and PQ8.6 define planned independent checks, records, release and reinspection; witness and hold points are required. Prior recorded approval for waiving a hold point is not clearly prescribed. The inspection process is a substantial match.

75% · 4/5

23 linked controls; content-based judgment: substantially (4/5, 75 points)

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0015-APP\_B\_X-0001, CRUMB-DOC-0016-APP\_B\_X-0007, CRUMB-DOC-0022-APP\_B\_X-0001, CRUMB-DOC-0022-APP\_B\_X-0002, CRUMB-DOC-0023-APP\_B\_X-0001, CRUMB-DOC-0024-APP\_B\_X-0001, CRUMB-DOC-0026-APP\_B\_X-0001, CRUMB-DOC-0026-APP\_B\_X-0002, CRUMB-DOC-0027-APP\_B\_X-0001, CRUMB-DOC-0028-APP\_B\_X-0001, CRUMB-DOC-0032-APP\_B\_X-0001, CRUMB-DOC-0032-APP\_B\_X-0002, CRUMB-DOC-0032-APP\_B\_X-0003, CRUMB-DOC-0032-APP\_B\_X-0004, CRUMB-DOC-0032-APP\_B\_X-0005, CRUMB-DOC-0032-APP\_B\_X-0006, CRUMB-DOC-0032-APP\_B\_X-0007, CRUMB-DOC-0032-APP\_B\_X-0008, CRUMB-DOC-0032-APP\_B\_X-0009, CRUMB-DOC-0032-APP\_B\_X-0010, CRUMB-DOC-0032-APP\_B\_X-0011, CRUMB-DOC-0032-APP\_B\_X-0012, CRUMB-DOC-0032-APP\_B\_X-0015; source documents: PQ07.5-6\_r5\_Kontrola\_dokumentacije\_koju\_prima\_Ekon.md, PQ07.5-7\_r10\_Kontrola\_zapisa.md, PQ08.3-1\_r4\_Kontrola\_studijskih\_projektnih\_radova\_.md, PQ08.4-1\_r3\_Kontrola\_studijskih\_projektnih\_radova\_.md, PQ08.4-2\_r9\_Kontrola\_nabave.md, PQ08.6\_r3\_Kontrola\_i\_verifikacija\_aktivnosti.md, PQ09.2\_r9\_Provjere.md, PQ09.3\_r6\_Pregled\_i\_ocjena\_sustava\_kvalitete\_zast.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 9.1.4 and PQ8.6 define planned independent checks, records, release and reinspection; witness and hold points are required. Prior recorded approval for waiving a hold point is not clearly prescribed. The inspection process is a substantial match.

#### ► AFFIRMATIVE ARGUMENT

Manual 8.6 and 9.1.4 require documented checks, acceptance, witness/hold points and indirect monitoring when inspection is unsuitable. PQ8.6 §3.2-3.7 assigns competent independent checking and record duties; repaired work is verified again.

#### ► CONTRARY ARGUMENT

The hold-point planning rule does not clearly require recorded consent before a hold point is waived, as NQA-1 Requirement 10 §300 requires. The real audit should also confirm exclusion of both the performer and direct supervisor from acceptance inspections.

### ⚖ JUDGE RULING

Substantially matched, 4/5. Inspection planning, independence, records and reinspection are defined. The written hold-point waiver safeguard needs clarification; lack of a completed inspection report alone is not the reason for the rating.

► Crumbs linked to this score (23)

### ✓ AUDITOR VERIFICATION ACTION

Resolve or verify these specific points: The hold-point planning rule does not clearly require recorded consent before a hold point is waived, as NQA-1 Requirement 10 §300 requires. The real

audit should also confirm exclusion of both the performer and direct supervisor from acceptance inspections.

**Anchor evidence:** Dokumente koje dobije na odobrenje (od dobavljača ili izvođača radova koje nadzire za Naručitelja) Voditelj/član tima pregledavaju i, ako je zahtijevano, odobravaju žigom **“ODOBRENO”** prikazanim u prilogu A ovog postupka. (source locator: 3. POSTUPAK > 3.9)

## XI Test Control

**SUBSTANTIALLY MATCHED**

Manual 9.1.4 defines customer test programs, acceptance criteria, conditions, records and result evaluation; shared instruction and equipment rules supply prerequisites. Software-method references and detailed nuclear test-record fields remain unclear. The written testing process is a substantial match.

75% · 4/5

4 linked controls; content-based judgment: substantially (4/5, 75 points)

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0032-APP\_B\_XI-0003, CRUMB-DOC-0032-APP\_B\_XI-0004, CRUMB-DOC-0032-APP\_B\_XI-0005, CRUMB-DOC-0032-APP\_B\_XI-0012; source documents: PQ07.5-7\_r10\_Kontrola\_zapisa.md, PQ08.2-2\_r5\_Priprema\_i\_postupanje\_s\_ugovornom\_doku.md, Priručnik\_sustava\_upravljanja\_rev.5\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 9.1.4 defines customer test programs, acceptance criteria, conditions, records and result evaluation; shared instruction and equipment rules supply prerequisites. Software-method references and detailed nuclear test-record fields remain unclear. The written testing process is a substantial match.

#### ► AFFIRMATIVE ARGUMENT

Manual 9.1.4 requires customer testing to have a program, written requirements, acceptance criteria, suitable conditions, records and result evaluation. Manual 7.5.1, PQ7.5-4 §3.1 and 7.1.5 provide prerequisites, qualified staff/equipment and calibration controls. Software verification is tied to defined change/use triggers.

#### ► CONTRARY ARGUMENT

The software-control procedure reference conflicts with Prilog 5, and the full verification method is not supplied. The nuclear test-record content is not clearly specified to the detail of NQA-1 Requirement 11 §601, including deviations and the person evaluating results.

### ⚖ JUDGE RULING

Substantially matched, 4/5. The written customer-testing process has the core test-control duties. Software-method identification and test-record detail need clarification. The manual's no-own-product-testing statement is preserved and does not cancel customer-testing duties.

#### ► Crumbs linked to this score (4)

### ✓ AUDITOR VERIFICATION ACTION

Resolve or verify these specific points: The software-control procedure reference conflicts with Prilog 5, and the full verification method is not supplied. The nuclear test-record content is not clearly specified to the detail of NQA-1 Requirement 11 §601, including deviations and the person evaluating results.

**Anchor evidence:** - - vezane uz sustav kvalitete kao što su izvještaji o provjerama, izvještaji o odstupanjima i neusklađenostima, izvještaji o obavljenim korektivnim akcijama; vezane uz odjel - radni nalog kao što su izvještaji o pregledima i verifikacijama, izvještaji o kvalificiranosti osoblja i postupaka, reklamacije naručitelja; (source locator: KONTROLA ZAPISA > 1. UVOD > 1.1. Opseg)

## XII Control of Measuring and Test Equipment

**SUBSTANTIALLY MATCHED**

Manual 7.1.5 and PQ7.1-2 define calibration intervals, responsible owners, records and removal of overdue equipment. The written rule for tracing use and checking earlier results after equipment failure is incomplete. Equipment control is a substantial match; confirm that look-back process in the real audit.

75% · 4/5

6 linked controls; content-based judgment: substantially (4/5, 75 points)

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0010-APP\_B\_XII-0001, CRUMB-DOC-0010-APP\_B\_XII-0002, CRUMB-DOC-0010-APP\_B\_XII-0003, CRUMB-DOC-0032-APP\_B\_XII-0002, CRUMB-DOC-0032-APP\_B\_XII-0003, CRUMB-DOC-0032-APP\_B\_XII-0004; source documents: PQ07.1-2\_r5\_Kontrola\_opreme\_za\_mjerenje\_inspekcij.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 7.1.5 and PQ7.1-2 define calibration intervals, responsible owners, records and removal of overdue equipment. The written rule for tracing use and checking earlier results after equipment failure is incomplete. Equipment control is a substantial match; confirm that look-back process in the real audit.

#### ► AFFIRMATIVE ARGUMENT

Manual 7.1.5 and PQ7.1-2 §§2-3 require equipment identification, periodic checks/calibration, assigned owners, status evidence and records. Overdue equipment is marked and removed from use; repeatedly faulty equipment is repaired or replaced. Commercial devices may be exempt only when they give the required precision.

#### ► CONTRARY ARGUMENT

The supplied procedure does not clearly require tracing equipment to its use and evaluating prior results back to the last acceptable calibration when equipment is lost, damaged or out of calibration. These are written-control gaps under NQA-1 Requirement 12 §§303.1-303.2.

### ⚖ JUDGE RULING

Substantially matched, 4/5. Calibration, ownership, status and exclusion duties are substantive. Use traceability and the look-back check need clearer instructions. The qualified commercial-device exception is consistent in intent with Requirement 12 §304 and is not treated as a failure.

#### ► Crumbs linked to this score (6)

### ✓ AUDITOR VERIFICATION ACTION

Resolve or verify these specific points: The supplied procedure does not clearly require tracing equipment to its use and evaluating prior results back to the last acceptable calibration when equipment is lost, damaged or out of calibration. These are written-control gaps under NQA-1 Requirement 12 §§303.1-303.2.

**Anchor evidence:** Ovaj se postupak primjenjuje na svu opremu/instrumente koji se u EKONERG-u koriste za provođenje kontrole, inspekcije, testiranja i mjerenja, osim opreme/instrumenata koji se koriste u Laboratoriju, što je definirano u dokumentaciji Laboratorija. (source locator: 1. UVOD > 1.1. Opseg)

### XIII Handling, Storage, and Shipping

**SUBSTANTIALLY MATCHED**

Manual 8.5.5 controls handling, storage, cleaning, packaging and shipment, with special marking, condition checks and trained handlers. It does not clearly prescribe pre-use or periodic checks of special handling tools. The preservation process is a substantial match for the stated scope.

**75% • 4/5**

**5 linked controls; content-based judgment: substantially (4/5, 75 points)**

#### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0032-APP\_B\_XIII-0001, CRUMB-DOC-0032-APP\_B\_XIII-0002, CRUMB-DOC-0032-APP\_B\_XIII-0003, CRUMB-DOC-0032-APP\_B\_XIII-0004, CRUMB-DOC-0032-APP\_B\_XIII-0005; source documents: PQ07.5-7\_r10\_Kontrola\_zapisa.md, PQ08.2-2\_r5\_Priprema\_i\_postupanje\_s\_ugovornom\_doku.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 8.5.5 controls handling, storage, cleaning, packaging and shipment, with special marking, condition checks and trained handlers. It does not clearly prescribe pre-use or periodic checks of special handling tools. The preservation process is a substantial match for the stated scope.

#### ► AFFIRMATIVE ARGUMENT

Manual 8.5.5 requires controlled handling, storage, cleaning, packaging, preservation and shipment to prevent damage, loss and deterioration. Sensitive items are marked and their conditions checked; project plans define special protection and handler competence.

#### ► CONTRARY ARGUMENT

The general preservation process is substantive. For special handling tools, the supplied rule does not clearly prescribe inspection/testing before use or at defined intervals, as NQA-1 Requirement 13 §400 requires when such tools are needed.

#### ⚖️ JUDGE RULING

Substantially matched, 4/5. Written preservation and special-condition controls cover the main duty. The special handling-tool check needs clarification only where that equipment is used; no unsupported claim about Ekonergr operating a warehouse or crane is made.

#### ► Crumbs linked to this score (5)

#### ✓ AUDITOR VERIFICATION ACTION

Resolve or verify these specific points: The general preservation process is substantive. For special handling tools, the supplied rule does not clearly prescribe inspection/testing before use or at defined intervals, as NQA-1 Requirement 13 §400 requires when such tools are needed.

**Anchor evidence:** - - vezane uz sustav zaštite okoliša kao što su lista primjenljive zakonske regulative, zapisi o značajnim aspektima okoliša; (source locator: KONTROLA ZAPISA > 1. UVOD > 1.1. Opseg)

## XIV Inspection, Test, and Operating Status

**SUBSTANTIALLY MATCHED**

Manual 8.6 and 9.1.4 require accepted work and authorized release, and Dodatak 1 §14 requires nuclear status planning. Authority to remove status marks and safeguards against operating-status bypass are not clear. The documented status-control process is a substantial match.

75% • 4/5

4 linked controls; content-based judgment: substantially (4/5, 75 points)

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0032-APP\_B\_XIV-0001, CRUMB-DOC-0032-APP\_B\_XIV-0002, CRUMB-DOC-0032-APP\_B\_XIV-0003, CRUMB-DOC-0032-APP\_B\_XIV-0004; source documents: PQ07.5-7\_r10\_Kontrola\_zapisa.md, PQ08.2-2\_r5\_Priprema\_i\_postupanje\_s\_ugovornom\_doku.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 8.6 and 9.1.4 require accepted work and authorized release, and Dodatak 1 §14 requires nuclear status planning. Authority to remove status marks and safeguards against operating-status bypass are not clear. The documented status-control process is a substantial match.

#### ► AFFIRMATIVE ARGUMENT

Manual 8.6 and 9.1.4 require acceptance evidence and an authorized release before delivery; nonconforming release requires special approval. Calibration status is marked and overdue equipment excluded. Dodatak 1 §14 requires a nuclear status document with a method, traceability and marking authority.

#### ► CONTRARY ARGUMENT

The service-release process is clear. The generic nuclear status rule does not clearly prescribe who may remove status marks and how an unsafe operating status or bypass is prevented under NQA-1 Requirement 14 §100.

### ⚖ JUDGE RULING

Substantially matched, 4/5. Written service acceptance and release controls are present, along with nuclear status planning. The remaining concern is the generic status-removal/operating safeguard, not a demand for completed plant tag records from an engineering-service supplier.

#### ► Crumbs linked to this score (4)

### ✓ AUDITOR VERIFICATION ACTION

Resolve or verify these specific points: The service-release process is clear. The generic nuclear status rule does not clearly prescribe who may remove status marks and how an unsafe operating status or bypass is prevented under NQA-1 Requirement 14 §100.

**Anchor evidence:** Pregledao: Krešimir Brckan, dipl.ing. (source locator: KONTROLA ZAPISA)

## **XV Nonconforming Materials, Parts, or Components**

**SUBSTANTIALLY MATCHED**

Manual 8.7 and PQ10.2-1 control reporting, segregation, disposition, approval and re-verification; design changes follow original design controls. A mandatory technical justification and matching as-built record for repair/use-as-is are not clear. Nonconformance control is a substantial match; Part 21 reporting is a separate follow-up.

**75% · 4/5**

**12 linked controls; content-based judgment: substantially (4/5, 75 points)**

### **SOURCE REFERENCES**

Ekonergr crumbs: CRUMB-DOC-0020-APP\_B\_XV-0001, CRUMB-DOC-0029-APP\_B\_XV-0001, CRUMB-DOC-0029-APP\_B\_XV-0002, CRUMB-DOC-0032-APP\_B\_XV-0001, CRUMB-DOC-0032-APP\_B\_XV-0002, CRUMB-DOC-0032-APP\_B\_XV-0003, CRUMB-DOC-0032-APP\_B\_XV-0004, CRUMB-DOC-0032-APP\_B\_XV-0005, CRUMB-DOC-0032-APP\_B\_XV-0006, CRUMB-DOC-0032-APP\_B\_XV-0007, CRUMB-DOC-0032-APP\_B\_XV-0008, CRUMB-DOC-0032-APP\_B\_XV-0010; source documents: PQ08.2-1\_r6\_Odnosi\_s\_Naručiteljima.md, PQ10.2-1\_r10\_Kontrola\_neusklađenosti.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### **► CRITERION SUMMARY**

Manual 8.7 and PQ10.2-1 control reporting, segregation, disposition, approval and re-verification; design changes follow original design controls. A mandatory technical justification and matching as-built record for repair/use-as-is are not clear. Nonconformance control is a substantial match; Part 21 reporting is a separate follow-up.

#### **► AFFIRMATIVE ARGUMENT**

Manual 8.7 and PQ10.2-1 §§2-3 define immediate reporting, marking/segregation or other safeguards, evaluation, approved disposition, prevention of use and verified completion. PQ8.3-1 §3.5 applies original design controls to changes caused by a nonconformance.

#### **► CONTRARY ARGUMENT**

Use-as-is or repair decisions do not clearly require a documented technical justification and matching as-built records as specified by NQA-1 Requirement 15 §404. Customer consent and QA approval are meaningful, but do not by themselves supply that technical basis. Part 21 reporting remains a separate unresolved follow-up.

### **👤 JUDGE RULING**

Substantially matched, 4/5. The written prevention, disposition and re-verification process is substantial. Technical justification and as-built treatment for repair/use-as-is need clarification. This rating covers Appendix B XV, not a finding of full Part 21 compliance.

#### **► Crumbs linked to this score (12)**

### **✓ AUDITOR VERIFICATION ACTION**

Resolve or verify these specific points: Use-as-is or repair decisions do not clearly require a documented technical justification and matching as-built records as specified by NQA-1 Requirement 15 §404. Customer consent and QA approval are meaningful, but do not by themselves supply that technical basis. Part 21 reporting remains a separate unresolved follow-up.

**Anchor evidence:** Voditelj Q/EP/HS službe po potrebi otvara Izvještaj o neusklađenosti (IN) prema postupku PQ.8-1 ili Zahtjev za korektivnu akciju (ZK) u skladu s postupkom PQ.8-4. (source locator:



**XVI Corrective Action****FULLY MATCHED**

Manual 8.7, 9.2 and 10.2 plus PQ10.2-2 require prompt correction, significant-condition cause analysis, recurrence prevention, records, management reporting and verified completion. The written corrective-action process is fully matched. Part 21 reporting remains applicable and unresolved, outside XVI's Appendix B score.

**100% • 5/5****25 linked controls; content-based judgment: fully (5/5, 100 points)****SOURCE REFERENCES**

Ekonergr crumbs: CRUMB-DOC-0020-APP\_B\_XVI-0001, CRUMB-DOC-0020-APP\_B\_XVI-0002, CRUMB-DOC-0027-APP\_B\_XVI-0001, CRUMB-DOC-0027-APP\_B\_XVI-0002, CRUMB-DOC-0028-APP\_B\_XVI-0001, CRUMB-DOC-0029-APP\_B\_XVI-0001, CRUMB-DOC-0029-APP\_B\_XVI-0002, CRUMB-DOC-0029-APP\_B\_XVI-0003, CRUMB-DOC-0029-APP\_B\_XVI-0004, CRUMB-DOC-0030-APP\_B\_XVI-0004, CRUMB-DOC-0030-APP\_B\_XVI-0005, CRUMB-DOC-0030-APP\_B\_XVI-0006, CRUMB-DOC-0032-APP\_B\_XVI-0001, CRUMB-DOC-0032-APP\_B\_XVI-0003, CRUMB-DOC-0032-APP\_B\_XVI-0004, CRUMB-DOC-0032-APP\_B\_XVI-0005, CRUMB-DOC-0032-APP\_B\_XVI-0006, CRUMB-DOC-0032-APP\_B\_XVI-0007, CRUMB-DOC-0032-APP\_B\_XVI-0008, CRUMB-DOC-0032-APP\_B\_XVI-0009, CRUMB-DOC-0032-APP\_B\_XVI-0010, CRUMB-DOC-0032-APP\_B\_XVI-0011, CRUMB-DOC-0032-APP\_B\_XVI-0012, CRUMB-DOC-0032-APP\_B\_XVI-0014, CRUMB-DOC-0032-APP\_B\_XVI-0016; source documents: PQ08.2-1\_r6\_Odnosi\_s\_Naručiteljima.md, PQ08.3-1\_r4\_Kontrola\_studijskih\_projektnih\_radova\_.md, PQ09.2\_r9\_Provjere.md, PQ09.3\_r6\_Pregled\_i\_ocjena\_sustava\_kvalitete,\_zašt.md, PQ10.2-1\_r10\_Kontrola\_neusklađenosti.md, PQ10.2-2\_r10\_Kontrola\_korektivnih\_akcija.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

**► CRITERION SUMMARY**

Manual 8.7, 9.2 and 10.2 plus PQ10.2-2 require prompt correction, significant-condition cause analysis, recurrence prevention, records, management reporting and verified completion. The written corrective-action process is fully matched. Part 21 reporting remains applicable and unresolved, outside XVI's Appendix B score.

**► AFFIRMATIVE ARGUMENT**

Manual 8.7, 9.2, 10.2 and Prilog 2 require prompt action, significant/repeated cause review, recurrence prevention, records, management reports and verified completion/effectiveness. PQ10.2-2 §§2.2, 2.5, 2.7 and 3.1-3.8 assign approval, follow-up, reopening and reporting duties.

**► CONTRARY ARGUMENT**

No missing Appendix B XVI written corrective-action duty is identified. The real audit must sample timely and effective completion. Part 21 remains applicable: the reporting route beyond the customer notification described in PQ10.2-1 §3.11 remains unresolved, and is not included in XVI's Appendix B score.

**🔗 JUDGE RULING**

Fully matched for documentation, 5/5. The written controls cover Appendix B XVI and NQA-1 Requirement 16 §100. Part 21 reporting is outside this criterion's score and remains unresolved; full here does not mean full Part 21 compliance or verified execution.

**► Crumbs linked to this score (25)****✓ AUDITOR VERIFICATION ACTION**

Resolve or verify these specific points: No missing Appendix B XVI written corrective-action duty is identified. The real audit must sample timely and effective completion. Part 21 remains applicable: the reporting route beyond the customer notification described in PQ10.2-1 §3.11 remains unresolved, and is not included in XVI's Appendix B score.

**Anchor evidence:** O rješenju svake primjedbe/reklamacije koja je ubilježena u Listu reklamacija Voditelj tima je dužan pisano izvijestiti Voditelja Q/EP/HS službe i Direktora odjela. Voditelj Q/EP/HS službe bilježi rješenje u Listi reklamacija, a također zatvara IN ili ZK, ako su za to ostvareni uvjeti. (source locator: ODNOSI S NARUČITELJIMA > 3.3.5.)

**XVII****Quality Assurance Records****SUBSTANTIALLY MATCHED**

PQ7.5-7 defines record identity, approval, retention, lifetime nuclear records and five-year media copying; the manual requires remote server copies. Conflicting backup references and incomplete access/technology-change retrieval rules leave a written gap. Record control is a substantial match.

**75% · 4/5****46 linked controls; content-based judgment: substantially (4/5, 75 points)****SOURCE REFERENCES**

Ekonergr crumbs: CRUMB-DOC-0008-APP\_B\_XVII-0001, CRUMB-DOC-0009-APP\_B\_XVII-0001, CRUMB-DOC-0009-APP\_B\_XVII-0002, CRUMB-DOC-0010-APP\_B\_XVII-0001, CRUMB-DOC-0011-APP\_B\_XVII-0003, CRUMB-DOC-0012-APP\_B\_XVII-0001, CRUMB-DOC-0013-APP\_B\_XVII-0001, CRUMB-DOC-0014-APP\_B\_XVII-0001, CRUMB-DOC-0015-APP\_B\_XVII-0001, CRUMB-DOC-0016-APP\_B\_XVII-0037, CRUMB-DOC-0016-APP\_B\_XVII-0038, CRUMB-DOC-0016-APP\_B\_XVII-0039, CRUMB-DOC-0016-APP\_B\_XVII-0040, CRUMB-DOC-0016-APP\_B\_XVII-0041, CRUMB-DOC-0016-APP\_B\_XVII-0042, CRUMB-DOC-0018-APP\_B\_XVII-0001, CRUMB-DOC-0019-APP\_B\_XVII-0001, CRUMB-DOC-0020-APP\_B\_XVII-0001, CRUMB-DOC-0020-APP\_B\_XVII-0002, CRUMB-DOC-0020-APP\_B\_XVII-0003, CRUMB-DOC-0021-APP\_B\_XVII-0007, CRUMB-DOC-0021-APP\_B\_XVII-0008, CRUMB-DOC-0022-APP\_B\_XVII-0001, CRUMB-DOC-0023-APP\_B\_XVII-0001, CRUMB-DOC-0024-APP\_B\_XVII-0001, CRUMB-DOC-0025-APP\_B\_XVII-0001, CRUMB-DOC-0026-APP\_B\_XVII-0001, CRUMB-DOC-0027-APP\_B\_XVII-0001, CRUMB-DOC-0027-APP\_B\_XVII-0002, CRUMB-DOC-0028-APP\_B\_XVII-0001, CRUMB-DOC-0029-APP\_B\_XVII-0001, CRUMB-DOC-0030-APP\_B\_XVII-0002, CRUMB-DOC-0032-APP\_B\_XVII-0001, CRUMB-DOC-0032-APP\_B\_XVII-0002, CRUMB-DOC-0032-APP\_B\_XVII-0003, CRUMB-DOC-0032-APP\_B\_XVII-0004, CRUMB-DOC-0032-APP\_B\_XVII-0005, CRUMB-DOC-0032-APP\_B\_XVII-0007, CRUMB-DOC-0032-APP\_B\_XVII-0009, CRUMB-DOC-0032-APP\_B\_XVII-0010, CRUMB-DOC-0032-APP\_B\_XVII-0011, CRUMB-DOC-0032-APP\_B\_XVII-0012, CRUMB-DOC-0032-APP\_B\_XVII-0013, CRUMB-DOC-0032-APP\_B\_XVII-0014, CRUMB-DOC-0032-APP\_B\_XVII-0015, CRUMB-DOC-0032-APP\_B\_XVII-0018; source documents:

PQ06.1\_Upravljanje\_rizicima.md, PQ07.1-1\_r8\_Kontrola\_školoovanja\_i\_treninga\_osoblja.md, PQ07.1-2\_r5\_Kontrola\_opreme\_za\_mjerenje\_inspekcij.md, PQ07.5-2\_r8\_Postupci\_sustava\_kvalitete\_sustava\_za.md, PQ07.5-3\_r3\_Kontrolni\_postupci.md, PQ07.5-4\_r6\_Radni\_postupci.md, PQ07.5-5\_r10\_Kontrola\_dokumenata\_koji\_nastaju\_u\_Ek.md, PQ07.5-6\_r5\_Kontrola\_dokumentacije\_koju\_prima\_Ekon.md, PQ07.5-7\_r10\_Kontrola\_zapisa.md, PQ08.1-2\_r4\_Plan\_kvalitete.md, PQ08.1-3\_r2\_Plan\_vođenja\_projekta.md, PQ08.2-1\_r6\_Odnosi\_s\_Naručiteljima.md, PQ08.2-2\_r5\_Priprema\_i\_postupanje\_s\_ugovornom\_doku.md, PQ08.3-1\_r4\_Kontrola\_studijskih\_projektnih\_radova\_.md, PQ08.4-1\_r3\_Kontrola\_studijskih\_projektnih\_radova\_.md, PQ08.4-2\_r9\_Kontrola\_nabave.md, PQ08.4-3\_r11\_Evaluacija\_i\_izbor\_dobavljača.md, PQ08.6\_r3\_Kontrola\_i\_verifikacija\_aktivnosti.md, PQ09.2\_r9\_Provjere.md, PQ09.3\_r6\_Pregled\_i\_ocjena\_sustava\_kvalitete\_zašt.md, PQ10.2-1\_r10\_Kontrola\_neusklađenosti.md, PQ10.2-2\_r10\_Kontrola\_korektivnih\_akcija.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

**► CRITERION SUMMARY**

PQ7.5-7 defines record identity, approval, retention, lifetime nuclear records and five-year media copying; the manual requires remote server copies. Conflicting backup references and incomplete access/technology-change retrieval rules leave a written gap. Record control is a substantial match.

**► AFFIRMATIVE ARGUMENT**

Manual 7.5.4, PQ7.5-7 §§3.1-3.8 and Prilog B define record identity, review, responsibility, retention and lifetime nuclear records. Electronic media are checked/copied within five years; Dodatak 1 §17

describes a central archive, a server and a remote parallel server.

► **CONTRARY ARGUMENT**

The backup method is cited as RSP-03 while Prilog 5 lists ROS-04. The supplied storage rules do not fully define protection/access and continued retrieval through hardware/software changes under NQA-1 Requirement 17 §§601 and 800. Five-year copying and remote storage are credited, not ignored.

⚖️ **JUDGE RULING**

Substantially matched, 4/5. Identification, retention, responsibility and physical/electronic preservation are substantive. The backup reference and long-term access/retrieval safeguards need clearer controlled instructions.

► **Crumbs linked to this score (46)**

✓ **AUDITOR VERIFICATION ACTION**

Resolve or verify these specific points: The backup method is cited as RSP-03 while Prilog 5 lists ROS-04. The supplied storage rules do not fully define protection/access and continued retrieval through hardware/software changes under NQA-1 Requirement 17 §§601 and 800. Five-year copying and remote storage are credited, not ignored.

**Anchor evidence:** Liste opasnosti čuvaju se kod vođitelja Q/EP/HS službe kao zasebni dokumenti, a kopije kod direktora odjela. (source locator: 4. ZAPISI)

## XVIII Audits

**SUBSTANTIALLY MATCHED**

Manual 9.2 and PQ9.2 define planned independent audits, qualified nuclear auditors, reports and verified follow-up. Supplier reviews occur after work and audits at least every three years. The annual or formally reviewed ongoing evaluation between nuclear supplier audits is not clear, so this is a substantial match.

75% • 4/5

16 linked controls; content-based judgment: substantially (4/5, 75 points)

### SOURCE REFERENCES

Ekonergr crumbs: CRUMB-DOC-0008-APP\_B\_XVIII-0001, CRUMB-DOC-0009-APP\_B\_XVIII-0001, CRUMB-DOC-0014-APP\_B\_XVIII-0001, CRUMB-DOC-0025-APP\_B\_XVIII-0001, CRUMB-DOC-0027-APP\_B\_XVIII-0001, CRUMB-DOC-0027-APP\_B\_XVIII-0002, CRUMB-DOC-0027-APP\_B\_XVIII-0003, CRUMB-DOC-0028-APP\_B\_XVIII-0001, CRUMB-DOC-0032-APP\_B\_XVIII-0001, CRUMB-DOC-0032-APP\_B\_XVIII-0002, CRUMB-DOC-0032-APP\_B\_XVIII-0003, CRUMB-DOC-0032-APP\_B\_XVIII-0004, CRUMB-DOC-0032-APP\_B\_XVIII-0005, CRUMB-DOC-0032-APP\_B\_XVIII-0006, CRUMB-DOC-0032-APP\_B\_XVIII-0007, CRUMB-DOC-0032-APP\_B\_XVIII-0010; source documents: PQ06.1\_Upravljanje\_rizicima.md, PQ07.1-1\_r8\_Kontrola\_školoovanja\_i\_treninga\_osoblja.md, PQ07.5-5\_r10\_Kontrola\_dokumenata\_koji\_nastaju\_u\_Ek.md, PQ07.5-7\_r10\_Kontrola\_zapisa.md, PQ08.4-3\_r11\_Evaluacija\_i\_izbor\_dobavljača.md, PQ09.2\_r9\_Provjere.md, PQ09.3\_r6\_Pregled\_i\_ocjena\_sustava\_kvalitete\_zajt.md, Priručnik\_sustava\_upravljanja\_rev.5\_\_9492b447c386.md

#### ► CRITERION SUMMARY

Manual 9.2 and PQ9.2 define planned independent audits, qualified nuclear auditors, reports and verified follow-up. Supplier reviews occur after work and audits at least every three years. The annual or formally reviewed ongoing evaluation between nuclear supplier audits is not clear, so this is a substantial match.

#### ► AFFIRMATIVE ARGUMENT

Manual 9.2 and PQ9.2 §§3.2-3.8 require planned and extra audits, independent trained auditors, checklists, reports to management, responses and verified follow-up. Nuclear lead-auditor qualification includes five audits in three years with a recent nuclear audit, continuing participation and an annual-evaluation form.

#### ► CONTRARY ARGUMENT

PQ8.4-3 §3.8 reviews supplier performance after engagements and PQ9.2 §3.2 prescribes triennial nuclear supplier audits. A required annual evaluation, or a formally reviewed ongoing alternative, between supplier audits is not clearly set out for all approved nuclear suppliers under NQA-1 Requirement 18 §202.

### ⚖ JUDGE RULING

Substantially matched, 4/5. The audit process and nuclear auditor qualification duties are substantive. The supplier performance-review interval needs clarification. Completed audit records are real-audit samples, not a prerequisite for crediting this written process.

► Crumbs linked to this score (16)

### ✓ AUDITOR VERIFICATION ACTION

Resolve or verify these specific points: PQ8.4-3 §3.8 reviews supplier performance after engagements and PQ9.2 §3.2 prescribes triennial nuclear supplier audits. A required annual evaluation, or a

formally reviewed ongoing alternative, between supplier audits is not clearly set out for all approved nuclear suppliers under NQA-1 Requirement 18 §202.

**Anchor evidence:** Kontrola učinkovitosti poduzetih mjera i kontrola preostalih rizika obavlja se od strane Q/EP/HS službe na internim auditima sustava kvalitete i sustava zaštite okoliša. (source locator: 3.4 Kontrola učinkovitosti poduzetih mjera)

## Ekonerg Evidence Matrix

Column headers sort the matrix. Ratings use the approved five-level Enconet scale.

| NO.<br>▲ | TITLE                     | STATUS                | SCORE        | EVIDENCE               | PRIMARY VERIFICATION A                                                                                                                                                                                                                                                                         |
|----------|---------------------------|-----------------------|--------------|------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| I        | Organization              | SUBSTANTIALLY MATCHED | 75% ·<br>4/5 | 52<br>linked<br>crumbs | Resolve or verify specific points: T written organizat rules do not clea protect QA decis when cost or sch conflicts with nu safety. Managem access and a stop route support independence, b not fully settle th conflict.                                                                     |
| II       | Quality Assurance Program | SUBSTANTIALLY MATCHED | 75% ·<br>4/5 | 47<br>linked<br>crumbs | Resolve or verify specific points: T program has a meaningful grad planning process written nuclear inspection/test personnel qualific rules do not clea the periodic re-evaluation and inactivity checks NQA-1 Requirem §203. General tra and certificate re do not fully defin those checks. |
| III      | Design Control            | SUBSTANTIALLY MATCHED | 75% ·<br>4/5 | 34<br>linked<br>crumbs | Resolve or verify specific points: T nuclear addendu Prilog 5 use inconsistent RSP ROS identifiers. T actual design-so verification meth not supplied, so written chain to a proven calculatio or independently                                                                                |

| NO.<br>▲ | TITLE                                  | STATUS                | SCORE         | EVIDENCE         | PRIMARY<br>VERIFICATION A                                                                                                                                                                                                                           |
|----------|----------------------------------------|-----------------------|---------------|------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|          |                                        |                       |               |                  | verified result is incomplete.                                                                                                                                                                                                                      |
| IV       | Procurement Document Control           | FULLY MATCHED         | 100%<br>• 5/5 | 11 linked crumbs | Resolve or verify specific points: N specific missing v procurement-document duty i identified in the reviewed scope. audit sampling n confirm that nuc purchase docum use the required clauses, including lower-tier flow-d and record/subm terms. |
| V        | Instructions, Procedures, and Drawings | FULLY MATCHED         | 100%<br>• 5/5 | 22 linked crumbs | Resolve or verify specific points: N specific missing general instructio content duty is identified. Task-s RVT/RPT/RMT/R and RSP/ROS me still need real-au checks in their ov technical areas; a alone is not proc a special method qualified.     |
| VI       | Document Control                       | SUBSTANTIALLY MATCHED | 75%<br>• 4/5  | 40 linked crumbs | Resolve or verify specific points: T supplied manual conflicting refere Dodatak 1 §11 ci ROS-02 for softw control while Pri lists ROS-03; §17 RSP-03 for backu while the registe ROS-04. These a navigation ambig not merely abser work samples.    |

| NO.<br>▲ | TITLE                                                          | STATUS                | SCORE        | EVIDENCE               | PRIMARY<br>VERIFICATION A                                                                                                                                                                                                                                                        |
|----------|----------------------------------------------------------------|-----------------------|--------------|------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| VII      | Control of Purchased Material, Equipment, and Services         | SUBSTANTIALLY MATCHED | 75% ·<br>4/5 | 24<br>linked<br>crumbs | Resolve or verify specific points: Commercial-prov dedication is des at a high level, w the detailed acceptance route Manual 8.4.3 des conformity evidence before/after installation, which not clearly secure required evidence before installatio use for safety-rel hardware. |
| VIII     | Identification and Control of Materials, Parts, and Components | SUBSTANTIALLY MATCHED | 75% ·<br>4/5 | 5 linked<br>crumbs     | Resolve or verify specific points: T process is clear f engineering deliverables. The generic nuclear hardware rules d clearly cover ider transfer on subd replacement of damaged storag marks, or limited item expiry unde NQA-1 Requirem §§202 and 302-3                       |
| IX       | Control of Special Processes                                   | PARTIALLY MATCHED     | 50% ·<br>3/5 | 3 linked<br>crumbs     | Resolve or verify specific points: T generic template procedure titles establish the acti special-process qualification met The supplied set not show how a specific NDT met demonstrated fit purpose, how its parameters/acce limits are approv and how current process, equipm |

| NO.<br>▲   | TITLE                                          | STATUS                       | SCORE                | EVIDENCE                        | PRIMARY<br>VERIFICATION A                                                                                                                                                                                                                                                                              |
|------------|------------------------------------------------|------------------------------|----------------------|---------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|            |                                                |                              |                      |                                 | and personnel qualifications are maintained.                                                                                                                                                                                                                                                           |
| <b>X</b>   | <b>Inspection</b>                              | <b>SUBSTANTIALLY MATCHED</b> | <b>75% ·<br/>4/5</b> | <b>23<br/>linked<br/>crumbs</b> | Resolve or verify specific points: The hold-point plan rule does not clearly require recorded consent before a point is waived, and NQA-1 Requirement 10 §300 requires a real audit should confirm exclusion both the performance and direct supervision from acceptance inspections.                  |
| <b>XI</b>  | <b>Test Control</b>                            | <b>SUBSTANTIALLY MATCHED</b> | <b>75% ·<br/>4/5</b> | <b>4 linked<br/>crumbs</b>      | Resolve or verify specific points: The software-control procedure reference conflicts with Primary and the full verification method is not supplied. The number of test-record content not clearly specified the detail of NQA-1 Requirement 11 including deviation and the person evaluating results. |
| <b>XII</b> | <b>Control of Measuring and Test Equipment</b> | <b>SUBSTANTIALLY MATCHED</b> | <b>75% ·<br/>4/5</b> | <b>6 linked<br/>crumbs</b>      | Resolve or verify specific points: The supplied procedure does not clearly require tracing equipment to its and evaluating performance results back to the acceptable calibration when equipment is lost, damaged or out of calibration. There are written-contr                                       |

| NO.<br>▲    | TITLE                                                | STATUS                       | SCORE            | EVIDENCE                | PRIMARY<br>VERIFICATION A                                                                                                                                                                                                                                                                                     |
|-------------|------------------------------------------------------|------------------------------|------------------|-------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|             |                                                      |                              |                  |                         | gaps under NQA-1 Requirement 12 §§303.1-303.2.                                                                                                                                                                                                                                                                |
| <b>XIII</b> | <b>Handling, Storage, and Shipping</b>               | <b>SUBSTANTIALLY MATCHED</b> | <b>75% · 4/5</b> | <b>5 linked crumbs</b>  | Resolve or verify specific points: The general preservation process is substantially matched. For special handling tools, the supplier does not clearly prescribe inspection/testing before use or at defined intervals. NQA-1 Requirement 13 §400 requires such tools are ne                                 |
| <b>XIV</b>  | <b>Inspection, Test, and Operating Status</b>        | <b>SUBSTANTIALLY MATCHED</b> | <b>75% · 4/5</b> | <b>4 linked crumbs</b>  | Resolve or verify specific points: The service-release process is clear. The general nuclear status rule does not clearly prescribe who must remove status markers and how an unsafe operating status bypass is prevented under NQA-1 Requirement 14                                                          |
| <b>XV</b>   | <b>Nonconforming Materials, Parts, or Components</b> | <b>SUBSTANTIALLY MATCHED</b> | <b>75% · 4/5</b> | <b>12 linked crumbs</b> | Resolve or verify specific points: The use or repair decisions do not clearly reflect documented technical justification and matching as-built records as specified in NQA-1 Requirement 15 §404. Custom consent and QA approval are meaningful, but by themselves such that technical base Part 21 reporting |

| NO.<br>▲ | TITLE                     | STATUS                | SCORE         | EVIDENCE               | PRIMARY<br>VERIFICATION A                                                                                                                                                                                                                                                                                                        |
|----------|---------------------------|-----------------------|---------------|------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|          |                           |                       |               |                        | remains a separate unresolved follow-up                                                                                                                                                                                                                                                                                          |
| XVI      | Corrective Action         | FULLY MATCHED         | 100%<br>• 5/5 | 25<br>linked<br>crumbs | Resolve or verify specific points: N missing Appendix XVI written corrective action duty is identified. The re audit must sample timely and effective completion. Part remains applicable reporting route beyond the customer notification described in PQ10.2-1 §3.1 remains unresolved and is not included in XVI's Appendix B |
| XVII     | Quality Assurance Records | SUBSTANTIALLY MATCHED | 75%<br>• 4/5  | 46<br>linked<br>crumbs | Resolve or verify specific points: T backup method cited as RSP-03 v Prilog 5 lists ROS The supplied storage rules do not fully define protection/access continued retrieval through hardware/software changes under N Requirement 17 and 800. Five-year copying and removal storage are credited not ignored.                   |
| XVIII    | Audits                    | SUBSTANTIALLY MATCHED | 75%<br>• 4/5  | 16 linked<br>crumbs    | Resolve or verify specific points: P 3 §3.8 reviews supplier performance after engagements and PQ9.2 §3.2 prescribe triennial nuclear supplier audits. A required annual                                                                                                                                                         |

| NO.<br>▲ | TITLE | STATUS | SCORE | EVIDENCE | PRIMARY<br>VERIFICATION A                                                                                                                                                   |
|----------|-------|--------|-------|----------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|          |       |        |       |          | evaluation, or a<br>formally reviewed<br>ongoing alternat<br>between supplie<br>audits is not clea<br>out for all approv<br>nuclear suppliers<br>NQA-1 Requirem<br>18 §202. |

## I Top Evidence Gaps Requiring Follow-up

- **IX — Control of Special Processes:** The generic template and procedure titles do not establish the actual special-process qualification method. The supplied set does not show how a specific NDT method is demonstrated fit for purpose, how its parameters/acceptance limits are approved, and how current process, equipment and personnel qualifications are maintained.
- **I — Organization:** The written organization rules do not clearly protect QA decisions when cost or schedule conflicts with nuclear safety. Management access and a stop-work route support independence, but do not fully settle that conflict.
- **II — Quality Assurance Program:** The program has a meaningful graded planning process. Its written nuclear inspection/test personnel qualification rules do not clearly set the periodic re-evaluation and inactivity checks in NQA-1 Requirement 2 §203. General training and certificate renewal do not fully define those checks.
- **III — Design Control:** The nuclear addendum and Prilog 5 use inconsistent RSP and ROS identifiers. The actual design-software verification method is not supplied, so the written chain to a proven calculation tool or independently verified result is incomplete.
- **VI — Document Control:** The supplied manual has conflicting references: Dodatak 1 §11 cites ROS-02 for software control while Prilog 5 lists ROS-03; §17 cites RSP-03 for backup while the register lists ROS-04. These are live navigation ambiguities, not merely absent work samples.
- **VII — Control of Purchased Material, Equipment, and Services:** Commercial-product dedication is described at a high level, without the detailed acceptance route. Manual 8.4.3 describes conformity evidence before/after installation, which does not clearly secure required evidence before installation or use for safety-related hardware.
- **VIII — Identification and Control of Materials, Parts, and Components:** The process is clear for engineering deliverables. The generic nuclear hardware rules do not clearly cover identity transfer on subdivision, replacement of damaged storage marks, or limited-life item expiry under NQA-1 Requirement 8 §§202 and 302-303.
- **X — Inspection:** The hold-point planning rule does not clearly require recorded consent before a hold point is waived, as NQA-1 Requirement 10 §300 requires. The real audit should also confirm exclusion of both the performer and direct supervisor from acceptance inspections.
- **XI — Test Control:** The software-control procedure reference conflicts with Prilog 5, and the full verification method is not supplied. The nuclear test-record content is not clearly specified to the detail of NQA-1 Requirement 11 §601, including deviations and the person evaluating results.
- **XII — Control of Measuring and Test Equipment:** The supplied procedure does not clearly require tracing equipment to its use and evaluating prior results back to the last acceptable calibration when equipment is lost, damaged or out of calibration. These are written-control gaps under NQA-1 Requirement 12 §§303.1-303.2.
- **XIII — Handling, Storage, and Shipping:** The general preservation process is substantive. For special handling tools, the supplied rule does not clearly prescribe inspection/testing before use or at defined intervals, as NQA-1 Requirement 13 §400 requires when such tools are needed.

- **XIV — Inspection, Test, and Operating Status:** The service-release process is clear. The generic nuclear status rule does not clearly prescribe who may remove status marks and how an unsafe operating status or bypass is prevented under NQA-1 Requirement 14 §100.
- **XV — Nonconforming Materials, Parts, or Components:** Use-as-is or repair decisions do not clearly require a documented technical justification and matching as-built records as specified by NQA-1 Requirement 15 §404. Customer consent and QA approval are meaningful, but do not by themselves supply that technical basis. Part 21 reporting remains a separate unresolved follow-up.
- **XVII — Quality Assurance Records:** The backup method is cited as RSP-03 while Prilog 5 lists ROS-04. The supplied storage rules do not fully define protection/access and continued retrieval through hardware/software changes under NQA-1 Requirement 17 §§601 and 800. Five-year copying and remote storage are credited, not ignored.
- **XVIII — Audits:** PQ8.4-3 §3.8 reviews supplier performance after engagements and PQ9.2 §3.2 prescribes triennial nuclear supplier audits. A required annual evaluation, or a formally reviewed ongoing alternative, between supplier audits is not clearly set out for all approved nuclear suppliers under NQA-1 Requirement 18 §202.

## I Priority Auditor Verification Actions

1. **IX:** Resolve or verify these specific points:  
The generic template and procedure titles do not establish the actual special-process qualification method. The supplied set does not show how a specific NDT method is demonstrated fit for purpose, how its parameters/acceptance limits are approved, and how current process, equipment and personnel qualifications are maintained.
2. **I:** Resolve or verify these specific points:  
The written organization rules do not clearly protect QA decisions when cost or schedule conflicts with nuclear safety. Management access and a stop-work route support independence, but do not fully settle that conflict.
3. **II:** Resolve or verify these specific points:  
The program has a meaningful graded planning process. Its written nuclear inspection/test personnel qualification rules do not clearly set the periodic re-evaluation and inactivity checks in NQA-1 Requirement 2 §203. General training and certificate renewal do not fully define those checks.
4. **III:** Resolve or verify these specific points:  
The nuclear addendum and Prilog 5 use inconsistent RSP and ROS identifiers. The actual design-software verification method is not supplied, so the written chain to a proven calculation tool or independently verified result is incomplete.
5. **VI:** Resolve or verify these specific points:  
The supplied manual has conflicting references: Dodatak 1 §11 cites ROS-02 for software control while Prilog 5 lists ROS-03; §17 cites RSP-03 for backup while the register lists ROS-04. These are live navigation ambiguities, not merely absent work samples.
6. **VII:** Resolve or verify these specific points:  
Commercial-product dedication is described at a high level, without the detailed acceptance route. Manual 8.4.3 describes conformity evidence before/after installation, which does not clearly secure required evidence before installation or use for safety-related hardware.
7. **VIII:** Resolve or verify these specific points:  
The process is clear for engineering deliverables. The generic nuclear hardware rules do not clearly cover identity transfer on subdivision, replacement of damaged storage marks, or limited-life item expiry under NQA-1 Requirement 8 §§202 and 302-303.
8. **X:** Resolve or verify these specific points:  
The hold-point planning rule does not clearly require recorded consent before a hold point is waived, as NQA-1 Requirement 10 §300 requires. The real audit should also confirm exclusion of both the performer and direct supervisor from acceptance inspections.
9. **XI:** Resolve or verify these specific points:  
The software-control procedure reference conflicts with Prilog 5, and the full verification method is not supplied. The nuclear test-record content is not clearly specified to the detail of NQA-1 Requirement 11 §601, including deviations and the person evaluating results.
10. **XII:** Resolve or verify these specific points:  
The supplied procedure does not clearly require tracing equipment to its use and evaluating prior results back to the last acceptable calibration when equipment is lost, damaged or out of calibration. These are written-control gaps under NQA-1 Requirement 12 §§303.1-303.2.
11. **XIII:** Resolve or verify these specific points:  
The general preservation process is substantive. For special handling tools, the supplied rule does not clearly prescribe inspection/testing before use or at defined

intervals, as NQA-1 Requirement 13 §400 requires when such tools are needed.

12. **XIV:** Resolve or verify these specific points: The service-release process is clear. The generic nuclear status rule does not clearly prescribe who may remove status marks and how an unsafe operating status or bypass is prevented under NQA-1 Requirement 14 §100.
13. **XV:** Resolve or verify these specific points: Use-as-is or repair decisions do not clearly require a documented technical justification and matching as-built records as specified by NQA-1 Requirement 15 §404. Customer consent and QA approval are meaningful, but do not by themselves supply that technical basis. Part 21 reporting remains a separate unresolved follow-up.
14. **XVII:** Resolve or verify these specific points: The backup method is cited as RSP-03 while Prilog 5 lists ROS-04. The supplied storage rules do not fully define protection/access and continued retrieval through hardware/software changes under NQA-1 Requirement 17 §§601 and 800. Five-year copying and remote storage are credited, not ignored.
15. **XVIII:** Resolve or verify these specific points: PQ8.4-3 §3.8 reviews supplier performance after engagements and PQ9.2 §3.2 prescribes triennial nuclear supplier audits. A required annual evaluation, or a formally reviewed ongoing alternative, between supplier audits is not clearly set out for all approved nuclear suppliers under NQA-1 Requirement 18 §202.
16. **IV:** Resolve or verify these specific points: No specific missing written procurement-document duty is identified in the reviewed scope. Real-audit sampling must confirm that nuclear purchase documents use the required clauses, including lower-tier flow-down and record/submittal terms.
17. **V:** Resolve or verify these specific points: No specific missing general instruction-content duty is identified. Task-specific RVT/RPT/RMT/RUT and RSP/ROS methods still need real-audit checks in their own technical areas; a title alone is not proof that a special method is qualified.
18. **XVI:** Resolve or verify these specific points: No missing Appendix B XVI written corrective-action duty is identified. The real audit must sample timely and effective completion. Part 21 remains applicable: the reporting route beyond the customer notification described in PQ10.2-1 §3.11 remains unresolved, and is not included in XVI's Appendix B score.