## पाँवर सिस्टम ऑपरेशन कारपोरेशन लिमिटेड राष्ट्रीय भार प्रेषण केंद्र, नई दिल्ली

Report for previous day **Date of Reporting** 11-Dec-14

## A. Maximum Demand

	NR	WR	SR	ER	NER	Total
Demand Met during Evening Peak hrs(MW)	38843	41684	32073	15021	2102	129723
Peak Shortage (MW)	2472	335	1454	633	79	4973
Energy Met (MU)	819	975	749	293	36	2872
Hydro Gen(MU)	99	53	82	25	6	264
Wind Gen(MU)	9	27	13			49

B. Frequency Profile (%)

Region	<49.2	<49.7	49.7-49.8	49.8-49.9	<49.9	49.9-50.05	> 50.05
NEW GRID	0.00	0.50	7.05	18.22	25.78	49.86	24.36
SR GRID	0.00	0.50	7.05	18.22	25.78	49.86	24.36

Power Supply Posi	tion in States		I as				
	Gr. A	Max. Demand Shortage during		Energy	Drawal	OD(+)/	Max
RegionRegion	States	Met during the day (MW)	maximum Demand (MW)	Met (MU)	Schedule (MU)	UD(-) (MU)	OD (MW)
	Punjab	5510	0	110.5	41.7	1.3	321
	Haryana	5644	276	116.5	62.3	1.0	279
	Rajasthan	9613	0	206.2	64.9	-1.2	985
	Delhi	3139	0	59.3	41.0	-0.1	243
NR	UP	16313	2200	225.4	80.6	-2.0	380
	Uttarakhand	1679	150	31.4	23.8	0.4	157
	HP	1378	0	24.7	19.9	0.1	173
	J&K	2030	511	42.0	33.9	2.4	251
	Chandigarh	191	0	3.4	3.2	0.2	6
	Chhattisgarh	3045	18	63.1	13.9	-0.9	245
	Gujarat	12022	34	265.7	34.9	-2.9	380
	MP	9917	0	205.9	119.2	-1.1	288
WR	Maharashtra	19194	68	402.6	130.9	1.7	667
WK	Goa	416	0	8.2	7.0	0.6	39
	DD	262	0	5.8	6.0	-0.2	24
	DNH	674	0	15.5	15.4	0.4	27
	Essar steel	402	0	8.4	8.0	0.4	197
	Andhra Pradesh	5888	7	137.7	27.4	4.7	489
	Telangana	5962	36	123.5	69.0	0.7	326
SR	Karnataka	8967	450	180.5	32.5	2.1	450
3K	Kerala	3114	125	58.3	38.0	2.7	255
	Tamil Nadu	10878	953	242.7	78.8	-0.8	455
	Pondy	289	0	6.2	6.1	0.1	17
	Bihar	2542	200	51.9	51.5	-2.6	185
	DVC	2256	0	52.5	-17.9	0.0	275
ER	Jharkhand	945	0	19.3	12.2	0.5	125
LIX	Odisha	3402	0	63.9	21.5	3.4	425
	West Bengal	6110	11	103.5	14.1	2.0	345
	Sikkim	100	0	1.9	1.5	0.4	32
NER	Arunachal Pradesh	103	6	1.8	1.4	0.4	45
	Assam	1198	44	20.9	13.7	1.6	155
	Manipur	126	6	2.2	2.2	0.0	48
	Meghalaya	283	1	4.7	4.1	-0.4	56
	Mizoram	82	4	1.2	1.0	0.2	20
	Nagaland	121	4	2.3	1.6	0.2	26
	Tripura	199	0	2.7	0.7	-0.1	23

## $\underline{\textbf{D. Transnational Exchanges} \ (MU) - Import(+ve) / Export(-ve)}$

	Bhutan	Nepal	Bangladesh
Actual(MU)	4.5	-3.5	-7.0
Max MW		-163.0	-459.0

E. Import/export By Regions(in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER
Schedule(MU)	111.1	-94.4	45.6	-69.5	7.6
Actual(MU)	119.3	-100.7	42.5	-64.7	8.8
O/D/U/D(MU)	8.2	-6.3	-3.1	4.8	1.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	Total
Central Sector	4321	9257	2070	2690	115	18453
State Sector	4330	11395	3172	6181	110	25188
Total	8651	20652	5242	8871	225	43641

सचिव(ऊर्जा)/ विशेष सचिव(ऊर्जा)/अतिरिक्त सचिव(ऊर्जा)/संयुक्त सचिव(पारेषण)/(ओ एम)/निदेशक(ओ एम)/मुख्य अभियंता-के॰वि॰प्रा॰(ग्रि॰प्र॰)/ अध्यक्ष एवं प्रबंध निदेशक (पावरग्रिङ)/मुख्य कार्यपालक अधिकारी(पोसोको)/सभी राज्यो के मुख्य सचिव/ऊर्जा सचिव

\$		INTER-REC	Date of I	11-Dec-14				
						Import=(	=(-ve)	
Sl No	Voltage Level	Line Details	Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
mport/H	Export of	ER (With NR)						
1	765KV	GAYA-FATEHPUR	S/C	0	-467	0.0	-7.0	-7.0
2	70314	SASARAM-FATEHPUR	S/C	0	0	0.0	-5.0	-5.0
3	HVDC LINK	PUSAULI B/B	S/C	0	0	0.0	0.0	0.0
4		PUSAULI-SARNATH	S/C	293	-1	4.0	0.0	4.0
5		PUSAULI -ALLAHABAD	D/C	212	0	2.0	0.0	2.0
6	400 KV	MUZAFFARPUR-GORAKHPUR	D/C	0	-447	0.0	-7.0	-7.0
7	1	PATNA-BALIA	Q/C	0	-366	0.0	-12.0	-12.0
9		BIHARSHARIFF-BALIA PUSAULI-BALIA	D/C D/C	50	-278 -37	0.0	-4.0 0.0	-4.0 0.0
10	220 KV	PUSAULI-SAHUPURI	S/C	0	-134	0.0	-2.0	-2.0
11	220 K V	SONE NAGAR-RIHAND	S/C	0	0	0.0	0.0	0.0
12	100 1717	GARWAH-RIHAND	S/C	42	0	1.0	0.0	1.0
13	132 KV	KARMANASA-SAHUPURI	S/C	0	0	0.0	0.0	0.0
14		KARMANASA-CHANDAULI	S/C	0	0	0.0	0.0	0.0
					ER-NR	7.0	-37.0	-30.0
_	Export of	ER (With WR)	T = /					
15	765 KV	JHARSUGUDA-DHARAMJAIGARH S/C	D/C	-112	116	0.0	0.4	0.4
16		NEW RANCHI-DHARAMJAIGARH ROURKELA - RAIGARH ( SEL LILO	S/C	-41	127	-0.7	0.0	-0.7
17	]	BYPASS)	S/C	0	0	0.0	-1.0	-1.0
18	400 KV	JHARSUGUDA-RAIGARH	D/C	0	0	0.0	-1.0	-1.0
19	<u> </u>	STERLITE-RAIGARH	D/C	1	0	0.0	-6.0	-6.0
20		RANCHI-SIPAT	D/C	108	-118	0.0	0.0	0.0
21	220 KV	BUDHIPADAR-RAIGARH	S/C	13	-127	0.0	-1.0	-1.0
22		BUDHIPADAR-KORBA	D/C	31	-33 ER-WR	0.0	0.0	0.0
mnort/F	Export of	ER (With SR)			EK-WK	-0.7	-8.6	-9.3
23	HVDC	JEYPORE-GAZUWAKA B/B	D/C	0	-837	0	-14	-14
23	LINK	TALCHER-KOLAR BIPOLE	D/C	0	-2357	0	-46	-46
24	400 KV	TALCHER-I/C		0	604	0	-10	-10
25	220 KV	BALIMELA-UPPER-SILERRU	S/C	0	0	0	0	0
					ER-SR	0.0	-24.0	-24.0
_		ER (With NER)	1	1	ı	r	1	
26		BINAGURI-BONGAIGAON	Q/C	0	-238	0	-8	-8
27	220 KV	BIRPARA-SALAKATI	D/C	0	-76	0	-1	-1
		WD (With ND)			ER-NER	0.0	-9.0	-9.0
28	HVDC	WR (With NR) V'CHAL B/B	D/C	300	-250	3.5	-0.8	2.7
29	765 KV		D/C D/C	0	-2070	0.0	-40.5	-40.5
30		ZERDA-KANKROLI	S/C	258	-42	1.6	0.0	1.6
31		ZERDA -BHINMAL	S/C	222	-147	0.0	-0.4	-0.4
32		V'CHAL -RIHAND	S/C	0	0	0.0	0.0	0.0
33		BADOD-KOTA	S/C	133	0	2.0	0.0	2.0
34	220 KV	BADOD-MORAK	S/C	95	0	1.0	0.0	1.0
35	-2011	MEHGAON-AURAIYA	S/C	82	0	1.6	0.0	1.6
36	40	MALANPUR-AURAIYA	S/C	46	0	0.8	0.0	0.8
37	132KV	GWALIOR-SAWAI MADHOPUR	S/C	0	0 WD ND	0.0	0.0	0.0
20	нурс	ADI MUC	D/C	0	2219		-41.7 54.4	-31.2
38 mnort/F		APL -MHG WR (With SR)	D/C	0	-2318	0.0	-54.4	-54.4
39	HVDC	BHADRAWATI B/B	-	0	-1000	0.0	-23.8	-23.8
40	LINK	BARSUR-L.SILERU	-	0	0	0.0	0.0	0.0
41	765 KV	SOLAPUR-RAICHUR	D/C	385	-419	0.0	-1.2	-1.2
42		KOLHAPUR-CHIKODI	D/C	0	-124	0.0	-1.9	-1.9
43	220 KV	PONDA-AMBEWADI	S/C	0	0	0.0	0.0	0.0
44		XELDEM-AMBEWADI	S/C	103	0	2.0	0.0	2.0
					WR-SR	2.0	-26.9	-24.9
		TRANSNA	TIONAL	EXCHAN	IGE			
45		BHUTAN						
		NEPAL						-
₹ 46 ₹ 47		BANGLADESH						