MAINTENANCE REPORT
Document ID: MR-2026-0142
Date: 2026-09-18
Equipment: Centrifugal pump CP-200
Technician: J. Moreau
Standards: ISO 13849-1

Measurements
- Measured pressure: 18.2 bar
- Maximum pressure: 16 bar
- Measured temperature: 96 °C
- Vibration: 7.1 mm/s

Observations: Leak detected at the discharge flange. Seal replaced; no corrosion found on the casing.