CABLE CERTIFICATION REPORT

Cable ID: AB | Standard: TIA Cat 5e Perm. Link | Date: Report #0

RESULT: FAIL

Cable ID:	**AB**	**Test Summary:**	**FAIL**	**Main Tester:**	FLUKE DSP-4000 S/N: 7572006 LIA011
Company:	Your Company Name	**Headroom:**	**-11.8 dB (NEXT 12-36)**	**Remote Tester:**	FLUKE DSP-4000SR S/N: 7572006 LIA011
Site:	Client Name	**Test Standard:**	TIA Cat 5e Perm. Link	**SW / Std Ver:**	3.925 / 5.17
Operator:	Your Name	**Cable Type:**	UTP 100 Ohm Cat 5e	**NVP:**	69.0%
Date / Time:	Report #0	**Shield Test:**	N/A	**Anomaly Thresh:**	15%

WIRE MAP

FAIL

	1	2	3	4	5	6	7	8	S
MAIN RJ45 PIN:	1	2	3	4	5	6	7	8	S
REMOTE RJ45 PIN:	?	2	?	4	5	6	7	8	S

CABLE PAIR PARAMETERS (LENGTH, DELAY, RESISTANCE, IMPEDANCE, ATTENUATION)

Pair	Len (m)	Lim (m)	Delay (ns)	Lim (ns)	Skew (ns)	Lim (ns)	Res (Ohm)	Imp (Ohm)	Atten (dB)	Freq (MHz)	Limit (dB)	Margin (dB)
12	0.0	90.0	0	498	0	44	N/A	N/A	99.9 F	2.4	3.0	-96.9
36	0.0	90.0	0	498	0	44	N/A	N/A	99.9 F	2.4	3.0	-96.9
45	0.0	90.0	0	498	0	44	N/A	N/A	0.3	100.0	21.0	+20.7
78	0.0	90.0	0	498	0	44	N/A	N/A	0.3	98.6	20.8	+20.5

TEST / PAIR	MAIN - WORST MARGIN				MAIN - WORST VALUE				REMOTE - WORST MARGIN				REMOTE - WORST VALUE			
Pair	Result(dB)	Freq(MHz)	Limit(dB)	Margin	Result(dB)	Freq(MHz)	Limit(dB)	Margin	Result(dB)	Freq(MHz)	Limit(dB)	Margin	Result(dB)	Freq(MHz)	Limit(dB)	Margin
RETURN LOSS FAIL																
12	3.1 F	3.8	19.0	-15.9	3.1	3.8	19.0	-15.9	3.1 F	4.4	19.0	-15.9	3.1	4.4	19.0	-15.9
36	3.1 F	1.2	19.0	-15.9	3.1	1.2	19.0	-15.9	3.0 F	1.2	19.0	-16.0	3.0	1.2	19.0	-16.0
45	14.4	100.0	0.0	+14.4	14.4	100.0	0.0	+14.4	24.0	100.0	0.0	+24.0	24.0	100.0	0.0	+24.0
78	28.1	100.0	0.0	+28.1	28.1	100.0	0.0	+28.1	28.2	100.0	0.0	+28.2	28.2	100.0	0.0	+28.2
PSNEXT FAIL																
12	24.7 F	56.4	33.4	-8.7	21.0	100.0	29.3	-8.3	50.5 F	1.0	57.0	-6.5	28.5	100.0	29.3	-0.8
36	24.6 F	56.4	33.4	-8.8	21.0	100.0	29.3	-8.3	50.5 F	1.0	57.0	-6.5	28.0	100.0	29.3	-1.3
45	38.9	47.8	34.6	+4.3	34.4	99.6	29.3	+5.1	36.1	96.8	29.6	+6.5	35.9	100.0	29.3	+6.6
78	45.4	76.6	31.2	+14.2	44.9	86.0	30.4	+14.5	50.5	30.7	37.7	+12.8	44.9	100.0	29.3	+15.6
PSACR FAIL																
12	-52.0 F	3.3	49.6	-101.6	-78.9	100.0	8.3	-87.2	-49.4 F	1.0	54.0	-103.4	-71.4	100.0	8.3	-79.7
36	-52.1 F	3.3	49.6	-101.7	-78.9	100.0	8.3	-87.2	-49.4 F	1.0	54.0	-103.4	-71.9	100.0	8.3	-80.2
45	61.7	3.4	49.4	+12.3	34.1	99.6	8.4	+25.7	62.6	4.0	47.9	+14.7	35.6	100.0	8.3	+27.3
78	77.1	2.0	53.6	+23.5	44.7	86.0	11.0	+33.7	51.6	26.7	28.4	+23.2	44.7	100.0	8.3	+36.4
NEXT FAIL																
12-36	24.9 F	54.0	36.7	-11.8	21.1	100.0	32.3	-11.2	50.5 F	1.0	60.0	-9.5	28.6	100.0	32.3	-3.7
12-45	41.3	73.8	34.5	+6.8	39.9	100.0	32.3	+7.6	43.1	86.2	33.4	+9.7	43.1	86.2	33.4	+9.7
12-78	59.1	100.0	32.3	+26.8	59.1	100.0	32.3	+26.8	55.3	99.4	32.4	+22.9	55.3	100.0	32.3	+23.0
36-45	40.1	47.8	37.6	+2.5	36.2	97.8	32.5	+3.7	36.8	100.0	32.3	+4.5	36.8	100.0	32.3	+4.5
36-78	54.3	29.4	41.0	+13.3	47.3	82.6	33.7	+13.6	52.0	29.1	41.1	+10.9	47.2	77.0	34.2	+13.0
45-78	46.7	99.8	32.3	+14.4	46.7	99.8	32.3	+14.4	46.7	99.4	32.4	+14.3	46.7	100.0	32.3	+14.4
ACR FAIL																
12-36	-52.0 F	3.3	52.6	-104.6	-78.8	100.0	11.3	-90.1	-49.4 F	1.0	57.0	-106.4	-71.3	100.0	11.3	-82.6
12-45	50.6	21.5	34.0	+16.6	39.6	100.0	11.3	+28.3	54.7	21.5	34.0	+20.7	42.9	86.2	14.0	+28.9
12-78	95.0	3.2	52.9	+42.1	58.9	100.0	11.3	+47.6	62.4	52.8	22.1	+40.3	55.1	100.0	11.3	+43.8
36-45	62.2	3.6	51.9	+10.3	35.9	97.8	11.7	+24.2	63.2	4.0	50.9	+12.3	36.5	100.0	11.3	+25.2
36-78	57.7	20.5	34.6	+23.1	47.1	82.6	14.8	+32.3	52.5	27.2	31.1	+21.4	47.0	77.0	16.0	+31.0
45-78	77.7	2.3	55.6	+22.1	46.5	99.8	11.3	+35.2	77.5	2.2	55.9	+21.6	46.5	100.0	11.3	+35.2
ELFEXT FAIL																
12-36	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6
12-45	99.8	1.0	58.6	+41.2	99.6	100.0	18.6	+81.0	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6
12-78	99.7	1.0	58.6	+41.1	99.6	98.6	18.7	+80.9	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6
36-12	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6
36-45	99.8	1.0	58.6	+41.2	99.6	100.0	18.6	+81.0	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6
36-78	99.7	1.0	58.6	+41.1	99.6	98.6	18.7	+80.9	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6
45-12	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6	99.8	1.0	58.6	+41.2	99.6	100.0	18.6	+81.0
45-36	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6	99.8	1.0	58.6	+41.2	99.6	100.0	18.6	+81.0
45-78	99.7	1.0	58.6	+41.1	99.6	98.6	18.7	+80.9	99.8	1.0	58.6	+41.2	99.6	100.0	18.6	+81.0
78-12	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6	99.7	1.0	58.6	+41.1	99.6	98.6	18.7	+80.9
78-36	0.0 F	1.0	58.6	-58.6	0.0	100.0	18.6	-18.6	99.7	1.0	58.6	+41.1	99.6	98.6	18.7	+80.9
78-45	99.8	1.0	58.6	+41.2	99.6	100.0	18.6	+81.0	99.7	1.0	58.6	+41.1	99.6	98.6	18.7	+80.9
PSELFEXT FAIL																
12	-4.8 F	1.0	55.6	-60.4	-4.8	100.0	15.6	-20.4	-4.8 F	1.0	55.6	-60.4	-4.8	100.0	15.6	-20.4
36	-4.8 F	1.0	55.6	-60.4	-4.8	100.0	15.6	-20.4	-4.8 F	1.0	55.6	-60.4	-4.8	100.0	15.6	-20.4
45	95.0	1.0	55.6	+39.4	94.8	100.0	15.6	+79.2	95.0	1.0	55.6	+39.4	94.8	100.0	15.6	+79.2
78	94.9	1.0	55.6	+39.3	94.8	98.6	15.7	+79.1	94.9	1.0	55.6	+39.3	94.8	98.6	15.7	+79.1