CABLE CERTIFICATION REPORT

Cable ID: AB | Standard: TIA Cat 5e Perm. Link | Date: 01/01/2000 12:51:17am

RESULT: PASS

Cable ID:	**AB**	**Test Summary:**	**PASS**	**Main Tester:**	FLUKE DSP-4000 S/N: 7572006 LIA011
Company:	Your Company Name	**Headroom:**	**5.9 dB (NEXT 36-45)**	**Remote Tester:**	FLUKE DSP-4000SR S/N: 7572006 LIA011
Site:	Client Name	**Test Standard:**	TIA Cat 5e Perm. Link	**SW / Std Ver:**	3.925 / 5.17
Operator:	Your Name	**Cable Type:**	UTP 100 Ohm Cat 5e	**NVP:**	69.0%
Date / Time:	01/01/2000 12:51:17am	**Shield Test:**	N/A	**Anomaly Thresh:**	15%

WIRE MAP

PASS

	1	2	3	4	5	6	7	8	S
MAIN RJ45 PIN:	1	2	3	4	5	6	7	8	S
REMOTE RJ45 PIN:	1	2	3	4	5	6	7	8	S

CABLE PAIR PARAMETERS (LENGTH, DELAY, RESISTANCE, IMPEDANCE, ATTENUATION)

Pair	Len (m)	Lim (m)	Delay (ns)	Lim (ns)	Skew (ns)	Lim (ns)	Res (Ohm)	Imp (Ohm)	Atten (dB)	Freq (MHz)	Limit (dB)	Margin (dB)
12	0.0	90.0	0	498	0	44	N/A	N/A	0.3	100.0	21.0	+20.7
36	0.0	90.0	0	498	0	44	N/A	N/A	0.4	89.8	19.8	+19.4
45	0.0	90.0	0	498	0	44	N/A	N/A	0.4	100.0	21.0	+20.6
78	0.0	90.0	0	498	0	44	N/A	N/A	0.3	100.0	21.0	+20.7

TEST / PAIR	MAIN - WORST MARGIN				MAIN - WORST VALUE				REMOTE - WORST MARGIN				REMOTE - WORST VALUE			
Pair	**Result(dB)**	**Freq(MHz)**	**Limit(dB)**	**Margin**	**Result(dB)**	**Freq(MHz)**	**Limit(dB)**	**Margin**	**Result(dB)**	**Freq(MHz)**	**Limit(dB)**	**Margin**	**Result(dB)**	**Freq(MHz)**	**Limit(dB)**	**Margin**
RETURN LOSS																
12	34.6	100.0	0.0	+34.6	34.6	100.0	0.0	+34.6	39.5	100.0	0.0	+39.5	39.5	100.0	0.0	+39.5
36	39.4	100.0	0.0	+39.4	39.4	100.0	0.0	+39.4	43.6	100.0	0.0	+43.6	43.6	100.0	0.0	+43.6
45	14.0	100.0	0.0	+14.0	14.0	100.0	0.0	+14.0	23.2	100.0	0.0	+23.2	23.2	100.0	0.0	+23.2
78	27.4	100.0	0.0	+27.4	27.4	100.0	0.0	+27.4	26.6	100.0	0.0	+26.6	26.6	100.0	0.0	+26.6
PSNEXT																
12	41.9	100.0	29.3	+12.6	41.9	100.0	29.3	+12.6	41.5	100.0	29.3	+12.2	41.5	100.0	29.3	+12.2
36	40.4	65.4	32.4	+8.0	37.4	100.0	29.3	+8.1	36.9	99.4	29.4	+7.5	36.9	100.0	29.3	+7.6
45	39.9	66.0	32.3	+7.6	37.4	100.0	29.3	+8.1	37.4	99.4	29.4	+8.0	37.4	100.0	29.3	+8.1
78	42.9	99.2	29.4	+13.5	42.9	100.0	29.3	+13.6	42.4	99.4	29.4	+13.0	42.4	100.0	29.3	+13.1
PSACR																
12	73.6	2.4	52.3	+21.3	41.6	100.0	8.3	+33.3	74.5	2.0	53.6	+20.9	41.2	100.0	8.3	+32.9
36	53.0	15.3	34.9	+18.1	37.1	100.0	8.3	+28.8	70.4	1.9	53.9	+16.5	36.6	100.0	8.3	+28.3
45	52.0	16.1	34.3	+17.7	37.0	100.0	8.3	+28.7	70.8	1.9	53.9	+16.9	37.0	100.0	8.3	+28.7
78	75.2	2.1	53.2	+22.0	42.6	100.0	8.3	+34.3	69.0	4.4	47.1	+21.9	42.1	100.0	8.3	+33.8
NEXT																
12-36	45.3	100.0	32.3	+13.0	45.3	100.0	32.3	+13.0	44.2	100.0	32.3	+11.9	44.2	100.0	32.3	+11.9
12-45	47.4	66.6	35.3	+12.1	44.6	100.0	32.3	+12.3	46.0	84.2	33.6	+12.4	44.9	100.0	32.3	+12.6
12-78	89.0	2.0	59.6	+29.4	63.2	99.8	32.3	+30.9	67.2	63.0	35.7	+31.5	64.3	100.0	32.3	+32.0
36-45	41.3	65.6	35.4	+5.9	39.1	100.0	32.3	+6.8	38.9	99.4	32.4	+6.5	38.9	100.0	32.3	+6.6
36-78	45.4	100.0	32.3	+13.1	45.4	100.0	32.3	+13.1	44.4	99.4	32.4	+12.0	44.4	100.0	32.3	+12.1
45-78	46.6	99.2	32.4	+14.2	46.6	100.0	32.3	+14.3	46.6	99.4	32.4	+14.2	46.6	99.8	32.3	+14.3
ACR																
12-36	77.6	1.8	57.0	+20.6	45.0	100.0	11.3	+33.7	76.7	2.0	56.6	+20.1	43.9	100.0	11.3	+32.6
12-45	75.9	2.7	54.3	+21.6	44.2	100.0	11.3	+32.9	73.9	3.4	52.4	+21.5	44.5	100.0	11.3	+33.2
12-78	88.9	2.0	56.6	+32.3	62.9	99.8	11.3	+51.6	92.6	2.1	56.3	+36.3	64.0	100.0	11.3	+52.7
36-45	52.0	18.3	35.9	+16.1	38.7	100.0	11.3	+27.4	72.4	1.9	56.9	+15.5	38.5	100.0	11.3	+27.2
36-78	78.1	2.1	56.3	+21.8	45.1	100.0	11.3	+33.8	78.0	2.1	56.3	+21.7	44.1	100.0	11.3	+32.8
45-78	78.7	2.0	56.6	+22.1	46.3	100.0	11.3	+35.0	72.0	4.4	50.1	+21.9	46.3	99.8	11.3	+35.0
ELFEXT																
12-36	76.5	1.1	57.8	+18.7	40.3	100.0	18.6	+21.7	76.5	1.1	57.8	+18.7	40.3	100.0	18.6	+21.7
12-45	87.5	1.0	58.6	+28.9	53.7	100.0	18.6	+35.1	87.5	1.0	58.6	+28.9	53.8	100.0	18.6	+35.2
12-78	93.9	1.0	58.6	+35.3	64.3	98.6	18.7	+45.6	93.9	1.0	58.6	+35.3	64.3	98.6	18.7	+45.6
36-12	77.1	1.0	58.6	+18.5	39.8	100.0	18.6	+21.2	77.1	1.0	58.6	+18.5	39.8	100.0	18.6	+21.2
36-45	73.1	1.0	58.6	+14.5	34.1	100.0	18.6	+15.5	73.1	1.0	58.6	+14.5	34.2	100.0	18.6	+15.6
36-78	73.5	1.6	54.6	+18.9	38.5	100.0	18.6	+19.9	73.5	1.6	54.6	+18.9	38.5	100.0	18.6	+19.9
45-12	85.0	1.0	58.6	+26.4	52.7	100.0	18.6	+34.1	85.0	1.0	58.6	+26.4	52.6	100.0	18.6	+34.0
45-36	72.7	1.0	58.6	+14.1	36.0	100.0	18.6	+17.4	72.7	1.0	58.6	+14.1	35.9	100.0	18.6	+17.3
45-78	88.2	1.5	55.1	+33.1	56.1	99.6	18.6	+37.5	88.3	1.5	55.1	+33.2	56.0	98.8	18.7	+37.3
78-12	95.1	1.1	57.8	+37.3	65.3	100.0	18.6	+46.7	95.1	1.1	57.8	+37.3	65.3	100.0	18.6	+46.7
78-36	76.5	1.1	57.8	+18.7	39.1	100.0	18.6	+20.5	76.5	1.1	57.8	+18.7	39.1	100.0	18.6	+20.5
78-45	92.5	1.1	57.8	+34.7	56.2	99.8	18.6	+37.6	92.5	1.1	57.8	+34.7	56.3	99.8	18.6	+37.7
PSELFEXT																
12	76.4	1.0	55.6	+20.8	39.6	100.0	15.6	+24.0	76.8	1.0	55.6	+21.2	40.1	100.0	15.6	+24.5
36	70.6	1.0	55.6	+15.0	33.3	100.0	15.6	+17.7	70.7	1.0	55.6	+15.1	32.0	100.0	15.6	+16.4
45	72.9	1.0	55.6	+17.3	34.1	100.0	15.6	+18.5	72.5	1.0	55.6	+16.9	35.8	100.0	15.6	+20.2
78	73.4	1.6	51.6	+21.8	38.4	100.0	15.6	+22.8	76.3	1.1	54.8	+21.5	39.0	100.0	15.6	+23.4