ONE LEGAL CULTURE / NEXTGEN SOCIO & ENVIRO ADVISORS
No.123, Green Avenue, SIDCO Industrial Estate, Coimbatore - 641 021, Tamil Nadu, India.

GROUNDWATER NOC COMPLIANCE REPORT

WRD/GW/TPR/2025/0187 | Valid | Prepared 17 Oct 2026

COMPANY Sri Balaji Textiles Private Limited - Weaving Unit	**NOC NUMBER** WRD/GW/TPR/2025/0187
ISSUING AUTHORITY Water Resources Department, SG & SWRDC, Chennai	**PURPOSE** Domestic
VALID FROM 09 Jun 2026	**VALID UNTIL** 08 Jun 2029 (renewed every 3 years)
APPROVED QUANTITY 1,00,000 litres a day (100 KLD)	**DOMESTIC / GARDENING / OTHER (LPD)** 36,000 / 20,000 / 44,000
WELL Bore well, 198 m deep, 6.5 in	**PUMP** 5 HP, 6 hours a day, 1 abstraction structure(s)

WATER DRAWN AGAINST THE APPROVED QUANTITY

Measured at: Borewell O/P (M1)

PERIOD	DAYS MEASURED	DRAWN (KL)	AVERAGE (KLD)	OF THE LIMIT	STATUS
Last 30 days	30	2,874	95.8	96%	Near limit
Whole record	140	12,713	90.8	91%	Near limit
Oct 2026	17	1,545	90.9	91%	Near limit
Sept 2026	30	3,009	100.3	100%	Over limit
Aug 2026	31	2,753	88.8	89%	Within limit
Jul 2026	31	2,717	87.6	88%	Within limit
Jun 2026	30	2,607	86.9	87%	Within limit
May 2026	1	83	83.4	83%	Within limit

Limit: 100 KLD. "Near limit" is 90 percent of it or more; "Over limit" is above it. Water between two readings is spread evenly over the days between them.

CONDITIONS OF THE NOC

13 of 18 met, 2 not met

NO.	CONDITION	STATUS	REMARKS
1	The NOC is valid only for the groundwater abstraction structures named in the certificate.	Compliant	-
2	Every other well on the premises (dug well, bore well, dug-cum-bore well) is used only for rainwater harvesting, or is sealed or closed, to avoid unauthorised extraction.	Compliant	-
3	A flow meter is installed on the suction line of the bore well at the time of extraction. Without it the NOC is cancelled immediately.	Compliant	Flow meter fitted on the suction line and sealed by the Executive Engineer on 12 June.

NO.	CONDITION	STATUS	REMARKS
4	The flow meter is sealed in the presence of the Executive Engineer or the Assistant Director (Geology) of the district. Only the permitted quantity is transported, and only in licensed vehicles.	Compliant	-
5	Calibrated flow meters keep continuous records of the water drawn, and a monthly statement of daily water drawal is submitted to the Executive Engineer, Groundwater Division.	Compliant	Monthly drawal statements filed up to the last quarter.
6	Officials of the Groundwater Wing are allowed to inspect the premises, verify water drawal records and check water quality and quantity at any time.	Compliant	-
7	Rainwater harvesting structures are established as directed and kept in working order.	Compliant	-
8	Violation of any condition leads to cancellation of the NOC without further notice.	Compliant	-
9	The firm pays groundwater extraction charges if the Government or the Water Resources Authority imposes them in future.	Compliant	-
10	At renewal the permitted quantity may be revised; the firm is ready to arrange alternative water sources (treated wastewater, desalinated water, local water bodies).	Not Applicable	-
11	One dedicated monitoring bore well is drilled within the premises within 30 days of the NOC, with a platform and a lockable cover (an unused existing bore well may be used).	Non-Compliant	No dedicated monitoring bore well yet. Quote obtained, work to be completed within 30 days.
12	The NOC is used only for the stated purpose (for example Domestic). Any deviation cancels it automatically.	Compliant	-
13	The NOC is renewed once every three years (G.O. (Ms) No. 142, PW (R2) Department, dated 23.07.2014).	Compliant	-
14	Officials may inspect the rainwater harvesting structures, the records and the drawal at any time; the records are kept up to date and available for inspection.	Compliant	-
15	If any information or document submitted by the firm is false or misleading, the department may cancel the NOC without prior notice.	Compliant	-
16	For industries drawing more than 2 lakh litres a day: a groundwater quality report for the abstraction well and the monitoring bore well, from an NABL-accredited laboratory, is submitted with the renewal application.	Not Applicable	-
17	For industries drawing more than 2 lakh litres a day: a report on the impact of the groundwater drawal, inside and outside the premises, is submitted with the renewal application.	Not Applicable	-
18	Rejected water and effluent is recycled and reused as per the TNPCB norms, and the unit moves to a zero liquid discharge facility as soon as possible, in consultation with TNPCB.	Non-Compliant	Treated water is reused in the garden; the ZLD plant is still at the design stage.

WATER METERS

METER	SOURCE / USE	COUNTS TOWARD NOC	LAST READING	LAST 30 DAYS (KL)
Borewell O/P (M1)	Borewell	Yes	53,963.1 KL on 17 Oct 2026	2,874
Canteen washing	Canteen	No	2,499.3 KL on 17 Oct 2026	149

METER	SOURCE / USE	COUNTS TOWARD NOC	LAST READING	LAST 30 DAYS (KL)
Gardening	Gardening	No	690 KL on 17 Oct 2026	60
Guest house flush water	Guest House	No	1,440.5 KL on 17 Oct 2026	105
RO feed water	RO Feed	No	19,106.5 KL on 17 Oct 2026	1,348
Toilet hand wash	Toilet	No	9,065 KL on 17 Oct 2026	572

Signature - Prepared by
Karthik Rajan

Signature - Company representative