



Dashboards

Sites >

Alarms <

Active alarms

Alarms history

Alarms report

Tickets >

Work Orders >

Activity Log >

Billing >

Graphs >

Reports >

Analytics >

Workforce >

Warranties >

Customers >

Components >

Settings >

Search sites, users, or settings...



Total Resolved

15

Avg Resolution Time

4h 36m

Last 7 Days

0

Alarms History

View resolved alarms and actions taken across all sites

Search by site, alarm type, device, or action taken...

All Severities

Alarm ID	Site	Device	Alarm Type	Severity	Occurred	Resolved	Resolution Time	Actions
ALM-2025-H001	Surya Nagar Solar Park	Inverter INV-SN-003	AC Over Voltage	HIGH	26/01/25, 2:20 pm	26/01/25, 4:30 pm	2h 10m	
ALM-2025-H002	Vid�ut Bhavan Installation	Inverter INV-VB-001	Emergency Stop Activated	CRITICAL	26/01/25, 10:00 am	26/01/25, 10:30 am	30m	
ALM-2025-H003	Marina Power Station	Inverter INV-MP-002	DC Isolation Fault	HIGH	25/01/25, 8:15 am	25/01/25, 11:45 am	3h 30m	
ALM-2025-H004	Himalayan Ridge Array	Meter MTR-HR-001	Communication Timeout	MEDIUM	25/01/25, 4:00 pm	25/01/25, 5:00 pm	1h 0m	
ALM-2025-H005	Pimpri Industrial Unit	Inverter INV-PI-001	Ground Fault	CRITICAL	24/01/25, 12:30 pm	24/01/25, 3:20 pm	2h 50m	
ALM-2025-H006	Surya Nagar Solar Park	Inverter INV-SN-004	Capacitor Voltage Imbalance	MEDIUM	24/01/25, 9:00 am	24/01/25, 2:00 pm	5h 0m	
ALM-2025-H007	Vid�ut Bhavan Installation	Inverter INV-VB-003	Thermal Shutdown	HIGH	23/01/25, 1:45 pm	23/01/25, 4:30 pm	2h 45m	
ALM-2025-H008	Marina Power Station	Inverter INV-MP-004	Phase Loss	CRITICAL	23/01/25, 11:00 am	23/01/25, 12:15 pm	1h 15m	
ALM-2025-H009	Himalayan Ridge Array	Inverter INV-HR-003	Low Irradiance	LOW	22/01/25, 5:30 pm	23/01/25, 6:30 am	13h 0m	
ALM-2025-H010	Pimpri Industrial Unit	Inverter INV-PI-003	IGBT Temperature High	HIGH	22/01/25, 2:00 pm	22/01/25, 3:30 pm	1h 30m	
ALM-2025-H011	Surya Nagar Solar Park	Inverter INV-SN-005	Firmware Update Required	LOW	21/01/25, 8:00 am	21/01/25, 10:00 am	2h 0m	
ALM-2025-H012	Vid�ut Bhavan Installation	Inverter INV-VB-004	Anti-Islanding Test Failed	MEDIUM	21/01/25, 3:30 pm	21/01/25, 4:00 pm	30m	
ALM-2025-H013	Marina Power Station	Meter MTR-MP-002	Energy Meter Calibration Due	LOW	20/01/25, 10:00 am	21/01/25, 2:00 pm	28h 0m	
ALM-2025-H014	Himalayan Ridge Array	Inverter INV-HR-004	String Reverse Polarity	CRITICAL	20/01/25, 7:15 am	20/01/25, 9:45 am	2h 30m	
ALM-2025-H015	Pimpri Industrial Unit	Inverter INV-PI-005	AC Contactor Failure	HIGH	19/01/25, 8:30 am	19/01/25, 11:00 am	2h 30m	