



One-Touch Automation, Inc.

Westfield, IN

Office: 317.896.1393

Fax: 317.614.7197

E-mail: info@one-touchautomation.com

REVISION: 11/2023

Rack Build Guidelines

Rack - Cable Ladder Guidelines:

Parts Needed:

- [90 Deg Section](#) (x1)
- [Cable Ladder](#) (x1)
- [Wall Bracket](#) (x1, x2 if ganged rack configuration)
- [J Bolts](#) (x4)
- [Butt Splice](#) (x1)
- [Rack Top](#) (If single rack used)

Mount wall bracket to plywood above DEB48 at 79 ½" height. Cable ladder to be cut down to 33 ½" section. Use butt splice kit to attach the 90 degree section and straight ladder together.