AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Enclosed Space
APM Object	CT.AIR.ENCSPACE
APM Description	Cark parks, workshops and other enclosed spaces.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 6M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.BMS HVAC.AHU	**Related CT Areas:**	Not Specified		

Scope

All sites where ventilation systems are used as mechanical means of ventilation for enclosed areas, such as car parks, workshops or basements. Note designated “confined spaces” should be managed via site specific controls and are not covered by this standard.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer’s instructions and recommendations.	Maintenance of all ventilation systems (including fans, control systems, sensors, filters, vents, ducting, mounts etc)	Competent person	Inspection and examination records, reports or certificates. Risk assessment.	PM					EVID		
All		At least every 12 months. More frequent inspections might be required based on risk assessment and environmental setting/ usage.	Thorough inspection of all mechanical ventilation systems and infrastructure to ensure safe and correct operation, including hygienic and ventilation properties.	Competent person, normally outsourced	Inspection and examination records, reports or certificates. Risk assessment.	PM					EVID		
All		Based on risk assessment, but at least every 12 months.	Monitoring of key air quality parameters to ensure compliance with maximum exposure limits if necessary (i.e. max concentration of CO of 30ppm averaged over an 8-hour period).	Competent person	Inspection and examination records, reports or certificates. Risk assessment.	(PM)					EVID		
All		In accordance with manufacturer’s instructions and recommendations but at least every: * 12 months (non-flammable/explosive atmosphere) * 6 months (explosive	If installed, calibration of air quality sensors to correct fume/gas (e.g. CO sensor) to ensure correct operation.	Competent person, normally outsourced	Inspection and examination records, reports or certificates. Risk assessment.	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Act. No. 22/1997 Coll. ČSN 331600 Government Regulation No 378/2001 Coll.	Competent person, Review technician.	Inspections of equipment Revision of electrical components.
DE	Betriebssicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbStättV) Technische Regel für Arbeitsstätten ASR A3.6 - Lüftung MPrüfVO - Muster-Prüfverordnung VDI 6022 Blatt 1 - Raumlufttechnik, Raumluftqualität - Hygieneanforderungen an raumlufttechnische Anlagen und Geräte (VDI-Lüftungsregeln)	Competent person (befähigte Person).	Inspections must be carried out before first use, after modifications subject to mandatory testing. Inspections at regular intervals based on risk assessment and manufacturer's specifications, but at least every 2 years for systems with humidifiers, and every 3 years for systems without humidifiers. Maintenance and cleaning work on ventilation systems must be carried out regularly based on risk assessment.
ES	Building Technical Code (CTE). Health Standards Basic Document (DB HS3 – Air Quality). Applicable on vehicle parking. RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2013 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections.	Competent person.	Regular maintenance in accordance with manufacturer's instructions.
FR	Arrêté du 8 octobre 1987 relatif au contrôle périodique des installations d'aération et d'assainissement des locaux de travail - Légifrance (legifrance.gouv.fr) Arrêté du 9 octobre 1987 relatif au contrôle de l'aération et de l'assainissement des locaux de travail pouvant être prescrit par l'agent de contrôle de l'inspection du travail mentionné à l'article L. 8112-1 du code du travail - Légifrance (legifrance.gouv.fr)	Competent and qualified person.	Every 12 months where recycled and non-recycled air is circulated. Every 6 months when only recycled air is circulated.
IT	Legislative Decree 9/04/2008 n.81 Decree 22/01/2008 n.37 UNI EN 16798-3:2018 (Functional requirements for ventilation systems) UNI 10339:1995 (Areaulic installations) UNI EN 15780:2011 (Pipework cleaning) UNI EN ISO 16890-1:2017 (Filters for ventilation systems)	Competent person.	Regular maintenance in accordance with manufacturer's instructions. The buyer is obliged to assign the work of installation, transformation, extension and ordinary and extraordinary maintenance of the systems to qualified companies. Filter's maintenance usually every 3 months, installation maintenance every 24 months.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333) Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Regulation of the Minister of Labor and Social Policy on General health and safety regulations (Journal of Laws 2003, number 169, item 1650) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of the Minister of Interior and Administration of June 7, 2010 on fire protection of buildings, other construction facilities and areas (Journal of Laws 2010, number 109, item 719)	Competent or qualified person.	Inspections every 12 months. If within a potentially explosive atmosphere, every 6 months
ROI	Safety, Health and Welfare at Work Act 2005 S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 S.I. No. 78/2001 - Safety, Health and Welfare At Work (Carcinogens) Regulations, 2001. S.I. No. 619/2001 - Safety, Health and Welfare At Work (Chemical Agents) Regulations, 2001	Competent person, best practice to outsource to specialist.	Inspections of all ventilation systems to be conducted at least every 14 months.
SK	Act No. 124/2006 Coll. on safety and health at work Act No. 355/2007 Coll. on the protection, promotion and development of public health Ordinance No. 259/2008 Coll. on details of the requirements for the indoor environment of buildings and of the minimum requirements for lower standard dwellings and accommodation Ordinance No. 25/1984 Coll. on ensuring work-safety in low-pressure boiler rooms Government Regulation No. 391/2006 Coll. on the minimum safety and health requirements for the workplace	Qualified and certified person, best practice to outsource to specialist.	Periodic maintenance in accordance with manufacturer's instructions. Inspections based on standardized testing of selected technical equipment.
UK	The Control of Substances Hazardous to Health Regulations 2002 The Workplace (Health, Safety and Welfare) Regulations 1992 EH40/2005 Workplace exposure limits Control of Substances Hazardous to Health Regulations (Northern Ireland) 2003 Workplace (Health, Safety and Welfare) Regulations (Northern Ireland) 1993	Competent person, best practice to outsource to specialist	Thorough Examination of ventilation systems to be conducted at least every 14 months unless part of fire system when 12 months.