AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Earthing and electrical discharging
APM Object	CT.ELEC.DISCHARGE
APM Description	Earthing and electrical discharging systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.EARTHING	**Related CT Areas:**	Not Specified		

Scope

Any site with an electrical installation. Inspection of the earthing and electrical discharging systems is mandatory as part of the inspection of the electrical installation as a whole.
Inspection requirements of electrical installations are covered under Compliance Standard CT.ELEC.ELECINST

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's and vendor's instructions and recommendations.	Routine maintenance of all electrical equipment and infrastructure	Competent person (e.g. Electrician accredited by NICEIC, ECA or SELECT.)	Maintenance logbook.	PM					EVID		
All	2	Inspection frequency based on type of installation or equipment, its use and operating conditions (risk assessment). It is generally part of the inspection of the electrical installation as a whole (see "Compliance HV inspection and	Thorough inspection of earthing and electrical discharging systems.	Competent person (Electrician accredited by NICEIC, ECA or SELECT.)	Inspection report, records or certificate Risk assessment	PM					EVID		
CZ	3	No additional requirements	Inspections as per [1] and [2].	No additional requirements	Protokol o urceni vnejsich vlivu	(PM)					EVID		
CZ	3	No additional requirements	Inspections as per [1] and [2].	No additional requirements	Protokol o urceni vnejsich vlivu	(PM)					EVID		
DE	4	Every 3 years	Additional inspection to comply with building regulations (testing for effectiveness and operational safety).	Expert according to state building law.	No additional requirements								3 year CT

DE	5	Based on insurance contract	Additional inspection (VdS-check) of HV installations and equipment for insurance cover purposes (fire risk).	VdS-approved electrical expert.	Periodic examination certificates VdS 2229								
ES	9	At least annual inspections when the soil is dryer	Inspection as per [2]	No additional requirements	No additional requirements	(PM)					EVID		
FR	6	Annual inspections.	Annual check to ensure electrical continuity and earthing efficiency.	No additional requirements	No additional requirements	(PM)					EVID		
FR	6	Annual inspections.	Annual check to ensure electrical continuity and earthing efficiency.	No additional requirements	No additional requirements	(PM)					EVID		
ROI	7	No additional requirements	Inspection as per [2]	No additional requirements	HV equipment register Schematic drawings of installation. Switchgear labelled.	(PM)					EVID		
UK	8	No additional requirements	Inspection as per [2]	No additional requirements	HV equipment register Schematic drawings of installation. Switchgear labelled.	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree 73/2010 Coll., Decree 50/1978 ČSN 331500, ČSN 332000-6 ed. 2, ČSN EN 62305, ČSN 332570, ČSN 332000, , ČSN 331600.ed.2	Competent, trained review technician	Frequency determined by the Protocol on the determination of external influences, between 6 and 60months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV Vorschrift 3 (§5) - Unfallverhütungsvorschrift Elektrische Anlagen und Betriebsmittel DIN VDE 0105-100 - Betrieb von elektrischen Anlagen DIN VDE 0100-600 VDE 0100-600:2017-06 - Errichten von Niederspannungsanlagen Teil 6: Prüfungen	Qualified electrician (Elektrofachkraft) An independent VdS-approved competent person for fire-safety insurance inspection.	Inspection must be conducted before first use and after any modification or repair to electrical installations or other conductive components of the building. Additional inspection and testing for effectiveness and operational safety in accordance with building regulations, at least every 3 years. Annual inspection of electrical installations for fire-safety insurance, preferably in the first 3 months of each insurance year.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. RD 337/2014, of May 9, which approves the high voltage electric systems and its 23 Complementary Technical Instructions. ITC-BT-18. Earthing and electrical discharging. ITC-RAT-13. Earthing and electrical discharging.	Accredited company (OCA) by ENAC.	At least annual inspections when the soil is dryer.
FR	Labour Code Art . R . 4226-16, R . 4226-17, R . 4226-19 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000022761568/#LEGISCTA000022765074 26th December 2011 Decree about electrical installations verification "Arrêté du 26 décembre 2011 relatif aux vérifications ou processus de vérification des installations électriques ainsi qu'au contenu des rapports correspondants" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000025046978/#:~:text=Le%20pr%C3%A9sent%20arr%C3%AAt%C3%A9%20fixe%20%3A,14%20du%20code%20du%20travail%20%3B&text=%E2%80%95%20les%20m%C3%A9thodes%2C%20l'%C3%A9tendue%20et%2C%20le%20cas%20%C3%A9ch%C3%A9a	Accredited organisation or employee who is qualified or trained.	Annual inspection
IT	Legislative Decree 8/04/2008 n.81 DPR 462/01 DM 22/01/2008 n.37 CEI EN 50110-1 (Operation of electrical installations) CEI 11-27 (Work on electrical installations) CEI 0-14 (Guidelines for application of DPR 462/01) CEI 64-14 (Guidelines for electrical installations inspections)	National authorities (ASL, ARPA) or accredited inspection organization	Routine maintenance. Grounding system inspection every 5 years after first putting into service, or every 2 if there is a risk of fire according to DPR 151/11.

PL	Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333) Act of 29 August 2014 on the energy performance of buildings (Journal of Laws 2021, item 497) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of April 10, 1997 - Energy Law (Journal of Laws of 1997, No. 54, item 348) Regulation of the Minister of Economy, Labor and Social Policy of 28 April 2003 on the detailed rules for confirming qualifications by persons involved in the operation of devices, installations and networks (Journal of Laws of 2003, No. 89, item 828) Regulation of the Minister of Energy of August 28, 2019 on health and safety at work with energy	Qualified or competent person	Inspection frequency depends on manufacturers or vendor recommendations, but at least every 5 years.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) NSAI 5th Edition National Rules for Electrical Installations, IS 10101:2020 on 6 March 2020	Competent and qualified electrician, approved by RECI or ECSSA.	Routine maintenance. Frequency of inspection and testing depends on the type of installation, its use and operation, but at least every 3 to 5 years.
SK	Act No. 124/2006 Coll. on safety and health at work Act No. 314/2001 Coll. on fire prevention Ordinance No. 726/2002 Coll. on the characteristics of the electric fire-safety system, the conditions of its operation and ensuring its regular inspection Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment	Qualified & certified person.	Once a year in case of complex inspection. Otherwise quarterly monthly or daily.
UK	The Electricity at Work Regulations 1989 (legislation.gov.uk) Approved code of practice BS 6626:1985 - Maintenance of Electrical Switchgear and Control gear for Voltages above 1 kV and up to and including 36 kV. BS 7671 / IET Wiring Regulations Keeping electrical switchgear safe HSG230 (hse.gov.uk) Electrical switchgear safety: A guide for owners and users (hse.gov.uk) The Electricity At Work Regulations (Northern Ireland) 1991 (legislation.gov.uk)	Registered electrician, approved by NICEIC, ECA or SELECT.	Routine maintenance. Inspection frequency of LV, MV and HV installation and/or equipment based on type of installation or equipment, its use and operating conditions, but at least every 3 (industrial premises) to 5 years (commercial premises).