AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Emergency Lighting systems
APM Object	CT.ELEC.EMERGENCYAC
APM Description	Emergency lighting system and associated infrastructure.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	LIGHT.SAFETY	**Related CT Areas:**	Not Specified		

Scope

Any site where an emergency lighting system (including battery) is installed to aid safety in the event of power failure and/or safe evacuation of the site in emergency situations.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's recommendations and instructions.	Regular maintenance and cleaning of equipment.	Competent person, usually internally sourced.	Maintenance logbook.	PM					EVID		
All	2	At least monthly, but more frequent inspections might be needed based on risk assessment.	Flick test, consisting of a mains power interruption to check correct operation of lighting	Competent person	Inspection records, report or certificate. Risk assessment	PM					EVID		
All	3	Based on risk assessment, but at least every 6 months.	Functional inspection of the entire emergency lighting system.	Competent person (e.g. Registered Electrician). Generally outsourced	Inspection records, report or certificate. Risk assessment	PM					EVID		
All	4	At least every 12 months, but more frequent inspections might be needed based on risk assessment.	Discharge test to be conducted, consisting of mains power interruption to assess the duration of the batteries under emergency situations.	Competent person (e.g. Registered Electrician). Generally outsourced	Inspection records, report or certificate. Risk assessment	PM					EVID		
All	5	In accordance with manufacturer's recommendations and instructions, but at least every 12 months.	Servicing of emergency lighting system, include inspection of the overall condition, readiness and marking of the equipment, completeness, integrity and functionality of the equipment, and the state of the alternative source of electricity.	Competent person (e.g. Registered Electrician). Generally outsourced	Inspection records, report or certificate. Risk assessment	PM					EVID		

DE	6	Every 3 years	Metering of illuminance of safety lighting according to DIN EN 1838	No additional requirements	If automatic equipment is used, record and keep the results of the rated endurance test.								3 Year CT
DE	7	Every 3 years	Inspection conducted by expert in accordance with building regulations.	Expert according to building law. Certification is necessary.	No additional requirements								3 Year CT
DE	8	In accordance with manufacturer's instructions and operating conditions. Generally 6-12 months.	Regular functional and safety inspection of batteries and its operating environment.	No additional requirements	No additional requirements	(PM)					EVID		
FR	9	At least every 6 months.	Inspection as per [1], [2], [3] & [4]. Discharge test (1 hour mini.)	No additional requirements	No additional requirements.	(PM)					EVID		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree No. 246/2001 Coll. EN 1838, EN 50172 ČSN 73 0802 ČSN 73 0804 ČSN 33 2000-6	Competent person, qualified electrician	Test carried out monthly. Full discharge test at least every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Arbeitsstättenverordnung (ArbStättV) Technische Regeln für Arbeitsstätten ASR 3.4/7 - Sicherheitsbeleuchtung, optische Sicherheitsleitsysteme DIN EN 50172 VDE 0108-100 – Sicherheitsbeleuchtungsanlagen DIN EN 1838:2019-11 - Angewandte Lichttechnik - Notbeleuchtung	Competent person (befähigte Person), qualified electrician (Elektrofachkraft).	Before building/facility is used for the first time, immediately after any modifications to the building or installation, and at least every 3 years.
ES	RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions. ITC-BT-09. Emergency lighting system. DB- SUA4 – CTE (Construction Technical Code- Safety Using Basic Document number 4 – section 2). UNE-EN 60.598-2-22 and UNE 20.392 o UNE 20.062	Accredited company (OCA) by ENAC.	Functional test to be conducted monthly. Discharge test conducted annually. Emergency lighting servicing to take place every 5 years.
FR	Labor Code Article R4226-7 & R4226-16 https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000022765084/ https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000022765070/ 14th December 2011 Ministerial Order on emergency lighting system "Arrêté du 14 décembre 2011 relatif aux installations d'éclairage de sécurité" https://www.legifrance.gouv.fr/loda/id/JORFTEXT000025055364/	Qualified person	Flick test conducted monthly. Discharge test conducted every 6 months. Servicing of emergency lighting systems at least annually.
IT	UNI CEI 11222:2013 (Maintenance) UNI EN 1838:2013 (Emergency lighting) CEI EN 60598-2-22/EC (Illumination systems- special applications: emergency systems) CEI EN 50172 (Emergency illumination systems) Legislative Decree 9.04.2008 n° 81 DPR 151/2011 DM 10/03/98 Decree 22/01/08 n.37	Competent person.	Functional check to be conducted every 6 months. Full discharge test to be conducted at least every 12 months (Autonomy verification). Emergency lighting servicing at least every 6 months.
PL	Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures and areas (Journal of Laws 2010, number 109, item 719) Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333)	Qualified or competent person.	Test conducted weekly/monthly. Full discharge test in accordance with manufacturer's instructions but at least every 12 months. Servicing of the lighting system at least every 12 months.
ROI	Safety, Health and Welfare at Work (General Application) Regulations 2007 to 2012	Competent, electrician registered on RECI or ECSSA.	Daily visual checks. Flick test to be conducted every 3 months. Functional test of the entire system to be conducted at least every 6 months. Full discharge test to be conducted at least every 12 months.

SK	Act No. 314/2001 Coll. on fire prevention Ordinance No. 121/2002 Coll. on fire prevention Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment Ordinance No. 726/2002 Coll. on the characteristics of the electric fire-safety system, the conditions of its operation and ensuring its regular inspection Government Regulation No. 387/2006 Coll. on requirements for ensuring safety and health marking at work	Qualified and certified person	If the complex inspection is realized on an annual basis, more frequent (and less complex) checks are not necessary.
UK	The Management of Health and Safety at Work Regulations 1999 (legislation.gov.uk) The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) Management of Health and Safety at Work Regulations (Northern Ireland) 2000 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) BS5266-8:2004 / BS EN 50172:2004 Emergency escape lighting systems	Competent, registered electrician on the Electrical Safety Register (NICEIC, ECA, SELECT	Weekly checks. Flick test to be conducted monthly. Functional test of the entire system to be conducted at least every 6 months. Full discharge test to be conducted at least every 12 months.