# AMAZON BASE BUILDING COMPLIANCE STANDARD

| | |
|---|---|
| **Task Title** | Power Generators |
| **APM Object** | CT.ELEC.POWERGENERATOR |
| **APM Description** | Diesel power generators. |
| **General tasks always required** | Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc.<br>Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required<br>Add notes for each observation and create a FWO if necessary to eliminate defects<br>Use appropriate tools, chemicals and industry standard practices (RME policy permitting)<br>Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE)<br>To suggest improvements please raise a SIM or contact document authors<br>Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA)<br>SIM - Link to SIM template |

| | | | | | | | |
|---|---|---|---|---|---|---|---|
| **Last Update: (Version)** | abr-24 | **Last Update Change Detail:** | PM evidence changed from 3M to 12M. | **Activities may be covered by No-Go restrictions:** | Not Specified | **Special Certification Required:** | **Delivered By:** |
| **Evidenced part or full by PM:** | Yes | **Related BBM PM:** | Diesel Back-up Power Generators | **Related CT Areas:** | Not Specified | | |

## Scope

Any site where diesel power generators are commissioned to produce electricity, generally as a back-up in emergency situations. This includes all diesel generators, whether stationary or mobile.
This Compliance Standard only covers the inspection requirements associated with the electrical components of diesel generators. The maintenance of a UPS is covered in CT.ELEC.UPS.

## Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

## Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

## Key to Abbreviations

The key to the below document is as follows:
**CT** - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
**CT*** - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
**(CT)** - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
**PM** - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
**(PM)** - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
**EVID** - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
**EVID*** - Conditional requirement to upload evidence at the interval provided
**N A R** - No Additional Requirement

## Required Tasks

| Region | Task Index | Task Frequency | Task Requirements | Qualification of Inspector | Records Required | PM | Weekly | Monthly | 3 Monthly | 6 Monthly | 12 Monthly | 24 Monthly | Additional |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| All | 1 | At least every month. | Operational check – fire generator and run for 30 minutes, check fuel levels and EVIDence of leaks and damage | Competent person | Maintenance logbook | PM | | | | | EVID | | |
| All | 2 | In accordance with manufacturer's recommendations, but at least every 12 months unless defects identified during monthly operational checks | Inspection and maintenance of all diesel generators (components, fuel pipes, exhaust flues etc) including load bank testing if required. | Competent person, often best practice to outsource | Maintenance logbook | PM | | | | | EVID | | |
| All | 3 | Based on risk assessment. Best practice states an inspection every 400 hours or 6 months, whichever comes first. | Inspection of electrical components and associated infrastructure (e.g. wiring, connections, batteries, alternators, etc.), including correct operation. | Competent person, often best practice to outsource | Inspection records, report or certificate.<br>Risk assessment | PM | | | | | EVID | | |
| All | 4 | As per permit requirements | Where generators are part of combustion plant with a permit (Medium Combustion Plant Directive) – complete air monitoring as dictated in permit conditions NB this is being phased in depending on type of plant, age of installation and capacity | Competent person, usually outsourced as requires emission monitoring of stack | Air quality results | PM | | | | | EVID | | |

## Related Regional Legislation

| Region | Relevant legislation | Vendor Certification | Statutory requirement |
|---|---|---|---|

| | | | |
|---|---|---|---|
| CZ | Government Regulation No. 101/2005 Coll.<br>Government Regulation No. 378/2001 Coll. | Competent person, best practice to outsource to specialist. | Checks to be conducted every 12 months. |
| DE | Betriebssicherheitsverordnung (BetrSichV)<br><br>Technische Regeln für Betriebssicherheit:<br><br>TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen<br><br>DGUV Vorschrift 3 - Unfallverhütungsvorschrift Elektrische Anlagen und Betriebsmittel<br><br>DGUV Information 203-032 - Auswahl und Betrieb von Stromerzeugern auf Bau- und Montagestellen | Qualified electrician (Elektrofachkraft) | Inspection prior to initial commissioning, and for mobile units a visual inspection before every use (by user).<br><br>Periodic inspection frequency based on risk assessment, but at least every 4 years for fixed installations. |
| ES | RD 842/2002, of August 2, which approves the electrotechnical regulation for low voltage and its 52 Complementary Technical Instructions.<br>ITC-BT-40. Low voltage generator facilities. | Accredited company (OCA) by ENAC. | Low voltage Inspections and testing at least every 5 years. |
| FR | N/A | N/A | N/A |
| IT | UNI EN ISO 8528-13:2016 (Safety requirements) | Competent person | Maintenance in accordance with manufacturer's instructions, usually every 12 months. |
| PL | Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333)<br>Regulation of Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065)<br>Act of April 10, 1997 - Energy Law (Journal of Laws of 1997, No. 54, item 348)<br>Regulation of the Minister of Economy, Labor and Social Policy of 28 April 2003 on the detailed rules for confirming qualifications by persons involved in the operation of devices, installations and networks (Journal of Laws of 2003, No. 89, item 828)<br>Regulation of the Minister of Energy of August 28, 2019 on health and safety at work with energy devices (Journal of Laws 2019, item 1830) | Qualified or competent person | Inspections and maintenance based on manufacturer's recommendations.<br>Inspections every 12 months if they relate to fire protection installations. |
| ROI | Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)<br>S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) | Competent person, best practice to outsource to specialist. | Inspection frequency not stipulated in regulations. Based on risk assessment. |
| SK | Act No. 124/2006 Coll. on safety and health at work<br>Ordinance No. 121/2002 Coll. on fire prevention<br>Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment<br>Government Regulation No. 392/2006 Coll. on the minimum safety and health requirements for the use of work equipment | Competent person, best practice to outsource to specialist. | Routine maintenance programme. Inspection frequency not stipulated, but it is best practice to conduct one every 12 months. |
| UK | The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk)<br>Safe use of work equipment. Provision and Use of Work Equipment Regulations 1998. Approved Code of Practice and guidance L22 (hse.gov.uk)<br>Health and Safety at Work etc. Act 1974 (legislation.gov.uk)<br>Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) | Competent person, best practice to outsource to specialist. | Maintenance in accordance with manufacturer's instructions. Inspection frequency not determined, based on risk assessment. |