AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Drainage system inspection
APM Object	CT.FAC.DRAIN
APM Description	Drainage system, above and below ground, including gutters and pipes
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	BLDG.RAINCOLL BLDG.DRAIN	**Related CT Areas:**	Not Specified		

Scope

All sites should conduct routine maintenance and inspections of the drainage system, including gutters, down pipes, and surface water and sewage pipe network to ensure they are free from blockages and prevent environmental pollution incidents and flooding.
Note that interceptor maintenance is covered in CT.ENVIRO.INTERCEPTOR and pumps associated with surface water and sewerage are covered in CT.SEWAGE.RAINWATERPUMP and CT.SEWAGE.SEWAGEPUMP.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Frequency dependant on environmental conditions (e.g. leaf fall) and surroundings, known issues etc, but at least 6 - monthly.	Regular visual checks and maintenance of all building drainage elements such as gutters, down pipes, drains, etc (including cleaning, leak inspections, signs of damage, etc.)	Competent person	Maintenance and inspection records.	PM					EVID		
All	2	CCTV drain inspections recommended if signs of blockages, damage or leaks to ground are identified.	CCTV inspection of waste and rainwater drains/sewers to ensure they are free from blockages or damage and to identify potential leaks to ground.	Competent person, best practice to outsource	Maintenance and inspection records.	PM					EVID		
All	3	Frequency dependent on risk assessment but at least annually.	Testing and inspection of pollution control valves installed in the drainage system (if fitted).	Competent person	Inspection records	PM					EVID		
DE	4	Every 20 years for domestic-type wastewater.	Inspection as per [2].	No additional requirements	Inspection records.	(PM)					EVID		
IT	5	No additional requirements	No additional requirements	No additional requirements	Worksheet of the building (Fascicolo dell'Opera)	PM					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	N/A	N/A	N/A
DE	Wasserhaushaltsgesetz (WHG) Self-monitoring Ordinance (Selbst- / Eigenkontrollverordnung) of the Federal States DIN 1986-3 - Entwässerungsanlagen für Gebäude und Grundstücke - Teil 3: Regeln für Betrieb und Wartung DIN 1986-30 - Entwässerungsanlagen für Gebäude und Grundstücke - Teil 30: Instandhaltung	Competent person (befähigte Person), best practice to outsource to specialist company (Fachbetrieb	Regular visual inspection of drainage facilities at least twice a year. According to DIN 1986-30, a tightness inspection must be conducted every 5 years for sites located in water protection zone II, every 15 years for sites located in water protection zones III and III A, and every 30 years in other locations. CCTV inspection of waste or rainwater sewer to detect obstruction or leaks at least every 5 years for systems located before a wastewater treatment plant, and for systems after a wastewater treatment plant every 20 years, or every 30 years for the first inspection of new systems with verifiable testing.
ES	RD 314/2006, of March 17, which approves the Building Technical Code, and further modifications such us RD732/2019, of December 20. Health Standards Basic Document (DB HS) – Water Discharge: DB HS3.	Competent person, best practice to outsource to specialist company.	Periodic maintenance according to DB HS5 (evacuación de aguas) – Section 7: - Every 6 month: cleaning of drains and gullies - Every year: sump boxes and the rest of the possible elements of the installation such as manholes or lifting pumps will be cleaned. - Every 10 years: cleaning of downpipe and drains, or before if smells are generated
FR	N/A	N/A	No additional requirements Observe local site permit and waste/rain water releases agreement from local municipality
IT	Legislative Decree 9/04/2008 n.81 DPR 06/06/2001 n.380	Competent person.	Regular maintenance and cleaning of gutters based on the maintenance program, contained in the worksheet (Fascicolo dell'Opera) provided by the building design coordinator. Frequency in dependence on weather conditions and location, best practice is every year. CCTV inspection of waste or rainwater sewer recommended if there are signs of blockages or leaks.
PL	Regulation of Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) Act of 7 July 1994 on Construction Law (Journal of Laws 2020, item 1333) Act of 7 June 2001 on collective water supply and collective sewage disposal. (Journal of Laws 2020, item 2028) Act of 20 July 2017 on Water Law (Journal of Laws 2021, item 624)	Competent person.	Regular maintenance and cleaning of gutters. Frequency dependant of weather conditions and surroundings, but at least annually.
ROI	S.I. No. 547/2008 - European Communities (Environmental Liability) Regulations 2008 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company.	Regular maintenance and cleaning of gutters. Frequency dependant of weather conditions and surroundings, but at least annually. CCTV inspection of waste or rainwater sewer recommended if there are signs of blockages or leaks.
SK	Act No. 442/2002 Coll. on public water supply and public sewerage STN 73 6760 Drainage systems inside buildings STN EN 752 Drain and sewer systems outside buildings - Sewer system management	Competent person, best practice to outsource to specialist company.	Inspection of sewerage network (Twice per year) Cleaning of drains and pipes (Annually) Maintenance of shafts (Annually) Restoration of coatings, grids (Annually)
UK	The Environmental Damage (Prevention and Remediation) (England) Regulations 2015 (legislation.gov.uk) The Environmental Damage (Prevention and Remediation) (Wales) Regulations 2009 (legislation.gov.uk) The Environmental Liability (Scotland) Regulations 2009 (legislation.gov.uk) The Environmental Liability (Prevention and Remediation) Regulations (Northern Ireland) 2009 (legislation.gov.uk) The Management of Health and Safety at Work Regulations 1999 (legislation.gov.uk) Management of Health and Safety at Work Regulations (Northern Ireland) 2000 (legislation.gov.uk) The Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk)	Competent person, best practice to outsource to specialist company.	Regular maintenance and cleaning of gutters. Frequency dependant of weather conditions and surroundings, but at least annually. CCTV inspection of waste or rainwater sewer recommended if there are signs of blockages or leaks. Annual testing and inspection of pollution control valves installed in the drainage system (if fitted).