AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Fire Doors
APM Object	CT.FIRE.DOORS
APM Description	Fire doors
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	FIRE.DOOR	**Related CT Areas:**	Not Specified		

Scope

Any site where fire doors are installed to aid in the event of a fire, by either preventing the fire from spreading between compartments or to provide means of escape

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations.	Regular maintenance and visual checks	Competent person, generally outsourced	Maintenance logbook	PM					EVID		
All	2	Based on risk assessment, but at least every 12 months.	Thorough inspection of mechanical and electrical components to ensure fire safety.	Competent person, generally outsourced	Risk assessment Inspection records, report or certificate	PM					EVID		
DE	3	Every 3 months	Functional inspection of electrically controlled systems	Not additional requirements	Not additional requirements	PM					EVID		
DE	4	Every 3 years	Additional inspection for effectiveness in accordance with building permit	Expert according to building law	Inspection records								36 Month CT
IT	5	Visual check every month. Inspection every 6 months.	Inspection as for [1] & [2]	No additional requirements	CE Declaration of Conformity (Commercial, garage and external use doors only).	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company – manufacturer - trained worker	Inspection conducted every 12 months unless the manufacturer sets a shorter time limit.
DE	Arbeitsstättenverordnung (ArbStättV) Federal State construction laws and according to building permits Technische Regel für Arbeitsstätten ASR A1.7 - Türen und Tore DGUV Information 208-022 Türen und Tore DGUV Information 208-026 Sicherheit von kraftbetätigten Karusselltüren DIN 14677 - Instandhaltung von elektrisch gesteuerten Feststellanlagen für Feuerschutz- und Rauchschutzabschlüsse sowie für elektrisch gesteuerte Feststellanlagen für Feuerschutzabschlüsse im	competent person (befähigte Person) for fire doors according to ASR A1.7 Expert (Sachverständiger) according to state building law	Manufacturer's operating, maintenance and test instructions have to be met. Inspection before the first commencement, significant changes and at regular intervals, at least every 12 months. Functional inspection by operator monthly and by competent person annually. Electrically-controlled systems need to have functional inspections conducted quarterly. Additional inspection for effectiveness in accordance with building permit every 3 years.
ES	RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) - Use and Accessibility Basic Document (DB SUA). RD 842/2013, of October 31, approving the classification of construction products and construction elements based on their reaction properties and resistance to fire. UNE 23740-1:2016: Fire safety. Shutter assemblies' elements. Specific requirements for installation, use and maintenance. Part 1 Fire doors.	Qualified person or competent external company	Maintenance (functional) before commissioning.
FR	Labor Code Article R4227-28 to 33: Firefighting and prevention means https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams	N/A	N/A
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 11473-1:2013 (Maintenance) UNI EN 16034:2014 (Performance requirements)	Competent, qualified person.	Visual checks (surveillance) usually monthly. Inspection every 6 months (check, lubrification, adjustment). Ordinary and extraordinary maintenance in the event of anomalies detected.
PL	Act of July 7, 1994 - Construction Law (Journal of Laws of 1994, No. 89, item 414) Regulation of Minister of Interior and Administration of 7 June 2010 on fire protection of buildings, other structures and areas (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of the Minister of Internal Affairs and Administration of 24 July 2009 on firefighting water supply and fire roads (Journal of Laws of 2009, No. 124, item 1030).	Qualified or competent person (e.g. fire specialist)	According to manufacturers instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie) British Standard 476 Fire Tests EN 1364-1: Fire resistance tests for non-loadbearing elements	Competent person, best practice to outsource to specialist.	Routine maintenance in accordance with manufacturer's recommendations. Inspection frequency based on risk assessment, but at least yearly.
SK	Ordinance No. 478/2008 Coll. on the properties, specific operating conditions and ensuring regular inspection of the fire separation closures Ordinance No. 121/2002 Coll. on fire prevention	Qualified & certified person	Inspection every 12 months unless stated otherwise by operating instructions.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999 : 2017 - Fire safety in the design, management and use of buildings. Code of practice British Standard 476 Fire Tests EN 1364-1: Fire resistance tests for non-loadbearing elements	Competent person, best practice to outsource to specialist.	Routine maintenance in accordance with manufacturer's recommendations. Inspection frequency based on risk assessment, but at least yearly.