AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Dry risers
APM Object	CT.FIRE.DRYRISERS
APM Description	Dry risers.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.SUP.DRYRISERS	**Related CT Areas:**	Not Specified		

Scope

Any site where dry risers are installed to aid firefighters in the event of a fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations, but at least every 6 months.	Routine maintenance to ensure correct operation of the dry risers, including valves, brackets, joints, etc.	Competent person (engineer), generally outsourced	Maintenance logbook	PM					EVID		
All	2	Every 12 months	Water pressure test.	Competent person (engineer), generally outsourced	Inspection & test records	PM					EVID		
ES	4	Every 6 months	Visual checks of pipes, tanks and hoses and their infrastructure	No additional requirements	No additional requirements					CT			
ES	5	At least every 3 months.	Inspection as per [1]	No additional requirements	No additional requirements				CT				
FR	3	No additional requirements	Inspection as per [1] & [2]	No additional requirements	Fire/Security register	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company - manufacturer-trained worker	Inspections and service every 12 months unless the manufacturer sets a shorter time limit.
DE	Arbeitsstättenverordnung (ArbStättV) DIN 14461-6 - Feuerlösch-Schlauchanschlusseinrichtungen - Teil 6: Wandhydranten mit Flachschlauch für geschultes Personal DIN 14462 - Löschwassereinrichtungen - Planung, Einbau, Betrieb und Instandhaltung von Wandhydrantenanlagen sowie Anlagen mit Über- und Unterflurhydranten	Competent person (befähigte Person) according to DIN 14462	Inspections by experts before commissioning and after significant changes. Inspection frequency in accordance with manufacturer's instructions. Every 2 years, the dry risers with their hose connection devices must be subjected to a cold water pressure test. A test report shall be prepared on the test. Quarterly visual inspections by operator.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE-EN 12845:2016+A1:2021. Fixed firefighting systems - Automatic sprinkler systems - Design, installation and maintenance	Quarterly and half-year servicing by competent person. Maintenance by authorised company. 10 years inspections by accredited company (OCA).	Regular maintenance of extinguishing agents and system components, including reading and checking manometers, checking signalling circuits and general cleaning every 3 months. Visual checks of pipes, tanks and hoses and their infrastructure every 6 months. Fully inspection every 1, 3 and 5 years. Intrusive Inspections every 10 years.
FR	Labor Code Article R4227-28 to 33 : Firefighting and prevention means https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Qualified person or competent external company	Inspections every 12 months
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI/TS 11559:2014 (Dry risers) UNI 10779:2021 (Fire hydrant networks)	Competent, qualified person, best practice to outsource to specialist.	Maintenance every 6 months (Valves manoeuvrability and status conditions of the coupling device, after completing operations ensure that the main shut-off valve is in the open positions) Functional testing (pressure test) and servicing every 12 months.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) Regulation of 24 July 2009 of the Minister of the Interior and Administration on fire water supply and fire routes (Journal of Laws 2009, number 124, item 1030)	Qualified or competent person	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist.	Annual pressure test and inspection annually.
SK	Ordinance No. 699/2004 Coll. on securing buildings with fire - fighting water	Competent person, best practice to outsource to specialist.	Inspections every 12 months unless more frequent inspection is prescribed by producer.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS 9999: 2017 - Fire safety in the design, management and use of buildings. Code of practice BS 5306 – Fire extinguishing installations BS 9990:2015 - Non automatic fire-fighting systems in buildings	Competent person, best practice to outsource to specialist.	Visual inspection (maintenance) at least every 6 months. Water pressure test every 12 months.