AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Fire pump test
APM Object	CT.FIRE.PUMP
APM Description	Fire pumps
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	FIRE.SUP	**Related CT Areas:**	Not Specified		

Scope

Any site with fire pumps used to supply water through the sprinkler system in the event of a fire.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Weekly	General maintenance and testing to ensure correct operation. Check fuel level is sufficient following the completion of the test.	Competent person, generally a manager.	Maintenance logbook	PM					EVID		
All	2	Annually	Servicing of fire pumps	Competent person, best practice to outsource (e.g. engineer).	Inspection records, reports or certificate.						CT		
DE	3	Every 6 months	Inspection as per [2].	No additional requirements	No additional requirements					CT			
FR	4	Every 6 months	Inspection as per [2].	No additional requirements	Fire/Security register					CT			
IT	5	Monthly	Inspections to check density of electrolyte.	No additional requirement	Inspection records	(PM)					EVID		

IT	6	Every 3 months	Inspection of valves, pipework and power supply.	No additional requirement	Inspection records	(PM)					EVID		
IT	7	Every 6 months	Inspection of the system and check of the alarm reporting link with the Fire Brigade	No additional requirement	Inspection records					CT			
IT	8	Annually	Pump flow test and inspection of filters, storage tank and diesel engines.	No additional requirement	Inspection records	(PM)					EVID		
SK	9	Weekly (visual check, test of functionality). Monthly (test of functionality, cleanliness check, completeness check). Annually (test of functionality, check of parameters).	If inspection frequency is not specified by manufacturer or technical description, following frequencies apply.	No additional requirement	Inspection records	(PM)					EVID		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll.	Accredited company - manufacturer-trained worker.	Inspection and service every 12 months unless the manufacturer sets a shorter time limit.
DE	Arbeitsstättenverordnung (ArbStättV) DIN EN 14466 - Feuerlöschpumpen - Tragkraftspritzen - Sicherheits- und Leistungsanforderungen, Prüfungen DIN EN 1028-1 - Feuerlöschpumpen - Feuerlöschkreiselpumpen mit Entlüftungseinrichtung - Teil 2: Feststellung der Übereinstimmung mit den allgemeinen und Sicherheitsanforderungen DIN EN 12845 - Ortsfeste Brandbekämpfungsanlagen - Automatische Sprinkleranlagen - Planung, Installation und Instandhaltung	Qualified person	Fire pumps should be controlled and tested according to manufacturer requirements and fire insurer. Portable pumps need to be checked after each use but at least once every three months. Weekly check of correct operation (e.g. functional readiness of the pumps and their drives). Inspection and service every 6 months.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE 23500: 2018: Water supplies systems for firefighting.	Quarterly and half-year servicing by competent person. Annual maintenance by authorised company. 10 years inspections by accredited company (OCA).	General maintenance every 3 to 6 months (tanks, valves, controls, pump alarms, signals, general cleaning, water levels, electric supply, etc.). Every 12 months: water supply, cleaning of filters, battery conditions and pump testing. Inspections carried out every 10 years.
FR	Labour Code Article R4227-28 to 33 https://www.legifrance.gouv.fr/codes/section_lc/LEGITEXT000006072050/LEGISCTA000018489127/#LEGISCTA000018532085 Site Authorization Permit can require additional periodic exams. APSAD or NF - voluntary standard for insurance	Competent person, best practice to outsource to specialist.	Inspections every 6 months
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI EN 12845:2020 (Maintenance)	Competent, qualified person.	Weekly checks to ensure correct operation (automatic pump start-up test and diesel engine restart test). Monthly inspections to check density of electrolyte. Inspection of valves, pipework and power supply every 3 months. Inspection of the system and check of the alarm reporting link with the Fire Brigade every 6 months. Tests of pump flow rate, of the failure to start the engine, float valve tests, tests on suction chambers and pump filters, at least annually.
PL	Regulation of the Minister of Interior and Administration of 7 June 2010 on fire protection of buildings, other buildings and land (Journal of Laws 2010, number 109, item 719 Regulation of the Minister of Infrastructure of 12 April 2002 on the technical conditions to be met by buildings and their location (Journal of Laws 2019, item 1065) (sejm.gov.pl) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869). (sejm.gov.pl) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650) (sejm.gov.pl) Regulation of the Minister of Interior and Administration of 24 July 2009 on fire water supply and fire roads (Journal of Laws 2009, number 124, item 1030). (sejm.gov.pl)	Qualified or competent person, usually a fire specialist.	According to manufacturer's instruction but at least once per year.
ROI	Safety, Health and Welfare at Work Act 2005 (irishstatutebook.ie) S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist.	Weekly testing to ensure correct operation. Serviced annually.

SK	Ordinance No. 169/2006 Coll. on the specific characteristics of fixed fire-fighting equipment and semi-stable fire-fighting equipment and on the conditions of their operation and ensuring their regular inspection Ordinance No. 699/2004 Coll. on securing buildings with water for fire – fighting	Competent and certified person	Inspection after the first installation. Regular inspections are realized according to manufacturer's instructions or technical descriptions.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) Emergency procedures (hse.gov.uk) BS EN 12845: 2015 + A1: 2019 Fixed firefighting systems. Automatic sprinkler systems. Design, installation and maintenance	Competent person, best practice to outsource to specialist company.	Weekly testing to ensure correct operation. Serviced annually.