AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	Suppression systems
APM Object	CT.FIRE.SUPPRESSION
APM Description	Fire suppression systems
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Foam Suppression System	**Related CT Areas:**	Not Specified		

Scope

Any site where fire suppression systems (e.g. foam, gas) are used to contain, extinguish and/or prevent fire from spreading or even occurring.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	Weekly	If the fire suppressor system is interfaced with the fire alarm system (FAS), it is inspected with the FAS.	Competent person	Test log book						EVID		
All	2	Every 6 to 12 months	Routine servicing of suppression systems to ensure correct operation.	Competent person	Inspection records, report or certificate. Risk assessment								One Off EVID
All	3	Before the installation is used for the first time. Every 12 months, unless it is proven (documented) that no changes have been made to the protected enclosure. Following changes in materials.	Inspection and testing of room integrity and hold time calculation.	Competent person, best practice to outsource (e.g. fire safety engineer).	Inspection records, report or certificate. Risk assessment						EVID		
ES	4	Every 3 months	Regular maintenance of all suppression systems	Accredited company or competent person	No additional requirements						EVID		
FR	5	No additional requirements	Inspection as per [2].	No additional requirements	Fire/Security register						EVID		

IT	6	Daily, weekly or monthly depending on the categories of the systems.	Surveillance and check	No additional requirements	No additional requirements						EVID		
IT	7	Every 3 to 6 and 12 months depending on the categories of the systems.	Periodic maintenance of fire suppression systems.	No additional requirements	No additional requirements						EVID		
IT	8	Every 10 years for water based and water mist systems.	Review of the installation	No additional requirements	No additional requirements								10Y CT
SK	9	functionality). Monthly (test of functionality, cleanliness check, completeness check). Annually (visual check, test of functionality, check of parameters).	If inspection frequency is not specified by manufacturer or technical description, following frequencies apply.	No additional requirement	Inspection records						EVID		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree no. 246/2001 Coll., Act. No. 133/1985 Coll. on Fire Protection. ČSN 332570, ČSN 332000, ČSN EN 62305, ČSN 331600.ed.2, Decree No. 50/1978 Coll.	Monthly test trained by a worker from the device manufacturer Accredited company Review technician	Control of the control panel once a month Check fire sensors every 6 months. Inspection of the entire FAS (service) system annually.
DE	Federal State building codes and building permit Arbeitsstättenverordnung (ArbStättV) Betriebssicherheitsverordnung (BetrSichV) VdS 2496 - VdS-Richtlinien für die Ansteuerung von Feuerlöschanlagen, Planung und Einbau Foam extinguishing systems (Schaumlöschanlagen): VdS 2108 - VdS-Richtlinien für Schaumlöschanlagen, Planung und Einbau; DIN EN 13565-2 - Ortsfeste Brandbekämpfungsanlagen - Schaumlöschanlagen - Teil 2: Planung, Einbau und Wartung	Accredited inspection body (ZÜS) for inspections according to BetrSichV Internal inspections conducted by competent person, generally the manager Service by VdS approved vendor if plant is VdS certified. Leak inspection by VdS Prüfstelle. Building regulations inspection by expert according to building law	Inspections according to BetrSichV comprise inspections prior first use (vor Inbetriebnahme), after significant changes (vor Wiederinbetriebnahme nach prüfpflichtigen Änderungen); inner inspection of pressure devices every 5 years and strength testing every 10 years of pressure devices. Internal inspections daily, weekly and monthly. Routine maintenance programme (service) annually. Leak inspection every year. Additional inspection to comply with building regulations every 3 years.
ES	RD 513/2017, which approves the Regulation of fire protection installations. RD 2267/2004, which approves the Regulation of fire safety in industrial establishments. RD 314/2006, which approves the Technical Building Code: - Fire Safety Basic Document (DB SI) UNE-EN 15004. Fixed firefighting systems - Gas extinguishing systems. UNE-EN 12094. Fixed firefighting systems - Components for gas extinguishing systems	Quarterly and half-year servicing by competent person. Annual and quinquennial maintenance by authorised company. 10 years inspections by accredited company (OCA).	Regular maintenance every 3 and 6 months. Regular functional inspections and verifications every 12 months and every 5 years. Intrusive inspection every 10 years.
FR	Labor Code https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000024769386 Site Authorization Permit can require additional periodic exams. APSAD - voluntary standard for insurance	Competent person	Inspection every 6 months
IT	Legislative Decree 09/04/2008 n.81 DPR 151/2011 DM 10/03/1998 (Currently being replaced) UNI 11280:2020 (Gas systems maintenance) UNI EN 12416-2:2007 (Powder systems maintenance) UNI EN 13565-1:2019 (Foam systems) NFPA 25:2020 (Water based systems maintenance) UNI CEN/TS 14816:2009 (Water based systems maintenance) NFPA 750:2019 (Water mist systems maintenance)	Competent, qualified person. Surveillance and checks conducted by trained employee.	Gas systems: Surveillance every month. Inspection every 6 months and review of the installations every 10 years. Powder systems: Surveillance every day, inspection every month and maintenance every 6 months. Foam systems: Surveillance and check every week and month by trained employee, inspection every 3 and 6 months. Chemical analysis every 12 months. Check of the pre-mixer membrane every 5 years. Water based systems: Surveillance and check every week and month by trained employee, inspection every 3, 6 and 12 months.
PL	Regulation of Minister of the Interior and Administration of 7 June 2010 on fire protection of buildings, other structures, and areas. (Journal of Laws 2010, number 109, item 719) Regulation of the Minister of Infrastructure of 12 April 2002 on technical conditions corresponding to the buildings and their location. (Jornal of Laws 2019, item 1065) Act of 24 August 1991 on fire protection (Journal of Laws 2021, item 869) Regulation of Minister of Labor and Social Policy of 26 September 1997 on general provisions on health and safety at work (Journal of Laws 2003, number 169, item 1650)	Qualified or competent person, usually a fire safety specialist	Regular inspection according to manufacturer's instruction but at least once per year.
ROI	Fire Services Act, 1981 (irishstatutebook.ie) ece4931c-46c0-44f7-88130ab7d78565d9.pdf (fia.uk.com)	Competent person, best practice to outsource to specialist	Inspected weekly if interfaced with fire alarm systems. Serviced 6 and 12 monthly. Room integrity Test (gaseous agents) every 12 months and when materials change takes place, unless evidence exists that no changes have been made to the protected enclosure.

SK	Act No. 314/2001 Coll. on fire prevention Ordinance No. 169/2006 Coll. on the specific characteristics of fixed fire-fighting equipment and semi-stable fire-fighting equipment and on the conditions of their operation and ensuring their regular inspection Ordinance No. 121/2002 Coll. on fire prevention	Competent and qualified person	Regular inspection at least annually unless manufacturer prescribes different period. Inspection and functionality check are realized after every repair and at the beginning of use period.
UK	The Regulatory Reform (Fire Safety) Order 2005 (legislation.gov.uk) The Fire Safety (Scotland) Regulations 2006 (legislation.gov.uk) The Fire Safety Regulations (Northern Ireland) 2010 (legislation.gov.uk) BS 9999:2017 Fire safety in the design, management and use of buildings. Code of practice (bsigroup.com) BS EN 15004-1:2019 Fixed firefighting systems. Gas extinguishing systems. Design, installation and maintenance (bsigroup.com) guidance on room integrity testing and interpretation (fia.uk.com)	Competent person, best practice to outsource to specialist.	Inspected weekly if interfaced with fire alarm systems. Serviced 6 and 12 monthly. Room integrity Test (gaseous agents) every 12 months and when materials change takes place, unless evidence exists that no changes have been made to the protected enclosure.