AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Mobile elevating working platforms
APM Object	CT.HEIGHT.MOBILEPLAT
APM Description	Mobile elevating working platforms (MEWP, cherry picker).
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	N/A	**Related CT Areas:**	Not Specified		

Scope

Any site where mobile elevating working platforms (MEWP) are operated, such as cherry pickers and scissor lifts.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's instructions and recommendations	Regular maintenance (lubrication, replacing components, topping-up fluid levels, routine adjustments).	Competent person.	N/A						CT		
All	2	Before it is first used and/or assembled	Thorough inspection of the integrity and correct operation of the scissor lifts. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be organised by insurance company	Inspection records, report or certificate. Retain until equipment is no longer in use.								EVID one off
All	3	Regularly, at least every 6 months. More frequent inspections might be needed depending on operating and environmental conditions, or after modifications or events which could have caused damage	Thorough inspection of the integrity and correct operation of the scissor lifts. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent person. Independent from person completing regular maintenance. Usually outsourced. Can be organised by insurance company	Inspection records, report or certificate. Retain until next report is made. Risk assessment					CT			
FR	5	Regular inspections every 3 to 6 months.	No additional requirements	No additional requirements	Maintenance logbook Training records					CT			
IT	6	Preliminary inspection if the equipment has not been used for more than 3 months.	No additional requirements	No additional requirements	CE Declaration of Conformity. Equipment control log, to be kept for at least 3 years								EVID on demand

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to accredited, H&S specialist	Inspections carried out every 12 months.
DE	Betriebssicherheitsverordnung (BetrSichV) Technische Regeln für Betriebssicherheit: TRBS 1201 - Prüfungen und Kontrollen von Arbeitsmitteln und überwachungsbedürftigen Anlagen DGUV 100-500 – Betrieben von Arbeitsmitteln DGUV Grundsatz 308-002 - Prüfung von Hebebühnen	Expert (Sachkundige) according to DGUV Regel 100-500	Inspection before initial commissioning (or recommissioning) and every 12 months, based on risk assessment.
ES	UNE 58921:2017 Instructions for installation, handling, maintenance, revisions and examinations of mobile elevating work platforms (UNE Norms available for a fee). Directive 2006/42 / EC of the European Parliament and of the Council of 17 May 2006 on machines RD 1644/2008, of October 10, which establishes the rules for the marketing and commissioning of machines. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment	Competent person. Scissor lifts inspections by an accredited company certified under UNE-EN ISO/IEC 17020	Annual revisions by competent personnel that can be from the owner's equipment. Inspections every 3 years by a certified company under UNE-EN ISO/IEC 17020. In case of modifications, accidents or long time without use, an extraordinary inspection would be required.
FR	1 March 2004 Decree relating to lifting equipment "Arrêté du 1er mars 2004 relatif aux vérifications des appareils et accessoires de levage." 1 March 2004 Decree (modified) https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000439029/ Ministerial Order of March 1st 2004 relating to inspection https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000439029/ Ministerial Order of March 2nd 2004 relating to maintenance logbook. https://www.legifrance.gouv.fr/loda/id/JORFTEXT000000252250/	Qualified person.	Inspections carried out every 3 to 6 months.
IT	UNI EN 1459-1:2020 Legislative Decree 9.04.2008 n° 81 Directive 2006/42/CE on machinery (Annex II A) UNI ISO 18893:2020 (Safety principles, inspection, maintenance and operation) UNI EN 1570:2015 (Safety requirements) UNI ISO 16653:2011 (Design, calculations, safety and test for special applications) UNI EN 280:2015 (Design, stability, construction, safety and test) UNI ISO 20381:2011 (Graphic symbols) DM 11/04/2011 (Periodic inspection)	Competent person.	Maintenance in accordance with manufacturer's instructions. Inspections every 12 months
PL	Regulation of the Minister of Entrepreneurship and Technology of 30 October 2018 on technical conditions of technical supervision in the field of operation, repair and modernization of handling equipment. Regulation of the Minister of Economy of 30 October 2002. On minimum requirements for health and safety in the use of machines by workers at work. (Journal of Laws of 2002, No. 191, item 1596)	Government body (UDT - Technical Inspection)	Full periodic verification of integrity and operation at least every 12 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource. Independent and INAB accredited company (BS EN ISO/IEC 17020:2004)	Through examination at least every 6 months and before it is first used. Regular maintenance (PPM).
SK	Act No. 124/2006 Coll. on safety and health at work and on the amendment of certain acts Ordinance No. 508/2009 Coll., laying down details to ensure safety and health protection when working with technical equipment - pressure, lifting, electrical and gas and which lays down technical equipment that is considered to be reserved technical equipment Government Regulation no. 392/2006 Coll. on the minimum safety and health requirements for the use of work equipment	Competent person, best practice to outsource to specialist company.	Professional inspections every 12 months, professional examination (testing) every 24 months.
UK	The Lifting Operations and Lifting Equipment Regulations 1998 The Provision and Use of Work Equipment Regulations 1998 Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999	Competent person, best practice to outsource. Independent and UKAS accredited company (BS EN ISO/IEC 17020:2004)	Thorough inspection of the integrity and correct operation of the equipment before it is first used / assembled and every 6 months. Planned maintenance programme in place.