AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Work at height Personal Protective Equipment
APM Object	CT.HEIGHT.PPE
APM Description	Work at height Personal Protective Equipment (PPE), such as harnesses, fall arrest systems and fall restraint lanyards.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site with Personal Protective Equipment (PPE) aimed to prevent falls of employees working at height. This Compliance Standard covers harnesses, fall arrest systems and fall restraint lanyards.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	At least every 6 months. More frequent inspections (interim) might be needed based on site specific risk assessment.	Thorough inspection of work-at-height PPE, including cuts, abrasion, degradation or contamination. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement - do Not use. Report issue.	Competent, independent person, H&S specialist.	Inspection records, report or certificate. Retain records. Risk assessment					CT			
FR	3	No additional requirements.	No additional requirements	No additional requirements	Training records								NAR
IT	5	No additional requirements.	No additional requirements	No additional requirements	CE Declaration of Conformity								NAR
PL	2	No additional requirements.	No additional requirements	No additional requirements	No additional requirements.								NAR
ROI	4	No additional requirements.	If equipment is hired, ensure inspections have been conducted and the results of those are satisfactory.	No additional requirements	Maintenance logbook Records to be kept for at least 5 years.								As Needed EVID

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement
CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to specialist company.	Inspections carried out every 12 months.
DE	PSA-Benutzungsverordnung (PSA-BV) DGUV Regel 112-198 - Benutzung von persönlichen Schutzausrüstungen gegen Absturz DGUV Grundsatz 312-906 - Grundlagen zur Qualifizierung von Personen für die sachkundige Überprüfung und Beurteilung von persönlichen Absturzschutzausrüstungen	Expert (sachkundige Person), DGUV 112-198.	Visual check prior to each use and inspection every 12 months, based on risk assessment.
ES	RD 2177/2004 for him that the minimum provisions are established safety and health for use by the workers of the work teams, in terms of temporary work at height. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment. Prevention Technical Note NTP 682. Prevention Technical Note NTP 1,108 (Risk and Prevention measures) Prevention Technical Note NTP 1,109 (Installation techniques) Prevention Technical Note NTP 1,110 (Ropes) UNE EN 795:2012 (Personal fall protection equipment - Anchor devices) and UNE EN 353 Standards (Personal fall protection equipment - Guided type fall arresters including an anchor line - Part 1:)	Competent person.	Inspections every 12 months. For anchoring systems, resistance and reliability of the systems must be checked by a competent person before installing them. Registers of the inspection must be kept.
FR	19th March 1993 Decree "Dispositions de l'arrêté du 19 mars 1993 concernant ces équipements" Ministerial Order of March 19th 1993 – PPE list with periodic inspection https://www.legifrance.gouv.fr/jorf/id/JORFTEXT000000730566	Qualified person.	Inspections carried out every 12 months.
IT	Legislative Decree 9.04.2008 n° 81 annex VIII UNI EN 361:2003 (Harness) UNI EN 813:2008 (Belts with leg loops) UNI EN 365:2005 (Use instructions, maintenance, inspection, repair, labelling and packaging) UNI EN 363:2019 (Fall arrest systems) UNI EN 362:2005 (Connectors) UNI EN 360:2003 (Retractable type fall arrest systems) UNI EN 358:2019 (Positioning belts and lanyards) UNI EN 355:2003 (Fall arrest lanyards) UNI EN 354:2010 (Fall restraint Lanyards)	Competent, qualified person.	Inspections every 12 months following manufacturer's instructions.
PL	Regulation of the Minister of Labor and Social Policy of September 26, 1997 on general provisions on health and safety at work (Journal of Laws of 1997, No. 129, item 844)	Government body (UDT - Technical Inspection)	Periodic inspection in accordance with manufacturer's instructions.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person, best practice to outsource to specialist company.	Pre-use checks, inspection frequency based on risk assessment, but at least every 6 months
SK	Ordinance No. 147/2013 Coll., laying down details for ensuring safety and health protection in construction work and work related to them and details on professional competence to perform certain work activities	Competent person, best practice to outsource to specialist company.	Visual check by user, prior to its use. Periodic inspection in accordance with manufacturer's instructions, at least every 12 months and after each emergency event, in particular after the fall of a person and after extreme stress in conditions which impair its safe condition.
UK	The Personal Protective Equipment at Work Regulations 1992 The Work at Height Regulations 2005 The Provision and Use of Work Equipment Regulations 1998 BS EN 365:2004 Personal protective equipment against falls from a height. INDG367 - Inspecting fall arrest equipment made from webbing or rope (hse.gov.uk) BS 7883:2019, Personal fall protection equipment Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 The Work at Height Regulations (Northern Ireland) 2005	Competent person, best practice to outsource to specialist company. Can be an internal, impartial and trained person.	Visual check prior each use. Statutory thorough inspection every 6 months, or more frequently based on risk assessment.