AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Work Restraint System
APM Object	CT.HEIGHT.RESTRAINT
APM Description	Work Restraint Systems (e.g. anchors)
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Not Specified	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site with Work Restraint Systems in place to protect employees working at height.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		Thorough inspection frequency based on risk assessment, but not to exceed 12 months.	Periodic inspection to ensure correct and safe operation. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issues.	Competent person, typically outsourced	Inspection records, report or certificate Risk assessment						CT		
IT	4	No additional requirements	Inspection as per [1]	No additional requirements	CE Declaration of Conformity if installed on reinforced concrete; Manufacturer's mark						(CT)		
PL	2	No additional requirements	Inspection as per [1]	No additional requirements	Maintenance logbook Training records Inspection records to be kept for at least 5 years.						(CT)		
ROI	3	No additional requirements	Inspection as per [1]	No additional requirements	Inspection records to be kept for at least 5 years.						(CT)		

Related Regional Legislation

Region	Relevant legislation	Vendor Certification	Statutory requirement

CZ	Regulation No. 101/2005 Coll. Regulation No. 378/2001 Coll.	Competent person, best practice to outsource to specialist company.	Inspections carried out every 12 months.
DE	DGUV Regel 112-198 - Benutzung von persönlichen Schutzausrüstungen gegen Absturz DGUV Grundsatz 312-906 - Grundlagen zur Qualifizierung von Personen für die sachkundige Überprüfung und Beurteilung von persönlichen Absturzschutzausrüstungen	Expert (sachkundige Person), DGUV 112-198.	Visual checks before each use. Inspections every 12 months based on risk assessment.
ES	UNE EN 795:2012 (Personal fall protection equipment - Anchor devices) UNE EN 353 (Personal protective equipment against falls from a height) Prevention Technical Note NTP 809 on anchoring systems RD 2177/2004 for him that the minimum provisions are established safety and health for use by the workers of the work teams, in terms of temporary work at height. RD 1215/97 establishing minimum security provisions and Health for the use by workers of work equipment.	Competent person.	Periodic inspections depending on use and conditions. Recommended every 12 months.
FR	Labour Code Art L. 4321-1 and Art R. 4322-1 (equipment maintenance) https://www.legifrance.gouv.fr/codes/article_lc/LEGIARTI000018531543/ 19th March 1993 Decree "Dispositions de l'arrêté du 19 mars 1993 concernant ces équipements" Ministerial Order of March 19th 1993 – PPE list with periodic inspection https://www.legifrance.gouv.fr/jorf/id/JORFTEXT000000730566	Qualified person.	Inspections carried out every 12 months.
IT	Legislative Decree 9.04.2008 n° 81 UNI EN 363:2019 UNI EN 365:2005 UNI EN 795:2012 UNI 11578:2015 (Requirements and test) UNI 11560:2014 (Roof anchoring systems) UNI 11158:2015 (Inspections) UNI EN 516:2006 (Installations for safe access to the roof) UNI EN 517:2006 (Safety anchors for roofs)	Competent and trained person	Periodic maintenance follow manufacturer's instructions every 12 months for anchorages complying with the standard UNI EN 795:2012, every 48 months according to the standard UNI 11578:2015
PL	Regulation of Minister of Labour and Social Policy on general provisions for occupational health and safety (OJ 2003 No 169 item 1650) as amended.	Competent person.	Periodic inspection in accordance with manufacturer's instructions.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent and trained person.	Based on risk assessment. Recommended pre-use checks and inspections at least every 6 months.
SK	Ordinance No. 147/2013 Coll., laying down details for ensuring safety and health protection in construction work and work related to them and details on professional competence to perform certain work activities	Competent person, best practice to outsource to specialist company.	Inspections must be carried out at least every 12 months.
UK	The Workplace (Health, Safety and Welfare) Regulations 1992 (legislation.gov.uk) The Work at Height Regulations 2005 (legislation.gov.uk) The Provision and Use of Work Equipment Regulations 1998 (legislation.gov.uk) Health and Safety at Work etc. Act 1974 (legislation.gov.uk) BS 7883:2019, Personal fall protection equipment. Anchor systems. System design, installation and inspection. Code of practice Provision and Use of Work Equipment Regulations (Northern Ireland) 1999 (legislation.gov.uk) The Work at Height Regulations (Northern Ireland) 2005 (legislation.gov.uk)	Competent and trained person	Visual checks before each use. Inspections every 12 months, or more frequently based on risk assessment.