AMAZON BASE BUILDING COMPLIANCE STANDARD

Task Title	Combined Heat and Power
APM Object	CT.HVAC.COMBINEDHP
APM Description	Gas-powered Combined Heat and Power systems and associated infrastructure.
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	ago-23	**Last Update Change Detail:**	Transfer to new template. Rationalisation of EU RME Minimum standards. Alignment with dependant PM. Released as Draft.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Not Specified	**Related BBM PM:**	Not Specified	**Related CT Areas:**	Not Specified		

Scope

Any site with gas-powered Combined Heat and Power (CHP) systems designed to provide power, heating and hot water.
This Compliance Standard only covers the gas installation of CHP systems, Inspections of gas installations, and pressure vessels are covered in Compliance Standards CT.HVAC.GASINSTALL and CT.PRESSURE.SYS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All		In accordance with manufacturer's instructions and recommendations.	Routine maintenance and inspections of all appliances, equipment and gas systems, as per manufacturer's recommendation and instructions.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, report or certificate.	PM					CT		
All		Based on risk assessment, but at least every 12 months	Periodic inspection and testing CHP systems. If defects are identified, prevent subsequent use through quarantine prior to repair or destruction and replacement – do Not use. Report issue.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, report or certificate.	PM					CT		
All		Inspection at least every 12 months.	Regular checks of slam shut valves (if present) to ensure correct operation.	Competent Person (e.g. Gas Safe registered engineer, accredited company, etc.)	Inspection records, report or certificate.	PM					CT		
CZ	4	Slam shut-off valves to be inspected every 4 months.	Inspection as per [3].	Certified specialised gas equipment technician.	APM Record								4M CT
DE	5	Every 2 years for plant older than 12 years (≤12J) Every 3 years for plants of 12 years or less.	Monitoring measurements based on heating plant certificate.	Authorised chimney sweeper.	Records of monitoring measurements. Sweep logbook Heating Plant Certificate							CT	

IT	8	Before first operation, during general maintenance or building reconstruction, during change of fuel, after 12 months of operation (at the beginning of every season in case of seasonal operation).	No additional requirements	Qualified person for boilers above 100 kW	Installation logbook. CE Declaration of Conformity Written report to be archived for 5 years.						CT		
PL	6	Every 6 months	Inspection of shut-off valves in buildings of more than 2,000 m2.	No additional requirements	No additional requirements					CT			
UK	7	No additional requirements	No additional requirements	No additional requirements	Planned maintenance programme.	PM					CT		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Decree No. 85/1978 Coll. Decree No.21/1979 Coll. Decree No. 34/2016 ČSN 69 0012, ČSN EN 12 186 ČSN 331600	Specialized technician of gas equipment. Inspection technician of electrical equipment. chimney sweep	Routine checks every year. Operational inspection every 3 years Inspection of shut-off valves every 4 months. Chimney inspection yearly.
DE	Gebäudeenergiegesetz – GEG § 60 Betriebssicherheitsverordnung (BetrSichV) Bundes-Immissionsschutzgesetz (BImSchG) §29a Technische Anleitung zur Reinhaltung der Luft (TA Luft) Verordnung zum Bundesimmissionsschutzgesetz (1. BImSchV) Kehr- und Überprüfungsordnung (KÜO) Schornsteinfegerhandwerksgesetz (SchfHwG)	Expert (Fachkundiger), according to GEG Authorised chimney sweeper.	Regular intervals determined by risk assessment, overall capacity and manufacturer specifications. Monitoring and inspections by chimney sweeper to be carried out every 1-3 years.
ES	RD 1027/2007, which approves the Facilities Regulation Thermal in Buildings (RITE). RD 238/2013 of Modifications to the RITE. Among other changes, it is mandatory to carry out Indoor Air Quality Inspections. RD 2060/2008, of December 12, which approve the regulation on pressure equipment and its complementary technical instructions.	Competent person. Authorised Maintainer.	Maintenance and inspections to be conducted annually. Inspections carried out by authorised companies every 5 years. For installations with power above 70 kW, biannual inspections are legally required. Inspections every 12 months (Pn>20KW heat, Pn>12kW cold)
FR	Ministerial Order of November 2nd 2017 relating to monitoring of electricity generation facilities: Arrêté du 2 novembre 2017 relatif aux modalités de contrôle des installations de production d'électricité - Légifrance (legifrance.gouv.fr)	Accredited company.	Every 4 years during the initial phase.
IT	Legislative Decree 9/04/2008 n.81 DM 11/04/2011 DM 329/2004 (for equipment not included in annex VII D.Lgs n.81/2008) Legislative Decree 3/04/2006 n.152 Decree 16/03/2017 Regulation 2402/2015/EU Legislative Decree 4/07/2014 n.102 DM 04/08/2011 Legislative Decree 3/03/2011 n.28 Legislative Decree 8/02/2007 n.20	Competent and accredited person, considered best practice to outsource to specialist company.	Operational inspection every 5 years. Maintenance as per manufacturer instructions. Generally, every 12 months. Slam shut-off valves maintenance in accordance with manufacturer's instructions, depending on the type and quality of gas used.
PL	Act of 7 July 1994 - Construction Law (Journal of Laws 2020, item 1333) Regulation of 12 April 2002 of Minister of Infrastructure on technical conditions to be met by buildings and their location. (Journal of Laws 2019, item 1065)	Qualified or competent person.	According to manufacturer's instruction, but at least every 12 months. Slam shut-off valves inspection every 12 months.
ROI	S.I. No. 299/2007 - Safety, Health and Welfare at Work (General Application) Regulations 2007 (irishstatutebook.ie)	Competent person. Must be a competent engineer on the Register of Gas Installers Ireland (RGII).	Routine maintenance in accordance with manufacturers recommendations. Inspections of CHP systems and shut-off valves at least every 12 months.
SK	Act No. 124/2006 Coll. on safety and health at work Act No. 309/2009 Coll. on the promotion of renewable energy sources and high-efficiency cogeneration Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems Ordinance No. 401/2007 Coll. on technical conditions and requirements for fire safety in the installation and operation of a fuel appliance, electrothermal appliance and central heating equipment and in the construction and use of chimneys and flues and on the deadlines for their cleaning and inspections Ordinance No. 508/2009 Coll. on details for ensuring safety and health protection at work with pressure, lifting, electrical and gas technical equipment	Qualified and certified person.	Periodic maintenance in accordance with manufacturer's instructions. Minimum period is 3 years but can be more frequent in specific cases. Inspections based on standardized testing of selected technical equipment.

UK	The Gas Safety (Installation and Use) Regulations 1998 Gas Safety (Installation and Use) Regulations (Northern Ireland) 2004	Competent person. Must be a competent engineer, accredited on the Gas Safe Register.	Routine maintenance carried out during regular examination, following manufacturer's recommendations. Inspections of system and shut-off valves at least every 12 months.