AMAZON BASE BUILDING COMPLIANCE STANDARD

amazon rme

Task Title	F-Gas Air-Conditioning
APM Object	CT.HVAC.FGAS
APM Description	All stationary refrigeration, air-conditioning, heat-pump (RAC), HV switchgear or fire protection equipment, fire extinguishers that contains F-Gas refrigerants
General tasks always required	Follow safety procedures - e.g. 1MRA, LOTO, PPE, etc. Ensure that all WOs are carried out by qualified, certified staff with appropriate familiarisation and supervision as required Add notes for each observation and create a FWO if necessary to eliminate defects Use appropriate tools, chemicals and industry standard practices (RME policy permitting) Ensure relevant logs, readings and certification is uploaded to APM prior to WO closure. CT evidence must be additionally uploaded to the DMS (WorkDocs in DE) To suggest improvements please raise a SIM or contact document authors Leonardo Vitale (LEOVITAL) Rob Gisby (EWARTGXR) or APM, Benito Sanchez Sanchez de Puerta (BPPUERTA) SIM - Link to SIM template

Last Update: (Version)	abr-24	**Last Update Change Detail:**	PM evidence changed from 3M to 12M.	**Activities may be covered by No-Go restrictions:**	Yes	**Special Certification Required:**	**Delivered By:**
Evidenced part or full by PM:	Yes	**Related BBM PM:**	Roof Top Units->Refrigeration Part Air Conditioning Units - inside unit AC Condenser Unit - outside unit Chillers	**Related CT Areas:**	CT.HVAC.ODS		

Scope

Any site with air conditioning systems containing fluorinated refrigerants listed in https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=CELEX%3A32014R0517&qid=1608306002561, where the combination of type and mass gives a CO2 equivalent in the range of 50-500 te. CO2 equivalent values for various refrigerants are given here:
https://www.gov.uk/guidance/calculate-the-carbon-dioxide-equivalent-quantity-of-an-f-gas
Some fire suppression systems and medium/high voltage equipment may also contain fluorinated refrigerants.
Units containing Ozone Depleting Substances (ODS) are outlined in standard CT.HVAC.ODS.

Using this document

This document is intended as a guide and may not be exhaustive. Whilst this document is based extensively on professional guidance and subject to periodic review, individual sites must be diligent to ensure they are aware of, and comply to, local and changing regulations.
The format of these standards is intended to improve navigation between maintenance and compliance standards and to allow frequent, minor updates to a single living resource. Please avoid offline or printed versions and check version dates and change log.
In the event of becoming aware of errors or omissions in this document, sites must provide detail, including references to relevant source information to their local planner for escalation - SIM Link above.
This document is considered released as draft.
For Information contact Authors: R Gisby (ewartgxr), Leonardo Vitale (leovital) and Benito Sanchez Sanchez de Puerta (bppuerta)

Maintenance and Compliance Relationship

Where relevant, associated Base Building PM's are listed on the header . In many cases maintenance contributes to, or fulfils compliance requirement. This may not be exhaustive and is intended to assist users to identify relevant maintenance.
If a BBM Maintenance activity fully meets the compliance requirements below, periodic upload of PM evidence will be required to APM and DMS / Workdays depending on region.

Key to Abbreviations

The key to the below document is as follows:
CT - Amazon compliance / statutory task - not otherwise covered by a BBM Standard PM. Evidence to be provided into APM and DMS upon task closure.
CT* - This is a conditional task based or based on findings from previous inspections. If a frequency is not used, a further appropriate frequency needs to be in either the region, or 'ALL'. Local teams must ensure appropriate frequency.
(CT) - Compliance task which is likely met or exceeded by a CT task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met.
PM - Requirement can demonstrated through appropriate maintenance - Refer to relevant PM Standard
(PM) - Maintenance task which is met or exceeded by a PM task in [ALL] and therefore achieved by proxy BUT local site must satisfy themselves that requirements are fully met including regional / manufacturer requirements.
EVID - Periodic upload of evidence to DMS, for non-CT task lines. For example, evidence of PM completion, certification, licence etc.
EVID* - Conditional requirement to upload evidence at the interval provided
N A R - No Additional Requirement

Required Tasks

Region	Task Index	Task Frequency	Task Requirements	Qualification of Inspector	Records Required	PM	Weekly	Monthly	3 Monthly	6 Monthly	12 Monthly	24 Monthly	Additional
All	1	In accordance with manufacturer's recommendations and instructions.	Regular maintenance of equipment containing F-gas.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Maintenance logbook	PM					EVID		
All	2	12 months without leak detection system. 24 months with leak detection system	Statutory requirement for leak inspection of all F-gas containing equipment with a CO2 equivalent of 5 to 50 tonnes of CO2. Best practice to include units <5 tonnes CO2 equivalent.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.							CT*	
All	3	6 months without leak detection system. 12 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 50 to 500 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.					CT*			
All	4	3 months without leak detection system. 6 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of more than 500 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.					CT*	CT*		
All	5	Every 12 months.	Leak detection system inspections.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.						CT		

All	6	Within 1 month	In the event that a leak is identified and fixed. Reinspection is required.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.								On Demand EVID
PL	7	Every 12 months without leak detection system or every 24 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 5 to 10 tonnes of CO2.	Competent person (e.g. City and Guilds Qualification in Refrigeration and Air Conditioning)	Inspection and maintenance records, report or certificate. Equipment register. Re-inspection evidence for fixed leaks.						CT	CT	
PL	8	Every 6 months without leak detection system or every 12 months with leak detection system.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of 10 to 50 tonnes of CO2.	No additional requirement	Equipment card if equipment has ≥3 kg of FGas or ≥5 tonnes of CO2 equivalent. Polish control system called "CRO".					CT*			
PL	9	Every 6 months. Leak detection system mandatory.	Leaks inspection of all F-gas containing equipment with a CO2 equivalent of more than 50 tonnes of CO2.	No additional requirement	Equipment card if equipment has ≥3 kg of FGas or ≥5 tonnes of CO2 equivalent. Polish control system called "CRO".					CT			
SK	10	Every 3 months without leak detection system or 6 months with leak detection system.	Leak inspection of units with more than 300 kg of fluid charge.	No additional requirements	No additional requirements.					CT*	CT*		

Related Regional Legislation			
Region	**Relevant legislation**	**Vendor Certification**	**Statutory requirement**
CZ	Regulation (EU) No 517/2014 of the European Parliament and of the Council of 16 April 2014 on fluorinated greenhouse gases and repealing Regulation (EC) No 842/2006 Act No. 73/2012 Coll., on substances depleting the ozone layer and F-gases (§4) Regulation No. 257/2012 Coll., on preventing ODS a F-gases emissions.	Third-party, independent vendor. Certified ECO specialist.	Every 12 months for units with 5-50 tonnes of CO2 equivalent, or 24 months if they have a leak detection system fitted. Every 6 months for units with 50-500 tonnes of CO2 equivalent, or 12 months if they have a leak detection system fitted. Every 3 months for units with more than 500 tonnes of CO2 equivalent, or 6 months if they have a leak detection system fitted. Leak detection system inspections every 12 months.
DE	European Regulation (EU) No 517/2014 of the European Parliament and of the Council for F Gas Chemikalien-Klimaschutzverordnung (ChemKlimaschutzV)	Competent person (befähigte Person).	Every 12 months for units with 5-50 tonnes of CO2 equivalent, or 24 months if a leak-detection system is fitted. Every 6 months for units with 50-500 tonnes of CO2 equivalent, or 12 months if a leak-detection system is fitted. Every 3 months for units with > 500 tonnes of CO2 equivalent, or 6 months if a leak-detection system is fitted.
ES	Regulation (EU) No 517/2014 of the European Parliament and of the Council of 16 April 2014 on fluorinated greenhouse gases and repealing Regulation (EC) No 842/2006 Roya Decree 115/2017 on commercialization, use and maintenance of equipment containing fluorinated gases.	Accredited company	Every 12 months for units with 5-50 tonnes of CO2 equivalent, or 24 months if they have a leak detection system fitted. Every 6 months for units with 50-500 tonnes of CO2 equivalent, or 12 months if they have a leak detection system fitted Every 3 months for units with more than 500 tonnes of CO2 equivalent, or 6 months if they have a leak detection system fitted.
FR	Arrêté du 29 février 2016 relatif à certains fluides frigorigènes et aux gaz à effet de serre fluorés - Légifrance (legifrance.gouv.fr)	Competent and qualified person.	No additional requirements
IT	DPR 146/2018 Legislative Decree 5/12/2019 n.163 Regulation 517/2014 of the European Parliament and of the Council for F Gas Regulation 303/2008/EC Regulation 1516/2007/EC DPR 43/2012 DPR 147/2006 UNI EN 15004-1:2019 (Fire protection equipment)	Competent and qualified person (Fgas register).	Every 12 months for units with 5-50 tonnes of CO2 equivalent, or 24 months if they have a leak detection system fitted. This doesn't apply to hermetically sealed systems of <10 tonnes CO2 equivalent. Every 6 months for units with 50-500 tonnes of CO2 equivalent, or 12 months if they have a leak detection system fitted. Every 3 months for units with more than 500 tonnes of CO2 equivalent, or 6 months if they have a leak detection system fitted.
PL	Act of 15 May 2015 on the on substances that deplete the ozone layer and some fluorinated greenhouse gases (Journal of Laws 2020, item 2065)	Competent and qualified person certified by the Polish State Office of UDT.	Every 12 months for units with 5-10 tonnes of CO2 equivalent, or 24 months if they have a leak detection system fitted. Every 6 months for units with 10-50 tonnes of CO2 equivalent, or 12 months if they have a leak detection system fitted. Every 6 months for units with more than 50 tonnes of CO2 equivalent.

ROI	S.I. No. 658/2016 - European Union (Fluorinated Greenhouse Gas) Regulations 2016. (irishstatutebook.ie)	Competent person, certified by the relevant body.	Every 12 months for units with 3-30 kg of fluid charge. This doesn't apply to hermetically sealed systems of <6 kg. Every 6 months for units with 30-300 kg of fluid charge. Every 3 months for units with more than 300 kg of fluid charge.
SK	Act No. 314/2012 Coll. on the regular inspection of heating systems and air conditioning systems Act No. 286/2009 Coll. on fluorinated greenhouse gases	Qualified and certified person.	Regular inspections every 5 years. Inspection of actual performance efficiency improvements proposal or upon the request from the state authority.
UK	The Fluorinated Greenhouse Gases Regulations 2015 (legislation.gov.uk) Regulation (EU) No 517/2014 of the European Parliament and of the Council of 16 April 2014 on fluorinated greenhouse gases and repealing Regulation (EC) No 842/2006 (Text with EEA relevance) (legislation.gov.uk) Fluorinated Greenhouse Gases Regulations (Northern Ireland) 2015 (as amended)	Accredited company certified by a DEFRA appointed certification body.	Every 12 months for units with 5-50 tonnes of CO2 equivalent, or 24 months if they have a leak detection system fitted. Every 6 months for units with 50-500 tonnes of CO2 equivalent, or 12 months if they have a leak detection system fitted. Every 3 months for units with more than 500 tonnes of CO2 equivalent, or 6 months if they have a leak detection system fitted.